

Facility ID	Owner Name	Facility Name	Facility Address	City	State	Zip	Last Inspection	Violations	Action
10680	Copiah County Schools	Crystal Springs Middle School	South Pat Harrison Dr	Crystal Springs	MS	39059	1/23/2007	Inadequate leak detection; No CP	Issued NOV with 10-8-07 deadline
11339	Harrison County	Harrison County Sand Beach	842 Commerce St	Gulfport	MS	39507	7/11/2007	Inadequate leak detection	Issued NOV with 10-9-07 deadline
11222	Harrison County Civil Def	Harrison County Civil Defense	1801 23rd Ave	Gulfport	MS	39501	6/20/2005	Inadequate CP	Originally issued NOV with 10-9-05 deadline - Hurrican Katrina hit shortly after NOV was issued. Currently, facility is scheduled to be reinspected in the near future to determine present compliance status
10429	City of Jackson	Emergency Operations Center	300 North West St	Jackson	MS	39205	4/23/2007	Failure to inspect CP rectifier	Issued NOV with 10-8-07 deadline
10125	City of Jackson	Westside Lift Station	4210 Church Circle	Jackson	MS	39209	4/23/2007	Failure to precision tightness test	Issued NOV with 10-8-07 deadline
7623	Harrison County	Long Beach Work Center	605 North Seal Ave	Long Beach	MS	39560	3/1/2007	Inadequate leak detection	Issued NOV with 10-9-07 Deadline
2443	City of Mound Bayou	City of Mound Bayou	201 Green St	Mound Bayou	MS	38762	6/20/2007	No CP test	Issued NOV with 10/80/7 deadline
10934	Lafayette County	Lafayette County Maintenance S	142 Hwy 7 South	Oxford	MS	38655			