



RHODE ISLAND
DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

235 Promenade Street, Providence, RI 02908-5767

TDD 401-222-4462

August 7, 2007

Administrator
Attn: State Government UST Compliance Report Submittal
U.S. Environmental Protection Agency
1200 Pennsylvania Avenue, NW, MC 001
Washington, DC 20460-0001

PROCESSED
2007 AUG 15 AM 11:15
OFFICE OF THE
EXECUTIVE SUPERVISOR

RE: State Government UST Compliance Report Submittal

Dear Administrator:

Enclosed you will find Rhode Island's State Government UST Compliance report. These facilities have violations that were noted during an on-site inspection and have been addressed in either a Letter or Non-Compliance ("LNC"), or a Notice of Violation ("NOV"). Two facilities were issued an NOV and are waiting for an administrative hearing, while the other facility has to respond to the LNC or an NOV will be issued.

If you have any questions or concerns regarding this submittal please feel free to contact me at (401) 222-2797, ext, 7116.

Sincerely,

Kevin W. Gillen, Supervising Engineer
Underground Storage Tank Program
RIDEM Office of Waste Management

CC: Kim Schweisberg, EPA

PROCESSED
2007 AUG 16 AM 7:21
OFFICE OF THE
EXECUTIVE SUPERVISOR

**State Compliance Report on
Government Underground Storage Tanks**

UST ID #	Owner Name	Facility Address	City	Zip Code	Violation Citation	Date of Last On-Site Inspection	Actions to Ensure Compliance
01396	TWN of Coventry (Municipality)	1670 Flat River Rd	Coventry	02816	Water in sumps and spill basins	5/3/07	Issued letter of non-compliance.
					CMS testing requirements,	all tanks	Comply with LNC or a Notice of Violation
					Inventory control		will be issued.
00831	TWN of Lincoln (Municipality)	100 Old River Rd	Lincoln	02865	Operation and Maintenance	3/4/04	Issued Notice of Violation.
					of Leak Detection equipment	all tanks	Awaiting administrative hearing.
					Inventory control, CMS testing		
00399	TWN of North Prov (Municipality)	1967 Mineral Spring Avenue	N.P.	02911	Corrosion Protection, inventory	3/7/06	Issued Notice of Violation,
					control, tightness testing,	all tanks	Awaiting administrative hearing.
					maintaining spill basins,		
					maintain observation wells		