## EDEN NORTH CAROLINA COAL ASH SPILL DRINKING WATER RESULTS

NOTE: The data below represents drinking water samples that were collected on Feb 20, 2014 by EPA SESD (Team 2). Water sample measurement are in milligrams per liter (mg/L), micrograms per liter (ug/L), and nanograms per liter (ng/L) for drinking water samples. The data is being compared to EPA and State Maximum Contaminant Levels (MCLs) and other health based levels. To date, there have been no samples that have exceeded drinking water levels. This sample represents the same water that is being delivered to your tap. Specific qualifiers and footnotes are listed below the summary table.

Analyte	Human Health Screening Standard for Drinking Water Samples <sup>1</sup>		Danville Water Plant Finished Water collected at their compliance sampling location.		Clarksville WTP		
Sample Information							
Sample ID	-		DVF04		CLKF01		
Date	-		02/20/2014		02/20/2014		
Time	-		1311		1045		
Status	-		Validation Complete		Validation Complete		
Media	-	-		Drinking Water		Drinking Water	
Dissolved Metals							
Aluminum	47,000	μg/L	100U	μg/L	380CRa	μg/L	
Antimony	6	μg/L	1U	μg/L	1U	μg/L	
Arsenic	5	μg/L	1U	μg/L	1U	μg/L	
Barium	2,000	μg/L	24	μg/L	27CR	μg/L	
Beryllium	4	μg/L	0.5U	μg/L	0.5U	μg/L	
Boron	9,300	μg/L	120	μg/L	87CR	μg/L	
Cadmium	5	μg/L	0.5U	μg/L	0.5U	μg/L	
Calcium	Essential n	Essential nutrient		μg/L	9400	μg/L	
Chromium	3	μg/L	1.1U,J	μg/L	1.1U,J	μg/L	
Cobalt	14	μg/L	5U	μg/L	5U	μg/L	
Copper	1,300	μg/L	4.6	μg/L	1.4CRb	μg/L	
Iron	33,000	μg/L	100U	μg/L	170CRa	μg/L	
Lead	15	μg/L	0.4U	μg/L	0.4U	μg/L	
Magnesium	Essential nutrient		2400	μg/L	3400	μg/L	
Manganese	970	μg/L	5U	μg/L	27CRa	μg/L	
Mercury	2,000	ng/L	0.51	ng/L	0.5	ng/L	
Molybdenum	78	μg/L	10U	μg/L	10U	μg/L	
Nickel	910	μg/L	10U	μg/L	10U	μg/L	
Potassium	Essential nutrient		1700	μg/L	1900	μg/L	
Selenium	50	μg/L	2U	μg/L	2U	μg/L	
Silver	210	μg/L	0.013U,J	μg/L	0.013U,J	μg/L	
Sodium	Essential nutrient		6300	μg/L	11000	μg/L	
Strontium	-	-	47	μg/L	68CR	μg/L	
Thallium	0.5	μg/L	0.2U	μg/L	0.2U	μg/L	
Tin	-	-	15U	μg/L	15U	μg/L	
Titanium	-	-	5U	μg/L	5.6CR	μg/L	
Vanadium	190	μg/L	5U	μg/L	5U	μg/L	
Yttrium	-	-	3U	μg/L	3U	μg/L	
Zinc	14,000	μg/L	10U	μg/L	10U	μg/L	



## EDEN NORTH CAROLINA COAL ASH SPILL DRINKING WATER RESULTS

Analyte	Screening S for Drinkin	Human Health Screening Standard for Drinking Water Samples <sup>1</sup>		Danville Water Plant Finished Water collected at their compliance sampling location.		Clarksville WTP	
Sample Information	•						
Sample ID	_		DVF04		CLKF01		
Total Metals							
Aluminum	47,000	μg/L	100U	μg/L	310	μg/L	
Antimony	6	μg/L	1U	μg/L	1U	μg/L	
Arsenic	5	μg/L	1U	μg/L	1U	μg/L	
Barium	2,000	μg/L	23	μg/L	24	μg/L	
Beryllium	4	μg/L	0.5U	μg/L	0.5U	μg/L	
Boron	9,300	μg/L	110	μg/L	84	μg/L	
Cadmium	5	μg/L	0.5U	μg/L	0.5U	μg/L	
Calcium	Essential r	Essential nutrient		μg/L	9,400	μg/L	
Chromium	3	μg/L	1.1U,J	μg/L	1.1U,J	μg/L	
Cobalt	14	μg/L	5U	μg/L	5U	μg/L	
Copper	1,300	μg/L	4.7	μg/L	1U	μg/L	
Iron	33,000	μg/L	100U	μg/L	100U	μg/L	
Lead	15	μg/L	0.4U	μg/L	0.4U	μg/L	
Magnesium	Essential r		2,400	μg/L	3,400	μg/L	
Manganese	970	μg/L	5U	μg/L	12	μg/L	
Mercury	2,000	ng/L	-	-	0.5U	ng/L	
Molybdenum	78	μg/L	10U	μg/L	10U	μg/L	
Nickel	910	μg/L	10U	μg/L	10U	μg/L	
Potassium	Essential r	Essential nutrient		μg/L	1,900	μg/L	
Selenium	50	50 μg/L		μg/L	2U	μg/L	
Silver	210	μg/L	0.013U,J	μg/L	0.013U,J	μg/L	
Sodium	Essential r	Essential nutrient		μg/L	11,000	μg/L	
Strontium	-	-	46	μg/L	66	μg/L	
Thallium	0.5	μg/L	0.2U	μg/L	0.2U	μg/L	
Tin	-	-	15U	μg/L	15U	μg/L	
Titanium	-	-	5U	μg/L	5U	μg/L	
Vanadium	190	μg/L	5U	μg/L	5U	μg/L	
Yttrium	-	-	3U	μg/L	3U	μg/L	
Zinc	14,000	μg/L	10U	μg/L	10U	μg/L	
Classical/Nutrient Analyses							
Cyanide (total)	200	μg/L	15U	μg/L	15U,J,QM-1	μg/L	
Nitrate as N	10	mg/L	0.33	mg/L	0.32	mg/L	
Nitrate/Nitrite as N	-	-	0.33	mg/L	0.32	mg/L	
Nitrite as N	1	mg/L	0.05U	mg/L	0.05U	mg/L	
Total Dissolved Solids	-	-	71	mg/L	87	mg/L	
Total Organic Carbon	-	-	1.1	mg/L	1U	mg/L	
Total Suspended Solids	-	-	4U	mg/L	4U	mg/L	

## Notes

Value obtained from EPA Maximum Contaminant

Level (MCL), Removal Management Levels, Secondary MCL, and Lifetime Health Advisory

values

CR Dissolved >Totals. Relative Percent Difference within method allowed precision

CRa Dissolved result is greater than total

CRb The dissolved result is greater than the total result

EPA U.S. Environmental Protection Agency

 $\begin{array}{ll} \mu g/L & \text{micrograms per liter} \\ mg/L & \text{milligrams per liter} \\ ng/L & \text{nanograms per liter} \end{array}$ 



## DATA QUALIFIER DEFINITIONS

B-2	Reporting level elevated due to trace amounts of analyte present in the method blank
B-3	Level in blank does not impact data quality
B-4	Level in blank impacts MRLs
B-5	Qualitative evidence of contamination in the blank at a concentration less than the MDL
C-2	Improper sample container used
H-1	Recommended holding time exceeded
J	The identification of the analyte is acceptable; the reported value is an estimate
MRL-1	MRL verification for Potable Water matrix (Drinking Water)
MRL-2	MRL verification for Non-Potable Water matrix
MRL-3	MRL verification for Soil matrix
MRL-6	MRL verification for Waste matrix
N	There is presumptive evidence that the analyte is present; the analyte is reported as a tentative identification
NA-5	Not Analyzed. Cannot exceed TCLP regulatory levels based on Total Scan analyses
NA-9	Not Analyzed. No sample container received.
NJ	Presumptive evidence that the analyte is present; reported as a tentative identification with an estimated value
P-6	Incorrect reagent or technique used to preserve sample
Q-2	Result greater than MDL but less than MRL
QC-1	Analyte concentration low in continuing calibration verification standard
QC-2	Analyte concentration high in continuing calibration verification standard
QC-5	Calibration check standard less than method control limits
QC-6	Calibration check standard greater than method control limits
QI-1	Internal standard was outside of method control limits
QL-1	Laboratory Control Spike Recovery less than method control limits
QL-2	Laboratory Control Spike Recovery greater than method control limits
QL-3	Laboratory Control Spike Precision outside of method control limits
QM-1	Matrix Spike Recovery less than method control limits
QM-2	Matrix Spike Recovery greater than method control limits
QM-3	Matrix Spike Precision outside method control limits
QR-1	MRL verification recovery less than lower control limits
QR-2	MRL verification recovery greater than upper control limits
TIC	Tentatively Identified Compound - AN analyte identified based on a match with the instrument software's mass spectral library. A calibration standard has not been analyzed to confirm the compound's identification or the estimated concentration reported.
U	The analyte was not detected at or above the reporting limit
XD-2	Duplicate results less than 5X MRL
XM-1	Sample background/spike ratio higher than method evaluation criteria



