

NOTES:

1. Year 2026 is the End-Year and should not be used for analysis.

	2007	2010	2015	2020	2026
1. Reserve Margin Capacity WINTER [MW]	909177.	916857.	946336.	1014679.	1109822.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In WINTER [MW]	6505.	6351.	5411.	4921.	5127.
Total R.M. Capacity WINTER [MW]	915682.	923208.	951747.	1019600.	1114948.
2. Peak Load WINTER [MW]	649218.	681168.	729980.	785419.	858870.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out WINTER [MW]	6637.	6480.	5521.	5021.	5231.
Net Demand WINTER [MW]	655855.	687648.	735502.	790440.	864102.
3. Reserve Margin WINTER [%]	40.	35.	30.	29.	29.
1. Reserve Margin Capacity SUMMER [MW]	909177.	916857.	946336.	1014679.	1109822.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In SUMMER [MW]	28939.	29359.	38993.	28199.	31579.
Total R.M. Capacity SUMMER [MW]	938117.	946216.	985329.	1042878.	1141400.
2. Peak Load SUMMER [MW]	724778.	761827.	817715.	881026.	965091.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out SUMMER [MW]	29530.	29958.	39788.	28774.	32223.
Net Demand SUMMER [MW]	754308.	791785.	857503.	909800.	997315.
3. Reserve Margin SUMMER [%]	25.	20.	16.	15.	15.
4. Generation [GWh]	4021374.	4198200.	4503754.	4850644.	5313689.
Inter-Region Transmission [GWh]	-12145.	-11882.	-10135.	-8996.	-9326.
Pumping & Storage Losses [GWh]	30156.	28783.	27721.	25254.	25812.
Plus Purchases [GWh]	0.	0.	0.	0.	0.
Less Sales [GWh]	0.	0.	0.	0.	0.
5. Total Supply for Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
6. Projected Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
Energy Not Served [GWh]	0.	0.	0.	0.	0.
Less DSM [GWh]	0.	0.	0.	0.	0.
Net Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
7. Dumped Energy [GWh]	0.	0.	0.	0.	0.
8. Total Supply for Demand [GWh]	3979073.	4157535.	4465898.	4816394.	5278551.
Less T&D Losses [GWh]	305718.	319430.	343122.	370051.	405559.
9. Total Sales [GWh]	3673355.	3838105.	4122776.	4446343.	4872992.
Capacity Avoided Costs [US\$/kW]	2007	2010	2015	2020	2026
ANNUAL	0.00	0.00	0.00	0.00	0.00
WINTER	0.00	0.00	0.00	0.00	0.00
SUMMER	1.03	0.42	29.35	36.12	34.94

10. Capacity by Plant Type [MW]		2007	2010	2015	2020	2026
-----						
Scrubbed Coal_SCR	1	30480.	31456.	37904.	49223.	89258.
Scrubbed Coal_SNCR	2	2125.	2125.	2125.	2125.	2125.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	63809.	60643.	49814.	49805.	49805.
Unscrubbed Coal_SCR	5	51354.	50564.	8533.	8522.	8522.
Unscrubbed Coal_SNCR	6	7457.	7370.	3395.	3206.	3167.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	121992.	114776.	50532.	46060.	44543.
Oil/Gas Steam	9	76440.	74726.	74726.	74666.	74666.
Oil/Gas Steam_SCR	10	8152.	5588.	5588.	5588.	5588.
Oil/Gas Steam_NOx	11	317.	317.	317.	317.	317.
Nuclear	12	100221.	100571.	102123.	102603.	102603.
Hydro	13	89877.	89877.	89877.	89877.	89877.
Comb.Cycle Gas	14	147149.	148543.	170071.	199254.	213724.
IGCC	15	612.	612.	612.	6050.	26052.
Combustion Turbine	16	130223.	129970.	129603.	151399.	172022.
Biomass	17	1358.	1456.	1456.	1456.	1456.
Geothermal	18	3165.	3289.	3399.	3399.	3399.
Landfill Gas	19	549.	581.	1003.	1003.	1003.
Wind	20	6896.	7218.	7278.	7297.	7297.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	449.	465.	494.	494.	494.
Non Fossil_Other	23	2173.	2207.	2207.	2207.	2207.
Fossil_Other	24	566.	566.	566.	566.	566.
Pump Storage	25	19766.	19766.	19766.	19766.	19766.
Int. Imports	26	9000.	9000.	9000.	9000.	9000.
Cgn_CT	27	5542.	5542.	5542.	5542.	5542.
Cgn_CC	28	17825.	17816.	17816.	17813.	17813.
Cgn_Oil/Gas Steam	29	312.	73.	65.	65.	65.
Cgn_Biomass	30	366.	366.	366.	366.	366.
Cgn_Fossil_Other	31	361.	361.	361.	361.	361.
Cgn_NonFossil_Other	32	314.	314.	314.	314.	314.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	2097.	2191.	2204.
Rep.O/G-CC	35	0.	8302.	8323.	8323.	8323.
Rep.Coal-IGCC	36	0.	93.	3317.	3539.	3554.
Ret.Scrubber	37	1087.	2523.	46178.	46811.	46829.
Ret.ExistSCR & Scrub	38	2734.	3507.	43605.	43612.	43612.
Ret.ExistSNCR & Scrub	39	502.	587.	3948.	4086.	4123.
Ret.SCR	40	14109.	16808.	7127.	7564.	8734.
Ret.ExistScrub & SCR	41	2506.	5280.	16043.	16051.	16051.
Ret.SNCR	42	2144.	4206.	5793.	8492.	8796.
Ret.ExistScrub & SNCR	43	0.	196.	243.	243.	243.
Ret.SCR+Scrb	44	3409.	3870.	30382.	30947.	30958.
Ret.SNCR+Scrub	45	0.	0.	74.	74.	74.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	8.	8.	8.	8.
Ret.ExistScrub&ACI	50	0.	195.	195.	195.	195.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	259.	259.	259.	259.
Ret.O/G SNCR	66	656.	993.	993.	1053.	1053.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2326.	2579.	3042.	3140.	3143.
CC Early Retirement	71	911.	1090.	1583.	1586.	1586.
O/G Early Retirement	72	41386.	42187.	42187.	42187.	42187.
Coal Early Retirement	73	296.	296.	296.	296.	296.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
-----		-----				
Total		970917.	980052.	1010546.	1078999.	1174145.

11. Capacity Additions and Changes  
by Plant Type [MW]

		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	0.	186.	6448.	11319.	40035.
Scrubbed Coal_SNCR	2	0.	0.	0.	0.	0.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	0.	0.	0.	0.	0.
Unscrubbed Coal_SCR	5	0.	0.	0.	0.	0.
Unscrubbed Coal_SNCR	6	0.	0.	0.	0.	0.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	0.	0.	0.	0.	0.
Oil/Gas Steam	9	0.	0.	0.	0.	0.
Oil/Gas Steam_SCR	10	0.	0.	0.	0.	0.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	0.	0.	0.	0.	0.
Hydro	13	0.	0.	0.	0.	0.
Comb.Cycle Gas	14	0.	1564.	22022.	29183.	14469.
IGCC	15	0.	0.	0.	5438.	20002.
Combustion Turbine	16	0.	0.	96.	21893.	20627.
Biomass	17	0.	0.	0.	0.	0.
Geothermal	18	0.	0.	0.	0.	0.
Landfill Gas	19	0.	0.	422.	0.	0.
Wind	20	0.	0.	0.	19.	0.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	0.	0.	0.	0.	0.
Non Fossil_Other	23	0.	0.	0.	0.	0.
Fossil_Other	24	0.	0.	0.	0.	0.
Pump Storage	25	0.	0.	0.	0.	0.
Int. Imports	26	0.	0.	0.	0.	0.
Cgn_CT	27	0.	0.	0.	0.	0.
Cgn_CC	28	0.	0.	0.	0.	0.
Cgn_Oil/Gas Steam	29	0.	0.	0.	0.	0.
Cgn_Biomass	30	0.	0.	0.	0.	0.
Cgn_Fossil_Other	31	0.	0.	0.	0.	0.
Cgn_NonFossil_Other	32	0.	0.	0.	0.	0.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	1182.	95.	12.
Rep.O/G-CC	35	0.	8302.	20.	0.	0.
Rep.Coal-IGCC	36	0.	93.	3224.	222.	15.
Ret.Scrubber	37	1355.	1824.	50173.	995.	19.
Ret.ExistSCR & Scrub	38	2734.	773.	40099.	6.	0.
Ret.ExistSNCR & Scrub	39	502.	85.	3361.	138.	38.
Ret.SCR	40	14109.	2699.	1088.	541.	1170.
Ret.ExistScrub & SCR	41	2506.	2774.	10763.	8.	0.
Ret.SNCR	42	2144.	2062.	1587.	2698.	304.
Ret.ExistScrub & SNCR	43	0.	196.	47.	0.	0.
Ret.SCR+Scrb	44	3409.	460.	26512.	565.	11.
Ret.SNCR+Scrub	45	0.	0.	74.	0.	0.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	8.	0.	0.	0.
Ret.ExistScrub&ACI	50	0.	195.	0.	0.	0.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	259.	0.	0.	0.
Ret.O/G SNCR	66	656.	336.	0.	61.	0.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2326.	253.	463.	98.	3.
CC Early Retirement	71	911.	179.	493.	3.	0.
O/G Early Retirement	72	41386.	800.	0.	0.	0.
Coal Early Retirement	73	296.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
Total		72335.	23964.	168074.	73282.	96705.

12. Generation by Plant Type [GWh]		2007	2010	2015	2020	2026
-----						
Scrubbed Coal_SCR	1	226665.	233884.	282268.	366596.	664473.
Scrubbed Coal_SNCR	2	14897.	15014.	15570.	15570.	15526.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	468045.	446671.	370174.	370335.	366382.
Unscrubbed Coal_SCR	5	371455.	369870.	63135.	63174.	63043.
Unscrubbed Coal_SNCR	6	48832.	51286.	22048.	22211.	21903.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	832635.	805774.	360912.	334212.	322771.
Oil/Gas Steam	9	28736.	34012.	26481.	16231.	11933.
Oil/Gas Steam_SCR	10	14407.	1676.	557.	557.	885.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	785243.	798667.	811008.	808645.	796944.
Hydro	13	275692.	275692.	275692.	275692.	275692.
Comb.Cycle Gas	14	543944.	610112.	827781.	1038962.	1070581.
IGCC	15	4702.	4702.	4702.	46470.	200102.
Combustion Turbine	16	23600.	29423.	31084.	57672.	76151.
Biomass	17	8444.	8719.	9077.	9007.	8801.
Geothermal	18	24121.	25066.	25904.	25904.	25904.
Landfill Gas	19	4328.	4580.	7724.	7724.	7724.
Wind	20	14091.	14738.	14821.	14889.	14889.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	444.	459.	488.	488.	488.
Non Fossil_Other	23	17132.	17400.	17400.	17400.	17400.
Fossil_Other	24	4462.	4462.	4462.	4462.	4462.
Pump Storage	25	22708.	21738.	20980.	19212.	19585.
Int. Imports	26	41303.	44063.	40296.	27331.	13578.
Cgn_CT	27	6955.	1771.	1337.	1003.	1121.
Cgn_CC	28	37850.	34163.	29215.	26799.	27480.
Cgn_Oil/Gas Steam	29	628.	0.	0.	0.	0.
Cgn_Biomass	30	2580.	2640.	2604.	2684.	2758.
Cgn_Fossil_Other	31	2351.	2309.	2846.	2846.	2846.
Cgn_NonFossil_Other	32	2412.	2412.	2412.	2412.	2412.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	157.	9042.	9730.	10211.
Rep.O/G-CC	35	0.	65750.	65912.	65804.	65279.
Rep.Coal-IGCC	36	0.	714.	25484.	27186.	27301.
Ret.Scrubber	37	7647.	17756.	339170.	346731.	344374.
Ret.ExistSCR & Scrub	38	20337.	26111.	321526.	322100.	320096.
Ret.ExistSNCR & Scrub	39	3147.	3782.	28581.	29537.	29528.
Ret.SCR	40	103656.	123026.	52782.	56114.	64812.
Ret.ExistScrub & SCR	41	17940.	39319.	119460.	119518.	119452.
Ret.SNCR	42	13905.	27075.	39913.	60079.	62056.
Ret.ExistScrub & SNCR	43	0.	1357.	1604.	1747.	1680.
Ret.SCR+Scrb	44	25386.	28814.	225918.	230162.	229894.
Ret.SNCR+Scrub	45	0.	0.	550.	551.	551.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	62.	62.	62.	62.
Ret.ExistScrub&ACI	50	0.	1452.	1452.	1452.	1452.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	477.	273.	273.	273.
Ret.O/G SNCR	66	692.	1047.	1047.	1110.	833.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
-----						
Total		4021374.	4198200.	4503754.	4850644.	5313689.

12a. Generation by Fuel Type [GWh]	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
Coal	2159250.	2196668.	2275311.	2413807.	2855459.
Oil	628.	0.	0.	0.	0.
Nuclear	785243.	798667.	811008.	808645.	796944.
Hydro	275692.	275692.	275692.	275692.	275692.
Gas	656183.	778587.	992728.	1218141.	1264747.
Other	11142.	11352.	15032.	15032.	15032.
None	122211.	125876.	122301.	107637.	94256.
Biomass	11024.	11359.	11682.	11691.	11560.
-----	-----	-----	-----	-----	-----
Total	4021374.	4198200.	4503754.	4850644.	5313689.

13. Generation by Plant Type [TBtu]		2007	2010	2015	2020	2026
<hr/>						
Scrubbed Coal_SCR	1	773.	798.	963.	1251.	2267.
Scrubbed Coal_SNCR	2	51.	51.	53.	53.	53.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	1597.	1524.	1263.	1264.	1250.
Unscrubbed Coal_SCR	5	1267.	1262.	215.	216.	215.
Unscrubbed Coal_SNCR	6	167.	175.	75.	76.	75.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	2841.	2749.	1231.	1140.	1101.
Oil/Gas Steam	9	98.	116.	90.	55.	41.
Oil/Gas Steam_SCR	10	49.	6.	2.	2.	3.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	2679.	2725.	2767.	2759.	2719.
Hydro	13	941.	941.	941.	941.	941.
Comb.Cycle Gas	14	1856.	2082.	2824.	3545.	3653.
IGCC	15	16.	16.	16.	159.	683.
Combustion Turbine	16	81.	100.	106.	197.	260.
Biomass	17	29.	30.	31.	31.	30.
Geothermal	18	82.	86.	88.	88.	88.
Landfill Gas	19	15.	16.	26.	26.	26.
Wind	20	48.	50.	51.	51.	51.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	2.	2.	2.	2.	2.
Non Fossil_Other	23	58.	59.	59.	59.	59.
Fossil_Other	24	15.	15.	15.	15.	15.
Pump Storage	25	77.	74.	72.	66.	67.
Int. Imports	26	141.	150.	137.	93.	46.
Cgn_CT	27	24.	6.	5.	3.	4.
Cgn_CC	28	129.	117.	100.	91.	94.
Cgn_Oil/Gas Steam	29	2.	0.	0.	0.	0.
Cgn_Biomass	30	9.	9.	9.	9.	9.
Cgn_Fossil_Other	31	8.	8.	10.	10.	10.
Cgn_NonFossil_Other	32	8.	8.	8.	8.	8.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	1.	31.	33.	35.
Rep.O/G-CC	35	0.	224.	225.	225.	223.
Rep.Coal-IGCC	36	0.	2.	87.	93.	93.
Ret.Scrubber	37	26.	61.	1157.	1183.	1175.
Ret.ExistSCR & Scrub	38	69.	89.	1097.	1099.	1092.
Ret.ExistSNCR & Scrub	39	11.	13.	98.	101.	101.
Ret.SCR	40	354.	420.	180.	191.	221.
Ret.ExistScrub & SCR	41	61.	134.	408.	408.	408.
Ret.SNCR	42	47.	92.	136.	205.	212.
Ret.ExistScrub & SNCR	43	0.	5.	5.	6.	6.
Ret.SCR+Scrb	44	87.	98.	771.	785.	784.
Ret.SNCR+Scrub	45	0.	0.	2.	2.	2.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI	50	0.	5.	5.	5.	5.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	0.	2.	1.	1.	1.
Ret.O/G SNCR	66	2.	4.	4.	4.	3.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
<hr/>		<hr/>				
Total		13721.	14324.	15367.	16550.	18130.

14. Capacity Factor by Plant Type [%]		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	84.9	84.9	85.0	85.0	85.0
Scrubbed Coal_SNCR	2	80.0	80.7	83.6	83.6	83.4
Scrubbed Coal_NOx	3	N/A	N/A	N/A	N/A	N/A
Scrubbed Coal	4	83.7	84.1	84.8	84.9	84.0
Unscrubbed Coal_SCR	5	82.6	83.5	84.5	84.6	84.4
Unscrubbed Coal_SNCR	6	74.8	79.4	74.1	79.1	78.9
Unscrubbed Coal_NOx	7	N/A	N/A	N/A	N/A	N/A
Unscrubbed Coal	8	77.9	80.1	81.5	82.8	82.7
Oil/Gas Steam	9	4.3	5.2	4.0	2.5	1.8
Oil/Gas Steam_SCR	10	20.2	3.4	1.1	1.1	1.8
Oil/Gas Steam_NOx	11	0.0	0.0	0.0	0.0	0.0
Nuclear	12	89.4	90.7	90.7	90.0	88.7
Hydro	13	35.0	35.0	35.0	35.0	35.0
Comb.Cycle Gas	14	42.2	46.9	55.6	59.5	57.2
IGCC	15	87.7	87.7	87.7	87.7	87.7
Combustion Turbine	16	2.1	2.6	2.7	4.3	5.1
Biomass	17	71.0	68.4	71.2	70.6	69.0
Geothermal	18	87.0	87.0	87.0	87.0	87.0
Landfill Gas	19	90.0	90.0	87.9	87.9	87.9
Wind	20	23.3	23.3	23.2	23.3	23.3
Fuel Cell	21	N/A	N/A	N/A	N/A	N/A
Solar	22	11.3	11.3	11.3	11.3	11.3
Non Fossil_Other	23	90.0	90.0	90.0	90.0	90.0
Fossil_Other	24	90.0	90.0	90.0	90.0	90.0
Pump Storage	25	13.1	12.6	12.1	11.1	11.3
Int. Imports	26	52.4	55.9	51.1	34.7	17.2
Cgn_CT	27	14.3	3.6	2.8	2.1	2.3
Cgn_CC	28	24.2	21.9	18.7	17.2	17.6
Cgn_Oil/Gas Steam	29	23.0	0.0	0.0	0.0	0.0
Cgn_Biomass	30	80.5	82.3	81.2	83.7	86.0
Cgn_Fossil_Other	31	74.4	73.0	90.0	90.0	90.0
Cgn_NonFossil_Other	32	87.7	87.7	87.7	87.7	87.7
Distributed Generation	33	N/A	N/A	N/A	N/A	N/A
Rep.Coal-CC	34	N/A	2.0	49.2	50.7	52.9
Rep.O/G-CC	35	N/A	90.4	90.4	90.3	89.5
Rep.Coal-IGCC	36	N/A	87.7	87.7	87.7	87.7
Ret.Scrubber	37	80.3	80.3	83.8	84.6	83.9
Ret.ExistSCR & Scrub	38	84.9	85.0	84.2	84.3	83.8
Ret.ExistSNCR & Scrub	39	71.6	73.5	82.6	82.5	81.7
Ret.SCR	40	83.9	83.6	84.5	84.7	84.7
Ret.ExistScrub & SCR	41	81.7	85.0	85.0	85.0	85.0
Ret.SNCR	42	74.0	73.5	78.7	80.8	80.5
Ret.ExistScrub & SNCR	43	N/A	78.9	75.3	82.0	78.9
Ret.SCR+Scrb	44	85.0	85.0	84.9	84.9	84.8
Ret.SNCR+Scrub	45	N/A	N/A	85.0	85.0	85.0
Ret.Gas Reburn	46	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub+GasR	47	N/A	N/A	N/A	N/A	N/A
Ret.GasReburn+Scrub	48	N/A	N/A	N/A	N/A	N/A
Ret.ACI	49	N/A	85.0	85.0	85.0	85.0
Ret.ExistScrub&ACI	50	N/A	85.0	85.0	85.0	85.0
Ret.ExistSCR&ACI	51	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI	52	N/A	N/A	N/A	N/A	N/A
Ret.ACI & SCR	53	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub&ACI&SCR	54	N/A	N/A	N/A	N/A	N/A
Ret.ACI & SNCR	55	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub&ACI&SNCR	56	N/A	N/A	N/A	N/A	N/A
Ret.ACI & Srub	57	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ACI&Scrub	58	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI&Scrub	59	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ExistScrub&ACI	60	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ExistScrub&ACI	61	N/A	N/A	N/A	N/A	N/A
Ret.ExistNOx&ExistScrub&ACI	62	N/A	N/A	N/A	N/A	N/A
Ret.SCR & Scrub & ACI	63	N/A	N/A	N/A	N/A	N/A
Ret.SNCR & Scrub & ACI	64	N/A	N/A	N/A	N/A	N/A
Ret.O/G SCR	65	N/A	21.1	12.0	12.0	12.0
Ret.O/G SNCR	66	12.0	12.0	12.0	12.0	9.0
Ret.Nuclear (age 30+10 yrs)	67	N/A	N/A	N/A	N/A	N/A
Ret.Nuclear (age 40+20 yrs)	68	N/A	N/A	N/A	N/A	N/A
Ret. Biomass Cofiring	69	N/A	N/A	N/A	N/A	N/A
CT Early Retirement	70	0.0	0.0	0.0	0.0	0.0
CC Early Retirement	71	0.0	0.0	0.0	0.0	0.0
O/G Early Retirement	72	0.0	0.0	0.0	0.0	0.0
Coal Early Retirement	73	0.0	0.0	0.0	0.0	0.0
Nuke Early Retirement	74	N/A	N/A	N/A	N/A	N/A
Average		47.3	48.9	50.9	51.3	51.7

15. Total Annual Production Cost  
[MMUS\$](\*)

	2007	2010	2015	2020	2026
Variable O&M	6468.3	6760.5	8882.3	9743.9	11040.2
Fixed O&M	29108.4	29744.9	32855.3	35449.1	37623.6
Fuel	44914.5	47396.3	51462.9	55816.5	59598.3
Capital	644.9	1562.3	7851.2	13903.6	25831.4
Total	81136.0	85463.9	101051.7	114913.1	134093.5
Sales Revenue	0.0	0.0	0.0	0.0	0.0

(\*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)

15a Total Annual Resource Cost  
[MMUS\$](\*)

	2007	2010	2015	2020	2026
Variable O&M	6468.3	6760.5	8882.3	9743.9	11040.2
Fixed O&M	29108.4	29744.9	32855.3	35449.1	37623.6
Fuel Total	94339.2	97775.6	102664.5	107995.2	111739.8
Fuel Elec.+Steam	38573.7	40921.7	45058.4	48941.5	51518.7
Capital	644.9	1562.3	7851.2	13903.6	25831.4
Total IPM	130560.8	135843.2	152253.3	167091.8	186235.0
Total Elec.+Steam	74795.2	78989.3	94647.1	108038.0	126013.9
Sales Revenue	0.0	0.0	0.0	0.0	0.0

(\*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)

16. Emissions

	2007	2010	2015	2020	2026
SO2 [MTons]	10509.2743	10084.2939	7363.1601	7410.9502	7268.4903
NOX [MTons]	3662.0845	3677.2334	2512.3256	2541.4523	2611.7567
TSP [MTons]	0.0000	0.0000	0.0000	0.0000	0.0000
CO2 [MMTonnes]	2389.5651	2469.4511	2625.6782	2809.3868	3156.7246
Carbon [MMTonnes]	651.6996	673.4867	716.0940	766.1964	860.9249



Fuel Consumption by Fuel and Fuel Type [TBtu]

Fuel	2007	2010	2015	2020	2026
Coal	22495.8	22901.6	23803.6	24964.8	28524.5
Oil	5.8	0.0	0.0	0.0	0.0
Nuclear	8276.8	8417.2	8543.8	8518.1	8394.5
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	5061.8	5875.8	7225.7	8629.0	8883.7
Other	128.3	131.3	177.4	177.4	177.4
None	591.7	606.5	619.5	619.5	619.5
Biomass	103.3	106.3	109.7	109.5	107.9
Grand Total	36663.5	38038.7	40479.6	43018.2	46707.5

Fuel Costs by Fuel and Fuel Type [MMUS\$]

Fuel	2007	2010	2015	2020	2026
Coal	24356.8	24108.2	23400.9	23234.9	25791.0
Oil	19.2	0.0	0.0	0.0	0.0
Nuclear	3410.0	3467.9	3477.3	3458.3	3408.2
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	16963.3	19650.1	24410.9	28952.1	30231.0
Other	0.0	0.0	0.0	0.0	0.0
None	0.0	0.0	0.0	0.0	0.0
Biomass	165.1	170.1	173.7	171.1	168.1

Fuel Costs by Fuel and Fuel Type [US\$/MMBtu]

Fuel	2007	2010	2015	2020	2026
Coal	1.08	1.05	0.98	0.93	0.90
Oil	3.29	0.00	0.00	0.00	0.00
Nuclear	0.41	0.41	0.41	0.41	0.41
Hydro	0.00	0.00	0.00	0.00	0.00
Gas	3.35	3.34	3.38	3.36	3.40
Other	0.00	0.00	0.00	0.00	0.00
None	0.00	0.00	0.00	0.00	0.00
Biomass	1.60	1.60	1.58	1.56	1.56

# Environmental Measures Report

Constraint Name: National Title IV SO2 Policy Case Constraint      Constraint #: 1  
 Constraint Type: Rate Cap [MTons]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.1439E+05	9046.	8643.	8643.	8643.
-Emissions at Affected Plants [MTons]	0.1029E+05	9864.	7161.	7207.	7069.
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	4091.	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	-818.3	0.000	0.000	0.000
Total [MTons]	0.1439E+05	9046.	7161.	7207.	7069.
TBtu Consumed	0.2243E+05	0.2279E+05	0.2370E+05	0.2486E+05	0.2842E+05
Rate - [lb/MMBtu]	0.9180	0.8657	0.6043	0.5799	0.4975
TWh Generated	2155.	2188.	2267.	2406.	2847.
TWh Generated Qualifying	2155.	2188.	2267.	2406.	2847.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	182.1	212.2	0.000	0.000	0.000

Constraint Name: WRAP SO2 Policy Case Constraint  
 Constraint Type: Rate Cap [MTons]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 2

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.000	0.000	198.9	198.9
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	198.9	198.9
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	198.9	198.9
TBtu Consumed	0.000	0.000	0.000	1543.	1543.
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2578	0.2578
TWh Generated	0.000	0.000	0.000	148.9	148.9
TWh Generated Qualifying	0.000	0.000	0.000	148.9	148.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	1722.	1423.

Constraint Name: NOx SIP CALL Constraint  
Constraint Type: Rate Cap [MTons]  
Run Year, Seasons Included: 2007 SUMMER  
Run Year, Seasons Included: 2010 SUMMER  
Run Year, Seasons Included: 2015 SUMMER  
Run Year, Seasons Included: 2020 SUMMER  
Run Year, Seasons Included: 2026 SUMMER

Constraint #: 4

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	528.0	528.0	528.0	528.0	528.0
-Emissions at Affected Plants [MTons]	528.0	528.0	528.0	528.0	528.0
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	528.0	528.0	528.0	528.0	528.0
TBtu Consumed	6533.	6798.	7436.	7811.	8298.
Rate - [lb/MMBtu]	0.1616	0.1553	0.1420	0.1352	0.1273
TWh Generated	652.2	679.5	745.1	789.7	852.2
TWh Generated Qualifying	652.2	679.5	745.1	789.7	852.2
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2265.	2444.	1751.	2131.	2157.

Constraint Name: NOX Policy for State of Illinois  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Constraint #: 5

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	29.99	32.89	33.71	33.96	33.67
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	29.99	32.89	33.71	33.96	33.67
TBtu Consumed	410.6	455.1	477.1	493.6	491.0
Rate - [lb/MMBtu]	0.1461	0.1445	0.1413	0.1376	0.1371
TWh Generated	39.01	43.06	44.48	46.02	45.78
TWh Generated Qualifying	39.01	43.06	44.48	46.02	45.78
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOX Policy for State of Massachusetts

Constraint #: 6

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	7.494	12.36	12.69	12.69	12.69
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.494	12.36	12.69	12.69	12.69
TBtu Consumed	104.8	159.2	163.5	163.5	163.5
Rate - [lb/MMBtu]	0.1430	0.1553	0.1553	0.1553	0.1553
TWh Generated	9.992	16.48	16.92	16.92	16.92
TWh Generated Qualifying	9.992	16.48	16.92	16.92	16.92
Constraint Shadow Price [US\$/Ton]	558.5	1192.	0.000	0.000	231.8



Constraint Name: SO2 Policy for State of Massachusetts

Constraint #: 7

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	9.445	17.14	17.56	17.56	17.56
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	9.445	17.14	17.56	17.56	17.56
TBtu Consumed	103.6	125.1	128.3	128.3	128.3
Rate - [lb/MMBtu]	0.1824	0.2741	0.2738	0.2738	0.2738
TWh Generated	9.883	11.43	11.71	11.71	11.71
TWh Generated Qualifying	9.883	11.43	11.71	11.71	11.71
Constraint Shadow Price [US\$/Ton]	1395.	806.7	1125.	1051.	1070.

Constraint Name: CO2 Policy for State of Massachusetts

Constraint #: 8

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	8993.	0.1483E+05	0.1523E+05	0.1523E+05	0.1523E+05
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8993.	0.1483E+05	0.1523E+05	0.1523E+05	0.1523E+05
TBtu Consumed	104.8	159.2	163.5	163.5	163.5
Rate - [lb/MMBtu]	171.6	186.4	186.3	186.3	186.3
TWh Generated	9.992	16.48	16.92	16.92	16.92
TWh Generated Qualifying	9.992	16.48	16.92	16.92	16.92
Constraint Shadow Price [US\$/Ton]	39.96	2.919	0.000	1.117	2.201

Constraint Name: NOx Policy for State of North Carolina Progressive Constraint #: 9

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	25.00	25.00	25.00	25.00	25.00
-Emissions at Affected Plants [MTons]	20.35	20.74	23.51	20.90	20.15
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	20.35	20.74	23.51	20.90	20.15
TBtu Consumed	391.4	397.5	413.9	413.4	404.8
Rate - [lb/MMBtu]	0.1040	0.1044	0.1136	0.1011	0.9955E-01
TWh Generated	35.65	36.17	37.31	37.27	36.51
TWh Generated Qualifying	35.65	36.17	37.31	37.27	36.51
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of North Carolina Duke  
 Constraint Type: Rate Cap [MTons] Constraint #: 10  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	35.00	31.80	31.00	31.00	31.00
-Emissions at Affected Plants [MTons]	35.00	31.80	24.02	21.97	21.77
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	35.00	31.80	24.02	21.97	21.77
TBTu Consumed	559.7	524.0	559.1	563.3	557.0
Rate - [lb/MMBTu]	0.1251	0.1214	0.8592E-01	0.7799E-01	0.7816E-01
TWh Generated	51.55	48.21	50.91	51.31	50.72
TWh Generated Qualifying	51.55	48.21	50.91	51.31	50.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	642.2	195.6	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of North Carolina Progressive Constraint #: 11

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	100.0	50.00	50.00	50.00
-Emissions at Affected Plants [MTons]	0.000	100.0	37.19	44.41	42.72
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	100.0	37.19	44.41	42.72
TBtu Consumed	0.000	397.5	413.9	413.4	404.8
Rate - [lb/MMBtu]	0.000	0.5031	0.1797	0.2149	0.2111
TWh Generated	0.000	36.17	37.31	37.27	36.51
TWh Generated Qualifying	0.000	36.17	37.31	37.27	36.51
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	256.1	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of North Carolina Duke      Constraint #: 12  
 Constraint Type: Rate Cap [MTons]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	150.0	80.00	80.00	80.00
-Emissions at Affected Plants [MTons]	0.000	150.0	42.35	45.13	43.50
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	150.0	42.35	45.13	43.50
TBtu Consumed	0.000	524.0	559.1	563.3	557.0
Rate - [lb/MMBtu]	0.000	0.5725	0.1515	0.1602	0.1562
TWh Generated	0.000	48.21	50.91	51.31	50.72
TWh Generated Qualifying	0.000	48.21	50.91	51.31	50.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	670.3	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New Hampshire

Constraint #: 13

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	3.644	3.644	3.644	3.644	3.644
-Emissions at Affected Plants [MTons]	2.082	2.082	2.126	2.100	2.099
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.082	2.082	2.126	2.100	2.099
TBtu Consumed	43.35	43.35	43.78	43.53	43.51
Rate - [lb/MMBtu]	0.9606E-01	0.9606E-01	0.9714E-01	0.9650E-01	0.9646E-01
TWh Generated	3.976	3.976	4.010	3.990	3.989
TWh Generated Qualifying	3.976	3.976	4.010	3.990	3.989
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New Hampshire - Hillsborou Constraint #: 14  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.161	1.161	1.205	1.153	1.177
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.161	1.161	1.205	1.153	1.177
TBtu Consumed	48.79	48.79	49.21	48.71	48.95
Rate - [lb/MMBtu]	0.4760E-01	0.4760E-01	0.4897E-01	0.4734E-01	0.4811E-01
TWh Generated	5.993	5.993	6.026	5.987	6.006
TWh Generated Qualifying	5.993	5.993	6.026	5.987	6.006
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: NOx Policy for State of New Hampshire Remaining Co Constraint #: 15  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2000	0.2000	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of New Hampshire

Constraint #: 16

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	7.289	7.289	7.289	7.289	7.289
-Emissions at Affected Plants [MTons]	7.289	7.152	7.426	7.289	7.289
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.1370	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-0.1370	0.000	0.000
Total [MTons]	7.289	7.289	7.289	7.289	7.289
TBTu Consumed	43.24	43.24	43.74	43.49	43.49
Rate - [lb/MMBtu]	0.3371	0.3308	0.3395	0.3352	0.3352
TWh Generated	3.968	3.968	4.007	3.987	3.987
TWh Generated Qualifying	3.968	3.968	4.007	3.987	3.987
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	738.8	695.3	901.8	917.0	1125.

Constraint Name: CO2 Policy for State of New Hampshire

Constraint #: 17

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	5426.	5426.	5426.	5426.	5426.
-Emissions at Affected Plants [MTons]	4445.	4445.	4492.	4467.	4466.
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4445.	4445.	4492.	4467.	4466.
TBtu Consumed	43.35	43.35	43.78	43.53	43.51
Rate - [lb/MMBtu]	205.1	205.1	205.2	205.2	205.3
TWh Generated	3.976	3.976	4.010	3.990	3.989
TWh Generated Qualifying	3.976	3.976	4.010	3.990	3.989
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New York  
Constraint Type: Rate Cap [MTons]  
Run Year, Seasons Included: 2007 WINTER  
Run Year, Seasons Included: 2010 WINTER  
Run Year, Seasons Included: 2015 WINTER  
Run Year, Seasons Included: 2020 WINTER  
Run Year, Seasons Included: 2026 WINTER

Constraint #: 18

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	39.91	39.91	39.91	39.91	39.91
-Emissions at Affected Plants [MTons]	28.24	27.49	24.96	25.54	26.22
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	28.24	27.49	24.96	25.54	26.22
TBtu Consumed	320.8	333.6	359.4	423.1	476.0
Rate - [lb/MMBtu]	0.1761	0.1648	0.1389	0.1207	0.1102
TWh Generated	36.58	39.05	43.58	52.59	59.92
TWh Generated Qualifying	36.58	39.05	43.58	52.59	59.92
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of New York  
Constraint Type: Rate Cap [MTons]  
Run Year, Seasons Included: 2007 WINTER SUMMER  
Run Year, Seasons Included: 2010 WINTER SUMMER  
Run Year, Seasons Included: 2015 WINTER SUMMER  
Run Year, Seasons Included: 2020 WINTER SUMMER  
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 19

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	197.0	131.4	131.4	131.4	131.4
-Emissions at Affected Plants [MTons]	197.0	131.4	131.4	131.4	131.4
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	197.0	131.4	131.4	131.4	131.4
TBTu Consumed	270.4	270.4	301.1	410.7	499.3
Rate - [lb/MMBTu]	1.457	0.9718	0.8729	0.6399	0.5263
TWh Generated	26.76	26.76	29.88	45.60	57.43
TWh Generated Qualifying	26.76	26.76	29.88	45.60	57.43
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	309.1	276.2	357.9	345.9	374.7

Constraint Name: NOx Policy for State of Wisconsin  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 20

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.2500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	13.48	5.680	5.680	5.642
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	13.48	5.680	5.680	5.642
TBtu Consumed	0.000	203.0	180.8	180.8	179.5
Rate - [lb/MMBtu]	0.000	0.1328	0.6282E-01	0.6282E-01	0.6284E-01
TWh Generated	0.000	19.32	17.11	17.11	16.99
TWh Generated Qualifying	0.000	19.32	17.11	17.11	16.99
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of Wisconsin  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 21

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.7000	0.4500	0.4500	0.4500
-Emissions at Affected Plants [MTons]	0.000	36.60	13.20	13.43	13.37
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	36.60	13.20	13.43	13.37
TBtu Consumed	0.000	203.0	180.8	180.8	179.5
Rate - [lb/MMBtu]	0.000	0.3606	0.1460	0.1486	0.1489
TWh Generated	0.000	19.32	17.11	17.11	16.99
TWh Generated Qualifying	0.000	19.32	17.11	17.11	16.99
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Houston Texas

Constraint #: 22

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	8.450	8.450	8.450	8.450	8.450
-Emissions at Affected Plants [MTons]	8.450	8.450	8.450	8.450	8.450
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8.450	8.450	8.450	8.450	8.450
TBtu Consumed	303.3	309.5	264.3	284.4	284.0
Rate - [lb/MMBtu]	0.5572E-01	0.5460E-01	0.6394E-01	0.5942E-01	0.5952E-01
TWh Generated	32.62	33.20	27.12	30.35	30.87
TWh Generated Qualifying	32.62	33.20	27.12	30.35	30.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1927E+05	0.2063E+05	0.1581E+05	9784.	4310.



Constraint Name: NOx Policy for Dallas/Fort Texas  
Constraint Type: Rate Cap [MTons]  
Run Year, Seasons Included: 2007 WINTER SUMMER  
Run Year, Seasons Included: 2010 WINTER SUMMER  
Run Year, Seasons Included: 2015 WINTER SUMMER  
Run Year, Seasons Included: 2020 WINTER SUMMER  
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 23

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	2.164	2.164	2.164	2.164	2.164
-Emissions at Affected Plants [MTons]	0.9841	1.420	0.5821	0.5557	0.4356
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9841	1.420	0.5821	0.5557	0.4356
TBtu Consumed	32.96	47.34	19.37	18.48	15.36
Rate - [lb/MMBtu]	0.5972E-01	0.6001E-01	0.6011E-01	0.6014E-01	0.5674E-01
TWh Generated	3.131	4.507	1.840	1.755	1.459
TWh Generated Qualifying	3.131	4.507	1.840	1.755	1.459
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for East Central Texas  
 Constraint Type: Rate Cap [MTons]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 24

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	123.5	123.5	123.5	123.5	123.5
-Emissions at Affected Plants [MTons]	118.7	123.5	115.7	110.5	103.2
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	118.7	123.5	115.7	110.5	103.2
TBtu Consumed	1681.	1773.	1582.	1506.	1389.
Rate - [lb/MMBtu]	0.1412	0.1393	0.1463	0.1467	0.1485
TWh Generated	178.3	186.3	161.6	154.4	142.3
TWh Generated Qualifying	178.3	186.3	161.6	154.4	142.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1747.	0.000	0.000	0.000

Constraint Name: SO2 Policy for Texas East (Senate Bill 7)      Constraint #: 25  
 Constraint Type: Rate Cap [MTons]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	111.2	111.2	111.2	111.2	111.2
-Emissions at Affected Plants [MTons]	85.64	85.64	8.560	8.560	8.137
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	85.64	85.64	8.560	8.560	8.137
TBTu Consumed	171.3	171.3	171.2	171.2	162.7
Rate - [lb/MMBtu]	1.000	1.000	0.1000	0.1000	0.1000
TWh Generated	16.98	16.98	16.62	16.62	15.86
TWh Generated Qualifying	16.98	16.98	16.62	16.62	15.86
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Rest of Texas East  
Constraint Type: Rate Cap [MTons]  
Run Year, Seasons Included: 2007 WINTER SUMMER  
Run Year, Seasons Included: 2010 WINTER SUMMER  
Run Year, Seasons Included: 2015 WINTER SUMMER  
Run Year, Seasons Included: 2020 WINTER SUMMER  
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 26

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	58.37	58.37	58.37	58.37	58.37
-Emissions at Affected Plants [MTons]	24.68	30.88	27.19	22.15	20.35
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	24.68	30.88	27.19	22.15	20.35
TBtu Consumed	313.4	418.1	351.4	287.9	257.4
Rate - [lb/MMBtu]	0.1575	0.1477	0.1548	0.1538	0.1581
TWh Generated	30.77	40.16	33.62	27.74	25.04
TWh Generated Qualifying	30.77	40.16	33.62	27.74	25.04
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Texas West

Constraint #: 27

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	18.03	18.03	18.03	18.03	18.03
-Emissions at Affected Plants [MTons]	6.388	9.112	6.515	4.267	2.631
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.388	9.112	6.515	4.267	2.631
TBtu Consumed	65.33	89.42	67.04	44.53	24.59
Rate - [lb/MMBtu]	0.1956	0.2038	0.1944	0.1916	0.2140
TWh Generated	6.030	8.325	6.160	4.096	2.366
TWh Generated Qualifying	6.030	8.325	6.160	4.096	2.366
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for El Paso Texas

Constraint #: 28

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	1.058	1.058	1.058	1.058	1.058
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut NOx Facility Specific Constraint      Constraint #: 29

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	2.113	0.8794	0.8794	0.8794	0.8794
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.113	0.8794	0.8794	0.8794	0.8794
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.1500	0.6243E-01	0.6243E-01	0.6243E-01	0.6243E-01
TWh Generated	2.820	2.808	2.808	2.808	2.808
TWh Generated Qualifying	2.820	2.808	2.808	2.808	2.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2311.	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut NOx Facility Specific Constraint    Constraint #: 30  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: BSM Connecticut NOx Facility Specific Constraint      Constraint #: 31

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01	0.8683E-01
TBtu Consumed	1.165	1.165	1.165	1.165	1.165
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.1234	0.1234	0.1234	0.1234	0.1234
TWh Generated Qualifying	0.1234	0.1234	0.1234	0.1234	0.1234
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLR Connecticut NOx Facility Specific Constraint      Constraint #: 32

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLQ Connecticut NOx Facility Specific Constraint      Constraint #: 33

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut NOx Facility Specific Constraint      Constraint #: 34

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKA Connecticut NOx Facility Specific Constraint      Constraint #: 35

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut NOx Facility Specific Constraint      Constraint #: 36

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJD Connecticut NOx Facility Specific Constraint      Constraint #: 37

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ATH Connecticut NOx Facility Specific Constraint      Constraint #: 38

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.774	4.017	3.919	3.106	3.568
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.774	4.017	3.919	3.106	3.568
TBtu Consumed	64.08	53.91	52.61	41.70	47.89
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	8.804	7.407	7.228	5.728	6.579
TWh Generated Qualifying	8.804	7.407	7.228	5.728	6.579
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: AIO Connecticut NOx Facility Specific Constraint      Constraint #: 39

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIN Connecticut NOx Facility Specific Constraint      Constraint #: 40

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.5639E-01	0.5639E-01	0.5639E-01	0.2408E-01	0.2408E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5639E-01	0.5639E-01	0.5639E-01	0.2408E-01	0.2408E-01
TBtu Consumed	0.7569	0.7569	0.7569	0.3232	0.3232
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.7099E-01	0.7099E-01	0.7099E-01	0.3031E-01	0.3031E-01
TWh Generated Qualifying	0.7099E-01	0.7099E-01	0.7099E-01	0.3031E-01	0.3031E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIM Connecticut NOx Facility Specific Constraint      Constraint #: 41  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.3984	0.2848	0.2848	0.1327	0.1327
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3984	0.2848	0.2848	0.1327	0.1327
TBtu Consumed	5.348	3.823	3.823	1.782	1.782
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.6147	0.4395	0.4395	0.2048	0.2048
TWh Generated Qualifying	0.6147	0.4395	0.4395	0.2048	0.2048
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIL Connecticut NOx Facility Specific Constraint      Constraint #: 42

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIK Connecticut NOx Facility Specific Constraint      Constraint #: 43

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01
TBtu Consumed	0.2342	0.2342	0.2342	0.2342	0.2342
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01
TWh Generated Qualifying	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut SO2 Facility Specific Constraint      Constraint #: 44

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	4.649	1.990	1.549	1.549	1.549
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.649	1.990	1.549	1.549	1.549
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.3300	0.1413	0.1100	0.1100	0.1100
TWh Generated	2.820	2.808	2.808	2.808	2.808
TWh Generated Qualifying	2.820	2.808	2.808	2.808	2.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	616.3	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut SO2 Facility Specific Constraint      Constraint #: 45

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	2.438	2.007	2.554	2.554	2.554
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.438	2.007	2.554	2.554	2.554
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.3150	0.2593	0.3300	0.3300	0.3300
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	29.48	0.000	9.076

Constraint Name: BLR Connecticut SO2 Facility Specific Constraint      Constraint #: 46

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: BLQ Connecticut SO2 Facility Specific Constraint      Constraint #: 47

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut SO2 Facility Specific Constraint      Constraint #: 48

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKA Connecticut SO2 Facility Specific Constraint      Constraint #: 49

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut SO2 Facility Specific Constraint      Constraint #: 50

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJD Connecticut SO2 Facility Specific Constraint      Constraint #: 51

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut Hg Facility Specific Constraint      Constraint #: 52  
 Constraint Type: Required Removal Level  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	135.8	51.82	51.08	51.08	51.08
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	135.8	51.82	51.08	51.08	51.08
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.4821E-05	0.1840E-05	0.1813E-05	0.1813E-05	0.1813E-05
TWh Generated	2.820	2.808	2.808	2.808	2.808
TWh Generated Qualifying	2.820	2.808	2.808	2.808	2.808
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut Hg Facility Specific Constraint      Constraint #: 53  
 Constraint Type: Required Removal Level  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	130.2	28.66	23.10	23.10	29.11
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	130.2	28.66	23.10	23.10	29.11
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.8411E-05	0.1851E-05	0.1492E-05	0.1492E-05	0.1881E-05
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCV Illinois NOx Facility Specific Constraint      Constraint #: 54  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
TBtu Consumed	14.32	14.32	14.32	14.32	14.32
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.648	1.648	1.648	1.648	1.648
TWh Generated Qualifying	1.648	1.648	1.648	1.648	1.648
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: ASU Illinois NOx Facility Specific Constraint      Constraint #: 55  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8101	1.047	1.453	1.453	1.453
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8101	1.047	1.453	1.453	1.453
TBtu Consumed	6.507	8.407	11.67	11.67	11.67
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	0.8806	1.138	1.580	1.580	1.580
TWh Generated Qualifying	0.8806	1.138	1.580	1.580	1.580
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFF Illinois NOx Facility Specific Constraint      Constraint #: 56  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFE Illinois NOx Facility Specific Constraint      Constraint #: 57  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 SUMMER  
 Run Year, Seasons Included: 2010 SUMMER  
 Run Year, Seasons Included: 2015 SUMMER  
 Run Year, Seasons Included: 2020 SUMMER  
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1155	0.4409	1.265	1.515	1.341
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1155	0.4409	1.265	1.515	1.341
TBtu Consumed	0.9277	3.541	10.16	12.17	10.77
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	0.8770E-01	0.3348	0.9602	1.150	1.018
TWh Generated Qualifying	0.8770E-01	0.3348	0.9602	1.150	1.018
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CKT Maine NOx Facility Specific Constraint      Constraint #: 58  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.6637	0.6637	0.6637	0.6637	0.6637
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6637	0.6637	0.6637	0.6637	0.6637
TBtu Consumed	6.033	6.033	6.033	6.033	6.033
Rate - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
TWh Generated	0.5659	0.5659	0.5659	0.5659	0.5659
TWh Generated Qualifying	0.5659	0.5659	0.5659	0.5659	0.5659
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3622E+05	0.000	0.000	0.000	3250.

Constraint Name: BLS Maine NOx Facility Specific Constraint      Constraint #: 59  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJG Maine NOx Facility Specific Constraint      Constraint #: 60  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJF Maine NOx Facility Specific Constraint      Constraint #: 61  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BEB Maine NOx Facility Specific Constraint      Constraint #: 62  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CZV New Source Review NOX Facility Specific Constr Constraint #: 63

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9750	0.9750	0.9750	0.9750
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9750	0.9750	0.9750	0.9750
TBtu Consumed	0.000	31.45	31.45	31.45	31.45
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.202	3.202	3.202	3.202
TWh Generated Qualifying	0.000	3.202	3.202	3.202	3.202
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3339.	0.000	0.000	0.000

Constraint Name: CZU New Source Review NOX Facility Specific Constr Constraint #: 64

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9373	0.9373	0.9373	0.9373
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9373	0.9373	0.9373	0.9373
TBtu Consumed	0.000	30.24	30.24	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4011.	0.000	4860.	0.000

Constraint Name: CZT New Source Review NOX Facility Specific Constr Constraint #: 65

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9718	0.9718	0.9718	0.9718
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9718	0.9718	0.9718	0.9718
TBtu Consumed	0.000	31.35	31.35	31.35	31.35
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2184.	2184.	4687.	0.000

Constraint Name: CPX New Source Review NOX Facility Specific Constr Constraint #: 66

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPW New Source Review NOX Facility Specific Constr Constraint #: 67

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPV New Source Review NOX Facility Specific Constr Constraint #: 68

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPS New Source Review NOX Facility Specific Constr Constraint #: 69

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNM New Source Review NOX Facility Specific Constr Constraint #: 70

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7202	0.7202	0.7202
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7202	0.7202	0.7202
TBtu Consumed	0.000	0.000	23.23	23.23	23.23
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.255	2.255	2.255
TWh Generated Qualifying	0.000	0.000	2.255	2.255	2.255
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7417.	8900.	3498.



Constraint Name: CNL New Source Review NOX Facility Specific Constr Constraint #: 71

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6736	0.6736	0.6736
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6736	0.6736	0.6736
TBtu Consumed	0.000	0.000	21.73	21.73	21.73
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.154	2.154	2.154
TWh Generated Qualifying	0.000	0.000	2.154	2.154	2.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4874.	3640.	3880.

Constraint Name: CNK New Source Review NOX Facility Specific Constr Constraint #: 72

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5978	0.5978	0.5978
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5978	0.5978	0.5978
TBtu Consumed	0.000	0.000	19.28	19.28	19.28
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.888	1.888	1.888
TWh Generated Qualifying	0.000	0.000	1.888	1.888	1.888
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8025.	2706.	299.0

Constraint Name: CNJ New Source Review NOX Facility Specific Constr Constraint #: 73

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5862	0.5862	0.5862
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5862	0.5862	0.5862
TBtu Consumed	0.000	0.000	18.91	18.91	18.91
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.885	1.885	1.885
TWh Generated Qualifying	0.000	0.000	1.885	1.885	1.885
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4902.	3075.	3725.

Constraint Name: CLT New Source Review NOX Facility Specific Constr Constraint #: 74

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5356	0.5356	0.5356
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5356	0.5356	0.5356
TBtu Consumed	0.000	0.000	17.28	17.28	17.28
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.581	1.581	1.581
TWh Generated Qualifying	0.000	0.000	1.581	1.581	1.581
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1971.	1472.	1726.

Constraint Name: CLS New Source Review NOX Facility Specific Constr Constraint #: 75

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	1.711	1.711	1.693
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.711	1.711	1.693
TBtu Consumed	0.000	0.000	55.20	55.20	55.10
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6145E-01
TWh Generated	0.000	0.000	5.237	5.237	5.228
TWh Generated Qualifying	0.000	0.000	5.237	5.237	5.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	590.0	0.000	0.000

Constraint Name: CLR New Source Review NOX Facility Specific Constr Constraint #: 76

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8049	0.8049	0.8049
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8049	0.8049	0.8049
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1229.	1090.	1122.

Constraint Name: CLQ New Source Review NOX Facility Specific Constr Constraint #: 77

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3574	0.3574	0.3574
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3574	0.3574	0.3574
TBtu Consumed	0.000	0.000	11.53	11.53	11.53
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.162	1.162	1.162
TWh Generated Qualifying	0.000	0.000	1.162	1.162	1.162
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1261.	0.000	558.7

Constraint Name: CLP New Source Review NOX Facility Specific Constr Constraint #: 78

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3845	0.3845	0.3845
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3845	0.3845	0.3845
TBtu Consumed	0.000	0.000	12.40	12.40	12.40
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.236	1.236	1.236
TWh Generated Qualifying	0.000	0.000	1.236	1.236	1.236
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	767.8	519.3	507.8



Constraint Name: CJG New Source Review NOX Facility Specific Constr Constraint #: 79

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
-Emissions at Affected Plants [MTons]	0.000	1.169	1.169	1.169	1.169
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.169	1.169	1.169	1.169
TBtu Consumed	0.000	38.98	38.98	38.98	38.98
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	3.880	3.880	3.880	3.880
TWh Generated Qualifying	0.000	3.880	3.880	3.880	3.880
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1053E+05	0.2146E+05	0.2538E+05	0.4838E+05

Constraint Name: CGW New Source Review NOX Facility Specific Constr Constraint #: 80

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	1.243	1.480	1.484	1.484	1.484
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.243	1.480	1.484	1.484	1.484
TBtu Consumed	40.10	47.85	47.88	47.88	47.88
Rate - [lb/MMBtu]	0.6200E-01	0.6188E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	3.740	4.464	4.466	4.466	4.466
TWh Generated Qualifying	3.740	4.464	4.466	4.466	4.466
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	373.5	0.000	232.8	0.000	64.85

Constraint Name: CFI New Source Review NOX Facility Specific Constr Constraint #: 81

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.9845	0.9845	0.9845	0.9845	0.9845
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9845	0.9845	0.9845	0.9845	0.9845
TBtu Consumed	31.76	31.76	31.76	31.76	31.76
Rate - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	3.269	3.269	3.269	3.269	3.269
TWh Generated Qualifying	3.269	3.269	3.269	3.269	3.269
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1141.	1141.	2021.	0.000	1141.

Constraint Name: CSD New Source Review SO2 Facility Specific Constr Constraint #: 82

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.831	1.369	1.369	1.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.831	1.369	1.369	1.362
TBtu Consumed	0.000	20.93	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.1750	0.1300	0.1300	0.1300
TWh Generated	0.000	1.960	1.971	1.971	1.961
TWh Generated Qualifying	0.000	1.960	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	807.8	0.000	0.000	0.000

Constraint Name: CSC New Source Review SO2 Facility Specific Constr Constraint #: 83

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.832	1.369	1.369	1.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.832	1.369	1.369	1.362
TBtu Consumed	0.000	20.94	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.1750	0.1300	0.1300	0.1300
TWh Generated	0.000	1.960	1.971	1.971	1.961
TWh Generated Qualifying	0.000	1.960	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	807.8	0.000	0.000	0.000

Constraint Name: CPX New Source Review SO2 Facility Specific Constr Constraint #: 84

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9690.	9967.	9690.

Constraint Name: CPW New Source Review SO2 Facility Specific Constr Constraint #: 85

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9690.	9967.	9690.

Constraint Name: CPV New Source Review SO2 Facility Specific Constr Constraint #: 86

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9690.	9967.	9690.



Constraint Name: CPS New Source Review SO2 Facility Specific Constr Constraint #: 87

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9690.	9967.	9690.

Constraint Name: CNM New Source Review SO2 Facility Specific Constr Constraint #: 88

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.162	1.162	1.162
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.162	1.162	1.162
TBtu Consumed	0.000	0.000	23.23	23.23	23.23
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.255	2.255	2.255
TWh Generated Qualifying	0.000	0.000	2.255	2.255	2.255
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNL New Source Review SO2 Facility Specific Constr Constraint #: 89

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.086	1.086	1.086
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.086	1.086	1.086
TBtu Consumed	0.000	0.000	21.73	21.73	21.73
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.154	2.154	2.154
TWh Generated Qualifying	0.000	0.000	2.154	2.154	2.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNK New Source Review SO2 Facility Specific Constr Constraint #: 90

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.581	1.581	1.581
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.581	1.581	1.581
TBtu Consumed	0.000	0.000	19.28	19.28	19.28
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.888	1.888	1.888
TWh Generated Qualifying	0.000	0.000	1.888	1.888	1.888
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3409.	3608.	2908.

Constraint Name: CNJ New Source Review SO2 Facility Specific Constr Constraint #: 91

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.551	1.551	1.551
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.551	1.551	1.551
TBtu Consumed	0.000	0.000	18.91	18.91	18.91
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.885	1.885	1.885
TWh Generated Qualifying	0.000	0.000	1.885	1.885	1.885
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3560.	3785.	2740.

Constraint Name: CMY New Source Review SO2 Facility Specific Constr Constraint #: 92

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1600	0.1600	0.1600	0.1600	0.1600
-Emissions at Affected Plants [MTons]	3.795	3.813	2.426	2.426	2.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.795	3.813	2.426	2.426	2.362
TBtu Consumed	47.44	47.66	48.53	48.53	47.24
Rate - [lb/MMBtu]	0.1600	0.1600	0.1000	0.1000	0.1000
TWh Generated	4.284	4.304	4.374	4.374	4.258
TWh Generated Qualifying	4.284	4.304	4.374	4.374	4.258
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1634.	1470.	0.000	0.000	0.000

Constraint Name: CLS New Source Review SO2 Facility Specific Constr Constraint #: 93

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	3.041	3.643	3.643	3.637
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.041	3.643	3.643	3.637
TBtu Consumed	0.000	46.08	55.20	55.20	55.10
Rate - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
TWh Generated	0.000	4.363	5.237	5.237	5.228
TWh Generated Qualifying	0.000	4.363	5.237	5.237	5.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.4036E+05	0.1782E+05	0.2077E+05	0.1428E+05

Constraint Name: CLR New Source Review SO2 Facility Specific Constr Constraint #: 94

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	0.000	1.714	1.714	1.714
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.714	1.714	1.714
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1008.	978.5	803.7



Constraint Name: CGQ New Source Review SO2 Facility Specific Constr Constraint #: 95

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.912	1.912	1.912
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.912	1.912	1.912
TBtu Consumed	0.000	0.000	25.49	25.49	25.49
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.332	2.332	2.332
TWh Generated Qualifying	0.000	0.000	2.332	2.332	2.332
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	893.4	956.8	788.5

Constraint Name: CGP New Source Review SO2 Facility Specific Constr Constraint #: 96

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.861	1.912	1.912	1.912
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.861	1.912	1.912	1.912
TBtu Consumed	0.000	24.82	25.49	25.49	25.49
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	2.270	2.332	2.332	2.332
TWh Generated Qualifying	0.000	2.270	2.332	2.332	2.332
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	692.4	923.2	910.3	788.5

Constraint Name: CAS BART Plant Specific SO2 Constraint

Constraint #: 97

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	2.471	2.498	2.498
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.471	2.498	2.498
TBtu Consumed	0.000	0.000	44.93	45.42	45.42
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	4.611	4.667	4.667
TWh Generated Qualifying	0.000	0.000	4.611	4.667	4.667
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2779E+05	0.2382E+05	0.1483E+05

Constraint Name: CAW BART Plant Specific SO2 Constraint

Constraint #: 98

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6849	0.6877	0.6877
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6849	0.6877	0.6877
TBtu Consumed	0.000	0.000	12.45	12.50	12.50
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	1.177	1.181	1.181
TWh Generated Qualifying	0.000	0.000	1.177	1.181	1.181
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1225.	1200.	1809.

Constraint Name: CAX BART Plant Specific SO2 Constraint

Constraint #: 99

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	1.628	1.615	1.615
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.628	1.615	1.615
TBtu Consumed	0.000	0.000	33.05	32.80	32.80
Rate - [lb/MMBtu]	0.000	0.000	0.9851E-01	0.9851E-01	0.9851E-01
TWh Generated	0.000	0.000	3.049	3.024	3.024
TWh Generated Qualifying	0.000	0.000	3.049	3.024	3.024
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	975.8	1200.	1809.

Constraint Name: CBU BART Plant Specific SO2 Constraint

Constraint #: 100

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.974	1.974	1.974
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.974	1.974	1.974
TBtu Consumed	0.000	0.000	39.49	39.49	39.49
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.686	3.686	3.686
TWh Generated Qualifying	0.000	0.000	3.686	3.686	3.686
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1362.	1980.	730.6

Constraint Name: CBY BART Plant Specific SO2 Constraint

Constraint #: 101

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.934	5.934	5.934
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.934	5.934	5.934
TBtu Consumed	0.000	0.000	118.7	118.7	118.7
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	11.43	11.43	11.43
TWh Generated Qualifying	0.000	0.000	11.43	11.43	11.43
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3235E+05	0.2750E+05	0.2453E+05

Constraint Name: CBZ BART Plant Specific SO2 Constraint

Constraint #: 102

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.207	2.207	2.207
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.207	2.207	2.207
TBtu Consumed	0.000	0.000	44.15	44.15	44.15
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.891	3.891	3.891
TWh Generated Qualifying	0.000	0.000	3.891	3.891	3.891
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3164E+05	0.2760E+05	0.2168E+05



Constraint Name: CCL BART Plant Specific SO2 Constraint

Constraint #: 103

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5443	0.5536	0.5536
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5443	0.5536	0.5536
TBtu Consumed	0.000	0.000	10.89	11.07	11.07
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.024	1.041	1.041
TWh Generated Qualifying	0.000	0.000	1.024	1.041	1.041
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4547.	4530.	4518.

Constraint Name: CCN BART Plant Specific SO2 Constraint

Constraint #: 104

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.138	3.138	3.138
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.138	3.138	3.138
TBtu Consumed	0.000	0.000	62.76	62.76	62.76
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	5.613	5.613	5.613
TWh Generated Qualifying	0.000	0.000	5.613	5.613	5.613
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3473.	3939.	7945.

Constraint Name: CCO BART Plant Specific SO2 Constraint

Constraint #: 105

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.925	1.925	1.925
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.925	1.925	1.925
TBtu Consumed	0.000	0.000	38.50	38.50	38.50
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.358	3.358	3.358
TWh Generated Qualifying	0.000	0.000	3.358	3.358	3.358
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1401.	803.6	1108.

Constraint Name: CCQ BART Plant Specific SO2 Constraint

Constraint #: 106

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8030	0.8030	0.8030
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8030	0.8030	0.8030
TBtu Consumed	0.000	0.000	16.06	16.06	16.06
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.520	1.519	1.519
TWh Generated Qualifying	0.000	0.000	1.520	1.519	1.519
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3361.	3166.	3159.

Constraint Name: CDC BART Plant Specific SO2 Constraint

Constraint #: 107

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	1.267	1.282	1.282
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.267	1.282	1.282
TBtu Consumed	0.000	0.000	23.03	23.31	23.31
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	2.155	2.181	2.181
TWh Generated Qualifying	0.000	0.000	2.155	2.181	2.181
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1293.	1293.	1298.

Constraint Name: CDD BART Plant Specific SO2 Constraint

Constraint #: 108

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.949	1.949	1.949
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.949	1.949	1.949
TBtu Consumed	0.000	0.000	38.97	38.97	38.97
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2926.	1781.	3372.

Constraint Name: CDE BART Plant Specific SO2 Constraint

Constraint #: 109

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.562	1.669	1.669
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.562	1.669	1.669
TBtu Consumed	0.000	0.000	31.24	33.38	33.38
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.921	3.120	3.120
TWh Generated Qualifying	0.000	0.000	2.921	3.120	3.120
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2842.	2180.	1908.

Constraint Name: CDF BART Plant Specific SO2 Constraint

Constraint #: 110

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	20.55	20.55	20.55
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	20.55	20.55	20.55
TBtu Consumed	0.000	0.000	373.6	373.6	373.6
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	37.72	37.72	37.72
TWh Generated Qualifying	0.000	0.000	37.72	37.72	37.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2231E+05	0.1581E+05	0.1787E+05



Constraint Name: CEF BART Plant Specific SO2 Constraint      Constraint #: 111  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7472	0.7472	0.7485
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7472	0.7472	0.7485
TBtu Consumed	0.000	0.000	13.59	13.59	13.61
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	1.289	1.289	1.291
TWh Generated Qualifying	0.000	0.000	1.289	1.289	1.291
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	662.8	600.6	583.6

Constraint Name: CEG BART Plant Specific SO2 Constraint

Constraint #: 112

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8665	0.8665	0.8665
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8665	0.8665	0.8665
TBtu Consumed	0.000	0.000	15.76	15.76	15.76
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	1.434	1.434	1.434
TWh Generated Qualifying	0.000	0.000	1.434	1.434	1.434
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	601.5	523.2	455.9

Constraint Name: CEI BART Plant Specific SO2 Constraint

Constraint #: 113

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	3.676	3.676	3.676
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.676	3.676	3.676
TBtu Consumed	0.000	0.000	83.54	83.54	83.54
Rate - [lb/MMBtu]	0.000	0.000	0.8800E-01	0.8800E-01	0.8800E-01
TWh Generated	0.000	0.000	7.633	7.633	7.633
TWh Generated Qualifying	0.000	0.000	7.633	7.633	7.633
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CEJ BART Plant Specific SO2 Constraint

Constraint #: 114

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.888	2.888	2.888
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.888	2.888	2.888
TBtu Consumed	0.000	0.000	57.76	57.76	57.76
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.293	6.293	6.293
TWh Generated Qualifying	0.000	0.000	6.293	6.293	6.293
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2151E+05	0.2458E+05	0.1839E+05

Constraint Name: CEN BART Plant Specific SO2 Constraint

Constraint #: 115

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	2.889	2.889	2.889
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.889	2.889	2.889
TBtu Consumed	0.000	0.000	52.53	52.53	52.53
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	5.159	5.159	5.159
TWh Generated Qualifying	0.000	0.000	5.159	5.159	5.159
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1231.	1236.	1164.

Constraint Name: CEO BART Plant Specific SO2 Constraint

Constraint #: 116

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6902	0.6902	0.6949
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6902	0.6902	0.6949
TBtu Consumed	0.000	0.000	12.55	12.55	12.64
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	1.113	1.113	1.121
TWh Generated Qualifying	0.000	0.000	1.113	1.113	1.121
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1438.	1427.	1405.

Constraint Name: CEQ BART Plant Specific SO2 Constraint

Constraint #: 117

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.447	2.447	2.447
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.447	2.447	2.447
TBTu Consumed	0.000	0.000	48.94	48.94	48.94
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.127	4.127	4.127
TWh Generated Qualifying	0.000	0.000	4.127	4.127	4.127
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3619.	3341.	3282.

Constraint Name: CEX BART Plant Specific SO2 Constraint

Constraint #: 118

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.131	2.131	2.131
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.131	2.131	2.131
TBtu Consumed	0.000	0.000	42.63	42.63	42.63
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.864	3.864	3.864
TWh Generated Qualifying	0.000	0.000	3.864	3.864	3.864
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2995.	2960.	2984.



Constraint Name: CEY BART Plant Specific SO2 Constraint

Constraint #: 119

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.047	2.047	2.047
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.047	2.047	2.047
TBtu Consumed	0.000	0.000	40.94	40.94	40.94
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.009	4.009	4.009
TWh Generated Qualifying	0.000	0.000	4.009	4.009	4.009
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	6350.	6861.	5804.

Constraint Name: CEZ BART Plant Specific SO2 Constraint

Constraint #: 120

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.099	2.099	2.099
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.099	2.099	2.099
TBtu Consumed	0.000	0.000	41.98	41.98	41.98
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.816	3.816	3.816
TWh Generated Qualifying	0.000	0.000	3.816	3.816	3.816
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1686.	552.8	0.000

Constraint Name: CFA BART Plant Specific SO2 Constraint

Constraint #: 121

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.870	5.870	5.870
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.870	5.870	5.870
TBtu Consumed	0.000	0.000	117.4	117.4	117.4
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	11.19	11.19	11.19
TWh Generated Qualifying	0.000	0.000	11.19	11.19	11.19
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2922.	1890.	2461.

Constraint Name: CFB BART Plant Specific SO2 Constraint

Constraint #: 122

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.988	3.988	3.988
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.988	3.988	3.988
TBtu Consumed	0.000	0.000	79.76	79.76	79.76
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	7.310	7.310	7.310
TWh Generated Qualifying	0.000	0.000	7.310	7.310	7.310
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2922.	1646.	2355.

Constraint Name: CFC BART Plant Specific SO2 Constraint

Constraint #: 123

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.274	1.274	1.274
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.274	1.274	1.274
TBtu Consumed	0.000	0.000	25.48	25.48	25.48
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.446	2.446	2.446
TWh Generated Qualifying	0.000	0.000	2.446	2.446	2.446
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2298.	2227.	2247.

Constraint Name: CFD BART Plant Specific SO2 Constraint

Constraint #: 124

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.318	1.318	1.318
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.318	1.318	1.318
TBtu Consumed	0.000	0.000	26.35	26.35	26.35
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2378.	2302.	2322.

Constraint Name: CFF BART Plant Specific SO2 Constraint

Constraint #: 125

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	2.144	2.144	2.144
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.144	2.144	2.144
TBtu Consumed	0.000	0.000	38.99	38.99	38.99
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2878.	2137.	3284.

Constraint Name: CFG BART Plant Specific SO2 Constraint

Constraint #: 126

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	2.459	2.459	2.459
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.459	2.459	2.459
TBtu Consumed	0.000	0.000	44.72	44.72	44.72
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	4.374	4.374	4.374
TWh Generated Qualifying	0.000	0.000	4.374	4.374	4.374
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1151E+05	4790.	4674.



Constraint Name: CFO BART Plant Specific SO2 Constraint

Constraint #: 127

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.985	1.985	1.985
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.985	1.985	1.985
TBtu Consumed	0.000	0.000	39.69	39.69	39.69
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.711	3.711	3.711
TWh Generated Qualifying	0.000	0.000	3.711	3.711	3.711
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2926.	1781.	3372.

Constraint Name: CFQ BART Plant Specific SO2 Constraint

Constraint #: 128

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.978	2.025	1.978
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.978	2.025	1.978
TBtu Consumed	0.000	0.000	39.56	40.51	39.56
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.755	3.845	3.755
TWh Generated Qualifying	0.000	0.000	3.755	3.845	3.755
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3485E+05	0.3306E+05	0.2711E+05

Constraint Name: CFR BART Plant Specific SO2 Constraint

Constraint #: 129

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	1.549	1.549	1.549
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.549	1.549	1.549
TBtu Consumed	0.000	0.000	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	2.808	2.808	2.808
TWh Generated Qualifying	0.000	0.000	2.808	2.808	2.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	650.6	869.1	1523.

Constraint Name: CFS BART Plant Specific SO2 Constraint

Constraint #: 130

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.448	2.448	2.448
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.448	2.448	2.448
TBtu Consumed	0.000	0.000	48.96	48.96	48.96
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	5.081	5.081	5.081
TWh Generated Qualifying	0.000	0.000	5.081	5.081	5.081
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2245E+05	0.2571E+05	0.1372E+05

Constraint Name: CFY BART Plant Specific SO2 Constraint      Constraint #: 131  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.627	4.627	4.627
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.627	4.627	4.627
TBtu Consumed	0.000	0.000	92.54	92.54	92.54
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.420	8.420	8.420
TWh Generated Qualifying	0.000	0.000	8.420	8.420	8.420
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7410.	7289.	6829.

Constraint Name: CFZ BART Plant Specific SO2 Constraint

Constraint #: 132

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.344	3.344	3.344
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.344	3.344	3.344
TBtu Consumed	0.000	0.000	66.88	66.88	66.88
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.266	6.266	6.266
TWh Generated Qualifying	0.000	0.000	6.266	6.266	6.266
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1604.	1582.	1560.

Constraint Name: CGG BART Plant Specific SO2 Constraint

Constraint #: 133

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5051	0.5051	0.5051
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5051	0.5051	0.5051
TBtu Consumed	0.000	0.000	10.10	10.10	10.10
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	0.9707	0.9707	0.9707
TWh Generated Qualifying	0.000	0.000	0.9707	0.9707	0.9707
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2473.	2325.	2315.

Constraint Name: CGI BART Plant Specific SO2 Constraint

Constraint #: 134

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9806	0.9859	0.9859
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9806	0.9859	0.9859
TBtu Consumed	0.000	0.000	19.61	19.72	19.72
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.876	1.884	1.884
TWh Generated Qualifying	0.000	0.000	1.876	1.884	1.884
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3476.	5023.	1461.



Constraint Name: CGO BART Plant Specific SO2 Constraint

Constraint #: 135

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	16.96	16.96	16.96
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	16.96	16.96	16.96
TBtu Consumed	0.000	0.000	226.1	226.1	226.1
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	21.14	21.14	21.14
TWh Generated Qualifying	0.000	0.000	21.14	21.14	21.14
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	6693.	0.1701E+05	0.1359E+05

Constraint Name: CGR BART Plant Specific SO2 Constraint

Constraint #: 136

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	3.800	3.800	3.800
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.800	3.800	3.800
TBtu Consumed	0.000	0.000	50.66	50.66	50.66
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	4.702	4.702	4.702
TWh Generated Qualifying	0.000	0.000	4.702	4.702	4.702
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8267.	0.1500E+05	0.1412E+05

Constraint Name: CGS BART Plant Specific SO2 Constraint

Constraint #: 137

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.934	1.936	1.936
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.934	1.936	1.936
TBtu Consumed	0.000	0.000	25.79	25.81	25.81
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.358	2.359	2.359
TWh Generated Qualifying	0.000	0.000	2.358	2.359	2.359
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	722.4	709.6	744.1

Constraint Name: CGV BART Plant Specific SO2 Constraint

Constraint #: 138

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9387	0.9409	0.9409
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9387	0.9409	0.9409
TBtu Consumed	0.000	0.000	12.52	12.55	12.55
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	1.213	1.215	1.215
TWh Generated Qualifying	0.000	0.000	1.213	1.215	1.215
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1212.	1169.	1155.

Constraint Name: CGY BART Plant Specific SO2 Constraint

Constraint #: 139

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	2.069	2.069	2.069
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.069	2.069	2.069
TBtu Consumed	0.000	0.000	27.59	27.59	27.59
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.611	2.611	2.611
TWh Generated Qualifying	0.000	0.000	2.611	2.611	2.611
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1297.	1199.	959.0

Constraint Name: CHG BART Plant Specific SO2 Constraint

Constraint #: 140

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	5.719	5.719	5.719
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.719	5.719	5.719
TBtu Consumed	0.000	0.000	76.25	76.25	76.25
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	7.623	7.623	7.623
TWh Generated Qualifying	0.000	0.000	7.623	7.623	7.623
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	814.9	803.6	570.2

Constraint Name: CHL BART Plant Specific SO2 Constraint

Constraint #: 141

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.308	2.433	2.433
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.308	2.433	2.433
TBtu Consumed	0.000	0.000	46.16	48.67	48.67
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.405	4.644	4.644
TWh Generated Qualifying	0.000	0.000	4.405	4.644	4.644
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3504E+05	0.2574E+05	0.2018E+05

Constraint Name: CHM BART Plant Specific SO2 Constraint

Constraint #: 142

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.256	2.256	2.256
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.256	2.256	2.256
TBtu Consumed	0.000	0.000	45.12	45.12	45.12
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.549	4.549	4.549
TWh Generated Qualifying	0.000	0.000	4.549	4.549	4.549
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2653E+05	0.1654E+05	0.2007E+05



Constraint Name: CHP BART Plant Specific SO2 Constraint

Constraint #: 143

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	3.673	3.673	3.673
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.673	3.673	3.673
TBtu Consumed	0.000	0.000	48.98	48.98	48.98
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	4.709	4.709	4.709
TWh Generated Qualifying	0.000	0.000	4.709	4.709	4.709
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9227.	0.2129E+05	0.1785E+05

Constraint Name: CHR BART Plant Specific SO2 Constraint

Constraint #: 144

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2942.	4216.	3671.

Constraint Name: CHT BART Plant Specific SO2 Constraint

Constraint #: 145

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1100	0.1100	0.1100
-Emissions at Affected Plants [MTons]	0.000	0.000	1.234	1.234	1.234
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.234	1.234	1.234
TBtu Consumed	0.000	0.000	22.43	22.43	22.43
Rate - [lb/MMBtu]	0.000	0.000	0.1100	0.1100	0.1100
TWh Generated	0.000	0.000	1.786	1.786	1.786
TWh Generated Qualifying	0.000	0.000	1.786	1.786	1.786
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2878.	2137.	3284.

Constraint Name: CHU BART Plant Specific SO2 Constraint

Constraint #: 146

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.138	2.138	2.138
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.138	2.138	2.138
TBtu Consumed	0.000	0.000	42.76	42.76	42.76
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.026	4.026	4.026
TWh Generated Qualifying	0.000	0.000	4.026	4.026	4.026
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3419E+05	0.2952E+05	0.2659E+05

Constraint Name: CHW BART Plant Specific SO2 Constraint

Constraint #: 147

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.544	2.566	2.566
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.544	2.566	2.566
TBtu Consumed	0.000	0.000	50.89	51.32	51.32
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.826	4.867	4.867
TWh Generated Qualifying	0.000	0.000	4.826	4.867	4.867
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1946.	2600.	1391.

Constraint Name: CHX BART Plant Specific SO2 Constraint

Constraint #: 148

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.967	4.013	4.013
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.967	4.013	4.013
TBtu Consumed	0.000	0.000	79.34	80.27	80.27
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.976	7.058	7.058
TWh Generated Qualifying	0.000	0.000	6.976	7.058	7.058
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2221.	2229.	2145.

Constraint Name: CIG BART Plant Specific SO2 Constraint

Constraint #: 149

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2600	0.2600	0.2600
-Emissions at Affected Plants [MTons]	0.000	0.000	19.14	19.14	19.14
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	19.14	19.14	19.14
TBtu Consumed	0.000	0.000	147.2	147.2	147.2
Rate - [lb/MMBtu]	0.000	0.000	0.2600	0.2600	0.2600
TWh Generated	0.000	0.000	13.77	13.77	13.77
TWh Generated Qualifying	0.000	0.000	13.77	13.77	13.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	880.9	910.4	809.5

Constraint Name: CIH BART Plant Specific SO2 Constraint

Constraint #: 150

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.324	1.338	1.338
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.324	1.338	1.338
TBtu Consumed	0.000	0.000	17.65	17.83	17.83
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	1.615	1.632	1.632
TWh Generated Qualifying	0.000	0.000	1.615	1.632	1.632
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1239.	1293.	1135.



Constraint Name: CII BART Plant Specific SO2 Constraint

Constraint #: 151

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1400	0.1400	0.1400
-Emissions at Affected Plants [MTons]	0.000	0.000	14.29	14.64	14.20
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	14.29	14.64	14.20
TBtu Consumed	0.000	0.000	204.2	209.1	202.8
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	19.09	19.55	18.96
TWh Generated Qualifying	0.000	0.000	19.09	19.55	18.96
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.8250E+05	0.7745E+05	0.7433E+05

Constraint Name: CIK BART Plant Specific SO2 Constraint

Constraint #: 152

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2700	0.2700	0.2700
-Emissions at Affected Plants [MTons]	0.000	0.000	5.180	5.180	5.180
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.180	5.180	5.180
TBtu Consumed	0.000	0.000	40.50	40.50	40.50
Rate - [lb/MMBtu]	0.000	0.000	0.2558	0.2558	0.2558
TWh Generated	0.000	0.000	4.216	4.216	4.216
TWh Generated Qualifying	0.000	0.000	4.216	4.216	4.216
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1061.	865.4	959.0

Constraint Name: CIQ BART Plant Specific SO2 Constraint

Constraint #: 153

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.307	1.307	1.307
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.307	1.307	1.307
TBtu Consumed	0.000	0.000	26.14	26.14	26.14
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.639	2.639	2.639
TWh Generated Qualifying	0.000	0.000	2.639	2.639	2.639
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3023.	2489.	3611.

Constraint Name: CJQ BART Plant Specific SO2 Constraint

Constraint #: 154

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.4181	0.4181
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.4181	0.4181
TBtu Consumed	0.000	0.000	0.000	8.361	8.361
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.1000	0.1000
TWh Generated	0.000	0.000	0.000	0.6790	0.6790
TWh Generated Qualifying	0.000	0.000	0.000	0.6790	0.6790
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	6596.	2554.	2528.

Constraint Name: CJZ BART Plant Specific SO2 Constraint

Constraint #: 155

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1400	0.1400	0.1400
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5432	0.5816	0.5816
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5432	0.5816	0.5816
TBtu Consumed	0.000	0.000	7.760	8.309	8.309
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	0.7627	0.8167	0.8167
TWh Generated Qualifying	0.000	0.000	0.7627	0.8167	0.8167
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1938.	1858.	1861.

Constraint Name: CKC BART Plant Specific SO2 Constraint

Constraint #: 156

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	1.238	1.250	1.250
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.238	1.250	1.250
TBtu Consumed	0.000	0.000	11.26	11.37	11.37
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	0.9493	0.9588	0.9588
TWh Generated Qualifying	0.000	0.000	0.9493	0.9588	0.9588
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	933.1	968.9	904.5

Constraint Name: CKI BART Plant Specific SO2 Constraint

Constraint #: 157

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2700	0.2700	0.2700
-Emissions at Affected Plants [MTons]	0.000	0.000	5.327	5.327	5.327
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.327	5.327	5.327
TBtu Consumed	0.000	0.000	39.46	39.46	39.46
Rate - [lb/MMBtu]	0.000	0.000	0.2700	0.2700	0.2700
TWh Generated	0.000	0.000	3.996	3.996	3.996
TWh Generated Qualifying	0.000	0.000	3.996	3.996	3.996
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1043.	883.4	968.2

Constraint Name: CKL BART Plant Specific SO2 Constraint

Constraint #: 158

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	2.055	2.059	2.059
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.055	2.059	2.059
TBtu Consumed	0.000	0.000	18.68	18.72	18.72
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	1.759	1.761	1.761
TWh Generated Qualifying	0.000	0.000	1.759	1.761	1.761
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	981.1	951.7	892.0



Constraint Name: CKP BART Plant Specific SO2 Constraint

Constraint #: 159

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8001.	7196.	7443.

Constraint Name: CKW BART Plant Specific SO2 Constraint

Constraint #: 160

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	2.557	2.509	2.509
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.557	2.509	2.509
TBtu Consumed	0.000	0.000	39.35	38.60	38.60
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	3.678	3.609	3.609
TWh Generated Qualifying	0.000	0.000	3.678	3.609	3.609
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.8250E+05	0.7745E+05	0.7433E+05

Constraint Name: CKX BART Plant Specific SO2 Constraint

Constraint #: 161

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1400	0.1400	0.1400
-Emissions at Affected Plants [MTons]	0.000	0.000	12.19	12.19	12.19
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	12.19	12.19	12.19
TBtu Consumed	0.000	0.000	174.1	174.1	174.1
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	15.73	15.73	15.73
TWh Generated Qualifying	0.000	0.000	15.73	15.73	15.73
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1339.	1243.	1268.

Constraint Name: CLB BART Plant Specific SO2 Constraint

Constraint #: 162

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	2.078	2.078	2.068
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.078	2.078	2.068
TBtu Consumed	0.000	0.000	31.97	31.97	31.82
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	2.993	2.993	2.978
TWh Generated Qualifying	0.000	0.000	2.993	2.993	2.978
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1339.	1005.	1054.

Constraint Name: CLC BART Plant Specific SO2 Constraint

Constraint #: 163

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	2.462	2.462	2.389
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.462	2.462	2.389
TBtu Consumed	0.000	0.000	37.88	37.88	36.76
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	3.215	3.215	3.120
TWh Generated Qualifying	0.000	0.000	3.215	3.215	3.120
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1297.	1172.	1256.

Constraint Name: CLR BART Plant Specific SO2 Constraint

Constraint #: 164

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.714	1.714	1.714
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.714	1.714	1.714
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLS BART Plant Specific SO2 Constraint

Constraint #: 165

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.643	3.643	3.637
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.643	3.643	3.637
TBtu Consumed	0.000	0.000	55.20	55.20	55.10
Rate - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
TWh Generated	0.000	0.000	5.237	5.237	5.228
TWh Generated Qualifying	0.000	0.000	5.237	5.237	5.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLT BART Plant Specific SO2 Constraint

Constraint #: 166

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1900	0.1900	0.1900
-Emissions at Affected Plants [MTons]	0.000	0.000	1.641	1.641	1.641
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.641	1.641	1.641
TBtu Consumed	0.000	0.000	17.28	17.28	17.28
Rate - [lb/MMBtu]	0.000	0.000	0.1900	0.1900	0.1900
TWh Generated	0.000	0.000	1.581	1.581	1.581
TWh Generated Qualifying	0.000	0.000	1.581	1.581	1.581
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1070.	1012.	698.8



Constraint Name: CLU BART Plant Specific SO2 Constraint

Constraint #: 167

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.198	3.198	3.198
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.198	3.198	3.198
TBtu Consumed	0.000	0.000	63.96	63.96	63.96
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.984	6.984	6.984
TWh Generated Qualifying	0.000	0.000	6.984	6.984	6.984
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2641E+05	0.2163E+05	0.1444E+05

Constraint Name: CMO BART Plant Specific SO2 Constraint

Constraint #: 168

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.883	3.883	3.883
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.883	3.883	3.883
TBtu Consumed	0.000	0.000	77.66	77.66	77.66
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.238	8.238	8.238
TWh Generated Qualifying	0.000	0.000	8.238	8.238	8.238
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2673E+05	0.1885E+05	0.1825E+05

Constraint Name: CMP BART Plant Specific SO2 Constraint

Constraint #: 169

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.677	4.677	4.254
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.677	4.677	4.254
TBtu Consumed	0.000	0.000	93.54	93.54	85.08
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.383	8.383	7.625
TWh Generated Qualifying	0.000	0.000	8.383	8.383	7.625
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1399E+05	0.2142E+05	0.2344E+05

Constraint Name: CMS BART Plant Specific SO2 Constraint

Constraint #: 170

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1400	0.1400	0.1400
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8789	0.8807	0.8807
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8789	0.8807	0.8807
TBtu Consumed	0.000	0.000	12.56	12.58	12.58
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	1.221	1.223	1.223
TWh Generated Qualifying	0.000	0.000	1.221	1.223	1.223
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	614.4	718.0	551.8

Constraint Name: CMT BART Plant Specific SO2 Constraint

Constraint #: 171

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1400	0.1400	0.1400
-Emissions at Affected Plants [MTons]	0.000	0.000	3.956	4.057	4.057
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.956	4.057	4.057
TBtu Consumed	0.000	0.000	56.51	57.96	57.96
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	4.899	5.025	5.025
TWh Generated Qualifying	0.000	0.000	4.899	5.025	5.025
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	429.7	614.2	254.5

Constraint Name: CMU BART Plant Specific SO2 Constraint

Constraint #: 172

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8823	0.8823	0.8823
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8823	0.8823	0.8823
TBtu Consumed	0.000	0.000	17.65	17.65	17.65
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.526	1.526	1.526
TWh Generated Qualifying	0.000	0.000	1.526	1.526	1.526
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1337.	1415.	1133.

Constraint Name: CMX BART Plant Specific SO2 Constraint

Constraint #: 173

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.114	7.042	6.574
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.114	7.042	6.574
TBtu Consumed	0.000	0.000	142.3	140.8	131.5
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	13.35	13.21	12.33
TWh Generated Qualifying	0.000	0.000	13.35	13.21	12.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2304E+05	0.2434E+05	0.1627E+05

Constraint Name: CMY BART Plant Specific SO2 Constraint

Constraint #: 174

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.426	2.426	2.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.426	2.426	2.362
TBtu Consumed	0.000	0.000	48.53	48.53	47.24
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.374	4.374	4.258
TWh Generated Qualifying	0.000	0.000	4.374	4.374	4.258
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2317E+05	0.2762E+05	0.2154E+05



Constraint Name: CNH BART Plant Specific SO2 Constraint

Constraint #: 175

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.827	4.827	4.827
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.827	4.827	4.827
TBtu Consumed	0.000	0.000	96.54	96.54	96.54
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	9.185	9.185	9.185
TWh Generated Qualifying	0.000	0.000	9.185	9.185	9.185
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2080E+05	0.3031E+05	0.1136E+05

Constraint Name: CNI BART Plant Specific SO2 Constraint

Constraint #: 176

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.522	4.522	4.113
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.522	4.522	4.113
TBtu Consumed	0.000	0.000	90.43	90.43	82.25
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.456	8.456	7.691
TWh Generated Qualifying	0.000	0.000	8.456	8.456	7.691
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2562E+05	0.2484E+05	0.2408E+05

Constraint Name: CNL BART Plant Specific SO2 Constraint

Constraint #: 177

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.086	1.086	1.086
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.086	1.086	1.086
TBtu Consumed	0.000	0.000	21.73	21.73	21.73
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.154	2.154	2.154
TWh Generated Qualifying	0.000	0.000	2.154	2.154	2.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3449.	4249.	2922.

Constraint Name: CNM BART Plant Specific SO2 Constraint

Constraint #: 178

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.162	1.162	1.162
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.162	1.162	1.162
TBtu Consumed	0.000	0.000	23.23	23.23	23.23
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.255	2.255	2.255
TWh Generated Qualifying	0.000	0.000	2.255	2.255	2.255
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3705.	3722.	2922.

Constraint Name: CNN BART Plant Specific SO2 Constraint

Constraint #: 179

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.977	1.977	1.977
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.977	1.977	1.977
TBtu Consumed	0.000	0.000	39.55	39.55	39.55
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.809	3.809	3.809
TWh Generated Qualifying	0.000	0.000	3.809	3.809	3.809
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1589.	1589.	1607.

Constraint Name: CNO BART Plant Specific SO2 Constraint

Constraint #: 180

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.040	2.040	2.040
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.040	2.040	2.040
TBtu Consumed	0.000	0.000	40.80	40.80	40.80
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.808	3.808	3.808
TWh Generated Qualifying	0.000	0.000	3.808	3.808	3.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1759.	1404.	1622.

Constraint Name: CNQ BART Plant Specific SO2 Constraint      Constraint #: 181  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.962	4.028	4.028
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.962	4.028	4.028
TBtu Consumed	0.000	0.000	79.24	80.56	80.56
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	7.254	7.375	7.375
TWh Generated Qualifying	0.000	0.000	7.254	7.375	7.375
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1925.	2111.	1715.

Constraint Name: CNR BART Plant Specific SO2 Constraint

Constraint #: 182

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.071	2.231	2.231
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.071	2.231	2.231
TBtu Consumed	0.000	0.000	41.42	44.62	44.62
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.918	4.221	4.221
TWh Generated Qualifying	0.000	0.000	3.918	4.221	4.221
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3227E+05	0.3146E+05	0.2563E+05



Constraint Name: CNS BART Plant Specific SO2 Constraint

Constraint #: 183

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.161	2.328	2.250
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.161	2.328	2.250
TBtu Consumed	0.000	0.000	43.22	46.56	45.00
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.918	4.221	4.079
TWh Generated Qualifying	0.000	0.000	3.918	4.221	4.079
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3250E+05	0.3037E+05	0.2292E+05

Constraint Name: CNW BART Plant Specific SO2 Constraint

Constraint #: 184

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	2.105	2.106	6.324
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.2708	0.2708	0.8133
TWh Generated Qualifying	0.000	0.000	0.2708	0.2708	0.8133
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	9690.	9967.	9690.

Constraint Name: COB BART Plant Specific SO2 Constraint

Constraint #: 185

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.068	3.068	3.068
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.068	3.068	3.068
TBtu Consumed	0.000	0.000	61.35	61.35	61.35
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	5.798	5.798	5.798
TWh Generated Qualifying	0.000	0.000	5.798	5.798	5.798
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2215.	2140.	1984.

Constraint Name: COC BART Plant Specific SO2 Constraint

Constraint #: 186

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.611	2.611	2.611
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.611	2.611	2.611
TBtu Consumed	0.000	0.000	52.21	52.21	52.21
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.848	4.848	4.848
TWh Generated Qualifying	0.000	0.000	4.848	4.848	4.848
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2722E+05	0.2246E+05	0.2367E+05

Constraint Name: COE BART Plant Specific SO2 Constraint

Constraint #: 187

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.661	2.777	2.777
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.661	2.777	2.777
TBtu Consumed	0.000	0.000	53.22	55.54	55.54
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.890	5.103	5.103
TWh Generated Qualifying	0.000	0.000	4.890	5.103	5.103
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1701E+05	0.1984E+05	0.2269E+05

Constraint Name: COF BART Plant Specific SO2 Constraint

Constraint #: 188

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.693	1.718	1.718
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.693	1.718	1.718
TBtu Consumed	0.000	0.000	33.85	34.36	34.36
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.232	3.280	3.280
TWh Generated Qualifying	0.000	0.000	3.232	3.280	3.280
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2140.	2492.	1744.

Constraint Name: COG BART Plant Specific SO2 Constraint

Constraint #: 189

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.492	1.512	1.512
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.492	1.512	1.512
TBtu Consumed	0.000	0.000	29.85	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.695	2.730	2.730
TWh Generated Qualifying	0.000	0.000	2.695	2.730	2.730
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2405.	3165.	1722.

Constraint Name: COH BART Plant Specific SO2 Constraint

Constraint #: 190

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8954	0.8954	0.8954
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8954	0.8954	0.8954
TBtu Consumed	0.000	0.000	17.91	17.91	17.91
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.707	1.707	1.707
TWh Generated Qualifying	0.000	0.000	1.707	1.707	1.707
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1304.	1277.	1276.



Constraint Name: COI BART Plant Specific SO2 Constraint

Constraint #: 191

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.146	4.146	4.146
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.146	4.146	4.146
TBtu Consumed	0.000	0.000	82.93	82.93	82.93
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	7.712	7.712	7.712
TWh Generated Qualifying	0.000	0.000	7.712	7.712	7.712
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2074.	803.6	1582.

Constraint Name: COJ BART Plant Specific SO2 Constraint

Constraint #: 192

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.109	2.109	2.109
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.109	2.109	2.109
TBtu Consumed	0.000	0.000	42.18	42.18	42.18
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.856	3.856	3.856
TWh Generated Qualifying	0.000	0.000	3.856	3.856	3.856
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1521.	1467.	1565.

Constraint Name: COK BART Plant Specific SO2 Constraint

Constraint #: 193

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.299	1.299	1.299
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.299	1.299	1.299
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.527	2.527	2.527
TWh Generated Qualifying	0.000	0.000	2.527	2.527	2.527
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1930.	1875.	1973.

Constraint Name: CON BART Plant Specific SO2 Constraint

Constraint #: 194

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6393	0.6393	0.6393
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6393	0.6393	0.6393
TBtu Consumed	0.000	0.000	12.79	12.79	12.79
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.141	1.141	1.141
TWh Generated Qualifying	0.000	0.000	1.141	1.141	1.141
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3094.	3094.	3090.

Constraint Name: COP BART Plant Specific SO2 Constraint

Constraint #: 195

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	10.94	10.94	10.94
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	10.94	10.94	10.94
TBtu Consumed	0.000	0.000	218.8	218.8	218.8
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	21.87	21.87	21.87
TWh Generated Qualifying	0.000	0.000	21.87	21.87	21.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2046E+05	9967.	9690.

Constraint Name: COR BART Plant Specific SO2 Constraint

Constraint #: 196

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	23.65	23.65	23.65
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	23.65	23.65	23.65
TBtu Consumed	0.000	0.000	168.9	168.9	168.9
Rate - [lb/MMBtu]	0.000	0.000	0.2800	0.2800	0.2800
TWh Generated	0.000	0.000	16.93	16.93	16.93
TWh Generated Qualifying	0.000	0.000	16.93	16.93	16.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	918.1	922.7	959.0

Constraint Name: COS BART Plant Specific SO2 Constraint

Constraint #: 197

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	3.685	3.685	3.685
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.685	3.685	3.685
TBtu Consumed	0.000	0.000	49.13	49.13	49.13
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	4.593	4.593	4.593
TWh Generated Qualifying	0.000	0.000	4.593	4.593	4.593
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5117.	5278.	5279.

Constraint Name: COT BART Plant Specific SO2 Constraint

Constraint #: 198

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	3.314	3.315	3.315
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.314	3.315	3.315
TBtu Consumed	0.000	0.000	55.13	55.13	55.13
Rate - [lb/MMBtu]	0.000	0.000	0.1202	0.1203	0.1203
TWh Generated	0.000	0.000	5.154	5.154	5.154
TWh Generated Qualifying	0.000	0.000	5.154	5.154	5.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: COU BART Plant Specific SO2 Constraint

Constraint #: 199

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	3.547	3.547	3.529
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.547	3.547	3.529
TBtu Consumed	0.000	0.000	54.56	54.56	54.30
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	5.110	5.110	5.085
TWh Generated Qualifying	0.000	0.000	5.110	5.110	5.085
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1307.	1186.	1054.

Constraint Name: COV BART Plant Specific SO2 Constraint

Constraint #: 200

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	1.986	1.986	1.986
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.986	1.986	1.986
TBtu Consumed	0.000	0.000	30.56	30.56	30.56
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	2.796	2.796	2.796
TWh Generated Qualifying	0.000	0.000	2.796	2.796	2.796
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1216.	1159.	1059.

Constraint Name: CPG BART Plant Specific SO2 Constraint      Constraint #: 201  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5423	0.5436	0.5446
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5423	0.5436	0.5446
TBtu Consumed	0.000	0.000	10.85	10.87	10.89
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.099	1.101	1.103
TWh Generated Qualifying	0.000	0.000	1.099	1.101	1.103
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2221.	2134.	2307.

Constraint Name: CPH BART Plant Specific SO2 Constraint

Constraint #: 202

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.318	6.319	6.335
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.318	6.319	6.335
TBtu Consumed	0.000	0.000	126.4	126.4	126.7
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	12.68	12.68	12.72
TWh Generated Qualifying	0.000	0.000	12.68	12.68	12.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1631.	2255.	1084.

Constraint Name: CPM BART Plant Specific SO2 Constraint

Constraint #: 203

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	3.369	3.369	3.369
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.369	3.369	3.369
TBtu Consumed	0.000	0.000	44.92	44.92	44.92
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	4.199	4.199	4.199
TWh Generated Qualifying	0.000	0.000	4.199	4.199	4.199
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1924E+05	0.1302E+05	0.1284E+05

Constraint Name: CPN BART Plant Specific SO2 Constraint

Constraint #: 204

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	2.195	2.205	2.205
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.195	2.205	2.205
TBtu Consumed	0.000	0.000	29.26	29.40	29.40
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.628	2.640	2.640
TWh Generated Qualifying	0.000	0.000	2.628	2.640	2.640
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1157.	1372.	1403.

Constraint Name: CPQ BART Plant Specific SO2 Constraint

Constraint #: 205

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.123	3.123	3.123
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.123	3.123	3.123
TBtu Consumed	0.000	0.000	62.47	62.47	62.47
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	5.913	5.913	5.913
TWh Generated Qualifying	0.000	0.000	5.913	5.913	5.913
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3232.	2550.	1019.

Constraint Name: CPR BART Plant Specific SO2 Constraint

Constraint #: 206

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.367	2.367	2.152
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.367	2.367	2.152
TBtu Consumed	0.000	0.000	47.33	47.33	43.05
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.607	4.607	4.190
TWh Generated Qualifying	0.000	0.000	4.607	4.607	4.190
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2447E+05	0.2713E+05	0.2625E+05



Constraint Name: CQC BART Plant Specific SO2 Constraint

Constraint #: 207

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.284	1.284	1.284
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.284	1.284	1.284
TBtu Consumed	0.000	0.000	25.68	25.68	25.68
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.480	2.480	2.480
TWh Generated Qualifying	0.000	0.000	2.480	2.480	2.480
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2115.	3087.	1210.

Constraint Name: CQD BART Plant Specific SO2 Constraint

Constraint #: 208

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.496	1.496	1.496
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.496	1.496	1.496
TBtu Consumed	0.000	0.000	29.92	29.92	29.92
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.916	2.916	2.916
TWh Generated Qualifying	0.000	0.000	2.916	2.916	2.916
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2016.	1857.	1617.

Constraint Name: CQE BART Plant Specific SO2 Constraint

Constraint #: 209

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.267	1.267	1.267
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.267	1.267	1.267
TBtu Consumed	0.000	0.000	25.35	25.35	25.35
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.421	2.421	2.421
TWh Generated Qualifying	0.000	0.000	2.421	2.421	2.421
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2195.	2190.	2098.

Constraint Name: CQF BART Plant Specific SO2 Constraint      Constraint #: 210  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8809	0.8809	0.8809
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8809	0.8809	0.8809
TBtu Consumed	0.000	0.000	17.62	17.62	17.62
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.590	1.590	1.590
TWh Generated Qualifying	0.000	0.000	1.590	1.590	1.590
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2399.	2399.	2092.

Constraint Name: CQI BART Plant Specific SO2 Constraint      Constraint #: 211  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.145	5.311	5.311
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.145	5.311	5.311
TBtu Consumed	0.000	0.000	102.9	106.2	106.2
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	9.645	9.961	9.961
TWh Generated Qualifying	0.000	0.000	9.645	9.961	9.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4273.	4017.	3273.

Constraint Name: CQJ BART Plant Specific SO2 Constraint

Constraint #: 212

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.145	4.205	4.205
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.145	4.205	4.205
TBtu Consumed	0.000	0.000	82.90	84.10	84.10
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.011	8.127	8.127
TWh Generated Qualifying	0.000	0.000	8.011	8.127	8.127
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2791.	2962.	2624.

Constraint Name: CQK BART Plant Specific SO2 Constraint

Constraint #: 213

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.370	1.370	1.370
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.370	1.370	1.370
TBtu Consumed	0.000	0.000	27.39	27.39	27.39
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.690	2.690	2.690
TWh Generated Qualifying	0.000	0.000	2.690	2.690	2.690
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3348.	3640.	2974.

Constraint Name: CRA BART Plant Specific SO2 Constraint

Constraint #: 214

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.381	1.493	1.493
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.381	1.493	1.493
TBtu Consumed	0.000	0.000	27.62	29.85	29.85
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.526	2.730	2.730
TWh Generated Qualifying	0.000	0.000	2.526	2.730	2.730
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1653.	1946.	1225.



Constraint Name: CRF BART Plant Specific SO2 Constraint

Constraint #: 215

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	3.475	3.475	3.225
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.475	3.475	3.225
TBtu Consumed	0.000	0.000	53.46	53.46	49.62
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	4.884	4.884	4.533
TWh Generated Qualifying	0.000	0.000	4.884	4.884	4.533
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2230E+05	0.1724E+05	0.1412E+05

Constraint Name: CRK BART Plant Specific SO2 Constraint

Constraint #: 216

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.581	2.581	2.581
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.581	2.581	2.581
TBtu Consumed	0.000	0.000	51.62	51.62	51.62
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.870	4.870	4.870
TWh Generated Qualifying	0.000	0.000	4.870	4.870	4.870
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2229E+05	0.2757E+05	0.1927E+05

Constraint Name: CRL BART Plant Specific SO2 Constraint

Constraint #: 217

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.163	1.175	1.175
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.163	1.175	1.175
TBtu Consumed	0.000	0.000	23.27	23.51	23.51
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.032	2.053	2.053
TWh Generated Qualifying	0.000	0.000	2.032	2.053	2.053
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2173.	2191.	2137.

Constraint Name: CRZ BART Plant Specific SO2 Constraint

Constraint #: 218

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	33.62	33.62	33.62
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	33.62	33.62	33.62
TBtu Consumed	0.000	0.000	305.6	305.6	305.6
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	32.36	32.36	32.36
TWh Generated Qualifying	0.000	0.000	32.36	32.36	32.36
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1534.	1270.	1182.

Constraint Name: CSA BART Plant Specific SO2 Constraint

Constraint #: 219

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.446	1.446	1.446
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.446	1.446	1.446
TBtu Consumed	0.000	0.000	32.87	32.87	32.87
Rate - [lb/MMBtu]	0.000	0.000	0.8800E-01	0.8800E-01	0.8800E-01
TWh Generated	0.000	0.000	3.157	3.157	3.157
TWh Generated Qualifying	0.000	0.000	3.157	3.157	3.157
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSB BART Plant Specific SO2 Constraint

Constraint #: 220

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	4.369	4.369	4.347
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.369	4.369	4.347
TBtu Consumed	0.000	0.000	67.21	67.21	66.88
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	6.643	6.643	6.611
TWh Generated Qualifying	0.000	0.000	6.643	6.643	6.611
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1274.	1057.	1054.

Constraint Name: CSC BART Plant Specific SO2 Constraint

Constraint #: 221

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	1.369	1.369	1.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.369	1.369	1.362
TBtu Consumed	0.000	0.000	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	1.971	1.971	1.961
TWh Generated Qualifying	0.000	0.000	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1139.	1242.	1054.

Constraint Name: CSD BART Plant Specific SO2 Constraint

Constraint #: 222

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	1.369	1.369	1.362
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.369	1.369	1.362
TBtu Consumed	0.000	0.000	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	1.971	1.971	1.961
TWh Generated Qualifying	0.000	0.000	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1306.	1026.	1054.



Constraint Name: CSE BART Plant Specific SO2 Constraint

Constraint #: 223

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	1.774	1.774	1.766
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.774	1.774	1.766
TBtu Consumed	0.000	0.000	27.29	27.29	27.16
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	2.555	2.555	2.543
TWh Generated Qualifying	0.000	0.000	2.555	2.555	2.543
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1302.	1192.	1054.

Constraint Name: CSF BART Plant Specific SO2 Constraint

Constraint #: 224

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.518	5.518	5.518
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.518	5.518	5.518
TBtu Consumed	0.000	0.000	36.78	36.78	36.78
Rate - [lb/MMBtu]	0.000	0.000	0.3000	0.3000	0.3000
TWh Generated	0.000	0.000	3.365	3.365	3.365
TWh Generated Qualifying	0.000	0.000	3.365	3.365	3.365
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	894.4	1230.	961.8

Constraint Name: CSI BART Plant Specific SO2 Constraint

Constraint #: 225

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	5.194	5.194	5.194
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.194	5.194	5.194
TBtu Consumed	0.000	0.000	69.26	69.26	69.26
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	6.328	6.328	6.328
TWh Generated Qualifying	0.000	0.000	6.328	6.328	6.328
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1615E+05	0.1791E+05	0.1181E+05

Constraint Name: CSJ BART Plant Specific SO2 Constraint

Constraint #: 226

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1700	0.1700	0.1700
-Emissions at Affected Plants [MTons]	0.000	0.000	4.388	4.388	4.388
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.388	4.388	4.388
TBtu Consumed	0.000	0.000	51.63	51.63	51.63
Rate - [lb/MMBtu]	0.000	0.000	0.1700	0.1700	0.1700
TWh Generated	0.000	0.000	5.271	5.271	5.271
TWh Generated Qualifying	0.000	0.000	5.271	5.271	5.271
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3777.	4880.	2745.

Constraint Name: CSK BART Plant Specific SO2 Constraint

Constraint #: 227

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1700	0.1700	0.1700
-Emissions at Affected Plants [MTons]	0.000	0.000	5.129	5.129	5.129
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.129	5.129	5.129
TBtu Consumed	0.000	0.000	60.34	60.34	60.34
Rate - [lb/MMBtu]	0.000	0.000	0.1700	0.1700	0.1700
TWh Generated	0.000	0.000	6.277	6.277	6.277
TWh Generated Qualifying	0.000	0.000	6.277	6.277	6.277
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4419.	4880.	3145.

Constraint Name: CSL BART Plant Specific SO2 Constraint

Constraint #: 228

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	7.153	7.153	7.153
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.153	7.153	7.153
TBtu Consumed	0.000	0.000	95.37	95.37	95.37
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	8.916	8.916	8.916
TWh Generated Qualifying	0.000	0.000	8.916	8.916	8.916
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1275E+05	0.2057E+05	0.1043E+05

Constraint Name: CSO BART Plant Specific SO2 Constraint

Constraint #: 229

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	9.008	9.212	9.235
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.008	9.212	9.235
TBtu Consumed	0.000	0.000	91.87	93.32	93.49
Rate - [lb/MMBtu]	0.000	0.000	0.1961	0.1974	0.1976
TWh Generated	0.000	0.000	10.59	10.74	10.76
TWh Generated Qualifying	0.000	0.000	10.59	10.74	10.76
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1075.	952.7	959.0

Constraint Name: CSP BART Plant Specific SO2 Constraint

Constraint #: 230

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	6.958	9.100	9.100
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.958	9.100	9.100
TBtu Consumed	0.000	0.000	49.70	65.00	65.00
Rate - [lb/MMBtu]	0.000	0.000	0.2800	0.2800	0.2800
TWh Generated	0.000	0.000	5.157	6.744	6.744
TWh Generated Qualifying	0.000	0.000	5.157	6.744	6.744
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1322.	1037.	1030.



Constraint Name: CTH BART Plant Specific SO2 Constraint      Constraint #: 231  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2600	0.2600	0.2600
-Emissions at Affected Plants [MTons]	0.000	0.000	12.70	12.70	12.70
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	12.70	12.70	12.70
TBtu Consumed	0.000	0.000	97.72	97.72	97.72
Rate - [lb/MMBtu]	0.000	0.000	0.2600	0.2600	0.2600
TWh Generated	0.000	0.000	9.528	9.528	9.528
TWh Generated Qualifying	0.000	0.000	9.528	9.528	9.528
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1263.	1266.	869.8

Constraint Name: CTP BART Plant Specific SO2 Constraint

Constraint #: 232

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2700	0.2700	0.2700
-Emissions at Affected Plants [MTons]	0.000	0.000	2.969	2.969	2.969
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.969	2.969	2.969
TBtu Consumed	0.000	0.000	21.99	21.99	21.99
Rate - [lb/MMBtu]	0.000	0.000	0.2700	0.2700	0.2700
TWh Generated	0.000	0.000	2.133	2.133	2.133
TWh Generated Qualifying	0.000	0.000	2.133	2.133	2.133
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1086.	1161.	982.0

Constraint Name: CTQ BART Plant Specific SO2 Constraint

Constraint #: 233

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2700	0.2700	0.2700
-Emissions at Affected Plants [MTons]	0.000	0.000	9.858	9.858	9.858
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.858	9.858	9.858
TBtu Consumed	0.000	0.000	73.02	73.02	73.02
Rate - [lb/MMBtu]	0.000	0.000	0.2700	0.2700	0.2700
TWh Generated	0.000	0.000	7.228	7.228	7.228
TWh Generated Qualifying	0.000	0.000	7.228	7.228	7.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	911.2	858.2	725.9

Constraint Name: CTZ BART Plant Specific SO2 Constraint

Constraint #: 234

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	11.59	11.61	11.61
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	11.59	11.61	11.61
TBtu Consumed	0.000	0.000	105.4	105.6	105.6
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	10.59	10.60	10.60
TWh Generated Qualifying	0.000	0.000	10.59	10.60	10.60
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1026.	1036.	908.8

Constraint Name: CUD BART Plant Specific SO2 Constraint

Constraint #: 235

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	8.836	8.836	8.836
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.836	8.836	8.836
TBtu Consumed	0.000	0.000	80.32	80.32	80.32
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	8.486	8.486	8.486
TWh Generated Qualifying	0.000	0.000	8.486	8.486	8.486
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	910.8	877.6	1067.

Constraint Name: CUE BART Plant Specific SO2 Constraint

Constraint #: 236

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	3.092	3.092	3.092
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.092	3.092	3.092
TBtu Consumed	0.000	0.000	28.11	28.11	28.11
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	2.775	2.775	2.775
TWh Generated Qualifying	0.000	0.000	2.775	2.775	2.775
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	910.8	858.1	661.2

Constraint Name: CUQ BART Plant Specific SO2 Constraint

Constraint #: 237

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	2.943	2.943	2.943
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.943	2.943	2.943
TBtu Consumed	0.000	0.000	26.76	26.76	26.76
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	2.661	2.661	2.661
TWh Generated Qualifying	0.000	0.000	2.661	2.661	2.661
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	760.1	627.8	532.3

Constraint Name: CUT BART Plant Specific SO2 Constraint

Constraint #: 238

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	2.805	2.805	2.805
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.805	2.805	2.805
TBtu Consumed	0.000	0.000	43.16	43.16	43.16
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	4.160	4.160	4.160
TWh Generated Qualifying	0.000	0.000	4.160	4.160	4.160
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1609.	1671.	1416.



Constraint Name: CUV BART Plant Specific SO2 Constraint

Constraint #: 239

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7888	0.7888	0.7733
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7888	0.7888	0.7733
TBtu Consumed	0.000	0.000	12.13	12.13	11.90
Rate - [lb/MMBtu]	0.000	0.000	0.1300	0.1300	0.1300
TWh Generated	0.000	0.000	1.103	1.103	1.081
TWh Generated Qualifying	0.000	0.000	1.103	1.103	1.081
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1586.	1432.	1540.

Constraint Name: CVA BART Plant Specific SO2 Constraint

Constraint #: 240

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1600	0.1600	0.1600
-Emissions at Affected Plants [MTons]	0.000	0.000	5.151	5.132	5.151
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.151	5.132	5.151
TBtu Consumed	0.000	0.000	64.39	64.15	64.39
Rate - [lb/MMBtu]	0.000	0.000	0.1600	0.1600	0.1600
TWh Generated	0.000	0.000	6.291	6.260	6.283
TWh Generated Qualifying	0.000	0.000	6.291	6.260	6.283
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1397.	1543.	1589.

Constraint Name: CVD BART Plant Specific SO2 Constraint      Constraint #: 241  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	15.08	14.98	15.08
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	15.08	14.98	15.08
TBtu Consumed	0.000	0.000	201.0	199.8	201.0
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	19.95	19.83	19.95
TWh Generated Qualifying	0.000	0.000	19.95	19.83	19.95
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1194.	1236.	1159.

Constraint Name: CVE BART Plant Specific SO2 Constraint

Constraint #: 242

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	2.722	2.722	2.845
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.722	2.722	2.845
TBtu Consumed	0.000	0.000	36.29	36.29	37.94
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	3.206	3.206	3.351
TWh Generated Qualifying	0.000	0.000	3.206	3.206	3.351
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1708.	1680.	1634.

Constraint Name: CVP BART Plant Specific SO2 Constraint

Constraint #: 243

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.346	1.353	1.353
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.346	1.353	1.353
TBtu Consumed	0.000	0.000	26.92	27.06	27.06
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.532	2.545	2.545
TWh Generated Qualifying	0.000	0.000	2.532	2.545	2.545
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1298.	1276.	1294.

Constraint Name: CVQ BART Plant Specific SO2 Constraint

Constraint #: 244

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	3.051	3.051	3.051
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.051	3.051	3.051
TBtu Consumed	0.000	0.000	27.74	27.74	27.74
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	2.632	2.632	2.632
TWh Generated Qualifying	0.000	0.000	2.632	2.632	2.632
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1349.	1954.	1233.

Constraint Name: CVU BART Plant Specific SO2 Constraint

Constraint #: 245

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	3.366	3.515	3.515
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.366	3.515	3.515
TBtu Consumed	0.000	0.000	30.60	31.96	31.96
Rate - [lb/MMBtu]	0.000	0.000	0.2200	0.2200	0.2200
TWh Generated	0.000	0.000	2.561	2.675	2.675
TWh Generated Qualifying	0.000	0.000	2.561	2.675	2.675
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	688.6	621.1	545.2

Constraint Name: CVV BART Plant Specific SO2 Constraint

Constraint #: 246

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.135	3.227	3.155
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.135	3.227	3.155
TBtu Consumed	0.000	0.000	62.70	64.54	63.10
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.718	6.916	6.761
TWh Generated Qualifying	0.000	0.000	6.718	6.916	6.761
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1466.	1517.	1396.



Constraint Name: CVW BART Plant Specific SO2 Constraint

Constraint #: 247

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.269	8.909	8.909
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.269	8.909	8.909
TBtu Consumed	0.000	0.000	165.4	178.2	178.2
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	15.56	16.77	16.77
TWh Generated Qualifying	0.000	0.000	15.56	16.77	16.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3185E+05	0.3108E+05	0.2528E+05

Constraint Name: CWC BART Plant Specific SO2 Constraint

Constraint #: 248

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4982	0.5091	0.5091
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4982	0.5091	0.5091
TBtu Consumed	0.000	0.000	9.964	10.18	10.18
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	0.9584	0.9794	0.9794
TWh Generated Qualifying	0.000	0.000	0.9584	0.9794	0.9794
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2415.	2369.	2319.

Constraint Name: CWN BART Plant Specific SO2 Constraint

Constraint #: 249

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.710	6.710	6.710
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.710	6.710	6.710
TBtu Consumed	0.000	0.000	134.2	134.2	134.2
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	13.18	13.18	13.18
TWh Generated Qualifying	0.000	0.000	13.18	13.18	13.18
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3023.	2489.	3611.

Constraint Name: CWU BART Plant Specific SO2 Constraint

Constraint #: 250

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	4.787	4.787	4.443
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.787	4.787	4.443
TBtu Consumed	0.000	0.000	63.83	63.83	59.24
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	5.832	5.832	5.413
TWh Generated Qualifying	0.000	0.000	5.832	5.832	5.413
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1107E+05	0.1485E+05	0.1380E+05

Constraint Name: CWV BART Plant Specific SO2 Constraint      Constraint #: 251  
 Constraint Type: Rate Limit [lb/MMBtu]  
 Run Year, Seasons Included: 2007 WINTER SUMMER  
 Run Year, Seasons Included: 2010 WINTER SUMMER  
 Run Year, Seasons Included: 2015 WINTER SUMMER  
 Run Year, Seasons Included: 2020 WINTER SUMMER  
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.041	6.041	6.041
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.041	6.041	6.041
TBtu Consumed	0.000	0.000	40.27	40.27	40.27
Rate - [lb/MMBtu]	0.000	0.000	0.3000	0.3000	0.3000
TWh Generated	0.000	0.000	4.192	4.192	4.192
TWh Generated Qualifying	0.000	0.000	4.192	4.192	4.192
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	933.1	854.8	792.8

Constraint Name: CWW BART Plant Specific SO2 Constraint

Constraint #: 252

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.859	1.859	1.859
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.859	1.859	1.859
TBtu Consumed	0.000	0.000	37.18	37.18	37.18
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.477	3.477	3.477
TWh Generated Qualifying	0.000	0.000	3.477	3.477	3.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4227.	3190.	2762.

Constraint Name: CWY BART Plant Specific SO2 Constraint

Constraint #: 253

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.515	1.515	1.515
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.515	1.515	1.515
TBtu Consumed	0.000	0.000	30.31	30.31	30.31
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.182	3.182	3.182
TWh Generated Qualifying	0.000	0.000	3.182	3.182	3.182
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3041.	1696.	1498.

Constraint Name: CXJ BART Plant Specific SO2 Constraint

Constraint #: 254

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	7.231	7.347	7.347
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.231	7.347	7.347
TBtu Consumed	0.000	0.000	57.84	58.78	58.78
Rate - [lb/MMBtu]	0.000	0.000	0.2500	0.2500	0.2500
TWh Generated	0.000	0.000	5.693	5.784	5.784
TWh Generated Qualifying	0.000	0.000	5.693	5.784	5.784
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1436.	1490.	1431.



Constraint Name: CXN BART Plant Specific SO2 Constraint

Constraint #: 255

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.348	1.348	1.348
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.348	1.348	1.348
TBtu Consumed	0.000	0.000	17.97	17.97	17.97
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	1.832	1.832	1.832
TWh Generated Qualifying	0.000	0.000	1.832	1.832	1.832
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1350.	1293.	1177.

Constraint Name: CXO BART Plant Specific SO2 Constraint

Constraint #: 256

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	9.180	9.328	9.328
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.180	9.328	9.328
TBtu Consumed	0.000	0.000	73.44	74.62	74.62
Rate - [lb/MMBtu]	0.000	0.000	0.2500	0.2500	0.2500
TWh Generated	0.000	0.000	7.137	7.252	7.252
TWh Generated Qualifying	0.000	0.000	7.137	7.252	7.252
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1421.	1488.	1404.

Constraint Name: CXZ BART Plant Specific SO2 Constraint

Constraint #: 257

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.920	10.14	10.14
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.920	10.14	10.14
TBtu Consumed	0.000	0.000	66.14	67.61	67.61
Rate - [lb/MMBtu]	0.000	0.000	0.3000	0.3000	0.3000
TWh Generated	0.000	0.000	6.663	6.811	6.811
TWh Generated Qualifying	0.000	0.000	6.663	6.811	6.811
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	794.1	1007.	947.2

Constraint Name: CYO BART Plant Specific SO2 Constraint

Constraint #: 258

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.321	1.321	1.321
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.321	1.321	1.321
TBtu Consumed	0.000	0.000	26.42	26.42	26.42
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.559	2.559	2.559
TWh Generated Qualifying	0.000	0.000	2.559	2.559	2.559
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4227.	3190.	2762.

Constraint Name: CY Y BART Plant Specific SO2 Constraint

Constraint #: 259

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.066	1.066	1.066
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.066	1.066	1.066
TBtu Consumed	0.000	0.000	21.32	21.32	21.32
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.192	2.192	2.192
TWh Generated Qualifying	0.000	0.000	2.192	2.192	2.192
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3307.	4165.	2100.

Constraint Name: CZE BART Plant Specific SO2 Constraint

Constraint #: 260

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	13.40	13.40	13.40
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	13.40	13.40	13.40
TBtu Consumed	0.000	0.000	268.1	268.1	268.1
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	24.33	24.33	24.33
TWh Generated Qualifying	0.000	0.000	24.33	24.33	24.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.3029E+05	9369.	8635.

Constraint Name: CZF BART Plant Specific SO2 Constraint

Constraint #: 261

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.701	1.705	1.683
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.701	1.705	1.683
TBtu Consumed	0.000	0.000	34.02	34.10	33.66
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.251	3.258	3.217
TWh Generated Qualifying	0.000	0.000	3.251	3.258	3.217
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3449.	3726.	3276.

Constraint Name: CZH BART Plant Specific SO2 Constraint

Constraint #: 262

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.364	2.458	2.458
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.364	2.458	2.458
TBtu Consumed	0.000	0.000	47.28	49.16	49.16
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	4.698	4.884	4.884
TWh Generated Qualifying	0.000	0.000	4.698	4.884	4.884
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2390E+05	0.2671E+05	0.2453E+05



Constraint Name: CZI BART Plant Specific SO2 Constraint

Constraint #: 263

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.794	1.794	1.794
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.794	1.794	1.794
TBtu Consumed	0.000	0.000	35.88	35.88	35.88
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.505	3.505	3.505
TWh Generated Qualifying	0.000	0.000	3.505	3.505	3.505
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1631.	1578.	1673.

Constraint Name: CZJ BART Plant Specific SO2 Constraint

Constraint #: 264

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.847	1.847	1.847
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.847	1.847	1.847
TBtu Consumed	0.000	0.000	36.94	36.94	36.94
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.400	3.400	3.400
TWh Generated Qualifying	0.000	0.000	3.400	3.400	3.400
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2149.	2111.	1356.

Constraint Name: CZL BART Plant Specific SO2 Constraint

Constraint #: 265

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	10.92	10.97	10.92
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	10.92	10.97	10.92
TBtu Consumed	0.000	0.000	77.97	78.36	77.97
Rate - [lb/MMBtu]	0.000	0.000	0.2800	0.2800	0.2800
TWh Generated	0.000	0.000	7.990	8.031	7.990
TWh Generated Qualifying	0.000	0.000	7.990	8.031	7.990
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1074.	854.8	959.0

Constraint Name: CZN BART Plant Specific SO2 Constraint

Constraint #: 266

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.504	3.504	3.504
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.504	3.504	3.504
TBtu Consumed	0.000	0.000	70.07	70.07	70.07
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.561	6.561	6.561
TWh Generated Qualifying	0.000	0.000	6.561	6.561	6.561
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3569.	3983.	3273.

Constraint Name: CZO BART Plant Specific SO2 Constraint

Constraint #: 267

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.378	4.378	4.378
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.378	4.378	4.378
TBtu Consumed	0.000	0.000	87.56	87.56	87.56
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	8.456	8.456	8.456
TWh Generated Qualifying	0.000	0.000	8.456	8.456	8.456
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2146E+05	0.1974E+05	0.1771E+05

Constraint Name: CZP BART Plant Specific SO2 Constraint

Constraint #: 268

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.105	6.105	6.105
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.105	6.105	6.105
TBtu Consumed	0.000	0.000	40.70	40.70	40.70
Rate - [lb/MMBtu]	0.000	0.000	0.3000	0.3000	0.3000
TWh Generated	0.000	0.000	4.336	4.336	4.336
TWh Generated Qualifying	0.000	0.000	4.336	4.336	4.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	855.2	1007.	930.0

Constraint Name: CZX BART Plant Specific SO2 Constraint

Constraint #: 269

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.850	1.850	1.850
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.850	1.850	1.850
TBtu Consumed	0.000	0.000	37.00	37.00	37.00
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2926.	1781.	3372.

Constraint Name: DAA BART Plant Specific SO2 Constraint

Constraint #: 270

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.850	1.896	1.896
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.850	1.896	1.896
TBtu Consumed	0.000	0.000	36.99	37.93	37.93
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.047	3.124	3.124
TWh Generated Qualifying	0.000	0.000	3.047	3.124	3.124
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1881.	2111.	1645.



Constraint Name: DAB BART Plant Specific SO2 Constraint

Constraint #: 271

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.950	1.973	1.973
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.950	1.973	1.973
TBtu Consumed	0.000	0.000	39.00	39.47	39.47
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	3.379	3.420	3.420
TWh Generated Qualifying	0.000	0.000	3.379	3.420	3.420
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2086.	2111.	2028.

Constraint Name: DAC BART Plant Specific SO2 Constraint

Constraint #: 272

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2700	0.2700	0.2700
-Emissions at Affected Plants [MTons]	0.000	0.000	6.590	6.728	6.728
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.590	6.728	6.728
TBtu Consumed	0.000	0.000	48.82	49.84	49.84
Rate - [lb/MMBtu]	0.000	0.000	0.2700	0.2700	0.2700
TWh Generated	0.000	0.000	4.610	4.708	4.708
TWh Generated Qualifying	0.000	0.000	4.610	4.708	4.708
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1546.	1099.	305.5

Constraint Name: DAR BART Plant Specific SO2 Constraint

Constraint #: 273

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8072	0.8149	0.8149
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8072	0.8149	0.8149
TBtu Consumed	0.000	0.000	16.14	16.30	16.30
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.516	1.531	1.531
TWh Generated Qualifying	0.000	0.000	1.516	1.531	1.531
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2125.	2133.	2053.

Constraint Name: DAS BART Plant Specific SO2 Constraint

Constraint #: 274

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.377	1.414	1.414
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.377	1.414	1.414
TBtu Consumed	0.000	0.000	27.55	28.28	28.28
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.450	2.515	2.515
TWh Generated Qualifying	0.000	0.000	2.450	2.515	2.515
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2778.	2742.	2607.

Constraint Name: DAT BART Plant Specific SO2 Constraint

Constraint #: 275

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.6181	0.6181
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.6181	0.6181
TBtu Consumed	0.000	0.000	0.000	12.36	12.36
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.1000	0.1000
TWh Generated	0.000	0.000	0.000	0.9922	0.9922
TWh Generated Qualifying	0.000	0.000	0.000	0.9922	0.9922
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3744.	2407.	2333.

Constraint Name: DAZ BART Plant Specific SO2 Constraint

Constraint #: 276

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.877	2.877	2.877
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.877	2.877	2.877
TBtu Consumed	0.000	0.000	57.53	57.53	57.53
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	6.073	6.073	6.073
TWh Generated Qualifying	0.000	0.000	6.073	6.073	6.073
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4227.	3190.	2762.

Constraint Name: DBE BART Plant Specific SO2 Constraint

Constraint #: 277

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.428	1.428	1.428
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.428	1.428	1.428
TBtu Consumed	0.000	0.000	28.57	28.57	28.57
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	2.829	2.829	2.829
TWh Generated Qualifying	0.000	0.000	2.829	2.829	2.829
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2064.	1855.	1598.

Constraint Name: DBF BART Plant Specific SO2 Constraint

Constraint #: 278

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8691	0.8691	0.8691
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8691	0.8691	0.8691
TBtu Consumed	0.000	0.000	17.38	17.38	17.38
Rate - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
TWh Generated	0.000	0.000	1.528	1.528	1.528
TWh Generated Qualifying	0.000	0.000	1.528	1.528	1.528
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2668.	3214.	1963.



Constraint Name: CAO BART Plant Specific NOX Constraint

Constraint #: 279

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.456	1.456	1.456
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.456	1.456	1.456
TBtu Consumed	0.000	0.000	48.53	48.53	48.53
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.632	4.632	4.632
TWh Generated Qualifying	0.000	0.000	4.632	4.632	4.632
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CAP BART Plant Specific NOX Constraint

Constraint #: 280

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.191	3.191	3.191
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.191	3.191	3.191
TBtu Consumed	0.000	0.000	106.4	106.4	106.4
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	11.66	11.66	11.66
TWh Generated Qualifying	0.000	0.000	11.66	11.66	11.66
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CAQ BART Plant Specific NOX Constraint

Constraint #: 281

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4663	0.4663	0.4663
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4663	0.4663	0.4663
TBtu Consumed	0.000	0.000	15.54	15.54	15.54
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.415	1.415	1.415
TWh Generated Qualifying	0.000	0.000	1.415	1.415	1.415
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CAZ BART Plant Specific NOX Constraint

Constraint #: 282

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.650	4.650	4.650
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.650	4.650	4.650
TBtu Consumed	0.000	0.000	46.50	46.50	46.50
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.192	4.192	4.192
TWh Generated Qualifying	0.000	0.000	4.192	4.192	4.192
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1047.	0.000	484.7

Constraint Name: CBA BART Plant Specific NOX Constraint

Constraint #: 283

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.430	7.430	7.430
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.430	7.430	7.430
TBtu Consumed	0.000	0.000	74.30	74.30	74.30
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	8.042	8.042	8.042
TWh Generated Qualifying	0.000	0.000	8.042	8.042	8.042
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	668.6	0.000	294.2

Constraint Name: CBG BART Plant Specific NOX Constraint

Constraint #: 284

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.379	2.379	2.379
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.379	2.379	2.379
TBtu Consumed	0.000	0.000	23.79	23.79	23.79
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.457	2.457	2.457
TWh Generated Qualifying	0.000	0.000	2.457	2.457	2.457
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3483.	205.3	1515.

Constraint Name: CBL BART Plant Specific NOX Constraint

Constraint #: 285

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.294	4.294	4.294
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.294	4.294	4.294
TBtu Consumed	0.000	0.000	42.94	42.94	42.94
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.095	4.095	4.095
TWh Generated Qualifying	0.000	0.000	4.095	4.095	4.095
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3996.	2071.	1043.

Constraint Name: CBM BART Plant Specific NOX Constraint

Constraint #: 286

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.798	4.798	4.798
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.798	4.798	4.798
TBtu Consumed	0.000	0.000	47.98	47.98	47.98
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.676	4.676	4.676
TWh Generated Qualifying	0.000	0.000	4.676	4.676	4.676
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3166.	0.000	1523.



Constraint Name: CBQ BART Plant Specific NOX Constraint

Constraint #: 287

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.283	4.283	4.283
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.283	4.283	4.283
TBtu Consumed	0.000	0.000	42.83	42.83	42.83
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.095	4.095	4.095
TWh Generated Qualifying	0.000	0.000	4.095	4.095	4.095
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2349.	2866.	1898.

Constraint Name: CBR BART Plant Specific NOX Constraint

Constraint #: 288

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.362	4.362	4.362
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.362	4.362	4.362
TBtu Consumed	0.000	0.000	43.62	43.62	43.62
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.095	4.095	4.095
TWh Generated Qualifying	0.000	0.000	4.095	4.095	4.095
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2384.	2941.	1898.

Constraint Name: CBS BART Plant Specific NOX Constraint

Constraint #: 289

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.014	3.014	3.014
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.014	3.014	3.014
TBtu Consumed	0.000	0.000	30.14	30.14	30.14
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.495	2.495	2.495
TWh Generated Qualifying	0.000	0.000	2.495	2.495	2.495
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2462.	2462.	2462.

Constraint Name: CBT BART Plant Specific NOX Constraint

Constraint #: 290

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.948	1.948	1.948
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.948	1.948	1.948
TBtu Consumed	0.000	0.000	27.24	27.24	27.24
Rate - [lb/MMBtu]	0.000	0.000	0.1430	0.1430	0.1430
TWh Generated	0.000	0.000	2.457	2.457	2.457
TWh Generated Qualifying	0.000	0.000	2.457	2.457	2.457
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CBX BART Plant Specific NOX Constraint

Constraint #: 291

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6333	0.6333	0.6333
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6333	0.6333	0.6333
TBtu Consumed	0.000	0.000	15.83	15.83	15.83
Rate - [lb/MMBtu]	0.000	0.000	0.8000E-01	0.8000E-01	0.8000E-01
TWh Generated	0.000	0.000	1.266	1.266	1.266
TWh Generated Qualifying	0.000	0.000	1.266	1.266	1.266
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCB BART Plant Specific NOX Constraint

Constraint #: 292

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	16.88	16.88	16.88
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	16.88	16.88	16.88
TBtu Consumed	0.000	0.000	168.8	168.8	168.8
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	16.75	16.75	16.75
TWh Generated Qualifying	0.000	0.000	16.75	16.75	16.75
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1296.	1296.	1296.

Constraint Name: CCC BART Plant Specific NOX Constraint

Constraint #: 293

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.382	8.382	8.382
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.382	8.382	8.382
TBtu Consumed	0.000	0.000	83.82	83.82	83.82
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	8.042	8.042	8.042
TWh Generated Qualifying	0.000	0.000	8.042	8.042	8.042
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5485.	0.000	1702.

Constraint Name: CCE BART Plant Specific NOX Constraint

Constraint #: 294

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.465	1.465	1.465
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.465	1.465	1.465
TBtu Consumed	0.000	0.000	20.35	20.35	20.35
Rate - [lb/MMBtu]	0.000	0.000	0.1440	0.1440	0.1440
TWh Generated	0.000	0.000	1.824	1.824	1.824
TWh Generated Qualifying	0.000	0.000	1.824	1.824	1.824
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CCF BART Plant Specific NOX Constraint

Constraint #: 295

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.289	6.289	6.289
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.289	6.289	6.289
TBtu Consumed	0.000	0.000	62.89	62.89	62.89
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.374	6.374	6.374
TWh Generated Qualifying	0.000	0.000	6.374	6.374	6.374
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4013.	0.000	1898.

Constraint Name: CCI BART Plant Specific NOX Constraint

Constraint #: 296

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	18.83	18.83	18.83
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	18.83	18.83	18.83
TBtu Consumed	0.000	0.000	188.3	188.3	188.3
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	17.95	17.95	17.95
TWh Generated Qualifying	0.000	0.000	17.95	17.95	17.95
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3484.	0.000	1967.

Constraint Name: CCP BART Plant Specific NOX Constraint

Constraint #: 297

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.572	3.572	3.572
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.572	3.572	3.572
TBtu Consumed	0.000	0.000	51.03	51.02	51.02
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	4.766	4.752	4.752
TWh Generated Qualifying	0.000	0.000	4.766	4.752	4.752
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCS BART Plant Specific NOX Constraint

Constraint #: 298

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.859	3.859	3.859
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.859	3.859	3.859
TBtu Consumed	0.000	0.000	128.6	128.6	128.6
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	12.67	12.67	12.67
TWh Generated Qualifying	0.000	0.000	12.67	12.67	12.67
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCT BART Plant Specific NOX Constraint

Constraint #: 299

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.404	1.404	1.404
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.404	1.404	1.404
TBtu Consumed	0.000	0.000	46.79	46.79	46.79
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.468	4.468	4.468
TWh Generated Qualifying	0.000	0.000	4.468	4.468	4.468
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCU BART Plant Specific NOX Constraint

Constraint #: 300

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.045	1.045	1.045
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.045	1.045	1.045
TBtu Consumed	0.000	0.000	34.84	34.84	34.84
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.239	3.239	3.239
TWh Generated Qualifying	0.000	0.000	3.239	3.239	3.239
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCZ BART Plant Specific NOX Constraint

Constraint #: 301

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.074	1.074	1.074
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.074	1.074	1.074
TBtu Consumed	0.000	0.000	35.80	35.80	35.80
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.477	3.477	3.477
TWh Generated Qualifying	0.000	0.000	3.477	3.477	3.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDB BART Plant Specific NOX Constraint

Constraint #: 302

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.762	5.762	5.762
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.762	5.762	5.762
TBtu Consumed	0.000	0.000	192.1	192.1	192.1
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	18.33	18.33	18.33
TWh Generated Qualifying	0.000	0.000	18.33	18.33	18.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CDM BART Plant Specific NOX Constraint

Constraint #: 303

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.775	7.775	7.775
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.775	7.775	7.775
TBtu Consumed	0.000	0.000	77.75	77.75	77.75
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.446	7.446	7.446
TWh Generated Qualifying	0.000	0.000	7.446	7.446	7.446
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	540.3	0.000	249.2

Constraint Name: CDN BART Plant Specific NOX Constraint

Constraint #: 304

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.785	8.785	8.785
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.785	8.785	8.785
TBtu Consumed	0.000	0.000	87.85	87.85	87.85
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	8.638	8.638	8.638
TWh Generated Qualifying	0.000	0.000	8.638	8.638	8.638
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1358.	0.000	660.5

Constraint Name: CDO BART Plant Specific NOX Constraint

Constraint #: 305

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.405	2.405	2.405
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.405	2.405	2.405
TBtu Consumed	0.000	0.000	24.05	24.05	24.05
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.241	2.241	2.241
TWh Generated Qualifying	0.000	0.000	2.241	2.241	2.241
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2152.	0.000	1109.

Constraint Name: CDP BART Plant Specific NOX Constraint

Constraint #: 306

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4267	0.4704	0.4704
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4267	0.4704	0.4704
TBtu Consumed	0.000	0.000	4.267	4.704	4.704
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.3539	0.3902	0.3902
TWh Generated Qualifying	0.000	0.000	0.3539	0.3902	0.3902
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1813E+05	0.1761E+05	0.1931E+05

Constraint Name: CDQ BART Plant Specific NOX Constraint

Constraint #: 307

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.583	5.583	5.583
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.583	5.583	5.583
TBtu Consumed	0.000	0.000	55.83	55.83	55.83
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.410	5.410	5.410
TWh Generated Qualifying	0.000	0.000	5.410	5.410	5.410
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	450.9	547.1	8.988

Constraint Name: CDT BART Plant Specific NOX Constraint

Constraint #: 308

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.746	2.746	2.746
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.746	2.746	2.746
TBtu Consumed	0.000	0.000	27.46	27.46	27.46
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.725	2.725	2.725
TWh Generated Qualifying	0.000	0.000	2.725	2.725	2.725
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	486.6	451.3	190.4

Constraint Name: CEB BART Plant Specific NOX Constraint

Constraint #: 309

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.213	1.213	1.213
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.213	1.213	1.213
TBtu Consumed	0.000	0.000	12.13	12.13	12.13
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.132	1.132	1.132
TWh Generated Qualifying	0.000	0.000	1.132	1.132	1.132
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3372.	0.000	1394.

Constraint Name: CEC BART Plant Specific NOX Constraint

Constraint #: 310

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.496	9.496	9.496
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.496	9.496	9.496
TBtu Consumed	0.000	0.000	132.8	132.8	132.8
Rate - [lb/MMBtu]	0.000	0.000	0.1430	0.1430	0.1430
TWh Generated	0.000	0.000	11.77	11.77	11.77
TWh Generated Qualifying	0.000	0.000	11.77	11.77	11.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CES BART Plant Specific NOX Constraint

Constraint #: 311

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.403	5.403	5.403
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.403	5.403	5.403
TBtu Consumed	0.000	0.000	54.03	54.03	54.03
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.279	5.279	5.279
TWh Generated Qualifying	0.000	0.000	5.279	5.279	5.279
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1900.	2883.	1043.

Constraint Name: CEU BART Plant Specific NOX Constraint

Constraint #: 312

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	10.89	10.89	10.89
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	10.89	10.89	10.89
TBtu Consumed	0.000	0.000	108.9	108.9	108.9
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	11.02	11.02	11.02
TWh Generated Qualifying	0.000	0.000	11.02	11.02	11.02
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1430.	0.000	807.7

Constraint Name: CEV BART Plant Specific NOX Constraint

Constraint #: 313

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.910	7.910	7.910
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.910	7.910	7.910
TBtu Consumed	0.000	0.000	79.10	79.10	79.10
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.342	7.342	7.342
TWh Generated Qualifying	0.000	0.000	7.342	7.342	7.342
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1794.	0.000	1013.

Constraint Name: CEW BART Plant Specific NOX Constraint

Constraint #: 314

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.558	4.558	4.558
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.558	4.558	4.558
TBtu Consumed	0.000	0.000	45.58	45.58	45.58
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.170	4.170	4.170
TWh Generated Qualifying	0.000	0.000	4.170	4.170	4.170
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2567.	0.000	898.3

Constraint Name: CFE BART Plant Specific NOX Constraint

Constraint #: 315

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.681	3.681	3.681
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.681	3.681	3.681
TBtu Consumed	0.000	0.000	36.81	36.81	36.81
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.291	3.291	3.291
TWh Generated Qualifying	0.000	0.000	3.291	3.291	3.291
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5741.	0.000	1947.

Constraint Name: CFH BART Plant Specific NOX Constraint

Constraint #: 316

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.689	3.689	3.689
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.689	3.689	3.689
TBtu Consumed	0.000	0.000	36.89	36.89	36.89
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.544	3.544	3.544
TWh Generated Qualifying	0.000	0.000	3.544	3.544	3.544
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1334.	1640.	739.2

Constraint Name: CFL BART Plant Specific NOX Constraint

Constraint #: 317

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.439	3.439	3.439
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.439	3.439	3.439
TBtu Consumed	0.000	0.000	34.39	34.39	34.39
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.321	3.321	3.321
TWh Generated Qualifying	0.000	0.000	3.321	3.321	3.321
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2598.	0.000	1377.

Constraint Name: CFM BART Plant Specific NOX Constraint

Constraint #: 318

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.485	1.485	1.485
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.485	1.485	1.485
TBtu Consumed	0.000	0.000	14.85	14.85	14.85
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.385	1.385	1.385
TWh Generated Qualifying	0.000	0.000	1.385	1.385	1.385
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3478.	0.000	1377.



Constraint Name: CGB BART Plant Specific NOX Constraint

Constraint #: 319

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.744	3.744	3.744
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.744	3.744	3.744
TBtu Consumed	0.000	0.000	37.44	37.44	37.44
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.783	3.783	3.783
TWh Generated Qualifying	0.000	0.000	3.783	3.783	3.783
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2045.	0.000	1121.

Constraint Name: CGC BART Plant Specific NOX Constraint

Constraint #: 320

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.165	1.165	1.165
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.165	1.165	1.165
TBtu Consumed	0.000	0.000	11.65	11.65	11.65
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.162	1.162	1.162
TWh Generated Qualifying	0.000	0.000	1.162	1.162	1.162
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2769.	205.3	1029.

Constraint Name: CGD BART Plant Specific NOX Constraint

Constraint #: 321

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6030	0.6030	0.6030
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6030	0.6030	0.6030
TBtu Consumed	0.000	0.000	6.030	6.030	6.030
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.5883	0.5883	0.5883
TWh Generated Qualifying	0.000	0.000	0.5883	0.5883	0.5883
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5898.	0.000	2878.

Constraint Name: CGJ BART Plant Specific NOX Constraint

Constraint #: 322

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8715	0.8715	0.8715
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8715	0.8715	0.8715
TBtu Consumed	0.000	0.000	11.94	11.94	11.94
Rate - [lb/MMBtu]	0.000	0.000	0.1460	0.1460	0.1460
TWh Generated	0.000	0.000	1.191	1.191	1.191
TWh Generated Qualifying	0.000	0.000	1.191	1.191	1.191
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGK BART Plant Specific NOX Constraint

Constraint #: 323

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.295	1.295	1.295
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.295	1.295	1.295
TBtu Consumed	0.000	0.000	16.82	16.81	16.81
Rate - [lb/MMBtu]	0.000	0.000	0.1540	0.1540	0.1540
TWh Generated	0.000	0.000	1.564	1.531	1.531
TWh Generated Qualifying	0.000	0.000	1.564	1.531	1.531
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGW BART Plant Specific NOX Constraint

Constraint #: 324

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.484	1.484	1.484
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.484	1.484	1.484
TBtu Consumed	0.000	0.000	47.88	47.88	47.88
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	4.466	4.466	4.466
TWh Generated Qualifying	0.000	0.000	4.466	4.466	4.466
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CHQ BART Plant Specific NOX Constraint

Constraint #: 325

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1704E+05	0.1486E+05	0.1224E+05

Constraint Name: CHV BART Plant Specific NOX Constraint

Constraint #: 326

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3064	0.3064	0.3064
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3064	0.3064	0.3064
TBtu Consumed	0.000	0.000	3.064	3.064	3.064
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.3025	0.3025	0.3025
TWh Generated Qualifying	0.000	0.000	0.3025	0.3025	0.3025
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2026E+05	0.1786E+05	0.1959E+05



Constraint Name: CHY BART Plant Specific NOX Constraint

Constraint #: 327

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.041	3.041	3.041
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.041	3.041	3.041
TBtu Consumed	0.000	0.000	101.4	101.4	101.4
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	9.680	9.680	9.680
TWh Generated Qualifying	0.000	0.000	9.680	9.680	9.680
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIA BART Plant Specific NOX Constraint

Constraint #: 328

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.361	1.361	1.361
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.361	1.361	1.361
TBtu Consumed	0.000	0.000	42.55	42.55	42.55
Rate - [lb/MMBtu]	0.000	0.000	0.6400E-01	0.6400E-01	0.6400E-01
TWh Generated	0.000	0.000	3.969	3.969	3.969
TWh Generated Qualifying	0.000	0.000	3.969	3.969	3.969
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIB BART Plant Specific NOX Constraint

Constraint #: 329

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.361	1.361	1.361
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.361	1.361	1.361
TBtu Consumed	0.000	0.000	42.55	42.55	42.55
Rate - [lb/MMBtu]	0.000	0.000	0.6400E-01	0.6400E-01	0.6400E-01
TWh Generated	0.000	0.000	3.969	3.969	3.969
TWh Generated Qualifying	0.000	0.000	3.969	3.969	3.969
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIC BART Plant Specific NOX Constraint

Constraint #: 330

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.780	2.780	2.780
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.780	2.780	2.780
TBtu Consumed	0.000	0.000	75.13	75.13	75.13
Rate - [lb/MMBtu]	0.000	0.000	0.7400E-01	0.7400E-01	0.7400E-01
TWh Generated	0.000	0.000	7.171	7.171	7.171
TWh Generated Qualifying	0.000	0.000	7.171	7.171	7.171
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CID BART Plant Specific NOX Constraint

Constraint #: 331

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.936	1.936	1.936
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.936	1.936	1.936
TBtu Consumed	0.000	0.000	47.81	47.81	47.81
Rate - [lb/MMBtu]	0.000	0.000	0.8100E-01	0.8100E-01	0.8100E-01
TWh Generated	0.000	0.000	4.654	4.654	4.654
TWh Generated Qualifying	0.000	0.000	4.654	4.654	4.654
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIE BART Plant Specific NOX Constraint

Constraint #: 332

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.970	1.970	1.970
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.970	1.970	1.970
TBtu Consumed	0.000	0.000	48.05	48.05	48.05
Rate - [lb/MMBtu]	0.000	0.000	0.8200E-01	0.8200E-01	0.8200E-01
TWh Generated	0.000	0.000	4.483	4.483	4.483
TWh Generated Qualifying	0.000	0.000	4.483	4.483	4.483
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIV BART Plant Specific NOX Constraint

Constraint #: 333

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7280	0.8026	0.8026
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7280	0.8026	0.8026
TBtu Consumed	0.000	0.000	7.280	8.026	8.026
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.6542	0.7212	0.7212
TWh Generated Qualifying	0.000	0.000	0.6542	0.7212	0.7212
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1866E+05	0.1760E+05	0.1513E+05

Constraint Name: CIX BART Plant Specific NOX Constraint

Constraint #: 334

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.940	8.940	8.940
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.940	8.940	8.940
TBtu Consumed	0.000	0.000	89.40	89.40	89.40
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	9.144	9.144	9.144
TWh Generated Qualifying	0.000	0.000	9.144	9.144	9.144
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1119.	0.000	525.4



Constraint Name: CJG BART Plant Specific NOX Constraint

Constraint #: 335

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.169	1.169	1.169
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.169	1.169	1.169
TBtu Consumed	0.000	0.000	38.98	38.98	38.98
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.880	3.880	3.880
TWh Generated Qualifying	0.000	0.000	3.880	3.880	3.880
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CJH BART Plant Specific NOX Constraint

Constraint #: 336

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.489	6.489	6.489
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.489	6.489	6.489
TBtu Consumed	0.000	0.000	64.89	64.89	64.89
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.218	6.218	6.218
TWh Generated Qualifying	0.000	0.000	6.218	6.218	6.218
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3572.	0.000	2017.

Constraint Name: CJJ BART Plant Specific NOX Constraint

Constraint #: 337

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.323	3.323	3.323
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.323	3.323	3.323
TBtu Consumed	0.000	0.000	33.23	33.23	33.23
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.090	3.090	3.090
TWh Generated Qualifying	0.000	0.000	3.090	3.090	3.090
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3244.	0.000	1832.

Constraint Name: CJP BART Plant Specific NOX Constraint

Constraint #: 338

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.2113	0.2367	0.2367
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.2113	0.2367	0.2367
TBtu Consumed	0.000	0.000	2.113	2.367	2.367
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.1966	0.2203	0.2203
TWh Generated Qualifying	0.000	0.000	0.1966	0.2203	0.2203
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1892E+05	0.1798E+05	0.1850E+05

Constraint Name: CMC BART Plant Specific NOX Constraint

Constraint #: 339

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.263	3.262	3.262
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.263	3.262	3.262
TBtu Consumed	0.000	0.000	32.63	32.62	32.62
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.165	3.098	3.098
TWh Generated Qualifying	0.000	0.000	3.165	3.098	3.098
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5195.	768.9	0.000

Constraint Name: CMF BART Plant Specific NOX Constraint

Constraint #: 340

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	38.72	38.72	35.21
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	38.72	38.72	35.21
TBtu Consumed	0.000	0.000	387.2	387.2	352.1
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	34.67	34.67	31.53
TWh Generated Qualifying	0.000	0.000	34.67	34.67	31.53
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2338.	3791.	1109.

Constraint Name: CMK BART Plant Specific NOX Constraint

Constraint #: 341

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.491	3.606	3.606
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.491	3.606	3.606
TBtu Consumed	0.000	0.000	34.91	36.06	36.06
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.027	3.127	3.127
TWh Generated Qualifying	0.000	0.000	3.027	3.127	3.127
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1102.	1418.	774.3

Constraint Name: CML BART Plant Specific NOX Constraint

Constraint #: 342

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.992	4.992	4.992
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.992	4.992	4.992
TBtu Consumed	0.000	0.000	49.92	49.92	49.92
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.498	4.498	4.498
TWh Generated Qualifying	0.000	0.000	4.498	4.498	4.498
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4348.	1213.	1738.



Constraint Name: CMQ BART Plant Specific NOX Constraint

Constraint #: 343

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7189	0.7189	0.7189
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7189	0.7189	0.7189
TBtu Consumed	0.000	0.000	7.189	7.189	7.189
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.5510	0.5510	0.5510
TWh Generated Qualifying	0.000	0.000	0.5510	0.5510	0.5510
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1979.	1979.	1979.

Constraint Name: CMW BART Plant Specific NOX Constraint

Constraint #: 344

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.448	1.448	1.448
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.448	1.448	1.448
TBtu Consumed	0.000	0.000	48.27	48.27	48.27
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.468	4.468	4.468
TWh Generated Qualifying	0.000	0.000	4.468	4.468	4.468
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CND BART Plant Specific NOX Constraint

Constraint #: 345

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	11.98	11.98	11.98
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	11.98	11.98	11.98
TBtu Consumed	0.000	0.000	176.2	176.2	176.2
Rate - [lb/MMBtu]	0.000	0.000	0.1360	0.1360	0.1360
TWh Generated	0.000	0.000	15.91	15.91	15.91
TWh Generated Qualifying	0.000	0.000	15.91	15.91	15.91
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNE BART Plant Specific NOX Constraint

Constraint #: 346

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	10.95	10.95	10.95
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	10.95	10.95	10.95
TBtu Consumed	0.000	0.000	109.5	109.5	109.5
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	10.45	10.45	10.45
TWh Generated Qualifying	0.000	0.000	10.45	10.45	10.45
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3506.	0.000	1980.

Constraint Name: COO BART Plant Specific NOX Constraint

Constraint #: 347

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.340	1.340	1.340
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.340	1.340	1.340
TBtu Consumed	0.000	0.000	37.75	37.75	37.75
Rate - [lb/MMBtu]	0.000	0.000	0.7100E-01	0.7100E-01	0.7100E-01
TWh Generated	0.000	0.000	4.252	4.252	4.252
TWh Generated Qualifying	0.000	0.000	4.252	4.252	4.252
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPA BART Plant Specific NOX Constraint

Constraint #: 348

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.119	6.119	6.119
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.119	6.119	6.119
TBtu Consumed	0.000	0.000	61.19	61.19	61.19
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.078	5.078	5.078
TWh Generated Qualifying	0.000	0.000	5.078	5.078	5.078
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	416.0	617.6	0.000

Constraint Name: CPB BART Plant Specific NOX Constraint

Constraint #: 349

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.828	2.828	2.828
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.828	2.828	2.828
TBtu Consumed	0.000	0.000	39.00	39.00	39.00
Rate - [lb/MMBtu]	0.000	0.000	0.1450	0.1450	0.1450
TWh Generated	0.000	0.000	3.597	3.597	3.597
TWh Generated Qualifying	0.000	0.000	3.597	3.597	3.597
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPD BART Plant Specific NOX Constraint

Constraint #: 350

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6010	0.6010	0.6010
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6010	0.6010	0.6010
TBtu Consumed	0.000	0.000	6.010	6.010	6.010
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.5734	0.5734	0.5734
TWh Generated Qualifying	0.000	0.000	0.5734	0.5734	0.5734
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2810.	2662.	2611.



Constraint Name: CPE BART Plant Specific NOX Constraint

Constraint #: 351

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.395	2.502	2.502
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.395	2.502	2.502
TBtu Consumed	0.000	0.000	23.95	25.02	25.02
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.892	1.977	1.977
TWh Generated Qualifying	0.000	0.000	1.892	1.977	1.977
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2086.	4038.	0.000

Constraint Name: CPU BART Plant Specific NOX Constraint

Constraint #: 352

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.340	1.340	1.340
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.340	1.340	1.340
TBtu Consumed	0.000	0.000	13.40	13.40	13.40
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.356	1.356	1.356
TWh Generated Qualifying	0.000	0.000	1.356	1.356	1.356
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1737E+05	0.1615E+05	0.1720E+05

Constraint Name: CPV BART Plant Specific NOX Constraint

Constraint #: 353

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPW BART Plant Specific NOX Constraint

Constraint #: 354

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPX BART Plant Specific NOX Constraint

Constraint #: 355

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPY BART Plant Specific NOX Constraint

Constraint #: 356

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.502	1.527	1.284
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.502	1.527	1.284
TBtu Consumed	0.000	0.000	15.02	15.27	12.84
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.439	1.463	1.231
TWh Generated Qualifying	0.000	0.000	1.439	1.463	1.231
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1708E+05	0.1736E+05	0.1637E+05

Constraint Name: CPZ BART Plant Specific NOX Constraint

Constraint #: 357

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.2679	0.3897	0.3758
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.2679	0.3897	0.3758
TBtu Consumed	0.000	0.000	2.679	3.897	3.758
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.2579	0.3760	0.3627
TWh Generated Qualifying	0.000	0.000	0.2579	0.3760	0.3627
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1889E+05	0.1597E+05	0.1474E+05

Constraint Name: CQV BART Plant Specific NOX Constraint

Constraint #: 358

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5537	0.5537	0.5537
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5537	0.5537	0.5537
TBtu Consumed	0.000	0.000	6.631	6.631	6.631
Rate - [lb/MMBtu]	0.000	0.000	0.1670	0.1670	0.1670
TWh Generated	0.000	0.000	0.6329	0.6329	0.6329
TWh Generated Qualifying	0.000	0.000	0.6329	0.6329	0.6329
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CRI BART Plant Specific NOX Constraint

Constraint #: 359

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5653	0.6303	0.6303
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5653	0.6303	0.6303
TBtu Consumed	0.000	0.000	5.653	6.303	6.303
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.5848	0.6519	0.6519
TWh Generated Qualifying	0.000	0.000	0.5848	0.6519	0.6519
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1659E+05	0.1518E+05	0.1609E+05

Constraint Name: CRP BART Plant Specific NOX Constraint

Constraint #: 360

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.493	1.493	1.493
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.493	1.493	1.493
TBtu Consumed	0.000	0.000	49.78	49.78	49.78
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.840	4.840	4.840
TWh Generated Qualifying	0.000	0.000	4.840	4.840	4.840
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CRQ BART Plant Specific NOX Constraint

Constraint #: 361

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3551	0.3551	0.3551
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3551	0.3551	0.3551
TBtu Consumed	0.000	0.000	7.719	7.719	7.719
Rate - [lb/MMBtu]	0.000	0.000	0.9200E-01	0.9200E-01	0.9200E-01
TWh Generated	0.000	0.000	0.6404	0.6404	0.6404
TWh Generated Qualifying	0.000	0.000	0.6404	0.6404	0.6404
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CRR BART Plant Specific NOX Constraint

Constraint #: 362

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3661	0.3661	0.3661
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3661	0.3661	0.3661
TBtu Consumed	0.000	0.000	7.959	7.959	7.959
Rate - [lb/MMBtu]	0.000	0.000	0.9200E-01	0.9200E-01	0.9200E-01
TWh Generated	0.000	0.000	0.6553	0.6553	0.6553
TWh Generated Qualifying	0.000	0.000	0.6553	0.6553	0.6553
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSX BART Plant Specific NOX Constraint

Constraint #: 363

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	12.02	12.02	12.02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	12.02	12.02	12.02
TBtu Consumed	0.000	0.000	120.2	120.2	120.2
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	12.66	12.66	12.66
TWh Generated Qualifying	0.000	0.000	12.66	12.66	12.66
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	645.3	1010.	0.000

Constraint Name: CTC BART Plant Specific NOX Constraint

Constraint #: 364

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.230	1.230	1.230
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.230	1.230	1.230
TBtu Consumed	0.000	0.000	41.01	41.01	41.01
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.515	3.515	3.515
TWh Generated Qualifying	0.000	0.000	3.515	3.515	3.515
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CTE BART Plant Specific NOX Constraint

Constraint #: 365

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.317	3.317	3.317
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.317	3.317	3.317
TBtu Consumed	0.000	0.000	33.17	33.17	33.17
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.979	2.979	2.979
TWh Generated Qualifying	0.000	0.000	2.979	2.979	2.979
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3155.	0.000	1407.

Constraint Name: CUJ BART Plant Specific NOX Constraint

Constraint #: 366

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.2070	0.2070	0.2070
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.2070	0.2070	0.2070
TBtu Consumed	0.000	0.000	2.070	2.070	2.070
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.2227	0.2227	0.2227
TWh Generated Qualifying	0.000	0.000	0.2227	0.2227	0.2227
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2373E+05	0.1961E+05	0.1959E+05



Constraint Name: CUR BART Plant Specific NOX Constraint

Constraint #: 367

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.353	2.353	2.188
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.353	2.353	2.188
TBtu Consumed	0.000	0.000	23.53	23.53	21.88
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.438	2.438	2.267
TWh Generated Qualifying	0.000	0.000	2.438	2.438	2.267
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1496E+05	0.1455E+05	0.1788E+05

Constraint Name: CUY BART Plant Specific NOX Constraint

Constraint #: 368

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8408	0.8408	0.8408
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8408	0.8408	0.8408
TBtu Consumed	0.000	0.000	8.408	8.408	8.408
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.7374	0.7374	0.7374
TWh Generated Qualifying	0.000	0.000	0.7374	0.7374	0.7374
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1301E+05	0.1216E+05	0.1502E+05

Constraint Name: CVG BART Plant Specific NOX Constraint

Constraint #: 369

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.508	4.508	4.508
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.508	4.508	4.508
TBtu Consumed	0.000	0.000	54.32	54.32	54.32
Rate - [lb/MMBtu]	0.000	0.000	0.1660	0.1660	0.1660
TWh Generated	0.000	0.000	5.302	5.302	5.302
TWh Generated Qualifying	0.000	0.000	5.302	5.302	5.302
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CVH BART Plant Specific NOX Constraint

Constraint #: 370

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1346E+05	0.1221E+05	0.1070E+05

Constraint Name: CVI BART Plant Specific NOX Constraint

Constraint #: 371

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.1564	0.1564	0.1564
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.1564	0.1564	0.1564
TBtu Consumed	0.000	0.000	2.234	2.234	2.234
Rate - [lb/MMBtu]	0.000	0.000	0.1400	0.1400	0.1400
TWh Generated	0.000	0.000	0.2234	0.2234	0.2234
TWh Generated Qualifying	0.000	0.000	0.2234	0.2234	0.2234
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CVN BART Plant Specific NOX Constraint

Constraint #: 372

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.096	1.096	1.096
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.096	1.096	1.096
TBtu Consumed	0.000	0.000	12.18	12.18	12.18
Rate - [lb/MMBtu]	0.000	0.000	0.1800	0.1800	0.1800
TWh Generated	0.000	0.000	1.109	1.109	1.109
TWh Generated Qualifying	0.000	0.000	1.109	1.109	1.109
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWG BART Plant Specific NOX Constraint

Constraint #: 373

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5070	0.5463	0.5463
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5070	0.5463	0.5463
TBtu Consumed	0.000	0.000	5.070	5.463	5.463
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.4312	0.4646	0.4646
TWh Generated Qualifying	0.000	0.000	0.4312	0.4646	0.4646
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2026E+05	0.2131E+05	0.1968E+05

Constraint Name: CWO BART Plant Specific NOX Constraint

Constraint #: 374

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.170	1.170	1.170
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.170	1.170	1.170
TBtu Consumed	0.000	0.000	39.00	39.00	39.00
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.723	3.723	3.723
TWh Generated Qualifying	0.000	0.000	3.723	3.723	3.723
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CWP BART Plant Specific NOX Constraint

Constraint #: 375

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5851	0.5851	0.5851
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5851	0.5851	0.5851
TBtu Consumed	0.000	0.000	19.50	19.50	19.50
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.862	1.862	1.862
TWh Generated Qualifying	0.000	0.000	1.862	1.862	1.862
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWQ BART Plant Specific NOX Constraint

Constraint #: 376

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4333	0.4333	0.4333
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4333	0.4333	0.4333
TBtu Consumed	0.000	0.000	11.26	11.26	11.26
Rate - [lb/MMBtu]	0.000	0.000	0.7700E-01	0.7700E-01	0.7700E-01
TWh Generated	0.000	0.000	1.050	1.050	1.050
TWh Generated Qualifying	0.000	0.000	1.050	1.050	1.050
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWR BART Plant Specific NOX Constraint

Constraint #: 377

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.751	5.751	5.751
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.751	5.751	5.751
TBtu Consumed	0.000	0.000	191.7	191.7	191.7
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	19.36	19.36	19.36
TWh Generated Qualifying	0.000	0.000	19.36	19.36	19.36
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWS BART Plant Specific NOX Constraint

Constraint #: 378

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.039	4.039	4.039
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.039	4.039	4.039
TBtu Consumed	0.000	0.000	115.4	115.4	115.4
Rate - [lb/MMBtu]	0.000	0.000	0.7000E-01	0.7000E-01	0.7000E-01
TWh Generated	0.000	0.000	11.91	11.91	11.91
TWh Generated Qualifying	0.000	0.000	11.91	11.91	11.91
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWT BART Plant Specific NOX Constraint

Constraint #: 379

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.494	4.494	4.494
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.494	4.494	4.494
TBtu Consumed	0.000	0.000	149.8	149.8	149.8
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	14.30	14.30	14.30
TWh Generated Qualifying	0.000	0.000	14.30	14.30	14.30
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CXA BART Plant Specific NOX Constraint

Constraint #: 380

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.684	9.684	9.684
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.684	9.684	9.684
TBtu Consumed	0.000	0.000	96.84	96.84	96.84
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	9.360	9.360	9.360
TWh Generated Qualifying	0.000	0.000	9.360	9.360	9.360
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1093.	376.1	674.5

Constraint Name: CXB BART Plant Specific NOX Constraint

Constraint #: 381

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.219	3.219	3.219
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.219	3.219	3.219
TBtu Consumed	0.000	0.000	32.19	32.19	32.19
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.031	3.031	3.031
TWh Generated Qualifying	0.000	0.000	3.031	3.031	3.031
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1093.	326.4	652.9

Constraint Name: CXI BART Plant Specific NOX Constraint

Constraint #: 382

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4491	0.5547	0.5547
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4491	0.5547	0.5547
TBtu Consumed	0.000	0.000	4.491	5.547	5.547
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.4214	0.5205	0.5205
TWh Generated Qualifying	0.000	0.000	0.4214	0.5205	0.5205
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1996E+05	0.1803E+05	0.1639E+05



Constraint Name: CXL BART Plant Specific NOX Constraint

Constraint #: 383

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.2696	0.4861	0.4861
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.2696	0.4861	0.4861
TBtu Consumed	0.000	0.000	2.696	4.861	4.861
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.2889	0.5210	0.5210
TWh Generated Qualifying	0.000	0.000	0.2889	0.5210	0.5210
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1938E+05	0.1553E+05	0.1442E+05

Constraint Name: CXM BART Plant Specific NOX Constraint

Constraint #: 384

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.2098	0.2098
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.2098	0.2098
TBtu Consumed	0.000	0.000	0.000	2.098	2.098
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.2151	0.2151
TWh Generated Qualifying	0.000	0.000	0.000	0.2151	0.2151
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1953E+05	0.1406E+05	0.1398E+05

Constraint Name: CYF BART Plant Specific NOX Constraint

Constraint #: 385

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.6263	0.6263
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.6263	0.6263
TBtu Consumed	0.000	0.000	0.000	6.263	6.263
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.5900	0.5900
TWh Generated Qualifying	0.000	0.000	0.000	0.5900	0.5900
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2121E+05	0.1538E+05	0.1480E+05

Constraint Name: CYI BART Plant Specific NOX Constraint

Constraint #: 386

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.2505	0.2505
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.2505	0.2505
TBtu Consumed	0.000	0.000	0.000	2.505	2.505
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.2488	0.2488
TWh Generated Qualifying	0.000	0.000	0.000	0.2488	0.2488
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2069E+05	0.1579E+05	0.1469E+05

Constraint Name: CYK BART Plant Specific NOX Constraint

Constraint #: 387

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3535	0.3809	0.3809
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3535	0.3809	0.3809
TBtu Consumed	0.000	0.000	3.535	3.809	3.809
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.2990	0.3221	0.3221
TWh Generated Qualifying	0.000	0.000	0.2990	0.3221	0.3221
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2026E+05	0.2082E+05	0.1959E+05

Constraint Name: CYU BART Plant Specific NOX Constraint

Constraint #: 388

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4247	0.4247	0.4247
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4247	0.4247	0.4247
TBtu Consumed	0.000	0.000	4.247	4.247	4.247
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.4017	0.4017	0.4017
TWh Generated Qualifying	0.000	0.000	0.4017	0.4017	0.4017
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1793E+05	0.1799E+05	0.2071E+05

Constraint Name: CYX BART Plant Specific NOX Constraint

Constraint #: 389

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.335	1.335	1.335
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.335	1.335	1.335
TBtu Consumed	0.000	0.000	13.35	13.35	13.35
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.275	1.275	1.275
TWh Generated Qualifying	0.000	0.000	1.275	1.275	1.275
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1253.	1578.	0.000

Constraint Name: CZR BART Plant Specific NOX Constraint

Constraint #: 390

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.672	1.672	1.672
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.672	1.672	1.672
TBtu Consumed	0.000	0.000	39.35	39.35	39.35
Rate - [lb/MMBtu]	0.000	0.000	0.8500E-01	0.8500E-01	0.8500E-01
TWh Generated	0.000	0.000	3.574	3.574	3.574
TWh Generated Qualifying	0.000	0.000	3.574	3.574	3.574
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CZT BART Plant Specific NOX Constraint

Constraint #: 391

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9718	0.9718	0.9718
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9718	0.9718	0.9718
TBtu Consumed	0.000	0.000	31.35	31.35	31.35
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	3.135	3.135	3.135
TWh Generated Qualifying	0.000	0.000	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZU BART Plant Specific NOX Constraint

Constraint #: 392

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9373	0.9373	0.9373
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9373	0.9373	0.9373
TBtu Consumed	0.000	0.000	30.24	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	3.135	3.135	3.135
TWh Generated Qualifying	0.000	0.000	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZV BART Plant Specific NOX Constraint

Constraint #: 393

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9750	0.9750	0.9750
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9750	0.9750	0.9750
TBtu Consumed	0.000	0.000	31.45	31.45	31.45
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	3.202	3.202	3.202
TWh Generated Qualifying	0.000	0.000	3.202	3.202	3.202
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZW BART Plant Specific NOX Constraint

Constraint #: 394

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.723	1.723	1.723
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.723	1.723	1.723
TBtu Consumed	0.000	0.000	17.23	17.23	17.23
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.653	1.653	1.653
TWh Generated Qualifying	0.000	0.000	1.653	1.653	1.653
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2053.	1885.	1873.

Constraint Name: DAG BART Plant Specific NOX Constraint

Constraint #: 395

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.7934	0.7934
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.7934	0.7934
TBtu Consumed	0.000	0.000	0.000	7.934	7.934
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.7522	0.7522
TWh Generated Qualifying	0.000	0.000	0.000	0.7522	0.7522
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.2136E+05	0.1518E+05	0.1499E+05

Constraint Name: DAM BART Plant Specific NOX Constraint

Constraint #: 396

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.1546
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.1546
TBtu Consumed	0.000	0.000	0.000	0.000	1.546
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.2000
TWh Generated	0.000	0.000	0.000	0.000	0.1577
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.1577
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1468E+05	0.1328E+05	0.1266E+05

Constraint Name: DAO BART Plant Specific NOX Constraint

Constraint #: 397

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.4863	0.6839
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.4863	0.6839
TBtu Consumed	0.000	0.000	0.000	4.863	6.839
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.4607	0.6480
TWh Generated Qualifying	0.000	0.000	0.000	0.4607	0.6480
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1965E+05	0.1558E+05	0.1421E+05

Constraint Name: DAX BART Plant Specific NOX Constraint

Constraint #: 398

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1984E+05	9959.	0.1090E+05



Constraint Name: DBC BART Plant Specific NOX Constraint

Constraint #: 399

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1642E+05	0.1255E+05	0.1008E+05

Constraint Name: DBD BART Plant Specific NOX Constraint

Constraint #: 400

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.036	1.668	1.668
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.036	1.668	1.668
TBtu Consumed	0.000	0.000	10.36	16.68	16.68
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.025	1.650	1.650
TWh Generated Qualifying	0.000	0.000	1.025	1.650	1.650
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1712E+05	0.1445E+05	0.1449E+05

Constraint Name: CAS BART Plant Specific NOX Constraint

Constraint #: 401

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.074	1.079	1.079
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.074	1.079	1.079
TBtu Consumed	0.000	0.000	44.93	45.42	45.42
Rate - [lb/MMBtu]	0.000	0.000	0.4780E-01	0.4750E-01	0.4750E-01
TWh Generated	0.000	0.000	4.611	4.667	4.667
TWh Generated Qualifying	0.000	0.000	4.611	4.667	4.667
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CAW BART Plant Specific NOX Constraint

Constraint #: 402

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.152	1.157	1.157
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.152	1.157	1.157
TBtu Consumed	0.000	0.000	12.45	12.50	12.50
Rate - [lb/MMBtu]	0.000	0.000	0.1850	0.1850	0.1850
TWh Generated	0.000	0.000	1.177	1.181	1.181
TWh Generated Qualifying	0.000	0.000	1.177	1.181	1.181
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CAX BART Plant Specific NOX Constraint

Constraint #: 403

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.305	3.280	3.280
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.305	3.280	3.280
TBtu Consumed	0.000	0.000	33.05	32.80	32.80
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.049	3.024	3.024
TWh Generated Qualifying	0.000	0.000	3.049	3.024	3.024
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8618.	4767.	6933.

Constraint Name: CBU BART Plant Specific NOX Constraint

Constraint #: 404

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.949	3.949	3.949
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.949	3.949	3.949
TBtu Consumed	0.000	0.000	39.49	39.49	39.49
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.686	3.686	3.686
TWh Generated Qualifying	0.000	0.000	3.686	3.686	3.686
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2149.	4603.	0.000

Constraint Name: CBY BART Plant Specific NOX Constraint

Constraint #: 405

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.510	4.510	4.510
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.510	4.510	4.510
TBtu Consumed	0.000	0.000	118.7	118.7	118.7
Rate - [lb/MMBtu]	0.000	0.000	0.7600E-01	0.7600E-01	0.7600E-01
TWh Generated	0.000	0.000	11.43	11.43	11.43
TWh Generated Qualifying	0.000	0.000	11.43	11.43	11.43
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CBZ BART Plant Specific NOX Constraint

Constraint #: 406

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.324	1.324	1.324
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.324	1.324	1.324
TBtu Consumed	0.000	0.000	44.15	44.15	44.15
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.891	3.891	3.891
TWh Generated Qualifying	0.000	0.000	3.891	3.891	3.891
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CCL BART Plant Specific NOX Constraint

Constraint #: 407

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.089	1.107	1.107
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.089	1.107	1.107
TBtu Consumed	0.000	0.000	10.89	11.07	11.07
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.024	1.041	1.041
TWh Generated Qualifying	0.000	0.000	1.024	1.041	1.041
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3151.	4417.	2046.

Constraint Name: CCN BART Plant Specific NOX Constraint

Constraint #: 408

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.236	4.236	4.236
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.236	4.236	4.236
TBtu Consumed	0.000	0.000	62.76	62.76	62.76
Rate - [lb/MMBtu]	0.000	0.000	0.1350	0.1350	0.1350
TWh Generated	0.000	0.000	5.613	5.613	5.613
TWh Generated Qualifying	0.000	0.000	5.613	5.613	5.613
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCO BART Plant Specific NOX Constraint

Constraint #: 409

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.850	3.850	3.850
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.850	3.850	3.850
TBtu Consumed	0.000	0.000	38.50	38.50	38.50
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.358	3.358	3.358
TWh Generated Qualifying	0.000	0.000	3.358	3.358	3.358
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2336.	459.0	0.000

Constraint Name: CCQ BART Plant Specific NOX Constraint

Constraint #: 410

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.606	1.606	1.606
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.606	1.606	1.606
TBtu Consumed	0.000	0.000	16.06	16.06	16.06
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.520	1.519	1.519
TWh Generated Qualifying	0.000	0.000	1.520	1.519	1.519
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7605.	0.000	0.000

Constraint Name: CDC BART Plant Specific NOX Constraint

Constraint #: 411

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6909	0.6992	0.6992
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6909	0.6992	0.6992
TBtu Consumed	0.000	0.000	23.03	23.31	23.31
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.155	2.181	2.181
TWh Generated Qualifying	0.000	0.000	2.155	2.181	2.181
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDD BART Plant Specific NOX Constraint

Constraint #: 412

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.169	1.169	1.169
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.169	1.169	1.169
TBtu Consumed	0.000	0.000	38.97	38.97	38.97
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDE BART Plant Specific NOX Constraint

Constraint #: 413

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9373	1.001	1.001
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9373	1.001	1.001
TBtu Consumed	0.000	0.000	31.24	33.38	33.38
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.921	3.120	3.120
TWh Generated Qualifying	0.000	0.000	2.921	3.120	3.120
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDF BART Plant Specific NOX Constraint

Constraint #: 414

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.993	8.993	8.993
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.993	8.993	8.993
TBtu Consumed	0.000	0.000	373.6	373.6	373.6
Rate - [lb/MMBtu]	0.000	0.000	0.4815E-01	0.4815E-01	0.4815E-01
TWh Generated	0.000	0.000	37.72	37.72	37.72
TWh Generated Qualifying	0.000	0.000	37.72	37.72	37.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CEF BART Plant Specific NOX Constraint

Constraint #: 415

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.359	1.359	1.361
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.359	1.359	1.361
TBtu Consumed	0.000	0.000	13.59	13.59	13.61
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.289	1.289	1.291
TWh Generated Qualifying	0.000	0.000	1.289	1.289	1.291
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1035.	450.1	673.9

Constraint Name: CEG BART Plant Specific NOX Constraint

Constraint #: 416

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.576	1.576	1.576
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.576	1.576	1.576
TBtu Consumed	0.000	0.000	15.76	15.76	15.76
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.434	1.434	1.434
TWh Generated Qualifying	0.000	0.000	1.434	1.434	1.434
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	959.3	179.6	311.8

Constraint Name: CEI BART Plant Specific NOX Constraint

Constraint #: 417

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.044	7.044	7.044
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.044	7.044	7.044
TBtu Consumed	0.000	0.000	83.54	83.54	83.54
Rate - [lb/MMBtu]	0.000	0.000	0.1686	0.1686	0.1686
TWh Generated	0.000	0.000	7.633	7.633	7.633
TWh Generated Qualifying	0.000	0.000	7.633	7.633	7.633
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CEJ BART Plant Specific NOX Constraint

Constraint #: 418

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.776	5.776	5.776
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.776	5.776	5.776
TBtu Consumed	0.000	0.000	57.76	57.76	57.76
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.293	6.293	6.293
TWh Generated Qualifying	0.000	0.000	6.293	6.293	6.293
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2290.	1397.	0.000

Constraint Name: CEN BART Plant Specific NOX Constraint

Constraint #: 419

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.253	5.253	5.253
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.253	5.253	5.253
TBtu Consumed	0.000	0.000	52.53	52.53	52.53
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.159	5.159	5.159
TWh Generated Qualifying	0.000	0.000	5.159	5.159	5.159
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2239.	775.1	317.8

Constraint Name: CEO BART Plant Specific NOX Constraint

Constraint #: 420

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.255	1.255	1.264
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.255	1.255	1.264
TBtu Consumed	0.000	0.000	12.55	12.55	12.64
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.113	1.113	1.121
TWh Generated Qualifying	0.000	0.000	1.113	1.113	1.121
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	857.7	420.6	560.8

Constraint Name: CEQ BART Plant Specific NOX Constraint

Constraint #: 421

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.894	4.894	4.894
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.894	4.894	4.894
TBtu Consumed	0.000	0.000	48.94	48.94	48.94
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.127	4.127	4.127
TWh Generated Qualifying	0.000	0.000	4.127	4.127	4.127
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1831.	1402.	0.000

Constraint Name: CEX BART Plant Specific NOX Constraint

Constraint #: 422

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.263	4.263	4.263
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.263	4.263	4.263
TBtu Consumed	0.000	0.000	42.63	42.63	42.63
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.864	3.864	3.864
TWh Generated Qualifying	0.000	0.000	3.864	3.864	3.864
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3128.	3194.	0.5794E-21



Constraint Name: CEY BART Plant Specific NOX Constraint

Constraint #: 423

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.848	3.848	3.848
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.848	3.848	3.848
TBtu Consumed	0.000	0.000	40.94	40.94	40.94
Rate - [lb/MMBtu]	0.000	0.000	0.1880	0.1880	0.1880
TWh Generated	0.000	0.000	4.009	4.009	4.009
TWh Generated Qualifying	0.000	0.000	4.009	4.009	4.009
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CEZ BART Plant Specific NOX Constraint

Constraint #: 424

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.198	4.198	4.198
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.198	4.198	4.198
TBtu Consumed	0.000	0.000	41.98	41.98	41.98
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.816	3.816	3.816
TWh Generated Qualifying	0.000	0.000	3.816	3.816	3.816
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5277.	825.7	0.000

Constraint Name: CFA BART Plant Specific NOX Constraint

Constraint #: 425

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.394	8.394	8.394
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.394	8.394	8.394
TBtu Consumed	0.000	0.000	117.4	117.4	117.4
Rate - [lb/MMBtu]	0.000	0.000	0.1430	0.1430	0.1430
TWh Generated	0.000	0.000	11.19	11.19	11.19
TWh Generated Qualifying	0.000	0.000	11.19	11.19	11.19
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFB BART Plant Specific NOX Constraint

Constraint #: 426

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.703	5.703	5.703
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.703	5.703	5.703
TBtu Consumed	0.000	0.000	79.76	79.76	79.76
Rate - [lb/MMBtu]	0.000	0.000	0.1430	0.1430	0.1430
TWh Generated	0.000	0.000	7.310	7.310	7.310
TWh Generated Qualifying	0.000	0.000	7.310	7.310	7.310
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFC BART Plant Specific NOX Constraint

Constraint #: 427

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.293	2.293	2.293
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.293	2.293	2.293
TBtu Consumed	0.000	0.000	25.48	25.48	25.48
Rate - [lb/MMBtu]	0.000	0.000	0.1800	0.1800	0.1800
TWh Generated	0.000	0.000	2.446	2.446	2.446
TWh Generated Qualifying	0.000	0.000	2.446	2.446	2.446
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFD BART Plant Specific NOX Constraint

Constraint #: 428

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.818	1.818	1.818
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.818	1.818	1.818
TBtu Consumed	0.000	0.000	26.35	26.35	26.35
Rate - [lb/MMBtu]	0.000	0.000	0.1380	0.1380	0.1380
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFF BART Plant Specific NOX Constraint

Constraint #: 429

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.170	1.170	1.170
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.170	1.170	1.170
TBtu Consumed	0.000	0.000	38.99	38.99	38.99
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFG BART Plant Specific NOX Constraint

Constraint #: 430

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.341	1.341	1.341
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.341	1.341	1.341
TBtu Consumed	0.000	0.000	44.72	44.72	44.72
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.374	4.374	4.374
TWh Generated Qualifying	0.000	0.000	4.374	4.374	4.374
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CFO BART Plant Specific NOX Constraint

Constraint #: 431

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.969	3.969	3.969
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.969	3.969	3.969
TBtu Consumed	0.000	0.000	39.69	39.69	39.69
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.711	3.711	3.711
TWh Generated Qualifying	0.000	0.000	3.711	3.711	3.711
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2086.	351.2	739.2

Constraint Name: CFQ BART Plant Specific NOX Constraint

Constraint #: 432

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.216	2.269	2.216
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.216	2.269	2.216
TBtu Consumed	0.000	0.000	39.56	40.51	39.56
Rate - [lb/MMBtu]	0.000	0.000	0.1120	0.1120	0.1120
TWh Generated	0.000	0.000	3.755	3.845	3.755
TWh Generated Qualifying	0.000	0.000	3.755	3.845	3.755
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR BART Plant Specific NOX Constraint

Constraint #: 433

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8794	0.8794	0.8794
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8794	0.8794	0.8794
TBtu Consumed	0.000	0.000	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.000	0.000	0.6243E-01	0.6243E-01	0.6243E-01
TWh Generated	0.000	0.000	2.808	2.808	2.808
TWh Generated Qualifying	0.000	0.000	2.808	2.808	2.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFS BART Plant Specific NOX Constraint

Constraint #: 434

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.896	4.896	4.896
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.896	4.896	4.896
TBtu Consumed	0.000	0.000	48.96	48.96	48.96
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.081	5.081	5.081
TWh Generated Qualifying	0.000	0.000	5.081	5.081	5.081
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2232.	1185.	0.000

Constraint Name: CFY BART Plant Specific NOX Constraint

Constraint #: 435

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.254	9.254	9.254
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.254	9.254	9.254
TBtu Consumed	0.000	0.000	92.54	92.54	92.54
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	8.420	8.420	8.420
TWh Generated Qualifying	0.000	0.000	8.420	8.420	8.420
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3072.	1087.	1479.

Constraint Name: CFZ BART Plant Specific NOX Constraint

Constraint #: 436

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.688	6.688	6.688
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.688	6.688	6.688
TBtu Consumed	0.000	0.000	66.88	66.88	66.88
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.266	6.266	6.266
TWh Generated Qualifying	0.000	0.000	6.266	6.266	6.266
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4520.	825.7	1083.

Constraint Name: CGG BART Plant Specific NOX Constraint

Constraint #: 437

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.010	1.010	1.010
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.010	1.010	1.010
TBtu Consumed	0.000	0.000	10.10	10.10	10.10
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.9707	0.9707	0.9707
TWh Generated Qualifying	0.000	0.000	0.9707	0.9707	0.9707
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2797.	5504.	352.3

Constraint Name: CGI BART Plant Specific NOX Constraint

Constraint #: 438

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.961	1.972	1.972
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.961	1.972	1.972
TBtu Consumed	0.000	0.000	19.61	19.72	19.72
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.876	1.884	1.884
TWh Generated Qualifying	0.000	0.000	1.876	1.884	1.884
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1761.	3290.	426.3



Constraint Name: CGO BART Plant Specific NOX Constraint

Constraint #: 439

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.576	7.576	7.576
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.576	7.576	7.576
TBtu Consumed	0.000	0.000	226.1	226.1	226.1
Rate - [lb/MMBtu]	0.000	0.000	0.6700E-01	0.6700E-01	0.6700E-01
TWh Generated	0.000	0.000	21.14	21.14	21.14
TWh Generated Qualifying	0.000	0.000	21.14	21.14	21.14
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGR BART Plant Specific NOX Constraint

Constraint #: 440

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.520	1.520	1.520
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.520	1.520	1.520
TBtu Consumed	0.000	0.000	50.66	50.66	50.66
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.702	4.702	4.702
TWh Generated Qualifying	0.000	0.000	4.702	4.702	4.702
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGS BART Plant Specific NOX Constraint

Constraint #: 441

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7737	0.7743	0.7743
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7737	0.7743	0.7743
TBtu Consumed	0.000	0.000	25.79	25.81	25.81
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.358	2.359	2.359
TWh Generated Qualifying	0.000	0.000	2.358	2.359	2.359
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGV BART Plant Specific NOX Constraint

Constraint #: 442

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.064	1.066	1.066
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.064	1.066	1.066
TBtu Consumed	0.000	0.000	12.52	12.55	12.55
Rate - [lb/MMBtu]	0.000	0.000	0.1700	0.1700	0.1700
TWh Generated	0.000	0.000	1.213	1.215	1.215
TWh Generated Qualifying	0.000	0.000	1.213	1.215	1.215
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CGY BART Plant Specific NOX Constraint

Constraint #: 443

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.075	1.075	1.075
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.075	1.075	1.075
TBtu Consumed	0.000	0.000	27.59	27.59	27.59
Rate - [lb/MMBtu]	0.000	0.000	0.7793E-01	0.7793E-01	0.7793E-01
TWh Generated	0.000	0.000	2.611	2.611	2.611
TWh Generated Qualifying	0.000	0.000	2.611	2.611	2.611
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CHG BART Plant Specific NOX Constraint

Constraint #: 444

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.625	7.625	7.625
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.625	7.625	7.625
TBtu Consumed	0.000	0.000	76.25	76.25	76.25
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.623	7.623	7.623
TWh Generated Qualifying	0.000	0.000	7.623	7.623	7.623
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	124.3	62.70	0.000

Constraint Name: CHL BART Plant Specific NOX Constraint

Constraint #: 445

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.616	4.867	4.867
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.616	4.867	4.867
TBtu Consumed	0.000	0.000	46.16	48.67	48.67
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.405	4.644	4.644
TWh Generated Qualifying	0.000	0.000	4.405	4.644	4.644
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1867.	2628.	1043.

Constraint Name: CHM BART Plant Specific NOX Constraint

Constraint #: 446

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.512	4.512	4.512
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.512	4.512	4.512
TBtu Consumed	0.000	0.000	45.12	45.12	45.12
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.549	4.549	4.549
TWh Generated Qualifying	0.000	0.000	4.549	4.549	4.549
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4543.	2071.	744.9



Constraint Name: CHP BART Plant Specific NOX Constraint

Constraint #: 447

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.469	1.469	1.469
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.469	1.469	1.469
TBtu Consumed	0.000	0.000	48.98	48.98	48.98
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.709	4.709	4.709
TWh Generated Qualifying	0.000	0.000	4.709	4.709	4.709
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CHR BART Plant Specific NOX Constraint

Constraint #: 448

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1667E+05	0.1200E+05	9406.

Constraint Name: CHT BART Plant Specific NOX Constraint

Constraint #: 449

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.525	1.525	1.525
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.525	1.525	1.525
TBtu Consumed	0.000	0.000	22.43	22.43	22.43
Rate - [lb/MMBtu]	0.000	0.000	0.1360	0.1360	0.1360
TWh Generated	0.000	0.000	1.786	1.786	1.786
TWh Generated Qualifying	0.000	0.000	1.786	1.786	1.786
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CHU BART Plant Specific NOX Constraint

Constraint #: 450

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.502	2.502	2.502
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.502	2.502	2.502
TBtu Consumed	0.000	0.000	42.76	42.76	42.76
Rate - [lb/MMBtu]	0.000	0.000	0.1170	0.1170	0.1170
TWh Generated	0.000	0.000	4.026	4.026	4.026
TWh Generated Qualifying	0.000	0.000	4.026	4.026	4.026
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CHW BART Plant Specific NOX Constraint

Constraint #: 451

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.089	5.132	5.132
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.089	5.132	5.132
TBtu Consumed	0.000	0.000	50.89	51.32	51.32
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.826	4.867	4.867
TWh Generated Qualifying	0.000	0.000	4.826	4.867	4.867
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1371.	2579.	316.2

Constraint Name: CHX BART Plant Specific NOX Constraint

Constraint #: 452

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.894	7.987	7.987
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.894	7.987	7.987
TBtu Consumed	0.000	0.000	79.34	80.27	80.27
Rate - [lb/MMBtu]	0.000	0.000	0.1990	0.1990	0.1990
TWh Generated	0.000	0.000	6.976	7.058	7.058
TWh Generated Qualifying	0.000	0.000	6.976	7.058	7.058
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIG BART Plant Specific NOX Constraint

Constraint #: 453

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.417	4.417	4.417
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.417	4.417	4.417
TBtu Consumed	0.000	0.000	147.2	147.2	147.2
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	13.77	13.77	13.77
TWh Generated Qualifying	0.000	0.000	13.77	13.77	13.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIH BART Plant Specific NOX Constraint

Constraint #: 454

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5294	0.5350	0.5350
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5294	0.5350	0.5350
TBtu Consumed	0.000	0.000	17.65	17.83	17.83
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.615	1.632	1.632
TWh Generated Qualifying	0.000	0.000	1.615	1.632	1.632
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CII BART Plant Specific NOX Constraint

Constraint #: 455

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.431	6.587	6.388
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.431	6.587	6.388
TBtu Consumed	0.000	0.000	204.2	209.1	202.8
Rate - [lb/MMBtu]	0.000	0.000	0.6300E-01	0.6300E-01	0.6300E-01
TWh Generated	0.000	0.000	19.09	19.55	18.96
TWh Generated Qualifying	0.000	0.000	19.09	19.55	18.96
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CIK BART Plant Specific NOX Constraint

Constraint #: 456

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.050	4.050	4.050
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.050	4.050	4.050
TBtu Consumed	0.000	0.000	40.50	40.50	40.50
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.216	4.216	4.216
TWh Generated Qualifying	0.000	0.000	4.216	4.216	4.216
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1353E+05	0.1211E+05	6536.

Constraint Name: CIQ BART Plant Specific NOX Constraint

Constraint #: 457

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.575	2.575	2.575
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.575	2.575	2.575
TBtu Consumed	0.000	0.000	26.14	26.14	26.14
Rate - [lb/MMBtu]	0.000	0.000	0.1970	0.1970	0.1970
TWh Generated	0.000	0.000	2.639	2.639	2.639
TWh Generated Qualifying	0.000	0.000	2.639	2.639	2.639
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CJQ BART Plant Specific NOX Constraint

Constraint #: 458

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.8361	0.8361
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.8361	0.8361
TBtu Consumed	0.000	0.000	0.000	8.361	8.361
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.6790	0.6790
TWh Generated Qualifying	0.000	0.000	0.000	0.6790	0.6790
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	287.1	708.1	411.2

Constraint Name: CJZ BART Plant Specific NOX Constraint

Constraint #: 459

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7760	0.8309	0.8309
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7760	0.8309	0.8309
TBtu Consumed	0.000	0.000	7.760	8.309	8.309
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.7627	0.8167	0.8167
TWh Generated Qualifying	0.000	0.000	0.7627	0.8167	0.8167
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	653.1	498.1	498.5

Constraint Name: CKC BART Plant Specific NOX Constraint

Constraint #: 460

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.126	1.137	1.137
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.126	1.137	1.137
TBtu Consumed	0.000	0.000	11.26	11.37	11.37
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.9493	0.9588	0.9588
TWh Generated Qualifying	0.000	0.000	0.9493	0.9588	0.9588
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	660.8	1011.	53.01

Constraint Name: CKI BART Plant Specific NOX Constraint

Constraint #: 461

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.946	3.946	3.946
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.946	3.946	3.946
TBtu Consumed	0.000	0.000	39.46	39.46	39.46
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.996	3.996	3.996
TWh Generated Qualifying	0.000	0.000	3.996	3.996	3.996
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1093.	485.1	646.6

Constraint Name: CKL BART Plant Specific NOX Constraint

Constraint #: 462

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.868	1.872	1.872
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.868	1.872	1.872
TBtu Consumed	0.000	0.000	18.68	18.72	18.72
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.759	1.761	1.761
TWh Generated Qualifying	0.000	0.000	1.759	1.761	1.761
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	989.8	1750.	0.000



Constraint Name: CKP BART Plant Specific NOX Constraint

Constraint #: 463

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CKW BART Plant Specific NOX Constraint

Constraint #: 464

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.935	3.860	3.860
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.935	3.860	3.860
TBtu Consumed	0.000	0.000	39.35	38.60	38.60
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.678	3.609	3.609
TWh Generated Qualifying	0.000	0.000	3.678	3.609	3.609
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1692.	1548.	1538.

Constraint Name: CKX BART Plant Specific NOX Constraint

Constraint #: 465

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.596	6.464	6.464
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.596	6.464	6.464
TBtu Consumed	0.000	0.000	174.1	174.1	174.1
Rate - [lb/MMBtu]	0.000	0.000	0.9872E-01	0.7424E-01	0.7424E-01
TWh Generated	0.000	0.000	15.73	15.73	15.73
TWh Generated Qualifying	0.000	0.000	15.73	15.73	15.73
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLB BART Plant Specific NOX Constraint

Constraint #: 466

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9752	0.9752	0.9705
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9752	0.9752	0.9705
TBtu Consumed	0.000	0.000	31.97	31.97	31.82
Rate - [lb/MMBtu]	0.000	0.000	0.6100E-01	0.6100E-01	0.6100E-01
TWh Generated	0.000	0.000	2.993	2.993	2.978
TWh Generated Qualifying	0.000	0.000	2.993	2.993	2.978
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLC BART Plant Specific NOX Constraint

Constraint #: 467

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.788	3.788	3.592
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.788	3.788	3.592
TBtu Consumed	0.000	0.000	37.88	37.88	36.76
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.1954
TWh Generated	0.000	0.000	3.215	3.215	3.120
TWh Generated Qualifying	0.000	0.000	3.215	3.215	3.120
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1330.	0.000	0.000

Constraint Name: CLR BART Plant Specific NOX Constraint

Constraint #: 468

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8049	0.8049	0.8049
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8049	0.8049	0.8049
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.373	2.373	2.373
TWh Generated Qualifying	0.000	0.000	2.373	2.373	2.373
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLS BART Plant Specific NOX Constraint

Constraint #: 469

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.711	1.711	1.693
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.711	1.711	1.693
TBtu Consumed	0.000	0.000	55.20	55.20	55.10
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6145E-01
TWh Generated	0.000	0.000	5.237	5.237	5.228
TWh Generated Qualifying	0.000	0.000	5.237	5.237	5.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CLT BART Plant Specific NOX Constraint

Constraint #: 470

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5356	0.5356	0.5356
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5356	0.5356	0.5356
TBtu Consumed	0.000	0.000	17.28	17.28	17.28
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.581	1.581	1.581
TWh Generated Qualifying	0.000	0.000	1.581	1.581	1.581
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CLU BART Plant Specific NOX Constraint

Constraint #: 471

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.396	6.396	6.396
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.396	6.396	6.396
TBtu Consumed	0.000	0.000	63.96	63.96	63.96
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.984	6.984	6.984
TWh Generated Qualifying	0.000	0.000	6.984	6.984	6.984
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	458.7	339.1	236.1

Constraint Name: CMO BART Plant Specific NOX Constraint

Constraint #: 472

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.572	7.572	7.572
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.572	7.572	7.572
TBtu Consumed	0.000	0.000	77.66	77.66	77.66
Rate - [lb/MMBtu]	0.000	0.000	0.1950	0.1950	0.1950
TWh Generated	0.000	0.000	8.238	8.238	8.238
TWh Generated Qualifying	0.000	0.000	8.238	8.238	8.238
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CMP BART Plant Specific NOX Constraint

Constraint #: 473

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.296	7.296	6.636
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.296	7.296	6.636
TBtu Consumed	0.000	0.000	93.54	93.54	85.08
Rate - [lb/MMBtu]	0.000	0.000	0.1560	0.1560	0.1560
TWh Generated	0.000	0.000	8.383	8.383	7.625
TWh Generated Qualifying	0.000	0.000	8.383	8.383	7.625
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CMS BART Plant Specific NOX Constraint

Constraint #: 474

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.256	1.258	1.258
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.256	1.258	1.258
TBtu Consumed	0.000	0.000	12.56	12.58	12.58
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.221	1.223	1.223
TWh Generated Qualifying	0.000	0.000	1.221	1.223	1.223
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2187.	4140.	482.9

Constraint Name: CMT BART Plant Specific NOX Constraint

Constraint #: 475

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.651	5.796	5.796
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.651	5.796	5.796
TBTu Consumed	0.000	0.000	56.51	57.96	57.96
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.899	5.025	5.025
TWh Generated Qualifying	0.000	0.000	4.899	5.025	5.025
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	774.8	1213.	363.9

Constraint Name: CMU BART Plant Specific NOX Constraint

Constraint #: 476

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.765	1.765	1.765
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.765	1.765	1.765
TBtu Consumed	0.000	0.000	17.65	17.65	17.65
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.526	1.526	1.526
TWh Generated Qualifying	0.000	0.000	1.526	1.526	1.526
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3822.	1323.	2394.

Constraint Name: CMX BART Plant Specific NOX Constraint

Constraint #: 477

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.268	4.225	3.944
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.268	4.225	3.944
TBtu Consumed	0.000	0.000	142.3	140.8	131.5
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	13.35	13.21	12.33
TWh Generated Qualifying	0.000	0.000	13.35	13.21	12.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CMY BART Plant Specific NOX Constraint

Constraint #: 478

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.456	1.456	1.417
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.456	1.456	1.417
TBtu Consumed	0.000	0.000	48.53	48.53	47.24
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.374	4.374	4.258
TWh Generated Qualifying	0.000	0.000	4.374	4.374	4.258
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CNH BART Plant Specific NOX Constraint

Constraint #: 479

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.268	9.268	9.268
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.268	9.268	9.268
TBtu Consumed	0.000	0.000	96.54	96.54	96.54
Rate - [lb/MMBtu]	0.000	0.000	0.1920	0.1920	0.1920
TWh Generated	0.000	0.000	9.185	9.185	9.185
TWh Generated Qualifying	0.000	0.000	9.185	9.185	9.185
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNI BART Plant Specific NOX Constraint

Constraint #: 480

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.189	7.189	6.539
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.189	7.189	6.539
TBtu Consumed	0.000	0.000	90.43	90.43	82.25
Rate - [lb/MMBtu]	0.000	0.000	0.1590	0.1590	0.1590
TWh Generated	0.000	0.000	8.456	8.456	7.691
TWh Generated Qualifying	0.000	0.000	8.456	8.456	7.691
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNL BART Plant Specific NOX Constraint

Constraint #: 481

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6736	0.6736	0.6736
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6736	0.6736	0.6736
TBtu Consumed	0.000	0.000	21.73	21.73	21.73
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.154	2.154	2.154
TWh Generated Qualifying	0.000	0.000	2.154	2.154	2.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNM BART Plant Specific NOX Constraint

Constraint #: 482

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7202	0.7202	0.7202
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7202	0.7202	0.7202
TBtu Consumed	0.000	0.000	23.23	23.23	23.23
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.255	2.255	2.255
TWh Generated Qualifying	0.000	0.000	2.255	2.255	2.255
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNN BART Plant Specific NOX Constraint

Constraint #: 483

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.907	2.907	2.907
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.907	2.907	2.907
TBtu Consumed	0.000	0.000	39.55	39.55	39.55
Rate - [lb/MMBtu]	0.000	0.000	0.1470	0.1470	0.1470
TWh Generated	0.000	0.000	3.809	3.809	3.809
TWh Generated Qualifying	0.000	0.000	3.809	3.809	3.809
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNO BART Plant Specific NOX Constraint

Constraint #: 484

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.448	2.448	2.448
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.448	2.448	2.448
TBtu Consumed	0.000	0.000	40.80	40.80	40.80
Rate - [lb/MMBtu]	0.000	0.000	0.1200	0.1200	0.1200
TWh Generated	0.000	0.000	3.808	3.808	3.808
TWh Generated Qualifying	0.000	0.000	3.808	3.808	3.808
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNQ BART Plant Specific NOX Constraint

Constraint #: 485

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.913	4.995	4.995
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.913	4.995	4.995
TBtu Consumed	0.000	0.000	79.24	80.56	80.56
Rate - [lb/MMBtu]	0.000	0.000	0.1240	0.1240	0.1240
TWh Generated	0.000	0.000	7.254	7.375	7.375
TWh Generated Qualifying	0.000	0.000	7.254	7.375	7.375
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNR BART Plant Specific NOX Constraint

Constraint #: 486

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.299	2.477	2.477
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.299	2.477	2.477
TBtu Consumed	0.000	0.000	41.42	44.62	44.62
Rate - [lb/MMBtu]	0.000	0.000	0.1110	0.1110	0.1110
TWh Generated	0.000	0.000	3.918	4.221	4.221
TWh Generated Qualifying	0.000	0.000	3.918	4.221	4.221
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CNS BART Plant Specific NOX Constraint

Constraint #: 487

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.247	2.421	2.340
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.247	2.421	2.340
TBtu Consumed	0.000	0.000	43.22	46.56	45.00
Rate - [lb/MMBtu]	0.000	0.000	0.1040	0.1040	0.1040
TWh Generated	0.000	0.000	3.918	4.221	4.079
TWh Generated Qualifying	0.000	0.000	3.918	4.221	4.079
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CNW BART Plant Specific NOX Constraint

Constraint #: 488

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.2105E-01	0.2106E-01	0.6324E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.2105E-01	0.2106E-01	0.6324E-01
TBtu Consumed	0.000	0.000	2.105	2.106	6.324
Rate - [lb/MMBtu]	0.000	0.000	0.2000E-01	0.2000E-01	0.2000E-01
TWh Generated	0.000	0.000	0.2708	0.2708	0.8133
TWh Generated Qualifying	0.000	0.000	0.2708	0.2708	0.8133
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COB BART Plant Specific NOX Constraint

Constraint #: 489

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.135	6.135	6.135
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.135	6.135	6.135
TBtu Consumed	0.000	0.000	61.35	61.35	61.35
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.798	5.798	5.798
TWh Generated Qualifying	0.000	0.000	5.798	5.798	5.798
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1368.	1711.	1043.

Constraint Name: COC BART Plant Specific NOX Constraint

Constraint #: 490

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.221	5.221	5.221
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.221	5.221	5.221
TBtu Consumed	0.000	0.000	52.21	52.21	52.21
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.848	4.848	4.848
TWh Generated Qualifying	0.000	0.000	4.848	4.848	4.848
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3881.	2071.	0.000

Constraint Name: COE BART Plant Specific NOX Constraint

Constraint #: 491

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.322	5.554	5.554
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.322	5.554	5.554
TBtu Consumed	0.000	0.000	53.22	55.54	55.54
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.890	5.103	5.103
TWh Generated Qualifying	0.000	0.000	4.890	5.103	5.103
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1383.	2071.	772.6

Constraint Name: COF BART Plant Specific NOX Constraint

Constraint #: 492

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.385	3.436	3.436
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.385	3.436	3.436
TBtu Consumed	0.000	0.000	33.85	34.36	34.36
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.232	3.280	3.280
TWh Generated Qualifying	0.000	0.000	3.232	3.280	3.280
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	525.3	1071.	37.44

Constraint Name: COG BART Plant Specific NOX Constraint

Constraint #: 493

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.985	3.024	3.024
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.985	3.024	3.024
TBtu Consumed	0.000	0.000	29.85	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.695	2.730	2.730
TWh Generated Qualifying	0.000	0.000	2.695	2.730	2.730
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1329.	1992.	749.8

Constraint Name: COH BART Plant Specific NOX Constraint

Constraint #: 494

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.791	1.791	1.791
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.791	1.791	1.791
TBtu Consumed	0.000	0.000	17.91	17.91	17.91
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.707	1.707	1.707
TWh Generated Qualifying	0.000	0.000	1.707	1.707	1.707
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2942.	2975.	1003.



Constraint Name: COI BART Plant Specific NOX Constraint

Constraint #: 495

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	8.293	8.293	8.293
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	8.293	8.293	8.293
TBtu Consumed	0.000	0.000	82.93	82.93	82.93
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.712	7.712	7.712
TWh Generated Qualifying	0.000	0.000	7.712	7.712	7.712
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3775.	825.7	0.000

Constraint Name: COJ BART Plant Specific NOX Constraint

Constraint #: 496

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.606	3.606	3.606
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.606	3.606	3.606
TBtu Consumed	0.000	0.000	42.18	42.18	42.18
Rate - [lb/MMBtu]	0.000	0.000	0.1710	0.1710	0.1710
TWh Generated	0.000	0.000	3.856	3.856	3.856
TWh Generated Qualifying	0.000	0.000	3.856	3.856	3.856
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COK BART Plant Specific NOX Constraint

Constraint #: 497

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.779	1.779	1.779
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.779	1.779	1.779
TBtu Consumed	0.000	0.000	25.97	25.97	25.97
Rate - [lb/MMBtu]	0.000	0.000	0.1370	0.1370	0.1370
TWh Generated	0.000	0.000	2.527	2.527	2.527
TWh Generated Qualifying	0.000	0.000	2.527	2.527	2.527
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CON BART Plant Specific NOX Constraint

Constraint #: 498

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.279	1.279	1.279
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.279	1.279	1.279
TBtu Consumed	0.000	0.000	12.79	12.79	12.79
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.141	1.141	1.141
TWh Generated Qualifying	0.000	0.000	1.141	1.141	1.141
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4786.	2455.	0.000

Constraint Name: COP BART Plant Specific NOX Constraint

Constraint #: 499

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.564	6.564	6.564
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.564	6.564	6.564
TBtu Consumed	0.000	0.000	218.8	218.8	218.8
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	21.87	21.87	21.87
TWh Generated Qualifying	0.000	0.000	21.87	21.87	21.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COR BART Plant Specific NOX Constraint

Constraint #: 500

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.406	5.406	5.406
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.406	5.406	5.406
TBtu Consumed	0.000	0.000	168.9	168.9	168.9
Rate - [lb/MMBtu]	0.000	0.000	0.6400E-01	0.6400E-01	0.6400E-01
TWh Generated	0.000	0.000	16.93	16.93	16.93
TWh Generated Qualifying	0.000	0.000	16.93	16.93	16.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COS BART Plant Specific NOX Constraint

Constraint #: 501

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.474	1.474	1.474
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.474	1.474	1.474
TBtu Consumed	0.000	0.000	49.13	49.13	49.13
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	4.593	4.593	4.593
TWh Generated Qualifying	0.000	0.000	4.593	4.593	4.593
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COT BART Plant Specific NOX Constraint

Constraint #: 502

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.654	1.654	1.654
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.654	1.654	1.654
TBtu Consumed	0.000	0.000	55.13	55.13	55.13
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	5.154	5.154	5.154
TWh Generated Qualifying	0.000	0.000	5.154	5.154	5.154
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: COU BART Plant Specific NOX Constraint

Constraint #: 503

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.637	1.637	1.629
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.637	1.637	1.629
TBtu Consumed	0.000	0.000	54.56	54.56	54.30
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	5.110	5.110	5.085
TWh Generated Qualifying	0.000	0.000	5.110	5.110	5.085
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COV BART Plant Specific NOX Constraint

Constraint #: 504

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9168	0.9168	0.9168
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9168	0.9168	0.9168
TBtu Consumed	0.000	0.000	30.56	30.56	30.56
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.796	2.796	2.796
TWh Generated Qualifying	0.000	0.000	2.796	2.796	2.796
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPG BART Plant Specific NOX Constraint

Constraint #: 505

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.085	1.087	1.089
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.085	1.087	1.089
TBtu Consumed	0.000	0.000	10.85	10.87	10.89
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.099	1.101	1.103
TWh Generated Qualifying	0.000	0.000	1.099	1.101	1.103
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	742.0	534.0	549.5

Constraint Name: CPH BART Plant Specific NOX Constraint

Constraint #: 506

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	12.64	12.64	12.67
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	12.64	12.64	12.67
TBtu Consumed	0.000	0.000	126.4	126.4	126.7
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	12.68	12.68	12.72
TWh Generated Qualifying	0.000	0.000	12.68	12.68	12.72
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1974.	1806.	1794.

Constraint Name: CPM BART Plant Specific NOX Constraint

Constraint #: 507

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.492	4.492	4.492
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.492	4.492	4.492
TBtu Consumed	0.000	0.000	44.92	44.92	44.92
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.199	4.199	4.199
TWh Generated Qualifying	0.000	0.000	4.199	4.199	4.199
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	641.4	0.000	205.7

Constraint Name: CPN BART Plant Specific NOX Constraint

Constraint #: 508

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.926	2.940	2.940
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.926	2.940	2.940
TBtu Consumed	0.000	0.000	29.26	29.40	29.40
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.628	2.640	2.640
TWh Generated Qualifying	0.000	0.000	2.628	2.640	2.640
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1594.	2073.	849.0

Constraint Name: CPQ BART Plant Specific NOX Constraint

Constraint #: 509

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.092	4.092	4.092
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.092	4.092	4.092
TBtu Consumed	0.000	0.000	62.47	62.47	62.47
Rate - [lb/MMBtu]	0.000	0.000	0.1310	0.1310	0.1310
TWh Generated	0.000	0.000	5.913	5.913	5.913
TWh Generated Qualifying	0.000	0.000	5.913	5.913	5.913
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPR BART Plant Specific NOX Constraint

Constraint #: 510

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.260	4.260	3.874
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.260	4.260	3.874
TBtu Consumed	0.000	0.000	47.33	47.33	43.05
Rate - [lb/MMBtu]	0.000	0.000	0.1800	0.1800	0.1800
TWh Generated	0.000	0.000	4.607	4.607	4.190
TWh Generated Qualifying	0.000	0.000	4.607	4.607	4.190
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CQC BART Plant Specific NOX Constraint

Constraint #: 511

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.568	2.568	2.568
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.568	2.568	2.568
TBtu Consumed	0.000	0.000	25.68	25.68	25.68
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.480	2.480	2.480
TWh Generated Qualifying	0.000	0.000	2.480	2.480	2.480
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2120.	1078.	147.4

Constraint Name: CQD BART Plant Specific NOX Constraint

Constraint #: 512

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.693	2.693	2.693
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.693	2.693	2.693
TBtu Consumed	0.000	0.000	29.92	29.92	29.92
Rate - [lb/MMBtu]	0.000	0.000	0.1800	0.1800	0.1800
TWh Generated	0.000	0.000	2.916	2.916	2.916
TWh Generated Qualifying	0.000	0.000	2.916	2.916	2.916
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CQE BART Plant Specific NOX Constraint

Constraint #: 513

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.584	1.584	1.584
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.584	1.584	1.584
TBtu Consumed	0.000	0.000	25.35	25.35	25.35
Rate - [lb/MMBtu]	0.000	0.000	0.1250	0.1250	0.1250
TWh Generated	0.000	0.000	2.421	2.421	2.421
TWh Generated Qualifying	0.000	0.000	2.421	2.421	2.421
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CQF BART Plant Specific NOX Constraint

Constraint #: 514

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.762	1.762	1.762
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.762	1.762	1.762
TBtu Consumed	0.000	0.000	17.62	17.62	17.62
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.590	1.590	1.590
TWh Generated Qualifying	0.000	0.000	1.590	1.590	1.590
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1169.	1472.	944.3

Constraint Name: CQI BART Plant Specific NOX Constraint

Constraint #: 515

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.221	7.153	7.153
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.221	7.153	7.153
TBtu Consumed	0.000	0.000	102.9	106.2	106.2
Rate - [lb/MMBtu]	0.000	0.000	0.1209	0.1347	0.1347
TWh Generated	0.000	0.000	9.645	9.961	9.961
TWh Generated Qualifying	0.000	0.000	9.645	9.961	9.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CQJ BART Plant Specific NOX Constraint

Constraint #: 516

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.088	7.190	7.190
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.088	7.190	7.190
TBtu Consumed	0.000	0.000	82.90	84.10	84.10
Rate - [lb/MMBtu]	0.000	0.000	0.1710	0.1710	0.1710
TWh Generated	0.000	0.000	8.011	8.127	8.127
TWh Generated Qualifying	0.000	0.000	8.011	8.127	8.127
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CQK BART Plant Specific NOX Constraint

Constraint #: 517

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.109	2.109	2.109
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.109	2.109	2.109
TBtu Consumed	0.000	0.000	27.39	27.39	27.39
Rate - [lb/MMBtu]	0.000	0.000	0.1540	0.1540	0.1540
TWh Generated	0.000	0.000	2.690	2.690	2.690
TWh Generated Qualifying	0.000	0.000	2.690	2.690	2.690
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CRA BART Plant Specific NOX Constraint

Constraint #: 518

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.762	2.985	2.985
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.762	2.985	2.985
TBtu Consumed	0.000	0.000	27.62	29.85	29.85
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.526	2.730	2.730
TWh Generated Qualifying	0.000	0.000	2.526	2.730	2.730
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1092.	1059.	1012.



Constraint Name: CRF BART Plant Specific NOX Constraint

Constraint #: 519

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.613	1.613	1.497
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.613	1.613	1.497
TBtu Consumed	0.000	0.000	53.46	53.46	49.62
Rate - [lb/MMBtu]	0.000	0.000	0.6035E-01	0.6035E-01	0.6035E-01
TWh Generated	0.000	0.000	4.884	4.884	4.533
TWh Generated Qualifying	0.000	0.000	4.884	4.884	4.533
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CRK BART Plant Specific NOX Constraint

Constraint #: 520

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.162	5.162	5.162
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.162	5.162	5.162
TBtu Consumed	0.000	0.000	51.62	51.62	51.62
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.870	4.870	4.870
TWh Generated Qualifying	0.000	0.000	4.870	4.870	4.870
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3670.	2172.	648.4

Constraint Name: CRL BART Plant Specific NOX Constraint

Constraint #: 521

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.884	1.904	1.904
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.884	1.904	1.904
TBtu Consumed	0.000	0.000	23.27	23.51	23.51
Rate - [lb/MMBtu]	0.000	0.000	0.1620	0.1620	0.1620
TWh Generated	0.000	0.000	2.032	2.053	2.053
TWh Generated Qualifying	0.000	0.000	2.032	2.053	2.053
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CRZ BART Plant Specific NOX Constraint

Constraint #: 522

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.168	9.168	9.168
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.168	9.168	9.168
TBtu Consumed	0.000	0.000	305.6	305.6	305.6
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	32.36	32.36	32.36
TWh Generated Qualifying	0.000	0.000	32.36	32.36	32.36
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSA BART Plant Specific NOX Constraint

Constraint #: 523

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9861	0.9861	0.9861
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9861	0.9861	0.9861
TBtu Consumed	0.000	0.000	32.87	32.87	32.87
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.157	3.157	3.157
TWh Generated Qualifying	0.000	0.000	3.157	3.157	3.157
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSB BART Plant Specific NOX Constraint

Constraint #: 524

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.016	2.016	2.007
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.016	2.016	2.007
TBtu Consumed	0.000	0.000	67.21	67.21	66.88
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	6.643	6.643	6.611
TWh Generated Qualifying	0.000	0.000	6.643	6.643	6.611
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSC BART Plant Specific NOX Constraint

Constraint #: 525

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6317	0.6317	0.6286
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6317	0.6317	0.6286
TBtu Consumed	0.000	0.000	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.971	1.971	1.961
TWh Generated Qualifying	0.000	0.000	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSD BART Plant Specific NOX Constraint

Constraint #: 526

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6317	0.6317	0.6286
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6317	0.6317	0.6286
TBtu Consumed	0.000	0.000	21.06	21.06	20.95
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	1.971	1.971	1.961
TWh Generated Qualifying	0.000	0.000	1.971	1.971	1.961
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: CSE BART Plant Specific NOX Constraint

Constraint #: 527

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8188	0.8188	0.8149
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8188	0.8188	0.8149
TBtu Consumed	0.000	0.000	27.29	27.29	27.16
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.555	2.555	2.543
TWh Generated Qualifying	0.000	0.000	2.555	2.555	2.543
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSF BART Plant Specific NOX Constraint

Constraint #: 528

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.104	1.104	1.104
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.104	1.104	1.104
TBtu Consumed	0.000	0.000	36.78	36.78	36.78
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.365	3.365	3.365
TWh Generated Qualifying	0.000	0.000	3.365	3.365	3.365
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSI BART Plant Specific NOX Constraint

Constraint #: 529

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.078	2.078	2.078
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.078	2.078	2.078
TBtu Consumed	0.000	0.000	69.26	69.26	69.26
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	6.328	6.328	6.328
TWh Generated Qualifying	0.000	0.000	6.328	6.328	6.328
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSJ BART Plant Specific NOX Constraint

Constraint #: 530

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.549	1.549	1.549
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.549	1.549	1.549
TBtu Consumed	0.000	0.000	51.63	51.63	51.63
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	5.271	5.271	5.271
TWh Generated Qualifying	0.000	0.000	5.271	5.271	5.271
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSK BART Plant Specific NOX Constraint

Constraint #: 531

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.810	1.810	1.810
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.810	1.810	1.810
TBtu Consumed	0.000	0.000	60.34	60.34	60.34
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	6.277	6.277	6.277
TWh Generated Qualifying	0.000	0.000	6.277	6.277	6.277
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSL BART Plant Specific NOX Constraint

Constraint #: 532

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.861	2.861	2.861
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.861	2.861	2.861
TBtu Consumed	0.000	0.000	95.37	95.37	95.37
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	8.916	8.916	8.916
TWh Generated Qualifying	0.000	0.000	8.916	8.916	8.916
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CSO BART Plant Specific NOX Constraint

Constraint #: 533

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.187	9.332	9.349
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.187	9.332	9.349
TBtu Consumed	0.000	0.000	91.87	93.32	93.49
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	10.59	10.74	10.76
TWh Generated Qualifying	0.000	0.000	10.59	10.74	10.76
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1129E+05	8229.	7040.

Constraint Name: CSP BART Plant Specific NOX Constraint

Constraint #: 534

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.970	6.500	6.500
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.970	6.500	6.500
TBtu Consumed	0.000	0.000	49.70	65.00	65.00
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.157	6.744	6.744
TWh Generated Qualifying	0.000	0.000	5.157	6.744	6.744
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.1502E+05	0.1032E+05	8981.



Constraint Name: CTH BART Plant Specific NOX Constraint

Constraint #: 535

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.772	9.772	9.772
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.772	9.772	9.772
TBtu Consumed	0.000	0.000	97.72	97.72	97.72
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	9.528	9.528	9.528
TWh Generated Qualifying	0.000	0.000	9.528	9.528	9.528
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1093.	477.0	0.000

Constraint Name: CTP BART Plant Specific NOX Constraint

Constraint #: 536

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.199	2.199	2.199
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.199	2.199	2.199
TBtu Consumed	0.000	0.000	21.99	21.99	21.99
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.133	2.133	2.133
TWh Generated Qualifying	0.000	0.000	2.133	2.133	2.133
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	116.9	17.46	0.000

Constraint Name: CTQ BART Plant Specific NOX Constraint

Constraint #: 537

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.302	7.302	7.302
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.302	7.302	7.302
TBtu Consumed	0.000	0.000	73.02	73.02	73.02
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.228	7.228	7.228
TWh Generated Qualifying	0.000	0.000	7.228	7.228	7.228
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	233.8	47.96	13.38

Constraint Name: CTZ BART Plant Specific NOX Constraint

Constraint #: 538

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	10.54	10.56	10.56
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	10.54	10.56	10.56
TBtu Consumed	0.000	0.000	105.4	105.6	105.6
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	10.59	10.60	10.60
TWh Generated Qualifying	0.000	0.000	10.59	10.60	10.60
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	560.9	822.9	5.208

Constraint Name: CUD BART Plant Specific NOX Constraint

Constraint #: 539

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.410	2.410	2.410
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.410	2.410	2.410
TBtu Consumed	0.000	0.000	80.32	80.32	80.32
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	8.486	8.486	8.486
TWh Generated Qualifying	0.000	0.000	8.486	8.486	8.486
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CUE BART Plant Specific NOX Constraint

Constraint #: 540

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.223	1.223	1.223
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.223	1.223	1.223
TBtu Consumed	0.000	0.000	28.11	28.11	28.11
Rate - [lb/MMBtu]	0.000	0.000	0.8700E-01	0.8700E-01	0.8700E-01
TWh Generated	0.000	0.000	2.775	2.775	2.775
TWh Generated Qualifying	0.000	0.000	2.775	2.775	2.775
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CUQ BART Plant Specific NOX Constraint

Constraint #: 541

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.676	2.676	2.676
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.676	2.676	2.676
TBtu Consumed	0.000	0.000	26.76	26.76	26.76
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.661	2.661	2.661
TWh Generated Qualifying	0.000	0.000	2.661	2.661	2.661
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2373.	0.000	0.000

Constraint Name: CUT BART Plant Specific NOX Constraint

Constraint #: 542

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.316	4.316	4.316
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.316	4.316	4.316
TBtu Consumed	0.000	0.000	43.16	43.16	43.16
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.160	4.160	4.160
TWh Generated Qualifying	0.000	0.000	4.160	4.160	4.160
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1801.	175.1	0.000



Constraint Name: CUV BART Plant Specific NOX Constraint

Constraint #: 543

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.213	1.213	1.158
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.213	1.213	1.158
TBtu Consumed	0.000	0.000	12.13	12.13	11.90
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.1946
TWh Generated	0.000	0.000	1.103	1.103	1.081
TWh Generated Qualifying	0.000	0.000	1.103	1.103	1.081
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	650.7	65.59	0.000

Constraint Name: CVA BART Plant Specific NOX Constraint

Constraint #: 544

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.439	6.378	6.439
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.439	6.378	6.439
TBtu Consumed	0.000	0.000	64.39	64.15	64.39
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.1989	0.2000
TWh Generated	0.000	0.000	6.291	6.260	6.283
TWh Generated Qualifying	0.000	0.000	6.291	6.260	6.283
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	205.9	0.000	0.000

Constraint Name: CVD BART Plant Specific NOX Constraint

Constraint #: 545

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	20.10	19.83	20.10
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	20.10	19.83	20.10
TBtu Consumed	0.000	0.000	201.0	199.8	201.0
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.1985	0.2000
TWh Generated	0.000	0.000	19.95	19.83	19.95
TWh Generated Qualifying	0.000	0.000	19.95	19.83	19.95
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	621.3	0.000	211.1

Constraint Name: CVE BART Plant Specific NOX Constraint

Constraint #: 546

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.629	3.629	3.794
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.629	3.629	3.794
TBtu Consumed	0.000	0.000	36.29	36.29	37.94
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.206	3.206	3.351
TWh Generated Qualifying	0.000	0.000	3.206	3.206	3.351
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	992.7	710.6	763.3

Constraint Name: CVP BART Plant Specific NOX Constraint

Constraint #: 547

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.978	1.989	1.989
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.978	1.989	1.989
TBtu Consumed	0.000	0.000	26.92	27.06	27.06
Rate - [lb/MMBtu]	0.000	0.000	0.1470	0.1470	0.1470
TWh Generated	0.000	0.000	2.532	2.545	2.545
TWh Generated Qualifying	0.000	0.000	2.532	2.545	2.545
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CVQ BART Plant Specific NOX Constraint

Constraint #: 548

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8321	0.8321	0.8321
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8321	0.8321	0.8321
TBtu Consumed	0.000	0.000	27.74	27.74	27.74
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	2.632	2.632	2.632
TWh Generated Qualifying	0.000	0.000	2.632	2.632	2.632
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CVU BART Plant Specific NOX Constraint

Constraint #: 549

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.060	3.196	3.196
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.060	3.196	3.196
TBtu Consumed	0.000	0.000	30.60	31.96	31.96
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.561	2.675	2.675
TWh Generated Qualifying	0.000	0.000	2.561	2.675	2.675
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	398.5	350.6	97.11

Constraint Name: CVV BART Plant Specific NOX Constraint

Constraint #: 550

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	6.270	6.454	6.126
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	6.270	6.454	6.126
TBtu Consumed	0.000	0.000	62.70	64.54	63.10
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.1942
TWh Generated	0.000	0.000	6.718	6.916	6.761
TWh Generated Qualifying	0.000	0.000	6.718	6.916	6.761
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	212.3	302.6	0.000



Constraint Name: CVW BART Plant Specific NOX Constraint

Constraint #: 551

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	9.179	9.889	9.889
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	9.179	9.889	9.889
TBtu Consumed	0.000	0.000	165.4	178.2	178.2
Rate - [lb/MMBtu]	0.000	0.000	0.1110	0.1110	0.1110
TWh Generated	0.000	0.000	15.56	16.77	16.77
TWh Generated Qualifying	0.000	0.000	15.56	16.77	16.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWC BART Plant Specific NOX Constraint

Constraint #: 552

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9964	1.018	1.018
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9964	1.018	1.018
TBtu Consumed	0.000	0.000	9.964	10.18	10.18
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	0.9584	0.9794	0.9794
TWh Generated Qualifying	0.000	0.000	0.9584	0.9794	0.9794
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1166.	1173.	1160.

Constraint Name: CWN BART Plant Specific NOX Constraint

Constraint #: 553

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	13.42	13.42	13.42
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	13.42	13.42	13.42
TBtu Consumed	0.000	0.000	134.2	134.2	134.2
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	13.18	13.18	13.18
TWh Generated Qualifying	0.000	0.000	13.18	13.18	13.18
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2165.	1627.	211.7

Constraint Name: CWU BART Plant Specific NOX Constraint

Constraint #: 554

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.915	1.915	1.777
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.915	1.915	1.777
TBtu Consumed	0.000	0.000	63.83	63.83	59.24
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	5.832	5.832	5.413
TWh Generated Qualifying	0.000	0.000	5.832	5.832	5.413
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWV BART Plant Specific NOX Constraint

Constraint #: 555

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.389	1.389	1.389
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.389	1.389	1.389
TBtu Consumed	0.000	0.000	40.27	40.27	40.27
Rate - [lb/MMBtu]	0.000	0.000	0.6900E-01	0.6900E-01	0.6900E-01
TWh Generated	0.000	0.000	4.192	4.192	4.192
TWh Generated Qualifying	0.000	0.000	4.192	4.192	4.192
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWW BART Plant Specific NOX Constraint

Constraint #: 556

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.115	1.115	1.115
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.115	1.115	1.115
TBtu Consumed	0.000	0.000	37.18	37.18	37.18
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.477	3.477	3.477
TWh Generated Qualifying	0.000	0.000	3.477	3.477	3.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CWY BART Plant Specific NOX Constraint

Constraint #: 557

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.031	3.031	3.031
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.031	3.031	3.031
TBtu Consumed	0.000	0.000	30.31	30.31	30.31
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.182	3.182	3.182
TWh Generated Qualifying	0.000	0.000	3.182	3.182	3.182
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4002.	2380.	2731.

Constraint Name: CXJ BART Plant Specific NOX Constraint

Constraint #: 558

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.784	5.878	5.878
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.784	5.878	5.878
TBtu Consumed	0.000	0.000	57.84	58.78	58.78
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	5.693	5.784	5.784
TWh Generated Qualifying	0.000	0.000	5.693	5.784	5.784
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	618.4	715.2	207.1



Constraint Name: CXN BART Plant Specific NOX Constraint

Constraint #: 559

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.797	1.797	1.797
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.797	1.797	1.797
TBtu Consumed	0.000	0.000	17.97	17.97	17.97
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	1.832	1.832	1.832
TWh Generated Qualifying	0.000	0.000	1.832	1.832	1.832
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	456.5	308.0	29.04

Constraint Name: CXO BART Plant Specific NOX Constraint

Constraint #: 560

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	7.344	7.462	7.462
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	7.344	7.462	7.462
TBtu Consumed	0.000	0.000	73.44	74.62	74.62
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	7.137	7.252	7.252
TWh Generated Qualifying	0.000	0.000	7.137	7.252	7.252
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	701.5	934.1	171.5

Constraint Name: CXZ BART Plant Specific NOX Constraint

Constraint #: 561

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.021	5.133	5.133
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.021	5.133	5.133
TBtu Consumed	0.000	0.000	66.14	67.61	67.61
Rate - [lb/MMBtu]	0.000	0.000	0.1518	0.1518	0.1518
TWh Generated	0.000	0.000	6.663	6.811	6.811
TWh Generated Qualifying	0.000	0.000	6.663	6.811	6.811
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CYO BART Plant Specific NOX Constraint

Constraint #: 562

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.642	2.642	2.642
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.642	2.642	2.642
TBtu Consumed	0.000	0.000	26.42	26.42	26.42
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	2.559	2.559	2.559
TWh Generated Qualifying	0.000	0.000	2.559	2.559	2.559
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	2877.	1898.	0.000

Constraint Name: CY Y BART Plant Specific NOX Constraint

Constraint #: 563

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6930	0.6930	0.6930
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6930	0.6930	0.6930
TBtu Consumed	0.000	0.000	21.32	21.32	21.32
Rate - [lb/MMBtu]	0.000	0.000	0.6500E-01	0.6500E-01	0.6500E-01
TWh Generated	0.000	0.000	2.192	2.192	2.192
TWh Generated Qualifying	0.000	0.000	2.192	2.192	2.192
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZE BART Plant Specific NOX Constraint

Constraint #: 564

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	26.40	26.40	26.40
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	26.40	26.40	26.40
TBtu Consumed	0.000	0.000	268.1	268.1	268.1
Rate - [lb/MMBtu]	0.000	0.000	0.1970	0.1970	0.1970
TWh Generated	0.000	0.000	24.33	24.33	24.33
TWh Generated Qualifying	0.000	0.000	24.33	24.33	24.33
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZF BART Plant Specific NOX Constraint

Constraint #: 565

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.402	3.410	3.298
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.402	3.410	3.298
TBtu Consumed	0.000	0.000	34.02	34.10	33.66
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.1960
TWh Generated	0.000	0.000	3.251	3.258	3.217
TWh Generated Qualifying	0.000	0.000	3.251	3.258	3.217
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	66.52	106.4	0.000

Constraint Name: CZH BART Plant Specific NOX Constraint

Constraint #: 566

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.728	4.916	4.916
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.728	4.916	4.916
TBTu Consumed	0.000	0.000	47.28	49.16	49.16
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.698	4.884	4.884
TWh Generated Qualifying	0.000	0.000	4.698	4.884	4.884
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	590.5	415.6	404.1



Constraint Name: CZI BART Plant Specific NOX Constraint

Constraint #: 567

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.552	3.552	3.552
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.552	3.552	3.552
TBtu Consumed	0.000	0.000	35.88	35.88	35.88
Rate - [lb/MMBtu]	0.000	0.000	0.1980	0.1980	0.1980
TWh Generated	0.000	0.000	3.505	3.505	3.505
TWh Generated Qualifying	0.000	0.000	3.505	3.505	3.505
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZJ BART Plant Specific NOX Constraint

Constraint #: 568

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.237	1.237	1.237
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.237	1.237	1.237
TBtu Consumed	0.000	0.000	36.94	36.94	36.94
Rate - [lb/MMBtu]	0.000	0.000	0.6700E-01	0.6700E-01	0.6700E-01
TWh Generated	0.000	0.000	3.400	3.400	3.400
TWh Generated Qualifying	0.000	0.000	3.400	3.400	3.400
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZL BART Plant Specific NOX Constraint

Constraint #: 569

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.339	2.351	2.339
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.339	2.351	2.339
TBtu Consumed	0.000	0.000	77.97	78.36	77.97
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	7.990	8.031	7.990
TWh Generated Qualifying	0.000	0.000	7.990	8.031	7.990
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZN BART Plant Specific NOX Constraint

Constraint #: 570

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.452	2.452	2.452
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.452	2.452	2.452
TBtu Consumed	0.000	0.000	70.07	70.07	70.07
Rate - [lb/MMBtu]	0.000	0.000	0.7000E-01	0.7000E-01	0.7000E-01
TWh Generated	0.000	0.000	6.561	6.561	6.561
TWh Generated Qualifying	0.000	0.000	6.561	6.561	6.561
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZO BART Plant Specific NOX Constraint

Constraint #: 571

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.429	5.429	5.429
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.429	5.429	5.429
TBtu Consumed	0.000	0.000	87.56	87.56	87.56
Rate - [lb/MMBtu]	0.000	0.000	0.1240	0.1240	0.1240
TWh Generated	0.000	0.000	8.456	8.456	8.456
TWh Generated Qualifying	0.000	0.000	8.456	8.456	8.456
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZP BART Plant Specific NOX Constraint

Constraint #: 572

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.378	3.378	3.378
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.378	3.378	3.378
TBtu Consumed	0.000	0.000	40.70	40.70	40.70
Rate - [lb/MMBtu]	0.000	0.000	0.1660	0.1660	0.1660
TWh Generated	0.000	0.000	4.336	4.336	4.336
TWh Generated Qualifying	0.000	0.000	4.336	4.336	4.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CZX BART Plant Specific NOX Constraint

Constraint #: 573

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.700	3.700	3.700
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.700	3.700	3.700
TBtu Consumed	0.000	0.000	37.00	37.00	37.00
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.645	3.645	3.645
TWh Generated Qualifying	0.000	0.000	3.645	3.645	3.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	651.0	193.3	345.1

Constraint Name: DAA BART Plant Specific NOX Constraint

Constraint #: 574

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.110	1.138	1.138
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.110	1.138	1.138
TBtu Consumed	0.000	0.000	36.99	37.93	37.93
Rate - [lb/MMBtu]	0.000	0.000	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	0.000	3.047	3.124	3.124
TWh Generated Qualifying	0.000	0.000	3.047	3.124	3.124
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000



Constraint Name: DAB BART Plant Specific NOX Constraint

Constraint #: 575

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	3.900	3.947	3.947
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	3.900	3.947	3.947
TBtu Consumed	0.000	0.000	39.00	39.47	39.47
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	3.379	3.420	3.420
TWh Generated Qualifying	0.000	0.000	3.379	3.420	3.420
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1176.	1303.	739.2

Constraint Name: DAC BART Plant Specific NOX Constraint

Constraint #: 576

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	4.882	4.984	4.984
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	4.882	4.984	4.984
TBtu Consumed	0.000	0.000	48.82	49.84	49.84
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	4.610	4.708	4.708
TWh Generated Qualifying	0.000	0.000	4.610	4.708	4.708
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	688.7	588.2	449.5

Constraint Name: DAR BART Plant Specific NOX Constraint

Constraint #: 577

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	1.292	1.304	1.304
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.292	1.304	1.304
TBtu Consumed	0.000	0.000	16.14	16.30	16.30
Rate - [lb/MMBtu]	0.000	0.000	0.1600	0.1600	0.1600
TWh Generated	0.000	0.000	1.516	1.531	1.531
TWh Generated Qualifying	0.000	0.000	1.516	1.531	1.531
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: DAS BART Plant Specific NOX Constraint

Constraint #: 578

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	2.397	2.460	2.460
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	2.397	2.460	2.460
TBtu Consumed	0.000	0.000	27.55	28.28	28.28
Rate - [lb/MMBtu]	0.000	0.000	0.1740	0.1740	0.1740
TWh Generated	0.000	0.000	2.450	2.515	2.515
TWh Generated Qualifying	0.000	0.000	2.450	2.515	2.515
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: DAT BART Plant Specific NOX Constraint

Constraint #: 579

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	1.236	1.236
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	1.236	1.236
TBtu Consumed	0.000	0.000	0.000	12.36	12.36
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2000	0.2000
TWh Generated	0.000	0.000	0.000	0.9922	0.9922
TWh Generated Qualifying	0.000	0.000	0.000	0.9922	0.9922
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1523.	1345.	1358.

Constraint Name: DAZ BART Plant Specific NOX Constraint

Constraint #: 580

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	5.753	5.753	5.753
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	5.753	5.753	5.753
TBtu Consumed	0.000	0.000	57.53	57.53	57.53
Rate - [lb/MMBtu]	0.000	0.000	0.2000	0.2000	0.2000
TWh Generated	0.000	0.000	6.073	6.073	6.073
TWh Generated Qualifying	0.000	0.000	6.073	6.073	6.073
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4228.	2265.	0.000

Constraint Name: DBE BART Plant Specific NOX Constraint

Constraint #: 581

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.9713	0.9713	0.9713
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.9713	0.9713	0.9713
TBtu Consumed	0.000	0.000	28.57	28.57	28.57
Rate - [lb/MMBtu]	0.000	0.000	0.6800E-01	0.6800E-01	0.6800E-01
TWh Generated	0.000	0.000	2.829	2.829	2.829
TWh Generated Qualifying	0.000	0.000	2.829	2.829	2.829
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: DBF BART Plant Specific NOX Constraint

Constraint #: 582

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2007 WINTER SUMMER

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	10.00	10.00	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6692	0.6692	0.6692
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6692	0.6692	0.6692
TBtu Consumed	0.000	0.000	17.38	17.38	17.38
Rate - [lb/MMBtu]	0.000	0.000	0.7700E-01	0.7700E-01	0.7700E-01
TWh Generated	0.000	0.000	1.528	1.528	1.528
TWh Generated Qualifying	0.000	0.000	1.528	1.528	1.528
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000