

NOTES:

1. Year 2026 is the End-Year and should not be used for analysis.

	2007	2010	2015	2020	2026
1. Reserve Margin Capacity WINTER [MW]	921132.	932160.	994991.	1075190.	1182823.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In WINTER [MW]	4657.	7609.	5438.	5037.	8220.
Total R.M. Capacity WINTER [MW]	925789.	939769.	1000429.	1080227.	1191043.
2. Peak Load WINTER [MW]	668845.	709399.	768917.	832230.	912422.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out WINTER [MW]	4752.	7764.	5549.	5140.	8387.
Net Demand WINTER [MW]	673596.	717163.	774466.	837369.	920810.
3. Reserve Margin WINTER [%]	38.	31.	29.	29.	30.
1. Reserve Margin Capacity SUMMER [MW]	921132.	932160.	994991.	1075190.	1182823.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In SUMMER [MW]	28320.	35440.	38340.	32036.	33796.
Total R.M. Capacity SUMMER [MW]	949452.	967600.	1033331.	1107226.	1216619.
2. Peak Load SUMMER [MW]	746704.	793420.	861345.	933543.	1025275.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out SUMMER [MW]	28898.	36163.	39122.	32689.	34486.
Net Demand SUMMER [MW]	775602.	829584.	900467.	966232.	1059761.
3. Reserve Margin SUMMER [%]	23.	17.	15.	15.	15.
4. Generation [GWh]	4143657.	4369148.	4739212.	5144837.	5654184.
Inter-Region Transmission [GWh]	-12044.	-11972.	-10165.	-10024.	-10739.
Pumping & Storage Losses [GWh]	32251.	27337.	24945.	31369.	35773.
Plus Purchases [GWh]	0.	0.	0.	0.	0.
Less Sales [GWh]	0.	0.	0.	0.	0.
5. Total Supply for Demand [GWh]	4099362.	4329840.	4704102.	5103444.	5607673.
6. Projected Demand [GWh]	4099362.	4329840.	4704102.	5103444.	5607673.
Energy Not Served [GWh]	0.	0.	0.	0.	0.
Less DSM [GWh]	0.	0.	0.	0.	0.
Net Demand [GWh]	4099362.	4329840.	4704102.	5103444.	5607673.
7. Dumped Energy [GWh]	0.	0.	0.	0.	0.
8. Total Supply for Demand [GWh]	4099362.	4329840.	4704102.	5103444.	5607673.
Less T&D Losses [GWh]	314957.	332665.	361420.	392102.	430842.
9. Total Sales [GWh]	3784405.	3997175.	4342682.	4711342.	5176831.
Capacity Avoided Costs [US\$/kW]	2007	2010	2015	2020	2026
ANNUAL	0.00	0.00	0.00	0.00	0.00
WINTER	0.00	0.00	0.00	0.00	0.00
SUMMER	2.30	1.89	34.04	34.69	33.20

10. Capacity by Plant Type [MW]		2007	2010	2015	2020	2026

Scrubbed Coal_SCR	1	30480.	32684.	75053.	103629.	159445.
Scrubbed Coal_SNCR	2	2280.	2280.	2280.	2280.	2280.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	62121.	60473.	58643.	58643.	58643.
Unscrubbed Coal_SCR	5	51360.	49878.	47629.	47629.	47625.
Unscrubbed Coal_SNCR	6	7457.	7297.	7297.	7297.	7262.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	112691.	106426.	101409.	100285.	98503.
Oil/Gas Steam	9	85698.	82808.	82808.	82465.	81578.
Oil/Gas Steam_SCR	10	9372.	5588.	5588.	5588.	5588.
Oil/Gas Steam_NOx	11	544.	317.	317.	317.	166.
Nuclear	12	100221.	100571.	102123.	102603.	102603.
Hydro	13	89877.	89877.	89877.	89877.	89877.
Comb.Cycle Gas	14	147149.	147404.	157737.	167495.	172574.
IGCC	15	612.	612.	9455.	36666.	64574.
Combustion Turbine	16	130226.	129973.	129409.	143970.	165466.
Biomass	17	1358.	1456.	1456.	1456.	1456.
Geothermal	18	3165.	3289.	3399.	3399.	3399.
Landfill Gas	19	796.	828.	1075.	1075.	1075.
Wind	20	6896.	7218.	7297.	7297.	7330.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	449.	465.	494.	494.	494.
Non Fossil_Other	23	2173.	2207.	2207.	2207.	2207.
Fossil_Other	24	566.	566.	566.	566.	566.
Pump Storage	25	19766.	19766.	19766.	19766.	19766.
Int. Imports	26	9000.	9000.	9000.	9000.	9000.
Cgn_CT	27	5542.	5542.	5542.	5542.	5542.
Cgn_CC	28	17871.	17836.	17833.	17813.	16723.
Cgn_Oil/Gas Steam	29	572.	551.	551.	551.	35.
Cgn_Biomass	30	366.	366.	366.	366.	366.
Cgn_Fossil_Other	31	361.	361.	361.	361.	361.
Cgn_NonFossil_Other	32	314.	314.	314.	314.	314.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	915.	915.	915.
Rep.O/G-CC	35	0.	14124.	14124.	14124.	14124.
Rep.Coal-IGCC	36	0.	125.	125.	125.	125.
Ret.Scrubber	37	1530.	2428.	2431.	3531.	3531.
Ret.ExistSCR & Scrub	38	2727.	4179.	6380.	6380.	6384.
Ret.ExistSNCR & Scrub	39	502.	659.	659.	659.	659.
Ret.SCR	40	19389.	21523.	22975.	22975.	22975.
Ret.ExistScrub & SCR	41	3506.	4770.	6600.	6600.	6600.
Ret.SNCR	42	6018.	7471.	8706.	8706.	10488.
Ret.ExistScrub & SNCR	43	688.	877.	877.	877.	877.
Ret.SCR+Scrb	44	3241.	4367.	6646.	6646.	6646.
Ret.SNCR+Scrub	45	0.	0.	0.	0.	0.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	82.	82.	82.	82.
Ret.ExistScrub&ACI	50	0.	195.	195.	195.	195.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	86.	86.	86.	86.	86.
Ret.O/G SNCR	66	982.	1448.	1448.	1448.	1448.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2323.	2576.	3140.	3140.	3140.
CC Early Retirement	71	865.	1070.	1566.	1586.	3129.
O/G Early Retirement	72	30010.	31155.	31155.	31498.	33053.
Coal Early Retirement	73	8.	8.	8.	8.	44.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
-----		-----				
Total		971158.	984012.	1047971.	1128533.	1239318.

11. Capacity Additions and Changes
by Plant Type [MW]

		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	0.	1414.	42369.	28577.	55816.
Scrubbed Coal_SNCR	2	0.	0.	0.	0.	0.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	0.	0.	0.	0.	0.
Unscrubbed Coal_SCR	5	0.	0.	0.	0.	0.
Unscrubbed Coal_SNCR	6	0.	0.	0.	0.	0.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	0.	0.	0.	0.	0.
Oil/Gas Steam	9	0.	0.	0.	0.	0.
Oil/Gas Steam_SCR	10	0.	0.	0.	0.	0.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	0.	0.	0.	0.	0.
Hydro	13	0.	0.	0.	0.	0.
Comb.Cycle Gas	14	0.	425.	10826.	9758.	5532.
IGCC	15	0.	0.	8843.	27211.	27908.
Combustion Turbine	16	0.	0.	0.	14561.	21496.
Biomass	17	0.	0.	0.	0.	0.
Geothermal	18	0.	0.	0.	0.	0.
Landfill Gas	19	247.	0.	247.	0.	0.
Wind	20	0.	0.	19.	0.	34.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	0.	0.	0.	0.	0.
Non Fossil_Other	23	0.	0.	0.	0.	0.
Fossil_Other	24	0.	0.	0.	0.	0.
Pump Storage	25	0.	0.	0.	0.	0.
Int. Imports	26	0.	0.	0.	0.	0.
Cgn_CT	27	0.	0.	0.	0.	0.
Cgn_CC	28	0.	0.	0.	0.	0.
Cgn_Oil/Gas Steam	29	0.	0.	0.	0.	0.
Cgn_Biomass	30	0.	0.	0.	0.	0.
Cgn_Fossil_Other	31	0.	0.	0.	0.	0.
Cgn_NonFossil_Other	32	0.	0.	0.	0.	0.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	915.	0.	0.	0.
Rep.O/G-CC	35	0.	14124.	0.	0.	0.
Rep.Coal-IGCC	36	0.	125.	0.	0.	0.
Ret.Scrubber	37	1530.	2015.	482.	1100.	0.
Ret.ExistSCR & Scrub	38	2727.	1452.	2202.	0.	4.
Ret.ExistSNCR & Scrub	39	502.	157.	0.	0.	0.
Ret.SCR	40	19389.	2134.	2632.	0.	0.
Ret.ExistScrub & SCR	41	3506.	1264.	1830.	0.	0.
Ret.SNCR	42	6018.	1453.	1235.	0.	1782.
Ret.ExistScrub & SNCR	43	688.	189.	0.	0.	0.
Ret.SCR+Scrb	44	3241.	1125.	2279.	0.	0.
Ret.SNCR+Scrub	45	0.	0.	0.	0.	0.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	82.	0.	0.	0.
Ret.ExistScrub&ACI	50	0.	195.	0.	0.	0.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	86.	0.	0.	0.	0.
Ret.O/G SNCR	66	982.	466.	0.	0.	0.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	2323.	253.	564.	0.	0.
CC Early Retirement	71	865.	205.	496.	20.	1543.
O/G Early Retirement	72	30010.	1145.	0.	343.	1554.
Coal Early Retirement	73	8.	0.	0.	0.	36.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
Total		72122.	29138.	74024.	81569.	115704.

12. Generation by Plant Type [GWh]		2007	2010	2015	2020	2026

Scrubbed Coal_SCR	1	226963.	243379.	558645.	771174.	1180772.
Scrubbed Coal_SNCR	2	16170.	16597.	16597.	16597.	16520.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	457765.	448591.	433047.	431288.	426024.
Unscrubbed Coal_SCR	5	374573.	369750.	352768.	351689.	348870.
Unscrubbed Coal_SNCR	6	50243.	52013.	52174.	51670.	50538.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	795579.	766042.	741515.	727211.	707531.
Oil/Gas Steam	9	43510.	39267.	22041.	15001.	11974.
Oil/Gas Steam_SCR	10	22536.	1676.	557.	1141.	1264.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	785243.	798667.	811008.	808645.	796944.
Hydro	13	275692.	275692.	275692.	275692.	275692.
Comb.Cycle Gas	14	589062.	667736.	678904.	680339.	600200.
IGCC	15	4702.	4702.	72626.	281622.	495974.
Combustion Turbine	16	29824.	36668.	30022.	45494.	62817.
Biomass	17	8827.	9229.	9286.	8958.	8973.
Geothermal	18	24121.	25066.	25904.	25904.	25904.
Landfill Gas	19	6168.	6420.	8261.	8261.	8261.
Wind	20	14091.	14738.	14889.	14889.	15013.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	444.	459.	488.	488.	488.
Non Fossil_Other	23	17132.	17400.	17400.	17400.	17400.
Fossil_Other	24	4462.	4462.	4462.	4462.	4462.
Pump Storage	25	24354.	20549.	18945.	23763.	27168.
Int. Imports	26	41303.	44063.	40296.	27331.	13578.
Cgn_CT	27	2941.	2037.	1162.	973.	611.
Cgn_CC	28	43079.	40014.	25113.	23943.	19350.
Cgn_Oil/Gas Steam	29	1217.	616.	0.	0.	0.
Cgn_Biomass	30	2702.	2662.	2792.	2792.	2728.
Cgn_Fossil_Other	31	2365.	2262.	2846.	2846.	2846.
Cgn_NonFossil_Other	32	2412.	2412.	2412.	2412.	2412.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	368.	679.	840.	840.
Rep.O/G-CC	35	0.	111860.	107146.	103943.	102075.
Rep.Coal-IGCC	36	0.	964.	964.	964.	964.
Ret.Scrubber	37	11003.	18073.	18088.	26026.	25823.
Ret.ExistSCR & Scrub	38	20306.	31115.	47509.	47226.	46843.
Ret.ExistSNCR & Scrub	39	3147.	4904.	4635.	4635.	4635.
Ret.SCR	40	144375.	160231.	170801.	170680.	170619.
Ret.ExistScrub & SCR	41	26108.	35521.	49148.	49148.	49148.
Ret.SNCR	42	40160.	50447.	60992.	59991.	69901.
Ret.ExistScrub & SNCR	43	5056.	6464.	6464.	6464.	6411.
Ret.SCR+Scrb	44	24137.	32515.	49486.	49486.	49486.
Ret.SNCR+Scrub	45	0.	0.	0.	0.	0.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	614.	614.	614.	614.
Ret.ExistScrub&ACI	50	0.	1452.	1452.	1452.	1452.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	158.	158.	90.	90.	90.
Ret.O/G SNCR	66	1726.	1293.	1293.	1293.	970.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.

Total		4143657.	4369148.	4739212.	5144837.	5654184.

12a. Generation by Fuel Type [GWh]	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
Coal	2200286.	2243373.	2637526.	3047936.	3652124.
Oil	3361.	616.	0.	0.	0.
Nuclear	785243.	798667.	811008.	808645.	796944.
Hydro	275692.	275692.	275692.	275692.	275692.
Gas	730694.	901078.	867007.	873058.	800192.
Other	12995.	13145.	15569.	15569.	15569.
None	123857.	124686.	120335.	112187.	101963.
Biomass	11529.	11891.	12077.	11750.	11702.
-----	-----	-----	-----	-----	-----
Total	4143657.	4369148.	4739212.	5144837.	5654184.

13. Generation by Plant Type [TBtu]		2007	2010	2015	2020	2026
<hr/>						
Scrubbed Coal_SCR	1	774.	830.	1906.	2631.	4029.
Scrubbed Coal_SNCR	2	55.	57.	57.	57.	56.
Scrubbed Coal_NOx	3	0.	0.	0.	0.	0.
Scrubbed Coal	4	1562.	1531.	1478.	1472.	1454.
Unscrubbed Coal_SCR	5	1278.	1262.	1204.	1200.	1190.
Unscrubbed Coal_SNCR	6	171.	177.	178.	176.	172.
Unscrubbed Coal_NOx	7	0.	0.	0.	0.	0.
Unscrubbed Coal	8	2715.	2614.	2530.	2481.	2414.
Oil/Gas Steam	9	148.	134.	75.	51.	41.
Oil/Gas Steam_SCR	10	77.	6.	2.	4.	4.
Oil/Gas Steam_NOx	11	0.	0.	0.	0.	0.
Nuclear	12	2679.	2725.	2767.	2759.	2719.
Hydro	13	941.	941.	941.	941.	941.
Comb.Cycle Gas	14	2010.	2278.	2316.	2321.	2048.
IGCC	15	16.	16.	248.	961.	1692.
Combustion Turbine	16	102.	125.	102.	155.	214.
Biomass	17	30.	31.	32.	31.	31.
Geothermal	18	82.	86.	88.	88.	88.
Landfill Gas	19	21.	22.	28.	28.	28.
Wind	20	48.	50.	51.	51.	51.
Fuel Cell	21	0.	0.	0.	0.	0.
Solar	22	2.	2.	2.	2.	2.
Non Fossil_Other	23	58.	59.	59.	59.	59.
Fossil_Other	24	15.	15.	15.	15.	15.
Pump Storage	25	83.	70.	65.	81.	93.
Int. Imports	26	141.	150.	137.	93.	46.
Cgn_CT	27	10.	7.	4.	3.	2.
Cgn_CC	28	147.	137.	86.	82.	66.
Cgn_Oil/Gas Steam	29	4.	2.	0.	0.	0.
Cgn_Biomass	30	9.	9.	10.	10.	9.
Cgn_Fossil_Other	31	8.	8.	10.	10.	10.
Cgn_NonFossil_Other	32	8.	8.	8.	8.	8.
Distributed Generation	33	0.	0.	0.	0.	0.
Rep.Coal-CC	34	0.	1.	2.	3.	3.
Rep.O/G-CC	35	0.	382.	366.	355.	348.
Rep.Coal-IGCC	36	0.	3.	3.	3.	3.
Ret.Scrubber	37	38.	62.	62.	89.	88.
Ret.ExistSCR & Scrub	38	69.	106.	162.	161.	160.
Ret.ExistSNCR & Scrub	39	11.	17.	16.	16.	16.
Ret.SCR	40	493.	547.	583.	582.	582.
Ret.ExistScrub & SCR	41	89.	121.	168.	168.	168.
Ret.SNCR	42	137.	172.	208.	205.	239.
Ret.ExistScrub & SNCR	43	17.	22.	22.	22.	22.
Ret.SCR+Scrb	44	82.	111.	169.	169.	169.
Ret.SNCR+Scrub	45	0.	0.	0.	0.	0.
Ret.Gas Reburn	46	0.	0.	0.	0.	0.
Ret.ExistScrub+GasR	47	0.	0.	0.	0.	0.
Ret.GasReburn+Scrub	48	0.	0.	0.	0.	0.
Ret.ACI	49	0.	2.	2.	2.	2.
Ret.ExistScrub&ACI	50	0.	5.	5.	5.	5.
Ret.ExistSCR&ACI	51	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI	52	0.	0.	0.	0.	0.
Ret.ACI & SCR	53	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SCR	54	0.	0.	0.	0.	0.
Ret.ACI & SNCR	55	0.	0.	0.	0.	0.
Ret.ExistScrub&ACI&SNCR	56	0.	0.	0.	0.	0.
Ret.ACI & Srub	57	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&Scrub	58	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&Scrub	59	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistScrub&ACI	60	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistScrub&ACI	61	0.	0.	0.	0.	0.
Ret.ExistNOx&ExistScrub&ACI	62	0.	0.	0.	0.	0.
Ret.SCR & Scrub & ACI	63	0.	0.	0.	0.	0.
Ret.SNCR & Scrub & ACI	64	0.	0.	0.	0.	0.
Ret.O/G SCR	65	1.	1.	0.	0.	0.
Ret.O/G SNCR	66	6.	4.	4.	4.	3.
Ret.Nuclear (age 30+10 yrs)	67	0.	0.	0.	0.	0.
Ret.Nuclear (age 40+20 yrs)	68	0.	0.	0.	0.	0.
Ret. Biomass Cofiring	69	0.	0.	0.	0.	0.
CT Early Retirement	70	0.	0.	0.	0.	0.
CC Early Retirement	71	0.	0.	0.	0.	0.
O/G Early Retirement	72	0.	0.	0.	0.	0.
Coal Early Retirement	73	0.	0.	0.	0.	0.
Nuke Early Retirement	74	0.	0.	0.	0.	0.
<hr/>		<hr/>				
Total		14138.	14908.	16170.	17554.	19292.

14. Capacity Factor by Plant Type [%]		2007	2010	2015	2020	2026
Scrubbed Coal_SCR	1	85.0	85.0	85.0	85.0	84.5
Scrubbed Coal_SNCR	2	81.0	83.1	83.1	83.1	82.7
Scrubbed Coal_NOx	3	N/A	N/A	N/A	N/A	N/A
Scrubbed Coal	4	84.1	84.7	84.3	84.0	82.9
Unscrubbed Coal_SCR	5	83.3	84.6	84.6	84.3	83.6
Unscrubbed Coal_SNCR	6	76.9	81.4	81.6	80.8	79.4
Unscrubbed Coal_NOx	7	N/A	N/A	N/A	N/A	N/A
Unscrubbed Coal	8	80.6	82.2	83.5	82.8	82.0
Oil/Gas Steam	9	5.8	5.4	3.0	2.1	1.7
Oil/Gas Steam_SCR	10	27.4	3.4	1.1	2.3	2.6
Oil/Gas Steam_NOx	11	0.0	0.0	0.0	0.0	0.0
Nuclear	12	89.4	90.7	90.7	90.0	88.7
Hydro	13	35.0	35.0	35.0	35.0	35.0
Comb.Cycle Gas	14	45.7	51.7	49.1	46.4	39.7
IGCC	15	87.7	87.7	87.7	87.7	87.7
Combustion Turbine	16	2.6	3.2	2.6	3.6	4.3
Biomass	17	74.2	72.4	72.8	70.2	70.4
Geothermal	18	87.0	87.0	87.0	87.0	87.0
Landfill Gas	19	88.5	88.5	87.7	87.7	87.7
Wind	20	23.3	23.3	23.3	23.3	23.4
Fuel Cell	21	N/A	N/A	N/A	N/A	N/A
Solar	22	11.3	11.3	11.3	11.3	11.3
Non Fossil_Other	23	90.0	90.0	90.0	90.0	90.0
Fossil_Other	24	90.0	90.0	90.0	90.0	90.0
Pump Storage	25	14.1	11.9	10.9	13.7	15.7
Int. Imports	26	52.4	55.9	51.1	34.7	17.2
Cgn_CT	27	6.1	4.2	2.4	2.0	1.3
Cgn_CC	28	27.5	25.6	16.1	15.3	13.2
Cgn_Oil/Gas Steam	29	24.3	12.8	0.0	0.0	0.0
Cgn_Biomass	30	84.3	83.0	87.1	87.1	85.1
Cgn_Fossil_Other	31	74.8	71.5	90.0	90.0	90.0
Cgn_NonFossil_Other	32	87.7	87.7	87.7	87.7	87.7
Distributed Generation	33	N/A	N/A	N/A	N/A	N/A
Rep.Coal-CC	34	N/A	4.6	8.5	10.5	10.5
Rep.O/G-CC	35	N/A	90.4	86.6	84.0	82.5
Rep.Coal-IGCC	36	N/A	87.7	87.7	87.7	87.7
Ret.Scrubber	37	82.1	85.0	85.0	84.1	83.5
Ret.ExistSCR & Scrub	38	85.0	85.0	85.0	84.5	83.8
Ret.ExistSNCR & Scrub	39	71.6	85.0	80.3	80.3	80.3
Ret.SCR	40	85.0	85.0	84.9	84.8	84.8
Ret.ExistScrub & SCR	41	85.0	85.0	85.0	85.0	85.0
Ret.SNCR	42	76.2	77.1	80.0	78.7	76.1
Ret.ExistScrub & SNCR	43	83.9	84.1	84.1	84.1	83.4
Ret.SCR+Scrb	44	85.0	85.0	85.0	85.0	85.0
Ret.SNCR+Scrub	45	N/A	N/A	N/A	N/A	N/A
Ret.Gas Reburn	46	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub+GasR	47	N/A	N/A	N/A	N/A	N/A
Ret.GasReburn+Scrub	48	N/A	N/A	N/A	N/A	N/A
Ret.ACI	49	N/A	85.0	85.0	85.0	85.0
Ret.ExistScrub&ACI	50	N/A	85.0	85.0	85.0	85.0
Ret.ExistSCR&ACI	51	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI	52	N/A	N/A	N/A	N/A	N/A
Ret.ACI & SCR	53	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub&ACI&SCR	54	N/A	N/A	N/A	N/A	N/A
Ret.ACI & SNCR	55	N/A	N/A	N/A	N/A	N/A
Ret.ExistScrub&ACI&SNCR	56	N/A	N/A	N/A	N/A	N/A
Ret.ACI & Srub	57	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ACI&Scrub	58	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI&Scrub	59	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ExistScrub&ACI	60	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ExistScrub&ACI	61	N/A	N/A	N/A	N/A	N/A
Ret.ExistNOx&ExistScrub&ACI	62	N/A	N/A	N/A	N/A	N/A
Ret.SCR & Scrub & ACI	63	N/A	N/A	N/A	N/A	N/A
Ret.SNCR & Scrub & ACI	64	N/A	N/A	N/A	N/A	N/A
Ret.O/G SCR	65	21.1	21.1	12.0	12.0	12.0
Ret.O/G SNCR	66	20.1	10.2	10.2	10.2	7.6
Ret.Nuclear (age 30+10 yrs)	67	N/A	N/A	N/A	N/A	N/A
Ret.Nuclear (age 40+20 yrs)	68	N/A	N/A	N/A	N/A	N/A
Ret. Biomass Cofiring	69	N/A	N/A	N/A	N/A	N/A
CT Early Retirement	70	0.0	0.0	0.0	0.0	0.0
CC Early Retirement	71	0.0	0.0	0.0	0.0	0.0
O/G Early Retirement	72	0.0	0.0	0.0	0.0	0.0
Coal Early Retirement	73	0.0	0.0	0.0	0.0	0.0
Nuke Early Retirement	74	N/A	N/A	N/A	N/A	N/A
Average		48.7	50.7	51.6	52.0	52.1

15. Total Annual Production Cost [MMUS\$](*)	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
Variable O&M	6690.4	7041.6	8188.3	9287.7	10836.1
Fixed O&M	29387.1	30073.0	33192.8	36627.5	39284.6
Fuel	49743.8	52978.9	56039.9	57092.8	59144.6
Capital	781.2	2194.9	11559.4	22404.1	37660.7
-----	-----	-----	-----	-----	-----
Total	86602.6	92288.5	108980.4	125412.1	146926.0
Sales Revenue	0.0	0.0	0.0	0.0	0.0
(*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)					

15a Total Annual Resource Cost [MMUS\$](*)	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
Variable O&M	6690.4	7041.6	8188.3	9287.7	10836.1
Fixed O&M	29387.1	30073.0	33192.8	36627.5	39284.6
Fuel Total	97245.2	101706.8	121157.9	129075.9	133111.3
Fuel Elec.+Steam	39702.5	43444.6	50662.3	54676.3	56143.7
Capital	781.2	2194.9	11559.4	22404.1	37660.7
-----	-----	-----	-----	-----	-----
Total IPM	134104.0	141016.3	174098.4	197395.2	220892.7
Total Elec.+Steam	76561.3	82754.1	103602.8	122995.7	143925.1
Sales Revenue	0.0	0.0	0.0	0.0	0.0
(*) Costs include only those items that are important for determining incremental cost of pollution control (industrial boiler costs are included)					

16. Emissions	2007	2010	2015	2020	2026
-----	-----	-----	-----	-----	-----
SO2 [MTons]	10523.6940	9925.2794	9040.6740	8871.6452	8882.1801
NOX [MTons]	3724.6949	3741.7603	3784.8464	3831.0471	3910.2406
TSP [MTons]	0.0000	0.0000	0.0000	0.0000	0.0000
CO2 [MMTonnes]	2468.5947	2566.1323	2855.2266	3155.2565	3582.6448
Carbon [MMTonnes]	673.2531	699.8543	778.6982	860.5245	977.0850

Fuel Consumption by Fuel and Fuel Type [TBtu]

Fuel	2007	2010	2015	2020	2026
Coal	22953.7	23396.2	26729.0	29941.1	34791.5
Oil	33.3	5.7	0.0	0.0	0.0
Nuclear	8276.8	8417.2	8543.8	8518.1	8394.5
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	5686.5	6795.0	6348.8	6313.2	5760.4
Other	153.5	156.1	184.7	184.7	184.7
None	591.7	606.5	619.5	619.5	619.5
Biomass	108.2	111.6	113.5	110.2	109.6
Grand Total	37803.6	39488.4	42539.3	45686.7	49860.2

Fuel Costs by Fuel and Fuel Type [MMUS\$]

Fuel	2007	2010	2015	2020	2026
Coal	24975.2	24728.3	27634.4	29668.5	33367.8
Oil	109.9	19.2	0.0	0.0	0.0
Nuclear	3410.0	3467.9	3477.3	3458.3	3408.2
Hydro	0.0	0.0	0.0	0.0	0.0
Gas	21068.2	24577.8	24741.7	23791.4	22195.5
Other	0.0	0.0	0.0	0.0	0.0
None	0.0	0.0	0.0	0.0	0.0
Biomass	180.5	185.7	186.4	174.5	173.2

Fuel Costs by Fuel and Fuel Type [US\$/MMBtu]

Fuel	2007	2010	2015	2020	2026
Coal	1.09	1.06	1.03	0.99	0.96
Oil	3.29	3.35	0.00	0.00	0.00
Nuclear	0.41	0.41	0.41	0.41	0.41
Hydro	0.00	0.00	0.00	0.00	0.00
Gas	3.70	3.62	3.90	3.77	3.85
Other	0.00	0.00	0.00	0.00	0.00
None	0.00	0.00	0.00	0.00	0.00
Biomass	1.67	1.66	1.64	1.58	1.58

Environmental Measures Report

Constraint Name: National Title IV SO2 Policy Case Constraint Constraint #: 1
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.1439E+05	9046.	8643.	8643.	8643.
-Emissions at Affected Plants [MTons]	0.1030E+05	9694.	8813.	8643.	8643.
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	4090.	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	-648.2	-169.9	0.000	0.000
Total [MTons]	0.1439E+05	9046.	8643.	8643.	8643.
TBtu Consumed	0.2291E+05	0.2328E+05	0.2661E+05	0.2983E+05	0.3468E+05
Rate - [lb/MMBtu]	0.8987	0.8327	0.6623	0.5796	0.4985
TWh Generated	2199.	2235.	2629.	3039.	3643.
TWh Generated Qualifying	2199.	2235.	2629.	3039.	3643.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	221.2	257.9	334.5	371.3	348.1

Constraint Name: WRAP SO2 Policy Case Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 2

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	0.000	0.000	198.9	198.9
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	198.9	198.9
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	198.9	198.9
TBtu Consumed	0.000	0.000	0.000	1543.	1543.
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.2578	0.2578
TWh Generated	0.000	0.000	0.000	148.9	148.9
TWh Generated Qualifying	0.000	0.000	0.000	148.9	148.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	1304.	1152.

Constraint Name: NOx SIP CALL Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Constraint #: 4

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	528.0	528.0	528.0	528.0	528.0
-Emissions at Affected Plants [MTons]	528.0	528.0	528.0	528.0	528.0
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	528.0	528.0	528.0	528.0	528.0
TBtu Consumed	6841.	7164.	7687.	8068.	8492.
Rate - [lb/MMBtu]	0.1544	0.1474	0.1374	0.1309	0.1244
TWh Generated	681.5	717.7	777.6	828.2	883.4
TWh Generated Qualifying	681.5	717.7	777.6	828.2	883.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2316.	2345.	2459.	2302.	2446.

Constraint Name: NOX Policy for State of Illinois
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 SUMMER
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2026 SUMMER

Constraint #: 5

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	30.73	32.87	34.77	33.32	32.68
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	30.73	32.87	34.77	33.32	32.68
TBtu Consumed	442.5	485.8	501.9	485.9	472.1
Rate - [lb/MMBtu]	0.1389	0.1353	0.1386	0.1371	0.1384
TWh Generated	41.92	45.89	47.38	45.87	44.55
TWh Generated Qualifying	41.92	45.89	47.38	45.87	44.55
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOX Policy for State of Massachusetts
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 6

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	9.095	13.09	12.57	12.57	12.47
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	9.095	13.09	12.57	12.57	12.47
TBtu Consumed	126.8	168.2	163.5	163.5	162.2
Rate - [lb/MMBtu]	0.1434	0.1556	0.1538	0.1538	0.1537
TWh Generated	12.13	17.45	16.92	16.92	16.78
TWh Generated Qualifying	12.13	17.45	16.92	16.92	16.78
Constraint Shadow Price [US\$/Ton]	416.3	1019.	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of Massachusetts
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 7

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	11.80	18.34	17.55	17.55	16.98
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	11.80	18.34	17.55	17.55	16.98
TBtu Consumed	125.2	133.0	128.3	128.3	127.3
Rate - [lb/MMBtu]	0.1885	0.2758	0.2736	0.2736	0.2669
TWh Generated	11.98	12.23	11.70	11.70	11.61
TWh Generated Qualifying	11.98	12.23	11.70	11.70	11.61
Constraint Shadow Price [US\$/Ton]	1851.	751.9	885.7	626.3	0.000

Constraint Name: CO2 Policy for State of Massachusetts
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.1091E+05	0.1562E+05	0.1523E+05	0.1523E+05	0.1511E+05
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1091E+05	0.1562E+05	0.1523E+05	0.1523E+05	0.1511E+05
TBtu Consumed	126.8	168.2	163.5	163.5	162.2
Rate - [lb/MMBtu]	172.1	185.7	186.3	186.3	186.3
TWh Generated	12.13	17.45	16.92	16.92	16.78
TWh Generated Qualifying	12.13	17.45	16.92	16.92	16.78
Constraint Shadow Price [US\$/Ton]	45.45	0.000	2.761	1.011	6.451

Constraint Name: NOx Policy for State of North Carolina Progressive Constraint #: 9
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	25.00	25.00	25.00	25.00	25.00
-Emissions at Affected Plants [MTons]	21.84	22.63	21.83	21.83	21.21
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	21.84	22.63	21.83	21.83	21.21
TBtu Consumed	401.5	408.1	402.4	401.8	397.7
Rate - [lb/MMBtu]	0.1088	0.1109	0.1085	0.1086	0.1067
TWh Generated	36.51	37.06	36.37	36.32	35.96
TWh Generated Qualifying	36.51	37.06	36.37	36.32	35.96
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of North Carolina Duke
Constraint Type: Rate Cap [MTons] Constraint #: 10
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	35.00	31.80	31.00	31.00	31.00
-Emissions at Affected Plants [MTons]	34.27	31.80	31.00	30.84	29.29
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	34.27	31.80	31.00	30.84	29.29
TBtu Consumed	570.6	572.8	573.2	571.9	558.6
Rate - [lb/MMBtu]	0.1201	0.1110	0.1082	0.1078	0.1049
TWh Generated	52.55	52.64	52.39	52.27	51.05
TWh Generated Qualifying	52.55	52.64	52.39	52.27	51.05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	194.5	311.5	0.000	0.000

Constraint Name: SO2 Policy for State of North Carolina Progressive Constraint #: 11
Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	100.0	50.00	50.00	50.00
-Emissions at Affected Plants [MTons]	0.000	100.0	50.00	50.00	50.00
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	100.0	50.00	50.00	50.00
TBtu Consumed	0.000	408.1	402.4	401.8	397.7
Rate - [lb/MMBtu]	0.000	0.4900	0.2485	0.2489	0.2514
TWh Generated	0.000	37.06	36.37	36.32	35.96
TWh Generated Qualifying	0.000	37.06	36.37	36.32	35.96
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	494.1	816.1	626.8	628.0

Constraint Name: SO2 Policy for State of North Carolina Duke
Constraint Type: Rate Cap [MTons] Constraint #: 12
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	0.000	150.0	80.00	80.00	80.00
-Emissions at Affected Plants [MTons]	0.000	150.0	80.00	80.00	80.00
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	150.0	80.00	80.00	80.00
TBtu Consumed	0.000	572.8	573.2	571.9	558.6
Rate - [lb/MMBtu]	0.000	0.5238	0.2791	0.2798	0.2865
TWh Generated	0.000	52.64	52.39	52.27	51.05
TWh Generated Qualifying	0.000	52.64	52.39	52.27	51.05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	631.7	879.2	720.4	628.0

Constraint Name: NOx Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 13

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	3.644	3.644	3.644	3.644	3.644
-Emissions at Affected Plants [MTons]	2.100	2.082	2.026	1.996	1.996
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.100	2.082	2.026	1.996	1.996
TBtu Consumed	43.53	43.35	42.82	42.54	42.54
Rate - [lb/MMBtu]	0.9650E-01	0.9606E-01	0.9462E-01	0.9386E-01	0.9386E-01
TWh Generated	3.990	3.976	3.935	3.913	3.913
TWh Generated Qualifying	3.990	3.976	3.935	3.913	3.913
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New Hampshire - Hillsborou Constraint #: 14
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.179	1.161	1.152	1.149	1.067
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.179	1.161	1.152	1.149	1.067
TBtu Consumed	48.96	48.79	48.71	48.68	41.06
Rate - [lb/MMBtu]	0.4816E-01	0.4760E-01	0.4732E-01	0.4721E-01	0.5195E-01
TWh Generated	6.007	5.993	5.987	5.985	4.909
TWh Generated Qualifying	6.007	5.993	5.987	5.985	4.909
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New Hampshire Remaining Co Constraint #: 15
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2000	0.2000	0.2000	0.2000	0.2000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	5947.	6932.	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 16

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	7.289	7.289	7.289	7.289	7.289
-Emissions at Affected Plants [MTons]	7.289	7.152	7.426	7.289	7.289
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.1370	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-0.1370	0.000	0.000
Total [MTons]	7.289	7.289	7.289	7.289	7.289
TBtu Consumed	43.49	43.24	42.79	42.54	42.54
Rate - [lb/MMBtu]	0.3352	0.3308	0.3471	0.3427	0.3427
TWh Generated	3.987	3.968	3.932	3.913	3.913
TWh Generated Qualifying	3.987	3.968	3.932	3.913	3.913
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1032.	922.4	1196.	852.0	804.5

Constraint Name: CO2 Policy for State of New Hampshire
Constraint Type: Rate Cap [MTons]

Constraint #: 17

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	5426.	5426.	5426.	5426.	5426.
-Emissions at Affected Plants [MTons]	4467.	4445.	4394.	4366.	4366.
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4467.	4445.	4394.	4366.	4366.
TBtu Consumed	43.53	43.35	42.82	42.54	42.54
Rate - [lb/MMBtu]	205.2	205.1	205.2	205.3	205.3
TWh Generated	3.990	3.976	3.935	3.913	3.913
TWh Generated Qualifying	3.990	3.976	3.935	3.913	3.913
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for State of New York
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER
Run Year, Seasons Included: 2010 WINTER
Run Year, Seasons Included: 2015 WINTER
Run Year, Seasons Included: 2020 WINTER
Run Year, Seasons Included: 2026 WINTER

Constraint #: 18

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	39.91	39.91	39.91	39.91	39.91
-Emissions at Affected Plants [MTons]	28.82	28.25	27.22	27.94	28.13
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	28.82	28.25	27.22	27.94	28.13
TBtu Consumed	339.0	367.4	406.1	463.3	514.7
Rate - [lb/MMBtu]	0.1700	0.1538	0.1340	0.1206	0.1093
TWh Generated	38.83	43.81	50.35	58.33	65.66
TWh Generated Qualifying	38.83	43.81	50.35	58.33	65.66
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of New York
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 19

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	197.0	131.4	131.4	131.4	131.4
-Emissions at Affected Plants [MTons]	197.0	129.7	133.1	131.4	131.4
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	1.675	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	-1.675	0.000	0.000
Total [MTons]	197.0	131.4	131.4	131.4	131.4
TBtu Consumed	270.4	270.4	416.3	502.3	631.0
Rate - [lb/MMBtu]	1.457	0.9594	0.6393	0.5232	0.4165
TWh Generated	26.76	26.76	47.02	58.93	76.80
TWh Generated Qualifying	26.76	26.76	47.02	58.93	76.80
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	261.4	263.1	341.2	312.8	260.1

Constraint Name: NOx Policy for State of Wisconsin
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 20

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.2500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	13.34	9.148	8.793	8.266
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	13.34	9.148	8.793	8.266
TBtu Consumed	0.000	202.1	201.5	194.8	186.0
Rate - [lb/MMBtu]	0.000	0.1320	0.9080E-01	0.9027E-01	0.8888E-01
TWh Generated	0.000	19.24	19.05	18.43	17.62
TWh Generated Qualifying	0.000	19.24	19.05	18.43	17.62
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SO2 Policy for State of Wisconsin
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 21

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.7000	0.4500	0.4500	0.4500
-Emissions at Affected Plants [MTons]	0.000	36.16	26.05	25.02	23.45
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	36.16	26.05	25.02	23.45
TBtu Consumed	0.000	202.1	201.5	194.8	186.0
Rate - [lb/MMBtu]	0.000	0.3578	0.2586	0.2568	0.2522
TWh Generated	0.000	19.24	19.05	18.43	17.62
TWh Generated Qualifying	0.000	19.24	19.05	18.43	17.62
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Houston Texas
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	8.450	8.450	8.450	8.450	8.450
-Emissions at Affected Plants [MTons]	8.450	8.450	8.450	8.450	8.450
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8.450	8.450	8.450	8.450	8.450
TBtu Consumed	304.9	309.3	259.4	256.5	277.9
Rate - [lb/MMBtu]	0.5542E-01	0.5463E-01	0.6514E-01	0.6589E-01	0.6082E-01
TWh Generated	32.80	33.16	26.95	26.95	30.55
TWh Generated Qualifying	32.80	33.16	26.95	26.95	30.55
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2162E+05	0.2312E+05	0.1162E+05	6187.	4255.

Constraint Name: NOx Policy for Dallas/Fort Texas
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 23

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	2.164	2.164	2.164	2.164	2.164
-Emissions at Affected Plants [MTons]	0.9841	2.164	0.5821	0.5524	0.4356
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9841	2.164	0.5821	0.5524	0.4356
TBtu Consumed	32.96	59.90	19.37	18.31	15.36
Rate - [lb/MMBtu]	0.5972E-01	0.7225E-01	0.6011E-01	0.6032E-01	0.5674E-01
TWh Generated	3.131	5.525	1.840	1.739	1.459
TWh Generated Qualifying	3.131	5.525	1.840	1.739	1.459
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1890.	0.000	0.000	0.000

Constraint Name: NOx Policy for East Central Texas
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 24

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	123.5	123.5	123.5	123.5	123.5
-Emissions at Affected Plants [MTons]	123.0	123.5	115.4	107.7	100.4
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	123.0	123.5	115.4	107.7	100.4
TBtu Consumed	1738.	1752.	1517.	1395.	1270.
Rate - [lb/MMBtu]	0.1415	0.1410	0.1522	0.1544	0.1582
TWh Generated	183.8	183.7	155.4	143.1	129.3
TWh Generated Qualifying	183.8	183.7	155.4	143.1	129.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2856.	0.000	0.000	0.000

Constraint Name: SO2 Policy for Texas East (Senate Bill 7) Constraint #: 25
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	111.2	111.2	111.2	111.2	111.2
-Emissions at Affected Plants [MTons]	85.64	85.64	85.64	81.41	77.89
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	85.64	85.64	85.64	81.41	77.89
TBtu Consumed	171.3	171.3	171.3	162.8	155.8
Rate - [lb/MMBtu]	1.000	1.000	1.000	1.000	1.000
TWh Generated	16.98	16.98	16.98	16.20	15.44
TWh Generated Qualifying	16.98	16.98	16.98	16.20	15.44
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Rest of Texas East
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Constraint #: 26

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	58.37	58.37	58.37	58.37	58.37
-Emissions at Affected Plants [MTons]	28.81	31.46	27.00	21.94	19.86
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	28.81	31.46	27.00	21.94	19.86
TBtu Consumed	364.6	431.2	348.7	285.2	252.7
Rate - [lb/MMBtu]	0.1581	0.1459	0.1549	0.1539	0.1572
TWh Generated	35.54	41.19	33.70	27.82	24.83
TWh Generated Qualifying	35.54	41.19	33.70	27.82	24.83
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for Texas West
Constraint Type: Rate Cap [MTons]

Constraint #: 27

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	18.03	18.03	18.03	18.03	18.03
-Emissions at Affected Plants [MTons]	6.388	10.27	5.394	4.290	3.286
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.388	10.27	5.394	4.290	3.286
TBtu Consumed	65.33	214.4	139.4	108.6	97.32
Rate - [lb/MMBtu]	0.1956	0.9581E-01	0.7739E-01	0.7899E-01	0.6752E-01
TWh Generated	6.030	27.05	18.24	14.19	13.21
TWh Generated Qualifying	6.030	27.05	18.24	14.19	13.21
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NOx Policy for El Paso Texas

Constraint #: 28

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2007 WINTER SUMMER
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [MTon]	1.058	1.058	1.058	1.058	1.058
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut NOx Facility Specific Constraint Constraint #: 29
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	2.113	1.183	1.183	1.183	1.183
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.113	1.183	1.183	1.183	1.183
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.1500	0.8400E-01	0.8400E-01	0.8400E-01	0.8400E-01
TWh Generated	2.821	2.820	2.820	2.820	2.820
TWh Generated Qualifying	2.821	2.820	2.820	2.820	2.820
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2289.	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut NOx Facility Specific Constraint Constraint #: 30
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4644	0.4644	0.4644	0.4644	0.4644
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BSM Connecticut NOx Facility Specific Constraint Constraint #: 31
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1852	0.1672	0.8683E-01	0.4999E-01	0.2890E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1852	0.1672	0.8683E-01	0.4999E-01	0.2890E-01
TBtu Consumed	2.485	2.244	1.165	0.6710	0.3879
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.2632	0.2377	0.1234	0.7107E-01	0.4109E-01
TWh Generated Qualifying	0.2632	0.2377	0.1234	0.7107E-01	0.4109E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLR Connecticut NOx Facility Specific Constraint Constraint #: 32
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	757.2	758.3

Constraint Name: BLQ Connecticut NOx Facility Specific Constraint Constraint #: 33
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut NOx Facility Specific Constraint Constraint #: 34
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4593.	2431.	4715.	758.3

Constraint Name: BKA Connecticut NOx Facility Specific Constraint Constraint #: 35
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut NOx Facility Specific Constraint Constraint #: 36
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	955.0	757.2	758.3

Constraint Name: BJD Connecticut NOx Facility Specific Constraint Constraint #: 37
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ATH Connecticut NOx Facility Specific Constraint Constraint #: 38
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	4.523	4.242	3.423	2.578	0.8683
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.523	4.242	3.423	2.578	0.8683
TBtu Consumed	60.72	56.95	45.94	34.60	11.66
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	8.341	7.823	6.311	4.754	1.601
TWh Generated Qualifying	8.341	7.823	6.311	4.754	1.601
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIO Connecticut NOx Facility Specific Constraint Constraint #: 39
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.4017E-01	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.4017E-01	0.000	0.000	0.000
TBtu Consumed	0.000	0.5392	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.1490	0.000	0.000	0.000
TWh Generated	0.000	0.4289E-01	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.4289E-01	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIN Connecticut NOx Facility Specific Constraint Constraint #: 40
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.4046E-01	0.5639E-01	0.2408E-01	0.2408E-01	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4046E-01	0.5639E-01	0.2408E-01	0.2408E-01	0.000
TBtu Consumed	0.5431	0.7569	0.3232	0.3232	0.000
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.000
TWh Generated	0.5094E-01	0.7099E-01	0.3031E-01	0.3031E-01	0.000
TWh Generated Qualifying	0.5094E-01	0.7099E-01	0.3031E-01	0.3031E-01	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIM Connecticut NOx Facility Specific Constraint Constraint #: 41
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.3984	0.3984	0.1327	0.1327	0.4418E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3984	0.3984	0.1327	0.1327	0.4418E-01
TBtu Consumed	5.348	5.348	1.782	1.782	0.5930
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.1490
TWh Generated	0.6147	0.6147	0.2048	0.2048	0.6817E-01
TWh Generated Qualifying	0.6147	0.6147	0.2048	0.2048	0.6817E-01
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIL Connecticut NOx Facility Specific Constraint Constraint #: 42
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AIK Connecticut NOx Facility Specific Constraint Constraint #: 43
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1745E-01	0.1745E-01	0.1745E-01	0.1745E-01	0.000
TBtu Consumed	0.2342	0.2342	0.2342	0.2342	0.000
Rate - [lb/MMBtu]	0.1490	0.1490	0.1490	0.1490	0.000
TWh Generated	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.000
TWh Generated Qualifying	0.2067E-01	0.2067E-01	0.2067E-01	0.2067E-01	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut SO2 Facility Specific Constraint Constraint #: 44
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	4.649	4.649	4.649	4.649	4.649
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.649	4.649	4.649	4.649	4.649
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
TWh Generated	2.821	2.820	2.820	2.820	2.820
TWh Generated Qualifying	2.821	2.820	2.820	2.820	2.820
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1040.	65.92	0.000	36.27	1118.

Constraint Name: CDU Connecticut SO2 Facility Specific Constraint Constraint #: 45
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	2.438	2.438	2.438	2.438	2.438
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.438	2.438	2.438	2.438	2.438
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.3150	0.3150	0.3150	0.3150	0.3150
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLR Connecticut SO2 Facility Specific Constraint Constraint #: 46
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BLQ Connecticut SO2 Facility Specific Constraint Constraint #: 47
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKB Connecticut SO2 Facility Specific Constraint Constraint #: 48
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BKA Connecticut SO2 Facility Specific Constraint Constraint #: 49
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJE Connecticut SO2 Facility Specific Constraint Constraint #: 50
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: BJD Connecticut SO2 Facility Specific Constraint Constraint #: 51
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CFR Connecticut Hg Facility Specific Constraint Constraint #: 52
 Constraint Type: Required Removal Level
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	132.1	44.49	27.67	27.67	27.67
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	132.1	44.49	27.67	27.67	27.67
TBtu Consumed	28.17	28.17	28.17	28.17	28.17
Rate - [lb/MMBtu]	0.4688E-05	0.1579E-05	0.9821E-06	0.9821E-06	0.9821E-06
TWh Generated	2.821	2.820	2.820	2.820	2.820
TWh Generated Qualifying	2.821	2.820	2.820	2.820	2.820
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CDU Connecticut Hg Facility Specific Constraint Constraint #: 53
 Constraint Type: Required Removal Level
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	130.2	28.93	17.17	17.17	17.17
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	130.2	28.93	17.17	17.17	17.17
TBtu Consumed	15.48	15.48	15.48	15.48	15.48
Rate - [lb/MMBtu]	0.8411E-05	0.1869E-05	0.1109E-05	0.1109E-05	0.1109E-05
TWh Generated	1.452	1.452	1.452	1.452	1.452
TWh Generated Qualifying	1.452	1.452	1.452	1.452	1.452
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CCV Illinois NOx Facility Specific Constraint Constraint #: 54
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4296	0.4296	0.4296	0.4296	0.4296
TBtu Consumed	14.32	14.32	14.32	14.32	14.32
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	1.648	1.648	1.648	1.648	1.648
TWh Generated Qualifying	1.648	1.648	1.648	1.648	1.648
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ASU Illinois NOx Facility Specific Constraint Constraint #: 55
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	1.114	1.453	1.453	1.453	1.453
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.114	1.453	1.453	1.453	1.453
TBtu Consumed	8.947	11.67	11.67	11.67	11.67
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	1.211	1.580	1.580	1.580	1.580
TWh Generated Qualifying	1.211	1.580	1.580	1.580	1.580
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFF Illinois NOx Facility Specific Constraint Constraint #: 56
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AFE Illinois NOx Facility Specific Constraint Constraint #: 57
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 SUMMER
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2026 SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.4694	1.008	1.758	1.182	1.023
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4694	1.008	1.758	1.182	1.023
TBtu Consumed	3.770	8.094	14.12	9.491	8.219
Rate - [lb/MMBtu]	0.2490	0.2490	0.2490	0.2490	0.2490
TWh Generated	0.3564	0.7651	1.335	0.8973	0.7770
TWh Generated Qualifying	0.3564	0.7651	1.335	0.8973	0.7770
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CKT Maine NOx Facility Specific Constraint	Constraint #: 58
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.6637	0.6637	0.6637	0.6637	0.6637
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6637	0.6637	0.6637	0.6637	0.6637
TBtu Consumed	6.033	6.033	6.033	6.033	6.033
Rate - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
TWh Generated	0.5659	0.5659	0.5659	0.5659	0.5659
TWh Generated Qualifying	0.5659	0.5659	0.5659	0.5659	0.5659
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3710E+05	0.000	2605.	0.000	0.000

Constraint Name: BLS Maine NOx Facility Specific Constraint Constraint #: 59
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.654	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.654	0.000	0.000	0.000	0.000
TBtu Consumed	22.05	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1500	0.000	0.000	0.000	0.000
TWh Generated	2.143	0.000	0.000	0.000	0.000
TWh Generated Qualifying	2.143	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	7067.	906.1	0.000	0.000	0.000

Constraint Name: BJB Maine NOx Facility Specific Constraint	Constraint #: 60
Constraint Type: Rate Limit [lb/MMBtu]	
Run Year, Seasons Included: 2007 WINTER	SUMMER
Run Year, Seasons Included: 2010 WINTER	SUMMER
Run Year, Seasons Included: 2015 WINTER	SUMMER
Run Year, Seasons Included: 2020 WINTER	SUMMER
Run Year, Seasons Included: 2026 WINTER	SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2554.	496.2	0.000	0.000	0.000

Constraint Name: BJF Maine NOx Facility Specific Constraint Constraint #: 61
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	640.8	0.000	0.000	0.000	0.000

Constraint Name: BEB Maine NOx Facility Specific Constraint Constraint #: 62
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	35.47	0.000	0.000

Constraint Name: CZV New Source Review NOX Facility Specific Constr Constraint #: 63
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9750	0.9750	0.9750	0.9750
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9750	0.9750	0.9750	0.9750
TBtu Consumed	0.000	31.45	31.45	31.45	31.45
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.202	3.202	3.202	3.202
TWh Generated Qualifying	0.000	3.202	3.202	3.202	3.202
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1941.	0.000	2352.	0.000

Constraint Name: CZU New Source Review NOX Facility Specific Constr Constraint #: 64
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9373	0.9373	0.9373	0.9373
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9373	0.9373	0.9373	0.9373
TBtu Consumed	0.000	30.24	30.24	30.24	30.24
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4010.	0.000	4860.	0.000

Constraint Name: CZT New Source Review NOX Facility Specific Constr Constraint #: 65
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.9718	0.9718	0.9718	0.9718
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.9718	0.9718	0.9718	0.9718
TBtu Consumed	0.000	31.35	31.35	31.35	31.35
Rate - [lb/MMBtu]	0.000	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	3.135	3.135	3.135	3.135
TWh Generated Qualifying	0.000	3.135	3.135	3.135	3.135
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3868.	0.000	4687.	0.000

Constraint Name: CPX New Source Review NOX Facility Specific Constr Constraint #: 66
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPW New Source Review NOX Facility Specific Constr Constraint #: 67
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPV New Source Review NOX Facility Specific Constr Constraint #: 68
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CPS New Source Review NOX Facility Specific Constr Constraint #: 69
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	251.0	0.000	0.000

Constraint Name: CNM New Source Review NOX Facility Specific Constr Constraint #: 70
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.7096	0.6887	0.6887
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.7096	0.6887	0.6887
TBtu Consumed	0.000	0.000	22.89	22.22	22.22
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.229	2.163	2.163
TWh Generated Qualifying	0.000	0.000	2.229	2.163	2.163
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8131.	5883.	6114.

Constraint Name: CNL New Source Review NOX Facility Specific Constr Constraint #: 71
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.6642	0.6466	0.6442
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.6642	0.6466	0.6442
TBtu Consumed	0.000	0.000	21.43	20.86	20.78
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.131	2.074	2.066
TWh Generated Qualifying	0.000	0.000	2.131	2.074	2.066
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	5288.	2937.	4522.

Constraint Name: CNK New Source Review NOX Facility Specific Constr Constraint #: 72
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5967	0.5967	0.5967
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5967	0.5967	0.5967
TBtu Consumed	0.000	0.000	19.25	19.25	19.25
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.885	1.885	1.885
TWh Generated Qualifying	0.000	0.000	1.885	1.885	1.885
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8235.	1368.	1493.

Constraint Name: CNJ New Source Review NOX Facility Specific Constr Constraint #: 73
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5797	0.5797	0.5797
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5797	0.5797	0.5797
TBtu Consumed	0.000	0.000	18.70	18.70	18.70
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.863	1.863	1.863
TWh Generated Qualifying	0.000	0.000	1.863	1.863	1.863
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	8218.	1754.	1313.

Constraint Name: CLT New Source Review NOX Facility Specific Constr Constraint #: 74
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5365	0.5365	0.5365
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5365	0.5365	0.5365
TBtu Consumed	0.000	0.000	17.31	17.31	17.31
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.614	1.614	1.614
TWh Generated Qualifying	0.000	0.000	1.614	1.614	1.614
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4001.	0.000	0.000

Constraint Name: CLS New Source Review NOX Facility Specific Constr Constraint #: 75
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	1.713	1.713	1.713
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.713	1.713	1.713
TBtu Consumed	0.000	0.000	55.27	55.27	55.27
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	5.256	5.256	5.256
TWh Generated Qualifying	0.000	0.000	5.256	5.256	5.256
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	7.213	0.000

Constraint Name: CLR New Source Review NOX Facility Specific Constr Constraint #: 76
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.8056	0.8056	0.8056
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.8056	0.8056	0.8056
TBtu Consumed	0.000	0.000	25.99	25.99	25.99
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	2.375	2.375	2.375
TWh Generated Qualifying	0.000	0.000	2.375	2.375	2.375
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1001.	1064.	1007.

Constraint Name: CLQ New Source Review NOX Facility Specific Constr Constraint #: 77
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3572	0.3572	0.3572
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3572	0.3572	0.3572
TBtu Consumed	0.000	0.000	11.52	11.52	11.52
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.161	1.161	1.161
TWh Generated Qualifying	0.000	0.000	1.161	1.161	1.161
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1065.	494.6	0.000

Constraint Name: CLP New Source Review NOX Facility Specific Constr Constraint #: 78
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3843	0.3843	0.3843
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3843	0.3843	0.3843
TBtu Consumed	0.000	0.000	12.40	12.40	12.40
Rate - [lb/MMBtu]	0.000	0.000	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	0.000	0.000	1.236	1.236	1.236
TWh Generated Qualifying	0.000	0.000	1.236	1.236	1.236
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	1032.	340.2	37.29

Constraint Name: CJG New Source Review NOX Facility Specific Constr Constraint #: 79
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
-Emissions at Affected Plants [MTons]	0.000	1.169	1.169	1.169	1.169
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.169	1.169	1.169	1.169
TBtu Consumed	0.000	38.98	38.98	38.98	38.98
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	3.880	3.880	3.880	3.880
TWh Generated Qualifying	0.000	3.880	3.880	3.880	3.880
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.3241E+05	0.3246E+05	0.3702E+05	0.3713E+05

Constraint Name: CGW New Source Review NOX Facility Specific Constr Constraint #: 80
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	1.484	1.437	1.437	1.437	1.437
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.484	1.437	1.437	1.437	1.437
TBtu Consumed	47.88	47.89	47.89	47.89	47.89
Rate - [lb/MMBtu]	0.6200E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	4.466	4.468	4.468	4.468	4.468
TWh Generated Qualifying	4.466	4.468	4.468	4.468	4.468
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	55.86	0.000	0.000	0.000	0.000

Constraint Name: CFI New Source Review NOX Facility Specific Constr Constraint #: 81
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
-Emissions at Affected Plants [MTons]	0.9845	0.9845	0.9845	0.9845	0.9845
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9845	0.9845	0.9845	0.9845	0.9845
TBtu Consumed	31.76	31.76	31.76	31.76	31.76
Rate - [lb/MMBtu]	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01	0.6200E-01
TWh Generated	3.269	3.269	3.269	3.269	3.269
TWh Generated Qualifying	3.269	3.269	3.269	3.269	3.269
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	4471.	364.8	3029.	0.000	0.000

Constraint Name: CSD New Source Review SO2 Facility Specific Constr Constraint #: 82
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.842	1.834	1.834	1.834
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.842	1.834	1.834	1.834
TBtu Consumed	0.000	21.06	20.96	20.96	20.96
Rate - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
TWh Generated	0.000	1.972	1.962	1.962	1.962
TWh Generated Qualifying	0.000	1.972	1.962	1.962	1.962
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	718.6	654.2	594.6	648.9

Constraint Name: CSC New Source Review SO2 Facility Specific Constr Constraint #: 83
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
-Emissions at Affected Plants [MTons]	0.000	1.842	1.834	1.834	1.834
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.842	1.834	1.834	1.834
TBtu Consumed	0.000	21.06	20.96	20.96	20.96
Rate - [lb/MMBtu]	0.000	0.1750	0.1750	0.1750	0.1750
TWh Generated	0.000	1.972	1.962	1.962	1.962
TWh Generated Qualifying	0.000	1.972	1.962	1.962	1.962
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	718.6	654.2	594.6	648.9

Constraint Name: CPX New Source Review SO2 Facility Specific Constr Constraint #: 84
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7440.	8838.	9400.

Constraint Name: CPW New Source Review SO2 Facility Specific Constr Constraint #: 85
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7440.	8838.	9400.

Constraint Name: CPV New Source Review SO2 Facility Specific Constr Constraint #: 86
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7440.	8838.	9400.

Constraint Name: CPS New Source Review SO2 Facility Specific Constr Constraint #: 87
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	7440.	8838.	9400.

Constraint Name: CNM New Source Review SO2 Facility Specific Constr Constraint #: 88
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.877	1.822	1.822
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.877	1.822	1.822
TBtu Consumed	0.000	0.000	22.89	22.22	22.22
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	2.229	2.163	2.163
TWh Generated Qualifying	0.000	0.000	2.229	2.163	2.163
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4219.	3315.	1749.

Constraint Name: CNL New Source Review SO2 Facility Specific Constr Constraint #: 89
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.757	1.710	1.704
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.757	1.710	1.704
TBtu Consumed	0.000	0.000	21.43	20.86	20.78
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	2.131	2.074	2.066
TWh Generated Qualifying	0.000	0.000	2.131	2.074	2.066
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4353.	3315.	1749.

Constraint Name: CNK New Source Review SO2 Facility Specific Constr Constraint #: 90
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.578	1.578	1.578
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.578	1.578	1.578
TBtu Consumed	0.000	0.000	19.25	19.25	19.25
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.885	1.885	1.885
TWh Generated Qualifying	0.000	0.000	1.885	1.885	1.885
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	3931.	3315.	1749.

Constraint Name: CNJ New Source Review SO2 Facility Specific Constr Constraint #: 91
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
-Emissions at Affected Plants [MTons]	0.000	0.000	1.533	1.533	1.533
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.533	1.533	1.533
TBtu Consumed	0.000	0.000	18.70	18.70	18.70
Rate - [lb/MMBtu]	0.000	0.000	0.1640	0.1640	0.1640
TWh Generated	0.000	0.000	1.863	1.863	1.863
TWh Generated Qualifying	0.000	0.000	1.863	1.863	1.863
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	4074.	3315.	1749.

Constraint Name: CMY New Source Review SO2 Facility Specific Constr Constraint #: 92
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.1600	0.1600	0.1600	0.1600	0.1600
-Emissions at Affected Plants [MTons]	3.765	3.813	3.854	3.568	3.253
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.765	3.813	3.854	3.568	3.253
TBtu Consumed	47.06	47.66	48.18	44.60	40.66
Rate - [lb/MMBtu]	0.1600	0.1600	0.1600	0.1600	0.1600
TWh Generated	4.251	4.304	4.351	4.028	3.672
TWh Generated Qualifying	4.251	4.304	4.351	4.028	3.672
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2319.	1437.	1510.	1103.	1431.

Constraint Name: CLS New Source Review SO2 Facility Specific Constr Constraint #: 93
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	3.648	3.648	3.648	3.648
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.648	3.648	3.648	3.648
TBtu Consumed	0.000	55.27	55.27	55.27	55.27
Rate - [lb/MMBtu]	0.000	0.1320	0.1320	0.1320	0.1320
TWh Generated	0.000	5.256	5.256	5.256	5.256
TWh Generated Qualifying	0.000	5.256	5.256	5.256	5.256
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1989E+05	0.1685E+05	0.1853E+05	0.1573E+05

Constraint Name: CLR New Source Review SO2 Facility Specific Constr Constraint #: 94
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
-Emissions at Affected Plants [MTons]	0.000	0.000	1.715	1.715	1.715
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.715	1.715	1.715
TBtu Consumed	0.000	0.000	25.99	25.99	25.99
Rate - [lb/MMBtu]	0.000	0.000	0.1320	0.1320	0.1320
TWh Generated	0.000	0.000	2.375	2.375	2.375
TWh Generated Qualifying	0.000	0.000	2.375	2.375	2.375
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	517.8	264.6	163.1

Constraint Name: CGQ New Source Review SO2 Facility Specific Constr Constraint #: 95
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	1.916	1.911	1.911
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	1.916	1.911	1.911
TBtu Consumed	0.000	0.000	25.55	25.48	25.48
Rate - [lb/MMBtu]	0.000	0.000	0.1500	0.1500	0.1500
TWh Generated	0.000	0.000	2.336	2.329	2.329
TWh Generated Qualifying	0.000	0.000	2.336	2.329	2.329
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	446.5	319.9	285.0

Constraint Name: CGP New Source Review SO2 Facility Specific Constr Constraint #: 96
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2007 WINTER SUMMER
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2026 WINTER SUMMER

Time Base: Seasonal/Annual	2007-2007	2008-2012	2013-2017	2018-2022	2023-2030
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.895	1.916	1.911	1.911
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.895	1.916	1.911	1.911
TBtu Consumed	0.000	25.26	25.55	25.48	25.48
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	2.310	2.336	2.329	2.329
TWh Generated Qualifying	0.000	2.310	2.336	2.329	2.329
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	494.8	438.9	319.9	285.0