

NEW COAL-FIRED POWER PLANT PERFORMANCE AND COST ESTIMATES

SL-009808

AUGUST 28, 2009
PROJECT 12301-003

PREPARED BY





55 East Monroe Street • Chicago, IL 60603-5780 USA • 312-269-2000
www.sargentlundy.com


LEGAL NOTICE

This report was prepared by Sargent & Lundy, L.L.C., hereinafter referred to as S&L, expressly for Perrin Quarles Associates, Inc., hereinafter referred to as PQA, in support of work for the U.S. Environmental Protection Agency (EPA) under EPA Contract No. EP-W-07-064. Neither S&L nor any person acting on its behalf (a) makes any warranty, express or implied, with respect to the use of any information or methods disclosed in this report or (b) assumes any liability with respect to the use of any information or methods disclosed in this report. Although prepared with EPA funding and reviewed by the EPA, this report has not been approved by the EPA for publication as an EPA report. The contents do not necessarily reflect the views or policies of the EPA, nor does mention of trade names or commercial products constitute endorsement or recommendation for use.

SARGENT & LUNDY, L.L.C - CONTRIBUTORS

PREPARED BY: 
David Hasler
Senior Process Engineer

REVIEWED BY: 
William Rosenquist
Technical Advisor

APPROVED BY:  8/27/09
Raj Gaikwad Date
Vice President,
Advanced Fossil Technologies

U.S. Environmental Protection Agency – Reviewer

William Stevens
Senior Advisor – Power Technology
Office of Atmospheric Programs

CONTENTS

| Section | Page |
|--|------------|
| 1. INTRODUCTION | 1-1 |
| 2. PC POWER PLANT PERFORMANCE ESTIMATES | 2-1 |
| 2.1 THERMAL CYCLES..... | 2-1 |
| 2.2 MATERIAL HANDLING..... | 2-2 |
| 2.3 BOILER SYSTEM | 2-2 |
| 2.4 ENVIRONMENTAL CONTROLS..... | 2-3 |
| 3. PC POWER PLANT CAPITAL, FIXED, VARIABLE, AND TOTAL PROJECT COST ESTIMATES..... | 3-1 |
| 3.1 COST ESTIMATE METHODOLOGY..... | 3-1 |
| 3.2 CAPITAL COSTS | 3-2 |
| 4. 600-MW NET IGCC PERFORMANCE ESTIMATES..... | 4-1 |
| 4.1 IGCC CONCEPTUAL DESIGN | 4-1 |
| 4.2 AIR SEPARATION UNIT..... | 4-1 |
| 4.3 COAL HANDLING..... | 4-2 |
| 4.4 GASIFICATION ISLAND | 4-2 |
| 4.5 THERMAL CYCLE | 4-3 |
| 4.6 PERFORMANCE | 4-3 |
| 5. IGCC PLANT COST ESTIMATES..... | 5-1 |
| 5.1 COST ESTIMATE METHODOLOGY..... | 5-1 |
| 5.2 COST ESTIMATES..... | 5-2 |
| 6. REFERENCES | 6-1 |

TABLES AND FIGURES

| No. | Page |
|---|------|
| Table 2-1. Cycle Conditions Used for Performance Estimates | 2-1 |
| Table 2-2. PC Performance Estimates Reported as Net Heat Rate (Btu/kWh) | 2-4 |
| Table 2-3. PC Performance Estimates Reported as Net Plant Efficiency (100%) | 2-4 |
| Table 3-1. Total Installed Cost Estimates ($\pm 30\%$) for Various PC Plants (\$2008/kW Net) | 3-4 |
| Table 4-1. 600-MW Net SC and IGCC Performance Reported as Heat Rate (Btu/kWh Net) and Thermal Efficiency (% Net) | 4-4 |
| Table 5-1. Total Installed Cost Estimates ($\pm 30\%$) for SC and IGCC Plants Based on Comparable 600-MW Net Output (\$2008/kW Net) | 5-2 |
| Figure 2-1. Bituminous Plant Performance Represented by Net Heat Rate | 2-5 |
| Figure 2-2. PRB Plant Performance Represented by Net Heat Rate | 2-6 |
| Figure 2-3. Lignite Plant Performance Represented by Net Heat Rate | 2-6 |

APPENDIXES

- A. PC Power Plant Performance and Cost Estimate Spreadsheets
- B. PC Power Plant Cost Estimate Details
- C. PC Power Plant Heat Balances
- D. PC Power Plant Heat Balance Calculation Details
- E. SC and IGCC Power Plant Performance and Cost Estimate Spreadsheets
- F. IGCC Power Plant Cost Estimate Details
- G. SC and IGCC Power Plant Heat Balances

1. INTRODUCTION

On behalf of Perrin Quarles Associates, Inc. (PQA), Sargent & Lundy, L.L.C. (S&L) developed for the EPA estimates of performance and order-of-magnitude costs of conventional pulverized coal (PC) and integrated gasification combined cycle (IGCC) power plants. The estimates cover a range of coals and plant sizes. PC analyses consider plant sizes of 400, 600, and 900 MW gross, and subcritical (subC), supercritical (SC), ultra-supercritical (USC), and advanced ultra-supercritical (AUSC) steam cycles, on greenfield sites. Coal types evaluated are Illinois bituminous No. 6, Texas lignite, and Powder River Basin (PRB). IGCC plant analyses are based on the same three coals, at a 600-MW net plant size.

This report summarizes the S&L estimates of performance, total installed cost (TIC), and operations and maintenance (O&M) cost for conventional PC power plants and for IGCC plants. The Appendixes provided include the details of these estimates.

The TIC as developed in this report includes cost escalation and interest during construction (IDC). Sufficient detail is provided to derive overnight costs, excluding escalation, with or without IDC. All costs in this report are based on mid-2008 market conditions, and are expressed in 2008 U.S. dollars, and therefore, likely reflect a historical peak in U.S. and global costs for power plant equipment, materials, labor, services, etc. Any subsequent moderation of market price levels that may have occurred - in connection with the global economic recession, which commenced in 2008 - is not reflected in this report.

2. PC POWER PLANT PERFORMANCE ESTIMATES

2.1 THERMAL CYCLES

Performance is compared for four PC plant types, with the steam conditions shown in Table 2-1, representing subC, SC, USC, and AUSC thermal cycles. These steam conditions are considered representative of current market offerings in the U.S., except for the AUSC plant. Materials and equipment for the AUSC thermal cycle require further development and are not likely to be constructed in the U.S. in the near future.

Table 2-1. Cycle Conditions Used for Performance Estimates

| Plant Type | Main Steam Pressure (psia) | Main Steam Temperature (°F) | Reheat Steam Temperature (°F) |
|-------------------|-----------------------------------|------------------------------------|--------------------------------------|
| subC | 2535 | 1050 | 1050 |
| SC | 3690 | 1050 | 1100 |
| USC | 3748 | 1100 | 1100 |
| AUSC | 4515 | 1300 | 1300 |

Steam turbines considered in the performance analyses include HP, IP, and LP sections configured in a tandem-compound arrangement, consisting of one HP, one IP, and opposed-flow LP turbines. The number of LP opposed-flow turbines varies based on size of the power plant. The 400-, 600-, and 900-MW plants were simulated with two, four, and six opposed-flow LP turbines, respectively. The steam turbine drives a single 3600-rpm electric generator.

Thermal cycles are based on a modified Rankine cycle, which uses feedwater heaters supplied with extraction steam from various stages of the turbines to preheat boiler feedwater prior to its entering the steam generator (boiler). The number of heaters considered in the performance analyses represents designs typically seen in commercial construction of U.S. power plants, and is a tradeoff between thermal efficiency and capital costs.

The subC case uses seven feedwater heaters, including one direct-contact type (Appendix C). Heaters 1-4 are supplied with steam extracted from the LP turbine; heater 5 is the deaerator, using steam from the IP turbine exhaust; heater 6 is supplied with IP turbine extraction steam; and heater 7 is supplied with HP turbine exhaust steam.

Both the SC and the USC cases involve eight feedwater heaters (Appendix C), with a distribution similar to the subC case except that the extra heater (8) is supplied with extraction steam from the HP turbine. The heater

configurations used for the SC and USC cases are commonly referred to as a *HARP* system, which is a Heater Above the Reheat Point of the turbine steam flow path.

Boiler feedwater is pressurized with a single HP boiler feedwater pump (BFP), powered by an electric drive for the 400- and 600-MW cases and a steam turbine drive for the 900-MW case. For steam turbine-driven cases, the exhaust is directed to the LP turbine condenser. A motor-driven BFP is used for the 400- and 600-MW plant sizes because advances in LP turbine design have led to increased efficiency and availability in recent years, while the cost of larger electric motors has decreased.

The plant cooling system uses mechanical-draft cooling towers with a circulating water temperature rise of 20°F. The condensers are evaluated as multi-flow units, one per each two-flow LP unit.

2.2 MATERIAL HANDLING

The material handling equipment electrical loads include items such as intermittent rail car unloading, conveyors and crushers. The electrical demand is intermittent and therefore an average load is used for auxiliary power consumption estimates.

The ash handling system encompasses equipment required to remove ash from the boiler, economizer, air heater, baghouse, and wet electrostatic precipitator (ESP) collection systems. Conveying equipment electrical loads include LP compressors, drag chains, fans, and conveyors. The average electrical load required by intermittent operation of the equipment is considered in the auxiliary power requirements.

2.3 BOILER SYSTEM

The total number of pulverizers (including one spare) and their associated power requirement is based on plant size and coal type. The 400-MW plant uses five pulverizers for bituminous and PRB cases, and six for lignite; the 600-MW plant uses six pulverizers for bituminous and PRB, and seven for lignite; and the 900-MW plant uses seven pulverizers for bituminous and PRB, and eight for lignite.

Estimated boiler performance is based on a balanced-draft unit operating with low-NO_x combustion systems and a submerged flight conveyor system for bottom ash removal. Steam is heated in the primary and secondary superheater sections and one reheater section. An economizer preheats feedwater prior to its entering the boiler water walls. Combustion air is preheated with one trisector air preheater in the 400-MW case and with two in the 600- and 900-MW cases.

Combustion air is delivered to the boiler by forced draft (FD) and primary air (PA) fans. Induced draft (ID) fans are used to transfer combustion gases through a flue gas desulfurization (FGD) system, baghouse, and stack. The 400-MW case uses a fan arrangement of 1 PA/1 FD/1 ID, and the 600- and 900-MW cases use a 2 PA/2 FD/2 ID fan arrangement (axial ID fans for 900-MW case). Fan power requirements are based on the fan arrangements, the estimated gas flows for each specific coal case, and the specific environmental equipment for each case.

2.4 ENVIRONMENTAL CONTROLS

NO_x formed in the boiler furnace is converted to nitrogen and water by catalytic reaction with ammonia in a selective catalytic reduction reactor (SCR). The pressure drop incurred by flue gas flowing through the SCR is accounted for in the fan power requirements.

SO₂ and SO₃ produced during the combustion of coal, and SO₃ formed in the SCR, are removed from the flue gas with a wet FGD system, wet ESP, or spray dryer absorber. The type of FGD is dependent on the coal burned, permitting requirements, and economic factors. For this conceptual performance estimate, the bituminous and lignite cases are both evaluated with wet FGD, whereas the PRB case is evaluated with spray dryer absorbers. A wet ESP is included to mitigate H₂SO₄ emissions for the bituminous coal case; using one wet ESP in the 400-MW case, two for the 600-MW case, and three for 900-MW case. PRB fuel cases are evaluated with one spray dryer absorber module for the 400-MW case, two for the 600-MW case, and three for the 900-MW case. All FGD power requirements related to limestone or lime preparation and conveyance, calcium sulfate product transfer and dewatering and general FGD operation are included in the auxiliary power requirements. Additionally, the pressure drop incurred by flue gas flowing through the absorbers is accounted for in the ID fan requirements.

Ash particles entrained with flue gas leaving the boiler are removed with a fabric filter baghouse system. Flue gas pressure drop through the baghouse is accounted for in the ID fan power requirements. Power required to operate the baghouse, such as compressor power for back-pulsing, is also included in auxiliary power requirements. One baghouse is included for the 400-MW case, two for 600-MW case, and three for the 900-MW case.

Mercury removal is achieved by activated carbon injection (ACI - brominated) into the flue gas and by mercury-bound particulate capture in the baghouse for the PRB and lignite cases. The bituminous case does not include ACI because the majority of the mercury is in the ionic form and is captured in the wet FGD system. The inherent capture of mercury in the bituminous case is due to significant levels of chloride and its ability to generate ionic mercury.

Results from the performance estimate analyses, net plant heat rate and net plant efficiency, are summarized in Table 2-2 and Table 2-3, below. Coal heating value, as used in the heat rate calculation, is the higher heating value (HHV), which accounts for all heat generated by combustion of the coal, including the heat of condensation of any water formed during the combustion process. Plant size, represented by gross generator output in megawatts, includes auxiliary power used internally by the plant. Performance calculations are based on ambient conditions of 59°F, 60% relative humidity, and sea level elevation. Details of the performance analyses, including heat rate calculations and air emissions, are presented in Appendix A.

Table 2-2. PC Performance Estimates Reported as Net Heat Rate (Btu/kWh)

| Plant Type | MW Gross (Btu/kW net) | | | | | | | | |
|------------|-----------------------|-------|-------|-------|-------|-------|---------------|-------|-------|
| | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
| | Bituminous | | | PRB | | | Texas Lignite | | |
| subC | 9,349 | 9,302 | 9,291 | 9,423 | 9,369 | 9,360 | 9,963 | 9,912 | 9,901 |
| SC | 9,058 | 9,017 | 8,990 | 9,128 | 9,080 | 9,057 | 9,647 | 9,603 | 9,576 |
| USC | 8,924 | 8,874 | 8,855 | 8,993 | 8,937 | 8,921 | 9,502 | 9,449 | 9,430 |
| AUSC | 8,349 | 8,305 | 8,279 | 8,414 | 8,363 | 8,341 | 8,882 | 8,834 | 8,808 |

Table 2-3. PC Performance Estimates Reported as Net Plant Efficiency (100%)

| Plant Type | MW Gross (η % net) | | | | | | | | |
|------------|--------------------------|------|------|------|------|------|---------------|------|------|
| | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
| | Bituminous | | | PRB | | | Texas Lignite | | |
| subC | 36.5 | 36.7 | 36.7 | 36.2 | 36.4 | 36.5 | 34.2 | 34.4 | 34.5 |
| SC | 37.7 | 37.8 | 38.0 | 37.4 | 37.6 | 37.7 | 35.4 | 35.5 | 35.6 |
| USC | 38.2 | 38.4 | 38.5 | 37.9 | 38.2 | 38.2 | 35.9 | 36.1 | 36.2 |
| AUSC | 40.9 | 41.1 | 41.2 | 40.6 | 40.8 | 40.9 | 38.4 | 38.6 | 38.7 |

The data presented in Table 2-2 and Table 2-3 and the figures below show the effects of plant scale, fuel type, and thermal cycle on the net plant heat rate and efficiency. Plants exhibit improved performance as the gross generation capacity is increased, which is the result of efficiencies of scale. These efficiencies are derived from a plantwide reduction in heat and friction process losses per unit of gross power generated.

Plant efficiency is strongly affected by fuel moisture content. As the fuel is varied from bituminous to PRB and lignite, plant performance decreases due to the corresponding increase in coal moisture content. Also note that

although the sulfur content of PRB is significantly lower than that of bituminous, thus allowing PRB to use a spray dryer FGD with its lower auxiliary power requirements, the adverse effects of higher PRB moisture content on boiler efficiency and plant heat rate more than offset PRB reduced FGD auxiliary power load.

The various thermal cycles affects plant performance by increasing the pressure and temperature of steam going to the steam turbine-generator. The increase in steam conditions (primarily the higher temperature) provides more energy that can be converted to shaft power in the steam turbine per pound of fuel combusted in the boiler. A comparison of the first three types of thermal cycle evaluated reveals that the subC to SC transition increases efficiency by approximately 1.2 percentage points at the 900-MW scale. The change in performance between SC and USC is about half of the initial subC to SC transition. The smaller increase is due primarily to the fact that only reheat temperature was increased in the transition to the USC cycle. The AUSC plant performance provides insight into potential efficiencies that may be realized by higher temperature designs. At the 900-MW scale, the transition from subC to AUSC could provide an approximate 4.4 percentage points increase in overall efficiency. The large increase in efficiency results from raising both the steam pressure and the main and reheat steam temperatures significantly above the values used for either the SC or USC cycles.

Figure 2-1. Bituminous Plant Performance Represented by Net Heat Rate




Figure 2-2. PRB Plant Performance Represented by Net Heat Rate





Figure 2-3. Lignite Plant Performance Represented by Net Heat Rate



3. PC POWER PLANT CAPITAL, FIXED, VARIABLE, AND TOTAL PROJECT COST ESTIMATES

3.1 COST ESTIMATE METHODOLOGY

Capital, fixed, and variable O&M costs are estimated based on 2008 market conditions and expressed in 2008 U.S. dollars. Plant conceptual designs are based on a greenfield site. Actual project capital costs may deviate significantly due to differences in the particular technologies chosen, the region where the plant is built, and the Owner's financing strategy. Fixed O&M costs are based on specific equipment maintenance requirements, operating and administrative labor, and industry standards. Variable O&M cost is primarily affected by changes in waste generation and consumables such as reagents, water, and catalysts.

Different coal types, with differing moisture, sulfur, and ash contents, can have a significant impact on plant design and cost. Lower-rank coals (PRB and lignite), with their lower heating values, require higher fuel feed rates and need larger or multiple pieces of equipment to obtain the same gross generation as a bituminous fired plant. Higher coal feed rate particularly affects the coal handling and pulverizer systems. For lignite, some of the additional costs of higher feed rate may be offset because such plants generally are associated with mine-mouth sites and do not require rail car dumpers or a loop track. Higher-ash coals, particularly lignite, increase the amount of ash produced and the associated cost of equipment to remove, cool, and transport the ash.

The use of higher moisture coals (PRB and lignite) reduces boiler efficiency because water in the coal is vaporized during the combustion process and the heat of vaporization is not recovered. The significant amount of heat used to vaporize water in the coal reduces the amount of heat available to generate steam in the boiler. Because higher moisture coals exhibit a lower heating value per pound of fuel, the overall size of the boiler must be increased to accommodate the increased amount of coal and air required per kilowatt of power produced. Likewise, lower-rank coals produce more flue gas per British thermal unit (Btu) of coal burned, and this increases the cost of fans (PA, FD, ID), which transport combustion air and flue gas through the boiler and pulverizers, flue gas ductwork, SCR, baghouse, FGD, and chimney.

The higher steam pressures and temperatures of advanced thermal cycles generally increase costs for the boiler, steam turbine (primarily HP), feedwater heaters, pumps, valves, and the associated piping. Either thicker-walled tubing, headers, and piping or more creep- and corrosion-resistant steels and alloys must be used, at greater expense. BFP motor or steam turbine drive costs are also increased at higher pressures.

Emission of sulfur oxides (SO_2 , SO_3) produced by the combustion of coal is controlled to an assumed permit limit by the FGD system. Higher-sulfur coal increases FGD costs due to the impacts of higher materials throughput. Items affected range from pumps, motors, and piping, to limestone preparation and gypsum handling equipment. With wet FGD there is also the requirement for a corrosion resistant wet chimney stack/liner due to the saturated moisture condition of flue gas leaving the FGD. Higher-sulfur coals also increase the formation of sulfuric acid mist, which is captured in a wet ESP to meet environmental regulations. Material, transport and landfill costs are also affected by the increased material handling requirements of higher-sulfur coals.

Removal of mercury from flue gas is achieved by ACI and subsequent mercury-bound particulate capture in the baghouse for the PRB and lignite cases. The bituminous case does not include ACI because most of the mercury is in ionic form and is captured in the wet FGD system. For ACI-baghouse cases, fixed O&M cost includes the filter bag replacement. Variable O&M cost is a function of the mercury content of the coal, which drives the costs of ACI sorbent, material transport, and landfill.

The AUSC analysis does not include capital or O&M cost estimates. Commercial development of AUSC technology in the U.S. stalled after the original units were built in the 1950s (Eddystone Unit 1 (5000 psi / 1200/1050/1050F) and Philo Unit 6 (4500 psi / 1150/1050/1000F)). This lack of development was primarily the result of economic factors. AUSC boiler pressure parts and related equipment pose a cost risk because of the need for very expensive materials, such as nickel-based super-alloys in their construction. Such materials are necessary at the high AUSC steam temperatures to handle high-sulfur coals and cycling operations. AUSC boilers can be manufactured today, but the economic risks associated with this unproven technology in the current market, outweigh the higher efficiencies to be gained. Steam turbines, on the other hand, are not exposed to the highly corrosive environments that boilers must endure and therefore, present less economic risk for long-term operation at AUSC temperatures. Overall, the cost of an AUSC boiler may actually become similar to a more conventional unit when all other items are accounted for, because the more efficient cycle requires less material throughput per kilowatt-hour generated. The higher efficiency would reduce the capacity requirements and physical sizes of various pieces of equipment, possibly lowering the overall cost of an AUSC plant. The performance of more advanced alloys is being actively investigated in the U.S., Western Europe, and Japan. If these developments are successful, they might become economic for commercial use in future advanced PC plants.

3.2 CAPITAL COSTS

The TIC as conceptually estimated for this report, includes all costs associated with constructing and financing a new coal-based power plant. Labor rate is based on conditions in the Gulf Coast.

In addition to the direct costs of structures, equipment, materials, labor, etc (Appendix B), the TIC includes the following: indirect project costs, contingency, Owner's costs, operating spare parts, escalation, and IDC. Generally, these additional costs vary significantly from Owner to Owner. Therefore, the estimated TIC values used in this report are intended to provide only a reasonable range of total project costs, with an accuracy of $\pm 30\%$.

Indirect project costs cover an architect and engineer's (AE) services, which include engineering, construction management, procurement expediting, startup, and commissioning. Contingency is based on a fixed percentage of 15% for the PC plants. Owner's costs are assumed to be 3%, and the operating and spare parts are accounted for as 1%. Project cost escalation for PCs is based on an annual rate of 4%, a project start date of January 2009, construction beginning by January 2011, and commercial operation by December 2013. Separate spend rate curves are developed for equipment, materials, labor, and indirect expenses. IDC is based on a 6% annual rate.

The use of an engineer, procure, and construct (EPC) lump-sum contract could increase the estimated TIC by 10-15%. The increased fees would be attributable to the EPC Contractor's fees and contingency costs associated with its exposure to financial risk stemming from unanticipated escalation in the market price for resources required for the project, as well as its liability for project schedule and performance.

The TIC estimates for the various cases are presented in Table 3-1. The costs are all-inclusive, representing all costs that may be incurred at completion of a PC project in 2013. The results indicate that the PRB-based plant is least expensive on a dollar per net kilowatt basis, followed by the bituminous and the lignite-based plants. This ordering of costs derives from characteristics of the coal types and the associated effects on the plant design. Compared with the PRB case, a plant designed for the bituminous coal as used in this report will include higher capital cost items, such as a wet FGD, wet ESP, and acid-resistant chimney liner, and its net kilowatt power output will be reduced due to a higher auxiliary power requirement. Although PRB coal requires a larger boiler and coal handling system than bituminous, due to PRB's greater fuel input per kilowatt of generation, that extra cost does not outweigh the even higher cost of wet FGD and wet ESP equipment associated with the high-sulfur bituminous case. Lignite requires the same type of emission control equipment as the bituminous case, excepting wet ESP, because of its significant sulfur content, and lignite necessitates an even larger boiler than PRB because it has the lowest heating value of the three fuels.

Table 3-1. Total Installed Cost Estimates ($\pm 30\%$) for Various PC Plants (\$2008/kW Net)

| Plant Type | MW Gross (\$/kW net) | | | | | | | | |
|------------|----------------------|-------|-------|-------|-------|-------|---------------|-------|-------|
| | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
| | Bituminous | | | PRB | | | Texas Lignite | | |
| subC | 4,523 | 3,844 | 3,190 | 4,186 | 3,555 | 2,951 | 4,760 | 4,045 | 3,357 |
| SC | 4,686 | 3,982 | 3,262 | 4,332 | 3,679 | 3,015 | 4,931 | 4,190 | 3,433 |
| USC | 4,835 | 4,109 | 3,362 | 4,466 | 3,792 | 3,105 | 5,090 | 4,325 | 3,540 |

4. 600-MW NET IGCC PERFORMANCE ESTIMATES

Estimated performance and total installed cost are compared for an IGCC plant and a conventional PC-fired SC plant. For this comparison, performance and costs were developed at 600-MW net output for both plants, and for the same three coal types as used in the PC-fired analysis presented in Sections 2 and 3.

4.1 IGCC CONCEPTUAL DESIGN

The assumed design basis for IGCC incorporates current industry trends in plant configuration, and uses the same site conditions as described for the PC plant analyses. The IGCC plant conceptual design is based on two gasification and cleanup trains supplying synthesis gas (syngas) fuel to two F-Class combustion turbine generators (CTGs), two heat recovery steam generators (HRSGs), and one steam turbine (STG). Each gasification train includes an air separation unit (ASU). Plant integration includes the transfer of steam, cooling water, and gases between the gasification island and the combined cycle power block. The gasification island is modeled with process simulation software (AspenPlus™); the power block is modeled with GateCycle™. The gasifier is based on Shell's entrained flow, oxygen-fired technology. The use of one gasification technology in this analysis is recognized as an approximation and a convenience, as other gasifiers in fact perform differently on some of the coal types considered. The selected gasifier does have a history of performance on coals similar to the three types used in this analysis, and a significant amount of performance information available in the open literature [Ref. 1].

4.2 AIR SEPARATION UNIT

The ASU produces oxygen and nitrogen streams used in the IGCC plant. The main liquid oxygen (O₂) stream is pumped to high pressure and then vaporized prior to sending it to the gasifier. A smaller, low-pressure O₂ stream is used in the Claus sulfur removal unit. The majority of the nitrogen (N₂) is compressed and sent back to the CTG as a syngas diluent. The remaining N₂ is used for coal drying, pneumatic transport of coal to the gasifier, and other process purposes. Integration between the ASU and the CTG air compressor involves the supply of 35% of the air to the ASU main air compressor (MAC) by a high-pressure extraction line from the CTG. This percentage of air extraction has been the norm in recent IGCC conceptual designs; but in practice, integration at 0-100% has been used in actual IGCC plants. Because the ASU requires a significant amount of power for air compression, full integration between the CTG and ASU can improve IGCC plant efficiency. But the use of full CTG-ASU integration can potentially reduce the availability of the plant and increase the complexity of the system at start up if a smaller, stand alone air compressor is not included in the plant design.

4.3 COAL HANDLING

Coal handling and milling for the IGCC are based on conventional equipment. Because the selected gasifier operates on a dry coal feed that is pneumatically injected into the gasifier, the coal must be dried to a specific moisture content to prevent flow instability. Coal is dried by pre-heated air as it flows through pulverizers. The air used for coal drying is heated with medium pressure (MP) steam produced in the gasification island. Drying air is supplemented with excess N₂ from the ASU to reduce its oxygen concentration and prevent coal fires. Dried pulverized coal is separated from its transport air in a baghouse and stored in silos. It then flows to lock-hoppers and is pneumatically injected into the gasifiers with high pressure (HP) N₂. The performance analysis is based on drying bituminous coal to 2%wt moisture content, PRB to 6%wt, and lignite to 7%wt. Low-moisture content in coal provides for effective transport of pulverized coal through the injection system.

4.4 GASIFICATION ISLAND

High-temperature syngas, produced by reacting the coal with oxygen and steam in the gasifier, is initially quenched by cooled syngas that has been recompressed and recycled back to the gasifier. After the gasifier, syngas is further cooled in a syngas cooler, generating steam. The syngas cooler provides both MP saturated steam and HP superheated steam. This HP steam is mixed with HP steam generated in the HRSG as main steam to the HP STG. MP steam is used in the ASU, the sulfur removal unit, and for coal drying. Additional LP steam is produced by further cooling of the syngas and is used in the ASU, acid gas removal unit, and sour water stripper.

The syngas particulate cleanup portion of the plant uses a high-temperature cyclone, candle filter, and low-temperature water scrubber. The cyclone and candle filter remove the majority of particulates, while the very fine particles are removed in a counter-flow water scrubber. Approximately half of the syngas is compressed and recycled back to the gasifier for quenching after flowing through the cyclone and candle filter. The remaining syngas enters the water scrubber, which removes the remaining fine particulates and absorbs most of the ammonia, hydrochloric acid, and other ionic compounds generated in the gasifier.

The majority of the ash present in the coal is liquefied in the gasifier and flows down through the bottom of the vessel into a water quench system. Solidified slag is removed via a crushing, cooling, and depressurization process before separation from the water for temporary storage and transport.

After particulate cleanup the syngas is processed in an acid gas removal (AGR) system to remove sulfur. Sulfur is present primarily in the form of hydrogen sulfide (H₂S) and carbonyl sulfide (COS). The AGR converts carbonyl

sulfide to hydrogen sulfide by reacting it with steam in a catalytic reactor. H₂S is separated from the syngas by preferential absorption in a gas-liquid absorption column.

Mercury is removed from the syngas by chemisorption onto the surface of activated carbon pellets in a packed bed vessel through which the syngas flows.

H₂S separated from the syngas in the AGR is converted to elemental sulfur in a Claus unit. Approximately a third of the H₂S is reacted with O₂ to generate SO₂. The remaining H₂S is then catalytically reacted with the SO₂ to form elemental sulfur. Unconverted gases are recycled back to the AGR.

4.5 THERMAL CYCLE

Clean syngas is diluted and reheated before being combusted in the CTG. The diluent consists of steam and N₂. The steam is extracted from the power block, and N₂, which is a product of the ASU, is compressed before mixing with the syngas. Hot exhaust gas from the CTG flows through the HRSG, which preheats feed water and generates main steam and reheat steam for the STG. The thermal cycle is based on conventional combined cycle conditions of 1800 psig/1000°F/1000°F.

The HRSG is configured with an SCR system for NO_x control. NO_x formed during the combustion process is converted back to N₂ by reaction with ammonia over an SCR catalyst.

4.6 PERFORMANCE

IGCC performance results are presented in Table 4-1, providing a comparison between the SC and IGCC cases.

IGCC performs better than conventional SC on all three fuel types, with the difference in performance becoming greater as the fuel moves from bituminous to the higher moisture coals. The higher efficiency of the IGCC on PRB and lignite is primarily due to the ability of the IGCC plant to pre-dry the coal prior to processing.

IGCC performance in this analysis is lower than that commonly reported for IGCC designs that are fully integrated with respect to air extraction from the CTG compressor for ASU air supply. The difference is primarily due to the increased power consumption of the ASU MAC in this analysis (compressing 65% of the air for the ASU versus extracting 100% of the air supply from the CTG compressor). IGCC units that have actually employed 100% integration are the Buggenum plant in the Netherlands and the Puertollano unit in Spain. They have yielded efficiencies over 42% (HHV basis).

**Table 4-1. 600-MW Net SC and IGCC Performance
 Reported as Heat Rate (Btu/kWh Net) and Thermal Efficiency (% Net)**

| | Bituminous | | PRB | | Lignite | |
|----------------------------|------------|-------|-------|-------|---------|-------|
| | SC | IGCC | SC | IGCC | SC | IGCC |
| Btu/kWh (net) | 9,000 | 8,425 | 9,063 | 8,062 | 9,584 | 8,515 |
| Thermal efficiency (% net) | 37.91 | 40.50 | 37.65 | 42.32 | 35.60 | 40.07 |

For this analysis, the IGCC performance with the PRB coal was more efficient than with the Illinois No. 6 bituminous coal. This is primarily due to the higher reactivity of the PRB coal and a lesser need for oxygen as a reactant in the gasifier. Similar results were reported by Shell in a paper in which they attributed this difference to the constituents of the particular Illinois No. 6 coal [Ref. 2]. Because the ASU consumes a significant amount of power to compress its air feed and oxygen product streams, a decrease in oxygen consumption by the gasification process can significantly reduce total plant auxiliary power requirements, thus increasing efficiency. The amounts of MP and LP steam used by the ASU are also reduced when the oxygen requirement of the gasifier is reduced. Furthermore, with PRB's lower sulfur content the amount of sulfur that has to be processed is significantly lower (COS hydrolysis, AGR, and Claus units affect performance through their steam and cooling demands). The gasification of PRB fuel produces a lower Btu per standard cubic foot (SCF) syngas than a bituminous fuel, which in turn, requires more syngas to be generated to fuel the CTGs and therefore more HP, MP and LP steam is generated to cool the higher mass flow of syngas. And since this analysis has included the use of a syngas cooler that generates superheated HP steam, the effects on the thermal cycle are more pronounced than if a saturated steam were produced. Further, because the PRB coal produces a lower Btu/SCF fuel, less diluent is needed prior to combustion, which reduces both steam and N₂ consumption demands. PRB's higher moisture content has a significant impact on performance because more steam is needed to dry PRB than bituminous, but the increased drying steam load for PRB does not offset the efficiency benefits of its smaller ASU and lower ash and sulfur contents.

IGCC performance on lignite is primarily affected by the fuel's moisture and ash content. The high moisture content requires a significant amount of steam for coal drying, which reduces the percentage of the steam generated in the gasification island that can be supplied to the power block. Lignite's high ash content affects gasifier performance because a considerable amount of heat is consumed to liquefy the ash into a molten slag, reducing the heat available to support endothermic gasification reactions. These negative impacts are partly offset by the highly reactive nature of the lignite, which requires less oxygen than the bituminous case. IGCC plant performance with lignite can be improved if the coal is dried to a lesser extent. Coal's inherent moisture content, and the type of

dense, pneumatic feed system used in the design, dictates the required extent of coal drying. This analysis uses a value of 7%wt, which is lower than some estimates, which indicate a 13%wt moisture content is feasible with a similar pneumatic injection system. By increasing the moisture content of the coal fed to the gasifier, the overall IGCC efficiency on lignite would increase due to the reduction in steam demand for the drying process.

An alternative IGCC design that uses a supercritical steam cycle could provide increased plant efficiency for all cases. Two concerns with such a design are that neither a HRSG nor a syngas cooler have been manufactured to operate on a SC steam cycle, and it will likely have significant cost disadvantages. Because a power plant designed around an SC thermal cycle has to take advantage of economies of scale in a competitive marketplace (450 MW or larger SC Class STG), an IGCC plant using an SC system might best be designed around the larger H-Class CTG. An IGCC design based on both an H-Class CTG and SC thermal cycle might benefit from the efficiency of SC steam conditions, but most of the efficiency improvement would likely be provided by the higher efficiency of the H-Class CTG.

5. IGCC PLANT COST ESTIMATES

5.1 COST ESTIMATE METHODOLOGY

Estimated IGCC power plant capital and fixed and variable O&M costs are based on the same principles and conventions used for the conventional PC-fired plants as explained in subsection 3.1, and the same caveats apply. Only those aspects of the IGCC plant that require a difference in the estimating approach are discussed here.

Coal reactivity determines the amount of oxygen necessary to effectively gasify the coal in an IGCC. Of the three coals compared, bituminous is the least reactive, requires the most oxygen, and therefore requires a larger ASU. The ASU constitutes a significant portion of the total plant cost. It directly affects auxiliary power consumption, and its size can therefore substantially affect plant capital and O&M costs.

Higher-moisture coals affect plant costs because the size of the equipment required to transport, mill, and dry the lower heating value fuel is increased. These coals also reduce power output from the plant as more steam is required to dry the fuel.

Higher ash coals increase costs associated with the equipment required to remove, cool, and transport the ash. Because ash content is significantly higher for the lignite, a third gasifier is added in the conceptual design to process that coal. A more cost-effective approach would scale-up the size of the gasifiers to handle the extra coal throughput and associated slag, keeping the lignite design at two gasifiers. However, it is difficult to accurately estimate an all-inclusive cost of a new gasifier design without working directly with a vendor on a specific coal. Therefore, the lignite-based IGCC cost may be significantly higher in this analysis than would otherwise be expected, due to the requirements of three standard-size gasifiers, syngas coolers, and associated coal feed and slag handling equipment. O&M costs associated with disposing gasifier slag are assumed to be negligible. Because slag is a vitreous, inert material, quite suitable for use in building products (concrete, shingles, etc.), it is assumed that it would be sold at a price equivalent to transportation costs.

The higher-sulfur bituminous coal requires larger equipment to process the sulfur byproduct. Sections of the plant most significantly affected by higher-sulfur coal are the hydrolysis reactors, the Claus unit, and the AGR. Higher-sulfur coal also requires more steam and electricity for processing the byproduct, which lowers plant thermal efficiency. O&M costs associated with sulfur processing include catalyst and chemical replacement.

Mercury removal from the syngas requires larger packed beds of activated carbon for the higher-mercury content fuels. Mercury capture itself affects O&M cost to some extent due to the necessity of handling the spent sorbent as a hazardous material.

5.2 COST ESTIMATES

The TIC as conceptually estimated for this report, includes all costs associated with constructing and financing a new IGCC power plant. The various elements of TIC for IGCC are the same as for the PC plants as explained in subsection 3.2. Only a few significant differences are discussed here. TIC estimates in this evaluation are intended only to provide a reasonable range of total project costs with an accuracy of $\pm 30\%$.

The IGCC contingency allowance is based on a fixed 20%, which is higher than the amount used for the PC plants due to the extra risk attributed to development of an IGCC plant. The project escalation amount is based on an annual rate of 4%, a project start date of January 2009, construction beginning by January 2011, and commercial operation by December 2015 for IGCC. IDC for IGCC is based on a 6% annual rate and a seven-year cash flow.

The TIC estimates for 600 MW net SC and IGCC plants are presented in Table 5-1 for comparison. The significant cost difference between the two types of plants can be attributed partly to the risks associated with financing an IGCC, but primarily to the more complex systems and advanced technology used in the IGCC plant.

**Table 5-1. Total Installed Cost Estimates ($\pm 30\%$) for SC and IGCC Plants
Based on Comparable 600-MW Net Output (\$2008/kW Net)**

| Plant Type | Bituminous | PRB | Lignite |
|-------------------|-------------------|------------|----------------|
| SC | 3,641 | 3,393 | 4,076 |
| IGCC | 4,589 | 4,652 | 5,763 |

6. REFERENCES

1. Eurlings, J. Th. G. M.; B. V. Demkolec, "Process Performance of the SCGP at Buggenum IGCC," Proceedings from the Gasification Technologies Conference, San Francisco, CA, 1999.
2. van der Ploeg, H. J.; T. Chhoa; P. L. Zuideveld, "The Shell Coal Gasification Process for the US Industry," Proceedings from the Gasification Technologies Conference, Washington, DC, 2004.

APPENDIX A

PC POWER PLANT PERFORMANCE AND COST ESTIMATE SPREADSHEETS

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Subcritical**

| | | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical |
|---|-----------------|------------------------------------|---------------------------------|-----------------------------|------------------------------------|---------------------------------|-----------------------------|------------------------------------|---------------------------------|-----------------------------|
| Base set-up for meeting Target BACT limits for NOx & SO2 | UNITS | 400MW - Subcritical PC, Bituminous | 400MW - Subcritical PC, Lignite | 400MW - Subcritical PC, PRB | 600MW - Subcritical PC, Bituminous | 600MW - Subcritical PC, Lignite | 600MW - Subcritical PC, PRB | 900MW - Subcritical PC, Bituminous | 900MW - Subcritical PC, Lignite | 900MW - Subcritical PC, PRB |
| Number of BFW Heaters | | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 | 7 |
| Number of FGD Absorbers | | 1 | 1 | 1 | 1 | 1 | 2 | 1 | 1 | 3 |
| Number of wet ESPs | | 1 | 0 | 0 | 2 | 0 | 0 | 3 | 0 | 0 |
| Number of Pulverizers | | 5 | 6 | 5 | 6 | 7 | 6 | 7 | 8 | 7 |
| SO2 | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| NOX | | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR |
| Primary Particulate Control | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Secondary Particulate Control | | Wet ESP | None | None | Wet ESP | None | None | Wet ESP | None | None |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| PLANT CONFIGURATION: (Gross-MW) | | 1x400 | 1x400 | 1x400 | 1x600 | 1x600 | 1x600 | 1x900 | 1x900 | 1x900 |
| NO. OF STEAM GENERATORS | | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler |
| Main Steam Pressure | psig | 2535 | 2535 | 2535 | 2535 | 2535 | 2535 | 2535 | 2535 | 2535 |
| Main Steam Temperature | °F | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 |
| Hot Reheat Temperature | °F | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 |
| NO. OF STEAM TURBINES | | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine |
| SOx CONTROL: | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| Uncontrolled SO2 Emission Rate | lb/mmBtu | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 |
| Target "Permit" SO ₂ Emission Rate | lb/mmBtu | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 |
| SULFUR REMOVAL percent required meet Target "Permit" Rate | % | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 |
| Typical Maximum SO2 Removal Guarantee from Vendor | % | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 |
| NOx CONTROL: | | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR |
| Uncontrolled Rate from Furnace | lb/mmBtu | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 |
| Target "Permit" NOx Emission Rate | lb/mmBtu | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 |
| Specified Design Guarantee from vendor | lb/mmBtu | 0.05 | 0.05 | 0.05 | 0.05 | 0.05 | 0.05 | 0.05 | 0.05 | 0.05 |
| PARTICULATE CONTROL | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Target "Permit" Emission Rate | lb/mmBtu | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| Cooling Method | | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT |
| PLANT PERFORMANCE: | | | | | | | | | | |
| Net Plant Heat Rate, HHV | Btu/net-kWh | 9,349 | 9,963 | 9,423 | 9,302 | 9,912 | 9,369 | 9,291 | 9,901 | 9,360 |
| Gross Plant Output | Gross-kW | 400,000 | 400,000 | 400,000 | 600,000 | 600,000 | 600,000 | 900,000 | 900,000 | 900,000 |
| Net Plant Output (based on Annual Average Conditions) | Net-kW | 359,151 | 355,843 | 362,958 | 539,059 | 534,133 | 545,152 | 828,433 | 820,750 | 837,573 |
| Gross Plant Heat Rate, HHV | Btu/gross-kWh | 8,394 | 8,863 | 8,550 | 8,358 | 8,824 | 8,513 | 8,552 | 9,030 | 8,711 |
| Auxiliary Power | kW | 40,849 | 44,157 | 37,042 | 60,941 | 65,867 | 54,848 | 71,567 | 79,250 | 62,427 |
| Turbine Heat Rate | Btu/kWh | 7,347 | 7,347 | 7,347 | 7,316 | 7,316 | 7,316 | 7,487 | 7,487 | 7,487 |
| Primary Fuel Feed Rate per Boiler | lb/hr | 288,672 | 594,036 | 408,025 | 431,129 | 887,181 | 609,379 | 661,740 | 1,361,727 | 935,335 |
| Primary Fuel Feed Rate per Boiler | Tons/hr | 144 | 297 | 204 | 216 | 444 | 305 | 331 | 681 | 468 |
| Primary Fuel Feed Rate per Boiler | lb/net-MWh | 804 | 1,669 | 1,124 | 800 | 1,661 | 1,118 | 799 | 1,659 | 1,117 |
| Full load Heat input to Boiler | mmBtu's/hr | 3,358 | 3,545 | 3,420 | 5,015 | 5,295 | 5,108 | 7,697 | 8,127 | 7,840 |
| Secondary Fuel Feed Rate | lb/hr | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Secondary Fuel Feed Rate | lb/net-MWh | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/hr | 25,433 | 13,216 | 1,920 | 37,984 | 19,739 | 2,867 | 58,302 | 30,296 | 4,401 |
| Lime/Limestone Feed Rate | lb/net-MWh | 70.8 | 37.1 | 5.3 | 70.5 | 37.0 | 5.3 | 70.4 | 36.9 | 5.3 |
| Ammonia Feed Rate(Anhydrous) | lb/hr | 264 | 210 | 203 | 297 | 314 | 303 | 456 | 482 | 465 |
| Ammonia Feed Rate | lb/net-MWh | 0.736 | 0.591 | 0.559 | 0.552 | 0.588 | 0.556 | 0.551 | 0.587 | 0.555 |
| Activated Carbon Injection Rate | lb/hr | 0 | 124 | 112 | 0 | 185 | 168 | 0 | 284 | 258 |
| Activated Carbon Injection Rate | lb/net-MWh | 0.00 | 0.35 | 0.31 | 0.00 | 0.35 | 0.31 | 0.00 | 0.35 | 0.31 |

PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Subcritical

| | | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical |
|---|--------------|---|--|------------------------------------|---|--|------------------------------------|---|--|------------------------------------|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Subcritical PC, Bituminous | 400MW - Subcritical PC, Lignite | 400MW - Subcritical PC, PRB | 600MW - Subcritical PC, Bituminous | 600MW - Subcritical PC, Lignite | 600MW - Subcritical PC, PRB | 900MW - Subcritical PC, Bituminous | 900MW - Subcritical PC, Lignite | 900MW - Subcritical PC, PRB |
| TOTAL Auxiliary Power | % | 10.21 | 11.04 | 9.26 | 10.16 | 10.98 | 9.14 | 7.95 | 8.81 | 6.94 |
| Net Unit Heat Rate | Btu/kWh | 9,349 | 9,963 | 9,423 | 9,302 | 9,912 | 9,369 | 9,291 | 9,901 | 9,360 |
| Plant Efficiency | % | 36.5 | 34.2 | 36.2 | 36.7 | 34.4 | 36.4 | 36.7 | 34.5 | 36.5 |
| ECONOMIC ANALYSIS INPUT: | | | | | | | | | | |
| 2008 to COD | years | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 |
| Start of Engineering to COD | months | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| Operating Life | years | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 |
| Fixed Labor Costs | \$ | 7,187,292 | 7,187,292 | 7,187,292 | 8,556,300 | 8,556,300 | 8,556,300 | 10,609,812 | 10,609,812 | 10,609,812 |
| Fixed Non-Labor O&M Costs | \$ | 5,280,000 | 5,280,000 | 5,280,000 | 6,660,000 | 6,660,000 | 6,660,000 | 8,460,000 | 8,460,000 | 8,460,000 |
| Total Fixed O&M Costs | \$ | 12,467,292 | 12,467,292 | 12,467,292 | 15,216,300 | 15,216,300 | 15,216,300 | 19,069,812 | 19,069,812 | 19,069,812 |
| Fixed O&M Costs | \$/net kW-yr | 34.71 | 35.04 | 34.35 | 28.23 | 28.49 | 27.91 | 23.02 | 23.23 | 22.77 |
| Property Taxes | \$/year | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 |
| FGD Reagent Cost | | | | | | | | | | |
| \$/ton, delivered | | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 |
| Activated Carbon | | | | | | | | | | |
| \$/ton, delivered | | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 |
| SCR Catalyst | | | | | | | | | | |
| \$/M ³ | | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 |
| Ammonia (Anhydrous) | | | | | | | | | | |
| \$/ton, delivered | | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 |
| Water Cost | | | | | | | | | | |
| \$/1000 gallons | | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Fly Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Fly Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Bottom Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Activated Carbon waste | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| FGD Waste Sale | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| FGD Waste Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Other Variable O&M Costs | \$/net-MWh | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| SO2 Allowance Market Cost | \$/ton | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 |
| NOX Allowance Market Cost | \$/ton | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 |
| Sulfur Byproduct | \$/ton | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| Equivalent Availability Factor | % | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Replacement Power cost | \$/gross-kWh | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 |
| Fuel Cost Delivered | \$/mmBtu | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 |
| \$/ton, delivered | | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 |
| ECONOMIC ANALYSIS OUTPUT: | | | | | | | | | | |
| Annual Capacity Factor | %/yr | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Equivalent Full Load Hours | Hr's | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 |
| Used for Potential to Emit (MW-hours@100%CF & Availability) | Mw-Hr/yr | 2,830,113 | 2,804,040 | 2,860,107 | 4,247,782 | 4,208,964 | 4,295,800 | 6,528,050 | 6,467,510 | 6,600,072 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Subcritical**

| | | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical | Subcritical |
|---|-----------|------------------------------------|---------------------------------|-----------------------------|------------------------------------|---------------------------------|-----------------------------|------------------------------------|---------------------------------|-----------------------------|
| Base set-up for meeting Target BACT limits for NOx & SO2 | UNITS | 400MW - Subcritical PC, Bituminous | 400MW - Subcritical PC, Lignite | 400MW - Subcritical PC, PRB | 600MW - Subcritical PC, Bituminous | 600MW - Subcritical PC, Lignite | 600MW - Subcritical PC, PRB | 900MW - Subcritical PC, Bituminous | 900MW - Subcritical PC, Lignite | 900MW - Subcritical PC, PRB |
| Capital costs | \$1,000 | | | | | | | | | |
| Direct & Indirect Costs \$1000 | \$1,000 | 1,624,527 | 1,693,870 | 1,519,360 | 2,071,959 | 2,160,403 | 1,937,827 | 2,642,629 | 2,755,430 | 2,471,549 |
| \$/kW Capital Cost based on net output | \$/net-kw | 4,523 | 4,760 | 4,186 | 3,844 | 4,045 | 3,555 | 3,190 | 3,357 | 2,951 |
| Capital Costs | | | | | | | | | | |
| Costs in year 2008 dollars | \$1,000 | 1,624,527 | 1,693,870 | 1,519,360 | 2,071,959 | 2,160,403 | 1,937,827 | 2,642,629 | 2,755,430 | 2,471,549 |
| Fixed O&M Costs | | | | | | | | | | |
| Fixed O&M Costs | \$1,000 | 12,467 | 12,467 | 12,467 | 15,216 | 15,216 | 15,216 | 19,070 | 19,070 | 19,070 |
| Variable O&M Costs (\$/yr) | | | | | | | | | | |
| Limestone Reagent | \$1,000 | 1,504 | 781 | 0 | 2,246 | 1,167 | 0 | 3,447 | 1,791 | 0 |
| Lime Reagent for Dry-FGD | \$1,000 | 0 | 0 | 719 | 0 | 0 | 1,074 | 0 | 0 | 1,648 |
| Activated Carbon | \$1,000 | 0 | 1,073 | 976 | 0 | 1,602 | 1,457 | 0 | 2,459 | 2,237 |
| Water | \$1,000 | 238 | 295 | 191 | 385 | 385 | 385 | 579 | 579 | 579 |
| Bottom Ash Disposal/Sale | \$1,000 | 442 | 1,679 | 290 | 659 | 2,507 | 432 | 1,012 | 3,848 | 664 |
| Fly ash sale/Disposal | \$1,000 | 1,762 | 6,710 | 1,154 | 2,632 | 10,021 | 1,724 | 4,039 | 15,381 | 2,645 |
| Gypsum sale/Disposal | \$1,000 | 3,094 | 1,614 | 305 | 4,621 | 2,411 | 565 | 7,093 | 3,700 | 867 |
| AC Waste Disposal | \$1,000 | 0 | 10 | 9 | 0 | 15 | 13 | 0 | 22 | 20 |
| Ammonia | \$1,000 | 469 | 373 | 360 | 527 | 557 | 537 | 810 | 855 | 825 |
| SCR-Catalyst Replacement | \$1,000 | 673 | 673 | 673 | 1,010 | 1,010 | 1,010 | 1,515 | 1,515 | 1,515 |
| Bags for Baghouse | \$1,000 | 210 | 242 | 231 | 336 | 380 | 346 | 516 | 583 | 531 |
| SO2 Allowances | \$1,000 | 662 | 559 | 539 | 988 | 835 | 805 | 1,517 | 1,281 | 1,236 |
| NOx Allowances | \$1,000 | 1,985 | 2,096 | 2,022 | 2,965 | 3,131 | 3,020 | 4,551 | 4,805 | 4,636 |
| Other | \$1,000 | 1,416 | 1,403 | 1,431 | 2,125 | 2,106 | 2,149 | 3,266 | 3,235 | 3,302 |
| Sulfur Sale | \$1,000 | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Total | \$1,000 | 11,550 | 17,507 | 8,900 | 18,495 | 26,125 | 13,517 | 28,345 | 40,056 | 20,705 |
| Variable O&M Costs | \$/MWh | 3.55 | 5.96 | 3.11 | 3.82 | 5.93 | 3.15 | 3.81 | 5.91 | 3.14 |
| Total Non-Fuel O&M Cost | \$1,000 | 24,017 | 29,974 | 21,367 | 33,711 | 41,341 | 28,733 | 47,415 | 59,126 | 39,775 |
| Total Non-Fuel O&M Cost | \$/MWh | 8.48 | 10.68 | 7.47 | 7.93 | 9.82 | 6.69 | 7.26 | 9.14 | 6.02 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical**

| | | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical |
|---|-----------------|---|--|--------------------------------------|---|--|--------------------------------------|---|--|--------------------------------------|
| Base set-up for meeting Target BACT limits for NOx & SO2 | UNITS | 400MW - Supercritical PC, Bituminous | 400MW - Supercritical PC, Lignite | 400MW - Supercritical PC, PRB | 600MW - Supercritical PC, Bituminous | 600MW - Supercritical PC, Lignite | 600MW - Supercritical PC, PRB | 900MW - Supercritical PC, Bituminous | 900MW - Supercritical PC, Lignite | 900MW - Supercritical PC, PRB |
| Number of BFW Heaters | | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) |
| Number of FGD Absorbers | | 1 | 1 | 1 | 1 | 1 | 2 | 1 | 1 | 3 |
| Number of wet ESPs | | 1 | 0 | 0 | 2 | 0 | 0 | 3 | 0 | 0 |
| Number of Pulverizers | | 5 | 6 | 5 | 6 | 7 | 6 | 7 | 8 | 7 |
| SO2 | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| NOX | | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR |
| Primary Particulate Control | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Secondary Particulate Control | | Wet ESP | None | None | Wet ESP | None | None | Wet ESP | None | None |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| PLANT CONFIGURATION: (Gross-MW) | | 1x400 | 1x400 | 1x400 | 1x600 | 1x600 | 1x600 | 1x900 | 1x900 | 1x900 |
| NO. OF STEAM GENERATORS | | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler |
| Main Steam Pressure | psig | 3690 | 3690 | 3690 | 3690 | 3690 | 3690 | 3690 | 3690 | 3690 |
| Main Steam Temperature | °F | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 | 1050 |
| Hot Reheat Temperature | °F | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 |
| NO. OF STEAM TURBINES | | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine |
| SOx CONTROL: | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| Uncontrolled SO2 Emission Rate | lb/mmBtu | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 |
| Target "Permit" SO2 Emission Rate | lb/mmBtu | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 |
| SULFUR REMOVAL percent required meet Target "Permit" Rate | % | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 |
| Typical Maximum SO2 Removal Guarantee from Vendor | % | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 |
| NOx CONTROL: | | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR |
| Uncontrolled Rate from Furnace | lb/mmBtu | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 |
| Target "Permit" NOx Emission Rate | lb/mmBtu | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 |
| PARTICULATE CONTROL | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Target "Permit" Emission Rate | lb/mmBtu | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| Cooling Method | | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT |
| PLANT PERFORMANCE: | | | | | | | | | | |
| Net Plant Heat Rate, HHV | Btu/net-kWh | 9,058 | 9,647 | 9,128 | 9,017 | 9,603 | 9,080 | 8,990 | 9,576 | 9,057 |
| Gross Plant Output | Gross-kW | 400,001 | 400,001 | 400,001 | 600,002 | 600,002 | 600,002 | 900,004 | 900,004 | 900,004 |
| Net Plant Output (based on Annual Average Conditions) | Net-kW | 355,105 | 352,033 | 358,912 | 532,967 | 528,392 | 539,062 | 829,725 | 822,441 | 838,866 |
| Gross Plant Heat Rate, HHV | Btu/gross-kWh | 8,041 | 8,490 | 8,191 | 8,009 | 8,456 | 8,158 | 8,288 | 8,751 | 8,442 |
| Auxiliary Power | kW | 44,896 | 47,968 | 41,089 | 67,035 | 71,610 | 60,940 | 70,279 | 77,563 | 61,138 |
| Turbine Heat Rate | Btu/kWh | 7,038 | 7,038 | 7,038 | 7,011 | 7,011 | 7,011 | 7,256 | 7,256 | 7,256 |
| Primary Fuel Feed Rate per Boiler | lb/hr | 276,536 | 569,063 | 390,871 | 413,162 | 850,208 | 583,983 | 641,330 | 1,319,728 | 906,487 |
| Primary Fuel Feed Rate per Boiler | Tons/hr | 138 | 285 | 195 | 207 | 425 | 292 | 321 | 660 | 453 |
| Primary Fuel Feed Rate per Boiler | lb/net-MWh | 779 | 1,617 | 1,089 | 775 | 1,609 | 1,083 | 773 | 1,605 | 1,081 |
| Full load Heat input to Boiler | mmBtu's/hr | 3,216 | 3,396 | 3,276 | 4,806 | 5,074 | 4,895 | 7,459 | 7,876 | 7,598 |
| Secondary Fuel Feed Rate | lb/hr | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Secondary Fuel Feed Rate | lb/net-MWh | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/hr | 24,364 | 12,661 | 1,839 | 36,401 | 18,916 | 2,748 | 56,503 | 29,362 | 4,266 |
| Lime/Limestone Feed Rate | lb/net-MWh | 68.6 | 36.0 | 5.1 | 68.3 | 35.8 | 5.1 | 68.1 | 35.7 | 5.1 |
| Ammonia Feed Rate(Anhydrous) | lb/hr | 253 | 201 | 194 | 285 | 301 | 290 | 442 | 467 | 451 |
| Ammonia Feed Rate | lb/net-MWh | 0.713 | 0.572 | 0.541 | 0.535 | 0.569 | 0.538 | 0.533 | 0.568 | 0.537 |
| Activated Carbon Injection Rate | lb/hr | 0 | 118 | 108 | 0 | 177 | 161 | 0 | 275 | 250 |
| Activated Carbon Injection Rate | lb/net-MWh | 0.00 | 0.34 | 0.30 | 0.00 | 0.34 | 0.30 | 0.00 | 0.33 | 0.30 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical**

| | | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical |
|---|--------------|---|--|--------------------------------------|---|--|--------------------------------------|---|--|--------------------------------------|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Supercritical PC, Bituminous | 400MW - Supercritical PC, Lignite | 400MW - Supercritical PC, PRB | 600MW - Supercritical PC, Bituminous | 600MW - Supercritical PC, Lignite | 600MW - Supercritical PC, PRB | 900MW - Supercritical PC, Bituminous | 900MW - Supercritical PC, Lignite | 900MW - Supercritical PC, PRB |
| TOTAL Auxiliary Power | % | 11.22 | 11.99 | 10.27 | 11.17 | 11.93 | 10.16 | 7.81 | 8.62 | 6.79 |
| Net Unit Heat Rate | Btu/kWh | 9,058 | 9,647 | 9,128 | 9,017 | 9,603 | 9,080 | 8,990 | 9,576 | 9,057 |
| Plant Efficiency | % | 37.7 | 35.4 | 37.4 | 37.8 | 35.5 | 37.6 | 38.0 | 35.6 | 37.7 |
| ECONOMIC ANALYSIS INPUT: | | | | | | | | | | |
| 2008 to COD | years | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 |
| Start of Engineering to COD | months | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| Operating Life | years | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 |
| Fixed Labor Costs | \$ | 7,187,292 | 7,187,292 | 7,187,292 | 8,556,300 | 8,556,300 | 8,556,300 | 10,609,812 | 10,609,812 | 10,609,812 |
| Fixed Non-Labor O&M Costs | \$ | 5,600,014 | 5,600,014 | 5,600,014 | 7,020,023 | 7,020,023 | 7,020,023 | 8,820,039 | 8,820,039 | 8,820,039 |
| Total Fixed O&M Costs | \$ | 12,787,306 | 12,787,306 | 12,787,306 | 15,576,323 | 15,576,323 | 15,576,323 | 19,429,851 | 19,429,851 | 19,429,851 |
| Fixed O&M Costs | \$/net kW-yr | 36.01 | 36.32 | 35.83 | 29.23 | 29.48 | 28.90 | 23.42 | 23.62 | 23.16 |
| Property Taxes | \$/year | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 |
| FGD Reagent Cost | | | | | | | | | | |
| \$/ton, delivered | | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 |
| Activated Carbon | | | | | | | | | | |
| \$/ton, delivered | | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 |
| SCR Catalyst | | | | | | | | | | |
| \$/M ³ | | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 |
| Ammonia (Anhydrous) | | | | | | | | | | |
| \$/ton, delivered | | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 |
| Water Cost | | | | | | | | | | |
| \$/1000 gallons | | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Fly Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Fly Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Bottom Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Activated Carbon waste | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| FGD Waste Sale | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| FGD Waste Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Other Variable O&M Costs | \$/net-MWh | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| SO2 Allowance Market Cost | \$/ton | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 |
| NOX Allowance Market Cost | \$/ton | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 |
| Sulfur Byproduct | \$/ton | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| Equivalent Availability Factor | % | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Replacement Power cost | \$/gross-kWh | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 |
| Fuel Cost Delivered | \$/mmBtu | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 |
| \$/ton, delivered | | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 |
| ECONOMIC ANALYSIS OUTPUT: | | | | | | | | | | |
| Annual Capacity Factor | %/yr | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Equivalent Full Load Hours | Hr's | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 |
| Used for Potential to Emit (MW-hours@100%CF & Availability) | Mw-Hr/yr | 2,798,226 | 2,774,021 | 2,828,225 | 4,199,782 | 4,163,729 | 4,247,807 | 6,538,232 | 6,480,833 | 6,610,262 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical**

| | | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical | Supercritical |
|---|-----------|--------------------------------------|-----------------------------------|-------------------------------|--------------------------------------|-----------------------------------|-------------------------------|--------------------------------------|-----------------------------------|-------------------------------|
| Base set-up for meeting Target BACT limits for NOx & SO2 | UNITS | 400MW - Supercritical PC, Bituminous | 400MW - Supercritical PC, Lignite | 400MW - Supercritical PC, PRB | 600MW - Supercritical PC, Bituminous | 600MW - Supercritical PC, Lignite | 600MW - Supercritical PC, PRB | 900MW - Supercritical PC, Bituminous | 900MW - Supercritical PC, Lignite | 900MW - Supercritical PC, PRB |
| Capital costs | \$1,000 | | | | | | | | | |
| Direct & Indirect Costs \$1000 | \$1,000 | 1,663,873 | 1,735,779 | 1,554,896 | 2,122,143 | 2,213,853 | 1,983,150 | 2,706,635 | 2,823,605 | 2,529,357 |
| \$/kW Capital Cost based on net summer output | \$/net-kw | 4,686 | 4,931 | 4,332 | 3,982 | 4,190 | 3,679 | 3,262 | 3,433 | 3,015 |
| Capital Costs | | | | | | | | | | |
| Costs in year 2008 dollars | \$1,000 | 1,663,873 | 1,735,779 | 1,554,896 | 2,122,143 | 2,213,853 | 1,983,150 | 2,706,635 | 2,823,605 | 2,529,357 |
| Fixed O&M Costs | | | | | | | | | | |
| Fixed O&M Costs | \$1,000 | 12,787 | 12,787 | 12,787 | 15,576 | 15,576 | 15,576 | 19,430 | 19,430 | 19,430 |
| Variable O&M Costs (\$/yr) | | | | | | | | | | |
| Limestone Reagent | \$1,000 | 1,441 | 749 | 0 | 2,152 | 1,118 | 0 | 3,341 | 1,736 | 0 |
| Lime Reagent for Dry-FGD | \$1,000 | 0 | 0 | 689 | 0 | 0 | 1,029 | 0 | 0 | 1,597 |
| Activated Carbon | \$1,000 | 0 | 1,028 | 935 | 0 | 1,535 | 1,396 | 0 | 2,383 | 2,168 |
| Water | \$1,000 | 238 | 295 | 191 | 386 | 386 | 386 | 581 | 581 | 581 |
| Bottom Ash Sale/Disposal | \$1,000 | 423 | 1,608 | 277 | 632 | 2,402 | 414 | 981 | 3,729 | 643 |
| Fly ash sale/Disposal | \$1,000 | 1,688 | 6,428 | 1,106 | 2,522 | 9,603 | 1,652 | 3,915 | 14,907 | 2,564 |
| Gypsum sale/Disposal | \$1,000 | 2,964 | 1,546 | 292 | 4,429 | 2,310 | 541 | 6,874 | 3,586 | 840 |
| AC Waste Disposal | \$1,000 | 0 | 9 | 8 | 0 | 14 | 13 | 0 | 22 | 20 |
| Ammonia | \$1,000 | 449 | 357 | 345 | 505 | 534 | 515 | 785 | 828 | 799 |
| SCR-Catalyst Replacement | \$1,000 | 673 | 673 | 673 | 1,010 | 1,010 | 1,010 | 1,515 | 1,515 | 1,515 |
| Bags for Baghouse | \$1,000 | 202 | 231 | 222 | 322 | 364 | 331 | 500 | 565 | 514 |
| SO2 Allowances | \$1,000 | 634 | 535 | 517 | 947 | 800 | 772 | 1,470 | 1,242 | 1,198 |
| NOx Allowances | \$1,000 | 1,902 | 2,008 | 1,937 | 2,842 | 3,000 | 2,894 | 4,411 | 4,657 | 4,493 |
| Other | \$1,000 | 1,400 | 1,388 | 1,415 | 2,101 | 2,083 | 2,125 | 3,271 | 3,242 | 3,307 |
| Sulfur Sale | \$1,000 | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Total | \$1,000 | 11,147 | 16,856 | 8,607 | 17,848 | 25,160 | 13,078 | 27,643 | 38,993 | 20,239 |
| Variable O&M Costs | \$/MWh | 3.98 | 6.07 | 3.04 | 3.74 | 5.77 | 3.08 | 3.72 | 5.75 | 3.06 |
| Total Non-Fuel O&M Cost | \$1,000 | 23,934 | 29,643 | 21,394 | 33,424 | 40,736 | 28,654 | 47,073 | 58,423 | 39,669 |
| Total Non-Fuel O&M Cost | \$/MWh | 8.55 | 10.68 | 7.56 | 7.95 | 9.78 | 6.74 | 7.20 | 9.01 | 6.00 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Ultra-Supercritical**

| | | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical |
|---|---------------|---|--|--|---|--|--|---|--|--|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Ultra-Supercritical PC, Bituminous | 400MW - Ultra-Supercritical PC, Lignite | 400MW - Ultra-Supercritical PC, PRB | 600MW - Ultra-Supercritical PC, Bituminous | 600MW - Ultra-Supercritical PC, Lignite | 600MW - Ultra-Supercritical PC, PRB | 900MW - Ultra-Supercritical PC, Bituminous | 900MW - Ultra-Supercritical PC, Lignite | 900MW - Ultra-Supercritical PC, PRB |
| Number of BFW Heaters | | 8 Heaters (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) |
| Number of FGD Absorbers | | 1 | 1 | 1 | 1 | 1 | 2 | 1 | 1 | 3 |
| Number of wet ESPs | | 1 | 0 | 0 | 2 | 0 | 0 | 3 | 0 | 0 |
| Number of Pulverizers | | 5 | 6 | 5 | 6 | 7 | 6 | 7 | 8 | 7 |
| SO2 | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| NOX | | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR |
| Primary Particulate Control | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Secondary Particulate Control | | Wet ESP | None | None | Wet ESP | None | None | Wet ESP | None | None |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| PLANT CONFIGURATION: (Gross-MW) | | 1x400 | 1x400 | 1x400 | 1x600 | 1x600 | 1x600 | 1x900 | 1x900 | 1x900 |
| NO. OF STEAM GENERATORS | | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler |
| Main Steam Pressure | psig | 3748 | 3748 | 3748 | 3748 | 3748 | 3748 | 3748 | 3748 | 3748 |
| Main Steam Temperature | °F | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 |
| Hot Reheat Temperature | °F | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 | 1100 |
| NO. OF STEAM TURBINES | | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine |
| SOx CONTROL: | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| Uncontrolled SO2 Emission Rate | lb/mmBtu | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 |
| Target "Permit" SO₂ Emission Rate | lb/mmBtu | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 |
| SULFUR REMOVAL percent required meet Target "Permit" Rate | % | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 |
| Typical Maximum SO2 Removal Guarantee from Vendor | % | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 |
| NOx CONTROL: | | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR |
| Uncontrolled Rate from Furnace | lb/mmBtu | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 |
| Target "Permit" NOx Emission Rate | lb/mmBtu | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 |
| PARTICULATE CONTROL | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Target "Permit" Emission Rate | lb/mmBtu | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 |
| Specified Design Guarantee from vendor | lb/mmBtu | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| Cooling Method | | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT |
| PLANT PERFORMANCE: | | | | | | | | | | |
| Net Plant Heat Rate, HHV | Btu/net-kWh | 8,924 | 9,502 | 8,993 | 8,874 | 9,449 | 8,937 | 8,855 | 9,430 | 8,921 |
| Gross Plant Output | Gross-kWh | 400,004 | 400,004 | 400,004 | 600,001 | 600,001 | 600,001 | 900,001 | 900,001 | 900,001 |
| Net Plant Output (based on Annual Average Conditions) | Net-kWh | 354,969 | 351,979 | 358,776 | 532,781 | 528,336 | 538,876 | 830,306 | 823,201 | 839,447 |
| Gross Plant Heat Rate, HHV | Btu/gross-kWh | 7,919 | 8,361 | 8,066 | 7,880 | 8,320 | 8,027 | 8,170 | 8,626 | 8,321 |
| Auxiliary Power | kWh | 45,035 | 48,025 | 41,228 | 67,220 | 71,665 | 61,125 | 69,695 | 76,800 | 60,554 |
| Turbine Heat Rate | Btu/kWh | 6,931 | 6,931 | 6,931 | 6,898 | 6,898 | 6,898 | 7,152 | 7,152 | 7,152 |
| Primary Fuel Feed Rate per Boiler | lb/hr | 272,335 | 560,418 | 384,933 | 406,504 | 836,508 | 574,573 | 632,138 | 1,300,812 | 893,494 |
| Primary Fuel Feed Rate per Boiler | Tons/hr | 136 | 280 | 192 | 203 | 418 | 287 | 316 | 650 | 447 |
| Primary Fuel Feed Rate per Boiler | lb/net-MWh | 767 | 1,592 | 1,073 | 763 | 1,583 | 1,066 | 761 | 1,580 | 1,064 |
| Full load Heat input to Boiler | mmBtu's/hr | 3,168 | 3,344 | 3,226 | 4,728 | 4,992 | 4,816 | 7,353 | 7,763 | 7,489 |
| Secondary Fuel Feed Rate | lb/hr | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Secondary Fuel Feed Rate | lb/net-MWh | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/hr | 23,994 | 12,469 | 1,811 | 35,814 | 18,611 | 2,704 | 55,694 | 28,941 | 4,204 |
| Lime/Limestone Feed Rate | lb/net-MWh | 67.6 | 35.4 | 5.0 | 67.2 | 35.2 | 5.0 | 67.1 | 35.2 | 5.0 |
| Ammonia Feed Rate(Anhydrous) | lb/hr | 249 | 198 | 191 | 280 | 296 | 286 | 436 | 460 | 444 |
| Ammonia Feed Rate | lb/net-MWh | 0.702 | 0.563 | 0.533 | 0.526 | 0.560 | 0.530 | 0.525 | 0.559 | 0.529 |
| Activated Carbon Injection Rate | lb/hr | 0 | 117 | 106 | 0 | 174 | 158 | 0 | 271 | 246 |
| Activated Carbon Injection Rate | lb/net-MWh | 0.00 | 0.33 | 0.30 | 0.00 | 0.33 | 0.29 | 0.00 | 0.33 | 0.29 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Ultra-Supercritical**

| | | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical |
|---|-------------------|---|--|--|---|--|--|---|--|--|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Ultra-Supercritical PC, Bituminous | 400MW - Ultra-Supercritical PC, Lignite | 400MW - Ultra-Supercritical PC, PRB | 600MW - Ultra-Supercritical PC, Bituminous | 600MW - Ultra-Supercritical PC, Lignite | 600MW - Ultra-Supercritical PC, PRB | 900MW - Ultra-Supercritical PC, Bituminous | 900MW - Ultra-Supercritical PC, Lignite | 900MW - Ultra-Supercritical PC, PRB |
| TOTAL Auxiliary Power | % | 11.26 | 12.01 | 10.31 | 11.20 | 11.94 | 10.19 | 7.74 | 8.53 | 6.73 |
| Net Unit Heat Rate | Btu/kWh | 8,924 | 9,502 | 8,993 | 8,874 | 9,449 | 8,937 | 8,855 | 9,430 | 8,921 |
| Plant Efficiency | % | 38.2 | 35.9 | 37.9 | 38.4 | 36.1 | 38.2 | 38.5 | 36.2 | 38.2 |
| ECONOMIC ANALYSIS INPUT: | | | | | | | | | | |
| 2008 to COD | years | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 |
| Start of Engineering to COD | months | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| Operating Life | years | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 |
| Fixed Labor Costs | \$ | 7,187,292 | 7,187,292 | 7,187,292 | 8,556,300 | 8,556,300 | 8,556,300 | 10,609,812 | 10,609,812 | 10,609,812 |
| Fixed Non-Labor O&M Costs | \$ | 5,760,058 | 5,760,058 | 5,760,058 | 7,200,012 | 7,200,012 | 7,200,012 | 9,000,010 | 9,000,010 | 9,000,010 |
| Total Fixed O&M Costs | \$ | 12,947,350 | 12,947,350 | 12,947,350 | 15,756,312 | 15,756,312 | 15,756,312 | 19,609,822 | 19,609,822 | 19,609,822 |
| Fixed O&M Costs | \$/net kW-yr | 36.47 | 36.78 | 36.09 | 29.57 | 29.82 | 29.24 | 23.62 | 23.82 | 23.36 |
| Property Taxes | \$/year | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 |
| FGD Reagent Cost | \$/ton, delivered | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 |
| Activated Carbon | \$/ton, delivered | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 |
| SCR Catalyst | \$/M ³ | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 |
| Ammonia (Anhydrous) | \$/ton, delivered | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 |
| Water Cost | \$/1000 gallons | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Fly Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Fly Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Bottom Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Activated Carbon waste | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| FGD Waste Sale | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| FGD Waste Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Other Variable O&M Costs | \$/net-MWh | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| SO2 Allowance Market Cost | \$/ton | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 |
| NOX Allowance Market Cost | \$/ton | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 |
| Sulfur Byproduct | \$/ton | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| Equivalent Availability Factor | % | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Replacement Power cost | \$/gross-kWh | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 |
| Fuel Cost Delivered | \$/mmBtu | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 |
| | \$/ton, delivered | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 |
| ECONOMIC ANALYSIS OUTPUT: | | | | | | | | | | |
| Annual Capacity Factor | %/yr | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Equivalent Full Load Hours | Hrs | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 |
| Used for Potential to Emit (MW-hours@100%CF & Availability) | Mw-Hr/yr | 2,797,154 | 2,773,596 | 2,827,155 | 4,198,317 | 4,163,290 | 4,246,345 | 6,542,808 | 6,486,823 | 6,614,840 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Ultra-Supercritical**

| | | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical | Ultra-Supercritical |
|---|--------------|---|--|--|---|--|--|---|--|--|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Ultra-Supercritical PC, Bituminous | 400MW - Ultra-Supercritical PC, Lignite | 400MW - Ultra-Supercritical PC, PRB | 600MW - Ultra-Supercritical PC, Bituminous | 600MW - Ultra-Supercritical PC, Lignite | 600MW - Ultra-Supercritical PC, PRB | 900MW - Ultra-Supercritical PC, Bituminous | 900MW - Ultra-Supercritical PC, Lignite | 900MW - Ultra-Supercritical PC, PRB |
| Capital costs | \$1,000 | | | | | | | | | |
| Direct & Indirect Costs \$1000 | \$1,000 | 1,716,256 | 1,791,529 | 1,602,263 | 2,188,954 | 2,284,959 | 2,043,564 | 2,791,846 | 2,914,296 | 2,606,412 |
| \$/kW Capital Cost based on net summer output | \$/net-kw | 4,835 | 5,090 | 4,466 | 4,109 | 4,325 | 3,792 | 3,362 | 3,540 | 3,105 |
| Capital Costs | | | | | | | | | | |
| Costs in year 2008 dollars | \$1,000 | 1,716,256 | 1,791,529 | 1,602,263 | 2,188,954 | 2,284,959 | 2,043,564 | 2,791,846 | 2,914,296 | 2,606,412 |
| Fixed O&M Costs | | | | | | | | | | |
| Fixed O&M Costs | \$1,000 | 12,947 | 12,947 | 12,947 | 15,756 | 15,756 | 15,756 | 19,610 | 19,610 | 19,610 |
| Variable O&M Costs (\$/yr) | | | | | | | | | | |
| Limestone Reagent | \$1,000 | 1,419 | 737 | 0 | 2,118 | 1,100 | 0 | 3,293 | 1,711 | 0 |
| Lime Reagent for Dry-FGD | \$1,000 | 0 | 0 | 678 | 0 | 0 | 1,013 | 0 | 0 | 1,575 |
| Activated Carbon | \$1,000 | 0 | 1,012 | 920 | 0 | 1,511 | 1,374 | 0 | 2,349 | 2,136 |
| Water | \$1,000 | 240 | 296 | 192 | 387 | 387 | 387 | 580 | 580 | 580 |
| Bottom Ash Sale/Disposal | \$1,000 | 417 | 1,584 | 273 | 622 | 2,364 | 408 | 967 | 3,676 | 634 |
| Fly ash sale/Disposal | \$1,000 | 1,662 | 6,330 | 1,089 | 2,481 | 9,449 | 1,625 | 3,859 | 14,693 | 2,527 |
| Gypsum sale/Disposal | \$1,000 | 2,919 | 1,523 | 288 | 4,357 | 2,273 | 533 | 6,776 | 3,534 | 828 |
| AC Waste Disposal | \$1,000 | 0 | 9 | 8 | 0 | 14 | 12 | 0 | 21 | 19 |
| Ammonia | \$1,000 | 442 | 352 | 339 | 497 | 525 | 507 | 773 | 817 | 788 |
| SCR-Catalyst Replacement | \$1,000 | 673 | 673 | 673 | 1,010 | 1,010 | 1,010 | 1,515 | 1,515 | 1,515 |
| Bags for Baghouse | \$1,000 | 199 | 228 | 218 | 317 | 358 | 326 | 493 | 557 | 507 |
| SO2 Allowances | \$1,000 | 624 | 527 | 509 | 932 | 787 | 759 | 1,449 | 1,224 | 1,181 |
| NOx Allowances | \$1,000 | 1,873 | 1,978 | 1,908 | 2,796 | 2,952 | 2,848 | 4,348 | 4,590 | 4,428 |
| Other | \$1,000 | 1,399 | 1,388 | 1,414 | 2,100 | 2,083 | 2,124 | 3,273 | 3,245 | 3,309 |
| Sulfur Sale | \$1,000 | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Total | \$1,000 | 11,013 | 16,636 | 8,511 | 17,617 | 24,813 | 12,925 | 27,325 | 38,512 | 20,026 |
| Variable O&M Costs | \$/MWh | 3.94 | 6.00 | 3.01 | 3.69 | 5.69 | 3.04 | 3.67 | 5.67 | 3.03 |
| Total Non-Fuel O&M Cost | \$1,000 | 23,960 | 29,583 | 21,458 | 33,373 | 40,569 | 28,681 | 46,935 | 58,122 | 39,636 |
| Total Non-Fuel O&M Cost | \$/MWh | 8.56 | 10.66 | 7.59 | 7.95 | 9.74 | 6.75 | 7.17 | 8.96 | 5.99 |

PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Advanced Ultra-Supercritical

| | | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC |
|---|---------------|---|--|--|---|--|--|---|--|--|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 400MW - Adv. Ultra Supercritical PC, Bituminous | 400MW - Adv. Ultra Supercritical PC, Lignite | 400MW - Adv. Ultra Supercritical PC, PRB | 600MW - Adv. Ultra Supercritical PC, Bituminous | 600MW - Adv. Ultra Supercritical PC, Lignite | 600MW - Adv. Ultra Supercritical PC, PRB | 900MW - Adv. Ultra Supercritical PC, Bituminous | 900MW - Adv. Ultra Supercritical PC, Lignite | 900MW - Adv. Ultra Supercritical PC, PRB |
| Number of BFW Heaters | | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) | 8 (HARP) |
| Number of FGD Absorbers | | 1 | 1 | 1 | 1 | 1 | 2 | 1 | 1 | 3 |
| Number of wet ESPs | | 1 | 0 | 0 | 2 | 0 | 0 | 3 | 0 | 0 |
| Number of Pulverizers | | 5 | 6 | 5 | 6 | 7 | 6 | 7 | 8 | 7 |
| SO2 | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| NOX | | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR | High Dust SCR |
| Primary Particulate Control | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Secondary Particulate Control | | Wet ESP | None | None | Wet ESP | None | None | Wet ESP | None | None |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| PLANT CONFIGURATION: (Gross-MW) | | 1x400 | 1x400 | 1x400 | 1x600 | 1x600 | 1x600 | 1x900 | 1x900 | 1x900 |
| NO. OF STEAM GENERATORS | | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler | 1 Boiler |
| Main Steam Pressure | psig | 4515 | 4515 | 4515 | 4515 | 4515 | 4515 | 4515 | 4515 | 4515 |
| Main Steam Temperature | °F | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 |
| Hot Reheat Temperature | °F | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 | 1300 |
| NO. OF STEAM TURBINES | | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine | 1 Turbine |
| SOx CONTROL: | | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD | Wet FGD | Wet FGD | Dry FGD |
| Uncontrolled SO2 Emission Rate | lb/mmBtu | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 |
| Target "Permit" SO2 Emission Rate | lb/mmBtu | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 | 0.10 | 0.08 | 0.08 |
| SULFUR REMOVAL percent required meet Target "Permit" Rate | % | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 | 97.68 | 96.27 | 84.76 |
| Typical Maximum SO2 Removal Guarantee from Vendor | % | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 | 98.15 | 97.20 | 84.76 |
| NOx CONTROL: | | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR | SCR |
| Uncontrolled Rate from Furnace | lb/mmBtu | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 | 0.25 | 0.20 | 0.20 |
| Target "Permit" NOx Emission Rate | lb/mmBtu | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 | 0.07 |
| PARTICULATE CONTROL | | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse | Baghouse |
| Target "Permit" Emission Rate | lb/mmBtu | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 |
| Specified Design Guarantee from vendor | lb/mmBtu | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 | 0.012 |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH | Inherent | ACI-w/BGH | ACI-w/BGH |
| Cooling Method | | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT |
| PLANT PERFORMANCE: | | | | | | | | | | |
| Net Plant Heat Rate, HHV | Btu/net-kWh | 8,349 | 8,882 | 8,414 | 8,305 | 8,834 | 8,363 | 8,279 | 8,808 | 8,341 |
| Gross Plant Output | Gross-kW | 400,003 | 400,003 | 400,003 | 600,004 | 600,004 | 600,004 | 900,000 | 900,000 | 900,000 |
| Net Plant Output (based on Annual Average Conditions) | Net-kW | 356,023 | 353,361 | 359,831 | 534,356 | 530,399 | 540,452 | 832,772 | 826,437 | 841,915 |
| Gross Plant Heat Rate, HHV | Btu/gross-kWh | 7,431 | 7,846 | 7,569 | 7,396 | 7,809 | 7,533 | 7,660 | 8,088 | 7,802 |
| Auxiliary Power | kW | 43,980 | 46,642 | 40,172 | 65,648 | 69,605 | 59,552 | 67,228 | 73,563 | 58,085 |
| Turbine Heat Rate | Btu/kWh | 6,504 | 6,504 | 6,504 | 6,474 | 6,474 | 6,474 | 6,706 | 6,706 | 6,706 |
| Primary Fuel Feed Rate per Boiler | lb/hr | 255,563 | 525,904 | 361,226 | 381,526 | 785,109 | 539,268 | 592,726 | 1,219,711 | 837,787 |
| Primary Fuel Feed Rate per Boiler | Tons/hr | 128 | 263 | 181 | 191 | 393 | 270 | 296 | 610 | 419 |
| Primary Fuel Feed Rate per Boiler | lb/net-MWh | 718 | 1,488 | 1,004 | 714 | 1,480 | 998 | 712 | 1,476 | 995 |
| Full load Heat input to Boiler | mmBtu's/hr | 2,973 | 3,139 | 3,028 | 4,438 | 4,685 | 4,520 | 6,894 | 7,279 | 7,022 |
| Secondary Fuel Feed Rate | lb/hr | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Secondary Fuel Feed Rate | lb/net-MWh | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/hr | 22,516 | 11,701 | 1,700 | 33,614 | 17,468 | 2,538 | 52,221 | 27,137 | 3,942 |
| Lime/Limestone Feed Rate | lb/net-MWh | 63.2 | 33.1 | 4.7 | 62.9 | 32.9 | 4.7 | 62.7 | 32.8 | 4.7 |
| Ammonia Feed Rate(Anhydrous) | lb/hr | 234 | 186 | 180 | 263 | 278 | 268 | 409 | 432 | 416 |
| Ammonia Feed Rate | lb/net-MWh | 0.657 | 0.527 | 0.499 | 0.492 | 0.524 | 0.496 | 0.491 | 0.522 | 0.495 |
| Activated Carbon Injection Rate | lb/hr | 0 | 110 | 100 | 0 | 163 | 149 | 0 | 254 | 231 |
| Activated Carbon Injection Rate | lb/net-MWh | 0.00 | 0.31 | 0.28 | 0.00 | 0.31 | 0.28 | 0.00 | 0.31 | 0.27 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Advanced Ultra-Supercritical**

| | | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC | Adv. USC |
|---|--------------|---|--|--|---|--|--|---|--|--|
| | UNITS | 400MW - Adv. Ultra Supercritical PC, Bituminous | 400MW - Adv. Ultra Supercritical PC, Lignite | 400MW - Adv. Ultra Supercritical PC, PRB | 600MW - Adv. Ultra Supercritical PC, Bituminous | 600MW - Adv. Ultra Supercritical PC, Lignite | 600MW - Adv. Ultra Supercritical PC, PRB | 900MW - Adv. Ultra Supercritical PC, Bituminous | 900MW - Adv. Ultra Supercritical PC, Lignite | 900MW - Adv. Ultra Supercritical PC, PRB |
| Base set-up for meeting Target BACT limits for NOX & SO2 | | | | | | | | | | |
| TOTAL Auxiliary Power | % | 10.99 | 11.66 | 10.04 | 10.94 | 11.60 | 9.93 | 7.47 | 8.17 | 6.45 |
| Net Unit Heat Rate | Btu/kWh | 8,349 | 8,882 | 8,414 | 8,305 | 8,834 | 8,363 | 8,279 | 8,808 | 8,341 |
| Plant Efficiency | % | 40.9 | 38.4 | 40.6 | 41.1 | 38.6 | 40.8 | 41.2 | 38.7 | 40.9 |
| ECONOMIC ANALYSIS INPUT: | | | | | | | | | | |
| 2008 to COD | years | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 | 5 |
| Start of Engineering to COD | months | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 | 55 |
| Operating Life | years | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 | 35 |
| Fixed Labor Costs | \$ | 7,187,292 | 7,187,292 | 7,187,292 | 8,556,300 | 8,556,300 | 8,556,300 | 10,609,812 | 10,609,812 | 10,609,812 |
| Fixed Non-Labor O&M Costs | \$ | NA | NA | NA | NA | NA | NA | NA | NA | NA |
| Total Fixed O&M Costs | \$ | 7,187,292 | 7,187,292 | 7,187,292 | 8,556,300 | 8,556,300 | 8,556,300 | 10,609,812 | 10,609,812 | 10,609,812 |
| Fixed O&M Costs | \$/net kW-yr | 20.19 | 20.34 | 19.97 | 16.01 | 16.13 | 15.83 | 12.74 | 12.84 | 12.60 |
| Property Taxes | \$/year | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 |
| FGD Reagent Cost | | | | | | | | | | |
| \$/ton, delivered | | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 | 15.00 | 15.00 | 95.00 |
| Activated Carbon | | | | | | | | | | |
| \$/ton, delivered | | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 | 2200 |
| SCR Catalyst | | | | | | | | | | |
| \$/M ³ | | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 |
| Ammonia (Anhydrous) | | | | | | | | | | |
| \$/ton, delivered | | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 | 450 |
| Water Cost | | | | | | | | | | |
| \$/1000 gallons | | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Fly Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Fly Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Bottom Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Activated Carbon waste | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| FGD Waste Sale | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| FGD Waste Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 | \$20.00 |
| Other Variable O&M Costs | \$/net-MWh | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| SO2 Allowance Market Cost | \$/ton | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 |
| NOX Allowance Market Cost | \$/ton | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 |
| Sulfur Byproduct | \$/ton | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 | \$0 |
| Equivalent Availability Factor | % | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Replacement Power cost | \$/gross-kWh | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 |
| Fuel Cost Delivered | \$/mmBtu | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 |
| \$/ton, delivered | | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 |
| ECONOMIC ANALYSIS OUTPUT: | | | | | | | | | | |
| Annual Capacity Factor | %/yr | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Equivalent Full Load Hours | Hr's | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 | 7,880 |
| Used for Potential to Emit (MW-hours@100%CF & Availability) | Mw-Hr/yr | 2,805,462 | 2,784,486 | 2,835,469 | 4,210,725 | 4,179,542 | 4,258,762 | 6,562,241 | 6,512,322 | 6,634,288 |

APPENDIX B

PC POWER PLANT COST ESTIMATE DETAILS

PQA
Greenfield Coal Fired PC Plants
Order of Magnitude Cost Study
Summary of Estimated Project Costs
Based on Bituminous Coal

| | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
|---|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|-------------------------|-------------------------|-------------------------|
| Unit Size, MW Gross | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
| Unit Size, MW Net | 359 | 539 | 828 | 355 | 533 | 830 | 355 | 533 | 830 |
| Configuration | Subcritical PC | Subcritical PC | Subcritical PC | Supercritical PC | Supercritical PC | Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC |
| Land and Land Rights | not included | not included | not included | not included | not included | not included | not included | not included | not included |
| Structures and Improvements | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 |
| Boiler Plant | 579,411,000 | 738,995,000 | 942,532,000 | 603,553,000 | 769,786,000 | 981,804,000 | 635,319,000 | 810,301,000 | 1,033,478,000 |
| Turbine Plant | 107,723,000 | 137,393,000 | 175,234,000 | 108,264,000 | 138,083,000 | 176,115,000 | 109,358,000 | 139,478,000 | 177,894,000 |
| Misc. Power Plant Equipment | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 |
| Main Power System | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 |
| Auxiliary Power System | 13,652,000 | 17,412,000 | 22,208,000 | 13,652,000 | 17,412,000 | 22,208,000 | 13,652,000 | 17,412,000 | 22,208,000 |
| Emergency Power System | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 |
| Electrical BOP. | 62,835,000 | 80,141,000 | 102,214,000 | 62,835,000 | 80,141,000 | 102,214,000 | 62,835,000 | 80,141,000 | 102,214,000 |
| Substation and Switchyard Structures and Facilities | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 |
| Substation and Switchyard Equipment | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 |
| Initial Fills | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 |
| Startup Personnel & Craft Startup Support | 4,609,000 | 5,879,000 | 7,498,000 | 4,609,000 | 5,879,000 | 7,498,000 | 4,609,000 | 5,879,000 | 7,498,000 |
| Consumables | 2,882,000 | 3,676,000 | 4,689,000 | 2,882,000 | 3,676,000 | 4,689,000 | 2,882,000 | 3,676,000 | 4,689,000 |
| Overtime Inefficiency & Overtime Premium Pay | 49,658,000 | 63,335,000 | 80,779,000 | 49,658,000 | 63,335,000 | 80,779,000 | 49,658,000 | 63,335,000 | 80,779,000 |
| Per Diem (Subsistence) | 55,537,000 | 70,833,000 | 90,342,000 | 55,537,000 | 70,833,000 | 90,342,000 | 55,537,000 | 70,833,000 | 90,342,000 |
| EPC Fees (0%) | - | - | - | - | - | - | - | - | - |
| Subtotal Direct Project Costs | 1,019,086,000 | 1,299,767,000 | 1,657,755,000 | 1,043,769,000 | 1,331,248,000 | 1,697,908,000 | 1,076,629,000 | 1,373,158,000 | 1,751,361,000 |
| Indirect Project Costs. | 76,066,000 | 97,016,000 | 123,737,000 | 77,908,000 | 99,366,000 | 126,734,000 | 80,361,000 | 102,495,000 | 130,724,000 |
| Contingency (15%) | 164,273,000 | 209,517,000 | 267,224,000 | 168,252,000 | 214,592,000 | 273,696,000 | 173,549,000 | 221,348,000 | 282,313,000 |
| Owner's Costs (3%) | 32,855,000 | 41,903,000 | 53,445,000 | 33,650,000 | 42,918,000 | 54,739,000 | 34,710,000 | 44,270,000 | 56,463,000 |
| Operating Spare Parts (1%) | 10,952,000 | 13,968,000 | 17,815,000 | 11,217,000 | 14,306,000 | 18,246,000 | 11,570,000 | 14,757,000 | 18,821,000 |
| Escalation (4% Annual Rate) | 198,399,000 | 253,043,000 | 322,737,000 | 203,204,000 | 259,171,000 | 330,553,000 | 209,601,000 | 267,330,000 | 340,959,000 |
| Interest During Construction (6% Annual Rate) | 122,896,000 | 156,745,000 | 199,916,000 | 125,873,000 | 160,542,000 | 204,759,000 | 129,836,000 | 165,596,000 | 211,205,000 |
| Subtotal Project Costs | 1,624,527,000 | 2,071,959,000 | 2,642,629,000 | 1,663,873,000 | 2,122,143,000 | 2,706,635,000 | 1,716,256,000 | 2,188,954,000 | 2,791,846,000 |
| \$/kW Net | 4,523 | 3,844 | 3,190 | 4,686 | 3,982 | 3,262 | 4,835 | 4,109 | 3,362 |

Notes:

1. The contracting scheme is based on multiple lump sum contracts. An EPC contract could add an additional 10-15% to the cost of the plant.
2. Total Project Cost represents cost at completion for a project started 01/2009 and completed 12/2013, a 5 year overall schedule.
3. Indirect Project Costs include engineering and construction management.
4. The labor cost is based on Gulf region of the U.S. Adjustments will be required for other regions of the country.
5. The costs provided are within a +/-30% range.
6. Adjustments for Bituminous coal fired plant from PRB coal fired plant:
 - Smaller Boiler and smaller Boiler Building
 - Wet FGD with Wet ESP in place of Dry FGD and no Wet ESP
 - Lined Chimney
 - Greater Auxiliary Power requirement
 - Greater Electrical BOP

PQA
Greenfield Coal Fired PC Plants
Order of Magnitude Cost Study
Summary of Estimated Project Costs
Based on PRB Coal

| | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
|---|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|-------------------------|-------------------------|-------------------------|
| Unit Size, MW Gross | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
| Unit Size, MW Net | 363 | 545 | 838 | 359 | 539 | 839 | 359 | 539 | 839 |
| Configuration | Subcritical PC | Subcritical PC | Subcritical PC | Supercritical PC | Supercritical PC | Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC |
| Land and Land Rights | not included | not included | not included | not included | not included | not included | not included | not included | not included |
| Structures and Improvements | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 |
| Boiler Plant | 522,039,000 | 665,821,000 | 849,204,000 | 543,790,000 | 693,563,000 | 884,587,000 | 572,410,000 | 730,066,000 | 931,144,000 |
| Turbine Plant | 107,723,000 | 137,393,000 | 175,234,000 | 108,264,000 | 138,083,000 | 176,115,000 | 109,358,000 | 139,478,000 | 177,894,000 |
| Misc. Power Plant Equipment | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 |
| Main Power System | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 |
| Auxiliary Power System | 13,600,000 | 17,346,000 | 22,123,000 | 13,600,000 | 17,346,000 | 22,123,000 | 13,600,000 | 17,346,000 | 22,123,000 |
| Emergency Power System | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 |
| Electrical BOP. | 61,770,000 | 78,783,000 | 100,482,000 | 61,770,000 | 78,783,000 | 100,482,000 | 61,770,000 | 78,783,000 | 100,482,000 |
| Substation and Switchyard Structures and Facilities | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 |
| Substation and Switchyard Equipment | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 |
| Initial Fills | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 |
| Startup Personnel & Craft Startup Support | 4,303,000 | 5,488,000 | 7,000,000 | 4,303,000 | 5,488,000 | 7,000,000 | 4,303,000 | 5,488,000 | 7,000,000 |
| Consumables | 2,692,000 | 3,433,000 | 4,378,000 | 2,692,000 | 3,433,000 | 4,378,000 | 2,692,000 | 3,433,000 | 4,378,000 |
| Overtime Inefficiency & Overtime Premium Pay | 46,360,000 | 59,129,000 | 75,414,000 | 46,360,000 | 59,129,000 | 75,414,000 | 46,360,000 | 59,129,000 | 75,414,000 |
| Per Diem (Subsistence) | 51,849,000 | 66,129,000 | 84,342,000 | 51,849,000 | 66,129,000 | 84,342,000 | 51,849,000 | 66,129,000 | 84,342,000 |
| EPC Fees (0%) | - | - | - | - | - | - | - | - | - |
| Subtotal Direct Project Costs | 953,115,000 | 1,215,625,000 | 1,550,436,000 | 975,407,000 | 1,244,057,000 | 1,586,700,000 | 1,005,121,000 | 1,281,955,000 | 1,635,036,000 |
| Indirect Project Costs. | 71,141,000 | 90,735,000 | 115,726,000 | 72,806,000 | 92,858,000 | 118,433,000 | 75,024,000 | 95,687,000 | 122,041,000 |
| Contingency (15%) | 153,638,000 | 195,954,000 | 249,924,000 | 157,232,000 | 200,537,000 | 255,770,000 | 162,022,000 | 206,646,000 | 263,562,000 |
| Owner's Costs (3%) | 30,728,000 | 39,191,000 | 49,985,000 | 31,446,000 | 40,107,000 | 51,154,000 | 32,404,000 | 41,329,000 | 52,712,000 |
| Operating Spare Parts (1%) | 10,243,000 | 13,064,000 | 16,662,000 | 10,482,000 | 13,369,000 | 17,051,000 | 10,801,000 | 13,776,000 | 17,571,000 |
| Escalation (4% Annual Rate) | 185,555,000 | 236,661,000 | 301,843,000 | 189,895,000 | 242,196,000 | 308,902,000 | 195,679,000 | 249,574,000 | 318,313,000 |
| Interest During Construction (6% Annual Rate) | 114,940,000 | 146,597,000 | 186,973,000 | 117,628,000 | 150,026,000 | 191,347,000 | 121,212,000 | 154,597,000 | 197,177,000 |
| Subtotal Project Costs | 1,519,360,000 | 1,937,827,000 | 2,471,549,000 | 1,554,896,000 | 1,983,150,000 | 2,529,357,000 | 1,602,263,000 | 2,043,564,000 | 2,606,412,000 |
| \$/kW Net | 4,186 | 3,555 | 2,951 | 4,332 | 3,679 | 3,015 | 4,466 | 3,792 | 3,105 |

Notes:

1. The contracting scheme is based on multiple lump sum contracts. An EPC contract could add an additional 10-15% to the cost of the plant.
2. Total Project Cost represents cost at completion for a project started 01/2009 and completed 12/2013, a 5 year overall schedule.
3. Indirect Project Costs include engineering and construction management.
4. The labor cost is based on Gulf region of the U.S. Adjustments will be required for other regions of the country.
5. The costs provided are within a +/-30% range.

PQA
Greenfield Coal Fired PC Plants
Order of Magnitude Cost Study
Summary of Estimated Project Costs
Based on Lignite Coal

| Unit Size, MW Gross | 400 | 600 | 900 | 400 | 600 | 900 | 400 | 600 | 900 |
|---|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|-------------------------|-------------------------|-------------------------|
| Unit Size, MW Net | 356 | 534 | 821 | 352 | 528 | 822 | 352 | 528 | 823 |
| Configuration | Subcritical PC | Subcritical PC | Subcritical PC | Supercritical PC | Supercritical PC | Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC | Ultra- Supercritical PC |
| Land and Land Rights | not included | not included | not included | not included | not included | not included | not included | not included | not included |
| Structures and Improvements | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 | 109,923,000 | 140,198,000 | 178,812,000 |
| Boiler Plant | 617,968,000 | 788,172,000 | 1,005,254,000 | 643,717,000 | 821,013,000 | 1,047,140,000 | 677,597,000 | 864,224,000 | 1,102,253,000 |
| Turbine Plant | 107,723,000 | 137,393,000 | 175,234,000 | 108,264,000 | 138,083,000 | 176,115,000 | 109,358,000 | 139,478,000 | 177,894,000 |
| Misc. Power Plant Equipment | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 | 11,540,000 | 14,719,000 | 18,773,000 |
| Main Power System | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 | 10,059,000 | 12,829,000 | 16,363,000 |
| Auxiliary Power System | 13,652,000 | 17,412,000 | 22,208,000 | 13,652,000 | 17,412,000 | 22,208,000 | 13,652,000 | 17,412,000 | 22,208,000 |
| Emergency Power System | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 | 784,000 | 1,000,000 | 1,275,000 |
| Electrical BOP. | 62,835,000 | 80,141,000 | 102,214,000 | 62,835,000 | 80,141,000 | 102,214,000 | 62,835,000 | 80,141,000 | 102,214,000 |
| Substation and Switchyard Structures and Facilities | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 | 957,000 | 1,220,000 | 1,556,000 |
| Substation and Switchyard Equipment | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 | 9,050,000 | 11,543,000 | 14,722,000 |
| Initial Fills | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 | 466,000 | 594,000 | 758,000 |
| Startup Personnel & Craft Startup Support | 4,811,000 | 6,136,000 | 7,826,000 | 4,811,000 | 6,136,000 | 7,826,000 | 4,811,000 | 6,136,000 | 7,826,000 |
| Consumables | 3,009,000 | 3,838,000 | 4,895,000 | 3,009,000 | 3,838,000 | 4,895,000 | 3,009,000 | 3,838,000 | 4,895,000 |
| Overtime Inefficiency & Overtime Premium Pay | 51,836,000 | 66,113,000 | 84,322,000 | 51,836,000 | 66,113,000 | 84,322,000 | 51,836,000 | 66,113,000 | 84,322,000 |
| Per Diem (Subsistence) | 57,973,000 | 73,940,000 | 94,305,000 | 57,973,000 | 73,940,000 | 94,305,000 | 57,973,000 | 73,940,000 | 94,305,000 |
| EPC Fees (0%) | - | - | - | - | - | - | - | - | - |
| Subtotal Direct Project Costs | 1,062,586,000 | 1,355,248,000 | 1,728,517,000 | 1,088,876,000 | 1,388,779,000 | 1,771,284,000 | 1,123,850,000 | 1,433,385,000 | 1,828,176,000 |
| Indirect Project Costs. | 79,313,000 | 101,158,000 | 129,019,000 | 81,275,000 | 103,660,000 | 132,211,000 | 83,885,000 | 106,989,000 | 136,457,000 |
| Contingency (15%) | 171,285,000 | 218,461,000 | 278,630,000 | 175,523,000 | 223,866,000 | 285,524,000 | 181,160,000 | 231,056,000 | 294,695,000 |
| Owner's Costs (3%) | 34,257,000 | 43,692,000 | 55,726,000 | 35,105,000 | 44,773,000 | 57,105,000 | 36,232,000 | 46,211,000 | 58,939,000 |
| Operating Spare Parts (1%) | 11,419,000 | 14,564,000 | 18,575,000 | 11,702,000 | 14,924,000 | 19,035,000 | 12,077,000 | 15,404,000 | 19,646,000 |
| Escalation (4% Annual Rate) | 206,867,000 | 263,843,000 | 336,512,000 | 211,985,000 | 270,371,000 | 344,838,000 | 218,794,000 | 279,055,000 | 355,914,000 |
| Interest During Construction (6% Annual Rate) | 128,143,000 | 163,437,000 | 208,451,000 | 131,313,000 | 167,480,000 | 213,608,000 | 135,531,000 | 172,859,000 | 220,469,000 |
| Subtotal Project Costs | 1,693,870,000 | 2,160,403,000 | 2,755,430,000 | 1,735,779,000 | 2,213,853,000 | 2,823,605,000 | 1,791,529,000 | 2,284,959,000 | 2,914,296,000 |
| \$/kW Net | 4,760 | 4,045 | 3,357 | 4,931 | 4,190 | 3,433 | 5,090 | 4,325 | 3,540 |

Notes:

1. The contracting scheme is based on multiple lump sum contracts. An EPC contract could add an additional 10-15% to the cost of the plant.
2. Total Project Cost represents cost at completion for a project started 01/2009 and completed 12/2013, a 5 year overall schedule.
3. Indirect Project Costs include engineering and construction management.
4. The labor cost is based on Gulf region of the U.S. Adjustments will be required for other regions of the country.
5. The costs provided are within a +/-30% range.
6. Adjustments for Lignite fired plant from Bituminous coal fired plant:
Larger Boiler and larger Boiler Building
No Wet ESP
Larger diameter Chimney
Smaller Limestone Handling & Gypsum Handling
Larger Bottom Ash & Fly Ash Handling
No Car Dumper and no Loop Track
Larger Coal Handling


APPENDIX C

PC POWER PLANT HEAT BALANCES

Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 IAPWS Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 11.6 Btu/lb
 Annulus Velocity = 812.6 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 400.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 7,347 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to BFP Motor) = 7,524 Btu/kWh

PRELIMINARY
 For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|----------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/19/2008 | L.Papadopoulos | | | Original Issue | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
SUBCRITICAL
400 MW
 2534.7 P / 1050 T / 1050 T



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 IAPWS Steam Table

ELEP = Expansion Line End Point
 UEELP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 7.9 Btu/lb
 Annulus Velocity = 606.1 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 600.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 7,316 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to BFP Motor) = 7,491 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|----------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose |
| 0 | 11/19/2008 | L.Papadopoulos | | | Original Issue |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |


PQA STUDY
 SUBCRITICAL
 600 MW
 2534.7 P / 1050 T / 1050 T



Note:
 Expected Plant Performance. Not Guaranteed
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEPP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 8.1 Btu/lb
 Annulus Velocity = 584.2 ft/sec



Gross Turbine Heat Rate = Heat Input / (Generator Output + Aux. Turbine Output) = 7,323 Btu/kWh
 Net Turbine Heat Rate = Heat Input / Generator Output = 7,487 Btu/kWh

| | |
|-------------------------|----------|
| Ambient Dry Bulb = | 59.0 T |
| Ambient Wet Bulb = | 51.4 T |
| Relative Humidity = | 60.1% |
| Site Elevation (AMSL) = | 1 ft |
| Steam Turbine Gross = | 900.0 MW |


| Drawing Release Record | | | | | | Project No.: | | | |
|------------------------|----------|--------|------|-----------|----------------|--------------|----------|----------------|----------------------|
| Legend: | Flow | Lb/h | Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| W= | Flow | Lb/h | 0 | 19-Nov-08 | L.Papadopoulos | | | Original Issue | |
| P= | Pressure | Psia | | | | | | | GateCycle Model/Case |
| T= | Temp. | °F | | | | | | | |
| H= | Enthalpy | Btu/Lb | | | | | | | |

PQA STUDY
 Subcritical
 900 MW
 2534.7 P / 1050 T / 1050 T

Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 9.9 Btu/lb
 Annulus Velocity = 754.9 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 400.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 7,038 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 7,291 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/19/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
SUPERCritical
400 MW
3690 P / 1050 T / 1100 T



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 9.6 Btu/lb
 Annulus Velocity = 743.2 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 600.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 7,011 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 7,262 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/19/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
SUPERCritical
600 MW
3690 P / 1050 T / 1100 T



Note:
 Expected Plant Performance. Not Guaranteed
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 9.5 Btu/lb
 Annulus Velocity = 528.3 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.1%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 900.0 MW

Gross Turbine Heat Rate = Heat Input / (Generator Output + Aux. Turbine Output) = 7,019 Btu/kWh
 Net Turbine Heat Rate = Heat Input / Generator Output = 7,256 Btu/kWh


| Legend: | | Drawing Release Record | | | | Project No.: | | PQA STUDY | |
|---------|----------|------------------------|-----------|----------------|----------|--------------|----------------|----------------------|--------------------------|
| W= | Flow | Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 | Supercritical |
| P= | Pressure | 0 | 19-Nov-08 | L.Papadopoulos | | | Original Issue | | 900 MW |
| T= | Temp. | | | | | | | GateCycle Model/Case | 3690 P / 1050 T / 1100 T |
| H= | Enthalpy | | | | | | | | |



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEELP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 9.2 Btu/lb
 Annulus Velocity = 734.4 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 400.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 6,931 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 7,193 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/18/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
ULTRA SUPERCRITICAL
400 MW
3748 P / 1100 T / 1100 T



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 8.9 Btu/lb
 Annulus Velocity = 721.4 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 600.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 6,898 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 7,156 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/18/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
 ULTRA SUPERCRITICAL
 600 MW
 3748 P / 1100 T / 1100 T



Note:
 Expected Plant Performance. Not Guaranteed
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEPP = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 8.0 Btu/lb
 Annulus Velocity = 671.7 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.1%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 900.0 MW

Gross Turbine Heat Rate = Heat Input / (Generator Output + Aux. Turbine Output) = 6,919 Btu/kWh
 Net Turbine Heat Rate = Heat Input / Generator Output = 7,152 Btu/kWh


| Legend: | | Drawing Release Record | | | | Project No.: | | PQA STUDY | |
|---------|----------|------------------------|-----------|----------------|----------|--------------|-----------|-------------------------------|--------------------------|
| W= | Flow | Rev. | Date | Prepared | Reviewed | Approved | 12301-003 | Ultra-Supercritical 900 MW | |
| P= | Pressure | 0 | 19-Nov-08 | L.Papadopoulos | | | | | |
| T= | Temp. | | | | | | GateCycle | Model/Case | 3748 P / 1100 T / 1100 T |
| H= | Enthalpy | | | | | | | | |



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 40.0 In.
 Exhaust Loss = 8.3 Btu/lb
 Annulus Velocity = 646.9 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 400.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 6,504 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 6,745 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | Project No.: | |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/19/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
ADVANCED SUPERCRITICAL
400 MW
4515 P / 1300 T / 1300 T



Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 8.2 Btu/lb
 Annulus Velocity = 635.1 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 600.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 6,474 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 6,712 Btu/kWh

PRELIMINARY
For Information Only

Legend:
 W= Flow, lb/hr
 P= Pressure, Psia
 T= Temperature, °F
 H= Enthalpy, Btu/lb

| Drawing Release Record | | | | | | Project No.: |
|------------------------|------------|----------------|----------|----------|-------------------|----------------------|
| Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 |
| 0 | 11/19/2008 | L.Papadopoulos | | | Feasibility Study | |
| | | | | | | GateCycle Model/Case |


PQA STUDY
ADVANCED SUPERCRITICAL
600 MW
4515 P / 1300 T / 1300 T



Note:
 Expected Plant Performance. Not Guaranteed
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEEP = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 8.5 Btu/lb
 Annulus Velocity = 582.9 ft/sec



Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.1%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 900.0 MW

Gross Turbine Heat Rate = Heat Input / (Generator Output + Aux. Turbine Output) = 6,481 Btu/kWh
 Net Turbine Heat Rate = Heat Input / Generator Output = 6,706 Btu/kWh

| Legend: | | | | Drawing Release Record | | | | Project No.: | | PQA STUDY | |
|---------|----------|--------|--|------------------------|-----------|----------------|----------|--------------|----------------|----------------------|--|
| W= | Flow | Lb/h | | Rev. | Date | Prepared | Reviewed | Approved | Purpose | 12301-003 | Advanced-Supercritical 900 MW 4515 P / 1300 T / 1300 T |
| P= | Pressure | Psia | | 0 | 19-Nov-08 | L.Papadopoulos | | | Original Issue | | |
| T= | Temp. | °F | | | | | | | | GateCycle Model/Case | |
| H= | Enthalpy | Btu/Lb | | | | | | | | | |



APPENDIX D

PC POWER PLANT HEAT BALANCE CALCULATION DETAILS

NET TURBINE HEAT RATE

Estimating net turbine heat rate was based on the assumptions described below.

1. Steam Turbine Predicted Performance

Steam turbine performance is reported as heat rate (Btu/kWh). This is a measure of the thermal heat energy provided to the steam cycle and the generated electrical output. Heat rate is related to the overall steam cycle efficiency.

The most common method of predicting steam turbine performance is the Spencer Cotton Cannon (SCC) method. This method, developed by General Electric and published in the 1960s, is used in most commercially available heat balance programs. However, due to modern steam turbine improvements in blade design and configurations for intermediate-pressure (IP) and low-pressure (LP) sections, the turbine section efficiencies are about 2% better than what would be predicted by SCC. This has been confirmed by comparing predicted performance to performance received from steam turbine manufacturers.

The high-pressure (HP) steam turbine design condition is at the operating condition corresponding to the maximum inlet steam flow rate with the maximum pressure and temperature. At this condition, it is assumed that the control valve is in the valve-wide-open position, thus establishing a throttle flow ratio of 1.0.

A 2.0% pressure drop is accounted for across the control valve at the inlet to the turbine. For opposed-flow HP-IP turbine sections, the heat balance calculation accounts for the shaft/seal leakage that occurs from the HP to the IP steam turbine. This leakage is approximated at 2.2% of the main steam flow rate into the turbine. It is assumed that it exits the HP section just before the governing stage and mixes with the hot reheat steam flow entering the IP steam turbine. The HP steam turbine discharge pressure generally is 20-25% of the steam pressure entering the turbine.

For the LP section, additional losses must be accounted for due to steam exhausting from the turbine into the condenser. These losses are primarily due to turbulent flow and directional changes when exiting the turbine. These losses are calculated using the "exhaust loss curve," which is unique for different last-stage blade lengths and LP frame sizes.

Using manufacturer-developed exhaust loss curves, the LP section last-stage blade length and related annulus area are analyzed with the purpose of minimizing the exhaust losses. The SCC method provides the predicted exhaust loss for a given blade length as a function of the exhaust steam velocity. The blade length used in performance analyses is selected to minimize exhaust losses (Btu/lb) and still maintain a reasonable exhaust velocity.

Because the LP turbine exhaust pressure can significantly affect exhaust losses, the condenser pressure is held constant at 2" HgA to provide comparable results between all cases.

2. Generator

The steam turbine generator is modeled with a 0.85 power factor, and a coolant pressure of 74.7 psia. The mechanical and electrical loss is approximated by 1.5-2.0% of the gross generator output.

3. Condensate Pump

The condensate pump discharge pressure is assumed to be 250 psia, with an overall pump efficiency of 85%.

4. Feedwater Heaters

When extraction steam from the steam turbines is used to heat the feedwater, this method of heating the boiler feedwater is known as regenerative feedwater heating. For a typical subcritical design, the cycle is designed with four LP and two HP feedwater heaters, with a direct-contact deaerating feedwater heater for seven stages of feedwater heating. For a supercritical and ultra-supercritical cycle, a HARP (heater above reheat point) feedwater heater is added to the cycle. These are established feedwater heater arrangements that have proven to be economically beneficial.

5. Boiler Feedwater Pump

For units operating below 650 MW, motor-driven boiler feed pumps are preferred. The boiler feedwater pump discharge pressure typically is designed as 125% of the main steam pressure into the HP turbine, and with a pump efficiency of 85%. For motor-driven feedwater pumps the motor efficiency of 95% is also included.

6. Boiler Feed Pump Turbine Drive

For units operating above 650 MW, a boiler feed pump turbine drive is normally selected. The usual steam source for these turbine drives is from IP extraction steam at normal unit loads, and main steam at low-unit loads and bypass cases. The boiler feed pump turbine drive exhaust pressure is assumed as 0.5 in.Hg Abs. greater than the condenser operating pressure. The turbine drive efficiency is calculated using the SCC method.

7. System Pressure Drops

The pressure drop characteristics of each pipeline, at the design condition, are listed in the following table:

| | Pressure Drop |
|-------------------|---|
| Reheat system | 8.0% ultra-supercritical 8.0% supercritical 10.0% subcritical |
| Extraction line | 5.0% |
| Turbine flange | 3.0% |
| BFP turbine drive | 3.0% |

8. Turbine Heat Rates

Turbine heat rate is a measure of steam turbine efficiency as defined by the following equation:

(Note that the definition of gross turbine heat rate and net turbine heat rate depends on whether the boiler feed pump is motor driven or turbine driven.)

$$\text{Heat Rate [Btu/kWh]} = \frac{\text{Heat added to turbine cycle [Btu / hr]}}{\text{Generator Output[kW]}}$$

$$\text{Heat Input} = Q_T (H_T - H_{FW}) + Q_{Rhr} (H_{HRH} - H_{CRH})$$

Where: Q_T = Throttle flow [lb/hr]

Q_{Rhr} = Reheater flow [lb/hr]

H_T = Throttle enthalpy [BTU/lb]

H_{FW} = Final feedwater enthalpy [BTU/lb]

H_{HRH} = Enthalpy leaving reheater [BTU/lb]

H_{CRH} = Enthalpy entering reheater [BTU/lb]

For cycles with motor driven boiler feed pump:

$$\text{Gross turbine heat rate [Btu/kWh]} = \frac{\text{Heat Input [Btu / hr]}}{\text{Generator Output[kW]}}$$

$$\text{Net turbine heat rate [Btu/kWh]} = \frac{\text{Heat Input [Btu / hr]}}{\text{Generator Output[kW]} - \text{Power to Motor [kW]}}$$

For cycles with steam driven boiler feed pump:

$$\text{Gross turbine heat rate [Btu/kWh]} = \frac{\text{Heat Input [Btu / hr]}}{\text{Generator Output[kW]} + \text{Auxiliary Turbine Output[kW]}}$$

$$\text{Net turbine heat rate [Btu/kWh]} = \frac{\text{Heat Input [Btu / hr]}}{\text{Generator Output[kW]}}$$

The net turbine heat rate is used to estimate the net unit heat rate by correcting it for boiler efficiency and auxiliary power.

BOILER EFFICIENCY

The boiler efficiency is estimated according to ASME guidelines. The inputs required for the boiler efficiency estimation include the following:

- Coal composition
- Ambient air temperature, humidity
- Excess air
- Uncorrected air heater outlet temperature

This information is used to calculate the following losses associated with un-recovered heat from the burned fuel:

- Radiation losses
- Sensible heat with dry flue gas
- Latent and sensible heat with water vapor from the fuel, moisture in combustion air, and the combustion of hydrogen in fuel
- Carbon loss, assumed as 0.5% for bituminous coal and 0.1% for PRB and lignite
- Unaccounted losses, 0.5% for all fuels
- Manufacturer's margin, 0.2% for all fuels

The air heater outlet temperature was estimated based on the sulfuric acid dew point. The sulfuric acid dew point was calculated for all three coals with estimated SO₃ concentrations at the air heater outlet. A 20°F margin was added to the acid dew point, which is a typical practice in the industry to eliminate the possibility of sulfuric acid condensation at the cold end of air heater and the downstream equipment.

AUXILIARY POWER ESTIMATION

The auxiliary power included the following categories:

- Condensate pumps
- Circulating water pumps
- Cooling towers
- Forced draft (FD) fan
- Induced draft (ID) fan
- Primary air (PA) fan
- Pulverizers
- Fuel handling
- Ash handling
- Baghouse
- Wet FGD for bituminous coal and lignite, dry FGD for PRB, wet ESP for bituminous coal
- Transformer losses
- Miscellaneous, 1% margin for all fuels

The pressure drop for the total system was estimated for FD and ID fans.

NET UNIT HEAT RATE

Net unit heat rate (NUHR) is a measure of overall plant efficiency and accounts for steam turbine efficiency, boiler efficiency, and auxiliary power demands.

$$\text{NUHR [Btu/kWh]} = \frac{\text{Net Turbine Heat Rate [Btu / kW h]}}{\text{Boiler Efficiency[\%]} / 100 \times (1 - (\text{Auxiliary Power} / 100[\%]))}$$

Plant Efficiency:

$$\text{Plant Efficiency [\%]} = \frac{3412 \text{ [Btu / kWh]}}{\text{NUHR [Btu / kWh]}} \times 100$$

APPENDIX E

SC AND IGCC POWER PLANT PERFORMANCE AND COST ESTIMATE SPREADSHEETS

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical and IGCC**

| | | Supercritical | Supercritical | Supercritical | subCritical | subCritical | subCritical |
|---|-----------------|---|--|--------------------------------------|----------------------------------|------------------------------|--------------------------|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 685MW - Supercritical PC, Bituminous | 685MW - Supercritical PC, Lignite | 685MW - Supercritical PC, PRB | 726 MW - IGCC, Bituminous | 711MW - IGCC, Lignite | 727MW - IGCC, PRB |
| Number of BFW Heaters | | 8 (HARP) | 8 (HARP) | 8 (HARP) | NA | NA | NA |
| Number of FGD Absorbers | | 1 | 1 | 2 | 2 AGR | 2 AGR | 2 AGR |
| Number of wet ESPs | | 2 | 0 | 0 | 2 CYC/CFLT/SCRB | 2 CYC/CFLT/SCRB | 2 CYC/CFLT/SCRB |
| Number of Pulverizers | | 6 | 7 | 6 | 5 | 9 | 6 |
| SO2 | | Wet FGD | Wet FGD | Dry FGD | Sulfinol | Sulfinol | Sulfinol |
| NOX | | High Dust SCR | High Dust SCR | High Dust SCR | SCR | SCR | SCR |
| Primary Particulate Control | | Baghouse | Baghouse | Baghouse | Cyclone/Candle Filter | Cyclone/Candle Filter | Cyclone/Candle Filter |
| Secondary Particulate Control | | Wet ESP | None | None | Wet Scrubber | Wet Scrubber | Wet Scrubber |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Carbon - Packed Bed | Carbon - Packed Bed | Carbon - Packed Bed |
| PLANT CONFIGURATION: (Gross-MW) | | 1x685 | 1x685 | 1x685 | 1x728 | 1x711 | 1x727 |
| NO. OF STEAM GENERATORS | | 1 Boiler | 1 Boiler | 1 Boiler | 2 SGC/HRSG | 2 SGC/HRSG | 2 SGC/HRSG |
| Main Steam Pressure | psig | 3690 | 3690 | 3690 | 1800 | 1800 | 1800 |
| Main Steam Temperature | *F | 1050 | 1050 | 1050 | 1000 | 1000 | 1000 |
| Hot Reheat Temperature | *F | 1100 | 1100 | 1100 | 1000 | 1000 | 1000 |
| NO. OF STEAM TURBINES | | 1 STG | 1 STG | 1 STG | 1 STG | 1 STG | 1 STG |
| NO. OF COMBUSTION TURBINES | | N/A | N/A | N/A | 2 CTG | 2 CTG | 2 CTG |
| SOx CONTROL: | | Wet FGD | Wet FGD | Dry FGD | Sulfinol | Sulfinol | Sulfinol |
| Uncontrolled SO2 Emission Rate | lb/mmBtu | 4.32 | 2.14 | 0.52 | 4.32 | 2.14 | 0.52 |
| Target "Permit" SO ₂ Emission Rate | lb/mmBtu | 0.10 | 0.08 | 0.08 | 0.02 | 0.02 | 0.02 |
| SULFUR REMOVAL percent required meet Target "Permit" Rate | % | 97.68 | 96.27 | 84.76 | 99.54 | 99.07 | 96.19 |
| Typical Maximum SO2 Removal Guarantee from Vendor | % | 98.15 | 97.20 | 88.57 | 99.77 | 99.53 | 98.10 |
| NOx CONTROL: | | SCR | SCR | SCR | SCR | SCR | SCR |
| Uncontrolled Rate from Boiler/CTG | lb/mmBtu | 0.25 | 0.20 | 0.20 | 0.048 | 0.050 | 0.048 |
| Target "Permit" NOx Emission Rate | lb/mmBtu | 0.07 | 0.07 | 0.07 | 0.022 | 0.022 | 0.022 |
| PARTICULATE CONTROL | | Baghouse | Baghouse | Baghouse | 2 CYC/CFLT/SCRB | 2 CYC/CFLT/SCRB | 2 CYC/CFLT/SCRB |
| Target "Permit" Emission Rate | lb/mmBtu | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 | 0.015 |
| Specified Design Guarantee from vendor | lb/mmBtu | 0.012 | 0.012 | 0.012 | 0.007 | 0.007 | 0.007 |
| Mercury Control | | Inherent | ACI-w/BGH | ACI-w/BGH | Carbon - Packed Bed | Carbon - Packed Bed | Carbon - Packed Bed |
| Cooling Method | | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT | MD-CT |
| PLANT PERFORMANCE: | | | | | | 0.162418206 | |
| Net Plant Heat Rate, HHV | Btu/net-kWh | 9,000 | 9,584 | 9,063 | 8,425 | 8,515 | 8,062 |
| Gross Plant Output | Gross-kW | 685,000 | 685,000 | 685,000 | 726,061 | 711,238 | 726,824 |
| Net Plant Output (based on Annual Average Conditions) | Net-kW | 609,083 | 603,868 | 616,041 | 610,232 | 595,720 | 612,365 |
| Gross Plant Heat Rate, HHV | Btu/gross-kWh | 8,002 | 8,449 | 8,151 | 7,081 | 7,132 | 6,792 |
| Auxiliary Power | kW | 75,917 | 81,132 | 68,959 | 115,829 | 115,518 | 114,459 |
| Turbine Heat Rate | Btu/kWh | 7,005 | 7,005 | 7,005 | NA | NA | NA |
| Primary Fuel Feed Rate per Boiler/Gasifier | lb/hr | 471,271 | 969,784 | 666,118 | 221,000 | 425,000 | 294,500 |
| Primary Fuel Feed Rate per Boiler/Gasifier | Tons/hr | 236 | 485 | 333 | 111 | 213 | 147 |
| Primary Fuel Feed Rate per Boiler/Gasifier | lb/net-MWh | 774 | 1,606 | 1,081 | 362 | 713 | 481 |
| Full load Heat input to Boiler/Gasifier | mmBtu's/hr | 5,481 | 5,788 | 5,583 | 2,571 | 2,536 | 2,468 |
| Secondary Fuel Feed Rate | lb/hr | N/A | N/A | N/A | N/A | N/A | N/A |
| Limestone Feed Rate | lb/net-MWh | | | | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/hr | 41,521 | 21,576 | 3,134 | N/A | N/A | N/A |
| Lime/Limestone Feed Rate | lb/net-MWh | 68.2 | 35.7 | 5.1 | N/A | N/A | N/A |
| Ammonia Feed Rate(Anhydrous) | lb/hr | 325 | 343 | 331 | 111 | 111 | 111 |
| Ammonia Feed Rate | lb/net-MWh | 0.534 | 0.568 | 0.537 | 0.182 | 0.186 | 0.181 |
| Activated Carbon Injection Rate | lb/hr | 0 | 202 | 184 | NA | NA | NA |
| Activated Carbon Injection Rate | lb/net-MWh | 0.00 | 0.33 | 0.30 | NA | NA | NA |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical and IGCC**

| | | Supercritical | Supercritical | Supercritical | subCritical | subCritical | subCritical |
|---|-------------|--------------------------------------|-----------------------------------|-------------------------------|---------------------------|-----------------------|-------------------|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 685MW - Supercritical PC, Bituminous | 685MW - Supercritical PC, Lignite | 685MW - Supercritical PC, PRB | 726 MW - IGCC, Bituminous | 711MW - IGCC, Lignite | 727MW - IGCC, PRB |
| Water Consumption | | | | | | | |
| Cycle Make-up & Misc. Services | gpm | 931 | 931 | 931 | 1,010 | 910 | 984 |
| Cooling Tower/lake make-up | gpm | 7,309 | 7,246 | 7,392 | 3,866 | 3,716 | 3,745 |
| Total Water | gpm | 8,240 | 8,177 | 8,323 | 4,876 | 4,626 | 4,729 |
| Water Consumption | gal/net-MWh | 812 | 812 | 811 | 479 | 466 | 463 |
| | | | | | | | |
| | | Bituminous | Lignite | PRB | Bituminous | Lignite | PRB |
| FUEL ANALYSIS: | | | | | | | |
| Ultimate Analysis | | | | | | | |
| Carbon | % | 63.75 | 36.27 | 50.25 | 63.75 | 36.27 | 50.25 |
| Sulfur | % | 2.51 | 0.64 | 0.22 | 2.51 | 0.64 | 0.22 |
| Oxygen | % | 6.88 | 10.76 | 13.55 | 6.88 | 10.76 | 13.55 |
| Hydrogen | % | 4.50 | 2.42 | 3.41 | 4.50 | 2.42 | 3.41 |
| Nitrogen | % | 1.25 | 0.71 | 0.65 | 1.25 | 0.71 | 0.65 |
| Chlorine | % | 0.29 | 0.00 | 0.00 | 0.29 | 0.00 | 0.00 |
| Ash | % | 9.70 | 17.92 | 4.50 | 9.70 | 17.92 | 4.50 |
| Moisture | % | 11.12 | 31.24 | 27.40 | 11.12 | 31.24 | 27.40 |
| Proximate Analysis | | | | | | | |
| Moisture | % | 11.12 | 31.24 | 27.40 | 11.12 | 31.24 | 27.40 |
| Volatile matter | % | 34.99 | | | 34.99 | | |
| Fixed Carbon | % | 44.19 | | | 44.19 | | |
| Ash | % | 9.70 | 17.92 | 4.50 | 9.70 | 17.92 | 4.50 |
| Gross Higher Heating Value (Dulong) | Btu/lb | 11,631 | 5,968 | 8,382 | 11,631 | 5,968 | 8,382 |
| SORBENT ANALYSIS: | | | | | | | |
| CaCO3 | % | 90 | 90 | 0 | NA | NA | NA |
| MgCO3 | % | 5 | 5 | 0 | NA | NA | NA |
| CaO | % | 0 | 0 | 90 | NA | NA | NA |
| Ash/Inerts | % | 5 | 5 | 10 | NA | NA | NA |
| Moisture | % | 0 | 0 | 0 | NA | NA | NA |
| STEAM GENERATOR DATA (Per Boiler): | | | | | | | |
| Theoretical Air | lb/lb-fuel | 8.70 | 4.57 | 6.39 | NA | NA | NA |
| Theoretical Dry Gas | lb/lb-fuel | 9.09 | 4.87 | 6.76 | NA | NA | NA |
| Actual Dry Gas | lb/lb-fuel | 10.83 | 5.78 | 8.04 | NA | NA | NA |
| Excess Air | % | 20 | 20 | 20 | NA | NA | NA |
| Total Dry Air Flow | lb/lb-fuel | 10.45 | 5.49 | 7.67 | NA | NA | NA |
| Ambient Air Moisture | lb/lb-lair | 0.025 | 0.025 | 0.025 | NA | NA | NA |
| Total Air Flow | lb/lb-fuel | 10.71 | 5.63 | 7.86 | NA | NA | NA |
| Flue Gas Moisture Flow | lb/lb-fuel | 0.774 | 0.666 | 0.770 | NA | NA | NA |
| Products of Combustion | lb/lb-fuel | 11.61 | 6.45 | 8.81 | NA | NA | NA |
| Air Heater Leakage | % | 5 | 5 | 5 | NA | NA | NA |
| Air Heater Inlet Temperature | °F | 100 | 100 | 100 | NA | NA | NA |
| Infiltration | % | 5 | 5 | 5 | NA | NA | NA |
| Exit Flue Gas Temperature | °F | 310 | 305 | 280 | NA | NA | NA |
| Flue Gas Temp. Uncorrected | °F | 319 | 314 | 288 | NA | NA | NA |
| Flue Gas Flow Rate (per boiler) | lb/hr | 5,932,472 | 6,752,621 | 6,349,254 | NA | NA | NA |
| Flue Gas Flow Rate (IGCC coal dry air) | acfm | 1,984,022 | 2,243,644 | 2,040,678 | 178,631 | 329,505 | 228,328 |
| Combustion Air Flow | lb/hr | 5,045,625 | 5,456,731 | 5,233,458 | NA | NA | NA |
| Combustion Air Flow | acfm | 1,203,590 | 1,301,655 | 1,248,396 | NA | NA | NA |
| Stack Flue Gas Temperature | °F | 135 | 140 | 170 | 210 | 210 | 210 |
| Stack Flue Gas Flow Rate per Flue | acfm | 1,623,422 | 1,863,384 | 1,875,057 | 1,214,183 | 1,214,790 | 1,214,487 |
| Radiation Loss | % | 0.182 | 0.182 | 0.182 | N/A | N/A | N/A |
| Dry Gas Heat Loss | % | 5.89 | 5.96 | 5.19 | N/A | N/A | N/A |
| Fuel Moisture Loss | % | 1.07 | 5.84 | 3.62 | N/A | N/A | N/A |
| Hydrogen in Fuel Loss | % | 3.89 | 4.07 | 4.06 | N/A | N/A | N/A |
| Air Moisture Heat Loss | % | 0.237 | 0.236 | 0.206 | N/A | N/A | N/A |
| Carbon Loss | % | 0.50 | 0.10 | 0.10 | N/A | N/A | N/A |
| Unaccounted Loss | % | 0.20 | 0.20 | 0.20 | N/A | N/A | N/A |
| Manufacturer's Margin | % | 0.50 | 0.50 | 0.50 | N/A | N/A | N/A |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical and IGCC**

| | | Supercritical | Supercritical | Supercritical | subCritical | subCritical | subCritical |
|--|---------------------|--|---|-------------------------------------|------------------------------|--------------------------|----------------------|
| Base set-up for meeting Target BACT limits for NOX & SO₂ | UNITS | 685MW - Supercritical PC, Bituminous | 685MW - Supercritical PC, Lignite | 685MW - Supercritical PC, PRB | 726 MW - IGCC, Bituminous | 711MW - IGCC, Lignite | 727MW - IGCC, PRB |
| Total Boiler Loss | % | 12.46 | 17.09 | 14.06 | NA | NA | NA |
| Boiler Efficiency | % | 87.54 | 82.91 | 85.94 | N/A | N/A | N/A |
| Total Heat Output from Boiler | mmBtu/hr | 4,798.43 | 4,798.43 | 4,798.43 | NA | NA | NA |
| Main Steam Flow | lb/hr | 4,248,925 | 4,248,925 | 4,248,925 | 1,491,728 | 1,410,067 | 1,508,954 |
| STEAM TURBINE/CYCLE DATA (Per Turbine): | | | | | | | |
| Turbine Back Pressure | in HgA | 2 | 2 | 2 | 2 | 2 | 2 |
| Steam Turbine Gross Output | kW | 685,000 | 685,000 | 685,000 | 262,031 | 247,208 | 262,794 |
| LP Turbine Exhaust to Condenser | lb/hr | 2,627,921 | 2,627,921 | 2,627,921 | 2,305,964 | 1,483,005 | 2,305,964 |
| Exhaust Energy | Btu/lb | 1,015.90 | 1,015.90 | 1,015.90 | 1,015.80 | 1,021.40 | 1,015.80 |
| Condensate Enthalpy | Btu/lb | 69.1 | 69.1 | 69.1 | 69.1 | 69.1 | 69.1 |
| Heat Rejection from LP Turbine | mmBtu/hr | 2,488 | 2,488 | 2,488 | 2,183 | 1,412 | 2,183 |
| BFP Turbine Drive Steam Flow | lb/hr | 0 | 0 | 0 | 0 | 0 | 0 |
| BFP Turbine Exhaust Enthalpy | Btu/lb | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Heat Rejection from BFP Turbine | Btu/hr | 0 | 0 | 0 | 0 | 0 | 0 |
| Total Heat Rejected to Condenser | mmBtu/hr | 2,488 | 2,488 | 2,488 | 2,183 | 1,412 | 2,183 |
| Circulating Water Temp. Rise | °F | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 | 20.0 |
| Circulating Water Flow | gpm | 263,104 | 263,104 | 263,104 | 225,244 | 191,580 | 230,896 |
| Number of Cooling Tower Cells | | 20 | 20 | 20 | 20 | 20 | 20 |
| Total Circ. Water Flow | gpm | 263,104 | 263,104 | 263,104 | 225,244 | 212,864 | 230,896 |
| Service Water Flow | gpm | 13,155 | 13,155 | 13,155 | 11,545 | 11,545 | 11,545 |
| Total Cooling Water Requirement | gpm | 276,259 | 276,259 | 276,259 | 236,789 | 224,409 | 242,441 |
| GAS TURBINE DATA (Per Turbine): | | | | | | | |
| Gas Turbine Power | Gross-kW Btu/kWh | N/A | N/A | N/A | 232,015 | 232,015 | 232,015 |
| PLANT AUXILIARY POWER: | | | | | | | |
| Induced Draft Fan Pressure Rise | Boiler *w.c | 44.0 | 44.0 | 41.8 | NA | NA | NA |
| Econ Outlet to SCR outlet | *w.c | 8.0 | 8.0 | 8.0 | NA | NA | NA |
| SCR Outlet to AH Outlet | *w.c | 6.0 | 6.0 | 6.0 | NA | NA | NA |
| AH Outlet to ESP Outlet | *w.c | 6.0 | 6.0 | 6.0 | NA | NA | NA |
| AH/ESP Outlet to COHPAC or Dry | *w.c | 0.0 | 0.0 | 0.0 | NA | NA | NA |
| FGD/BH Outlet | *w.c | 8.0 | 8.0 | 16.0 | NA | NA | NA |
| COHPAC/Dry FGD BH Outlet to stack | *w.c | 0.0 | 0.0 | 2.0 | NA | NA | NA |
| ID inlet to Wet FGD outlet | *w.c | 8.0 | 8.0 | 0.0 | NA | NA | NA |
| Wet FGD outlet to stack outlet | *w.c | 4.0 | 4.0 | 0.0 | NA | NA | NA |
| Total ID fan static pressure | *w.c | 40.0 | 40.0 | 38.0 | NA | NA | NA |
| Percent Total Air to FD Fan | % | 70 | 70 | 70 | NA | NA | NA |
| Forced Draft Fan Pressure Rise | *w.c | 20 | 20 | 20 | NA | NA | NA |
| Percent Total Air to PA Fan | % | 30 | 30 | 30 | NA | NA | NA |
| Primary Air Fan Pressure Rise | *w.c | 40 | 40 | 40 | NA | NA | NA |
| Percent Total Air to SA Fan | % | 0 | 0 | 0 | NA | NA | NA |
| Secondary Air Fan Pressure Rise | *w.c | 15 | 15 | 15 | NA | NA | NA |
| Condensate P/P | % | 0.36 | 0.36 | 0.36 | NA | NA | NA |
| Circulating Water P/P | % | 0.46 | 0.46 | 0.46 | NA | NA | NA |
| Cooling Towers | % | 0.60 | 0.60 | 0.60 | NA | NA | NA |
| Feedwater P/P | % | 3.50 | 3.50 | 3.50 | NA | NA | NA |
| Subtotal CWS | % | 4.93 | 4.93 | 4.93 | NA | NA | NA |
| Forced Draft Fan | % | 0.34 | 0.37 | 0.36 | NA | NA | NA |
| Induced Draft Fan | % | 1.99 | 2.25 | 1.78 | NA | NA | NA |
| Primary Air Fan | % | 0.30 | 0.32 | 0.31 | NA | NA | NA |
| Pulverizer | % | 0.50 | 1.02 | 0.70 | NA | NA | NA |
| Fuel Handling | % | 0.12 | 0.22 | 0.16 | NA | NA | NA |
| Ash Handling | % | 0.19 | 0.60 | 0.14 | NA | NA | NA |
| Wet ESP for H ₂ SO ₄ collection | % | 0.15 | 0.00 | 0.00 | NA | NA | NA |
| Baghouse | % | 0.12 | 0.12 | 0.12 | NA | NA | NA |
| FGD | % | 1.25 | 0.82 | 0.38 | NA | NA | NA |
| Transformer Losses | % | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 | 0.20 |
| Miscellaneous | . | 1.00 | 1.00 | 1.00 | 0.80 | 0.80 | 0.80 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical and IGCC**

| | | Supercritical | Supercritical | Supercritical | subCritical | subCritical | subCritical |
|---|--------------|--------------------------------------|-----------------------------------|-------------------------------|---------------------------|-----------------------|-------------------|
| Base set-up for meeting Target BACT limits for NOX & SO2 | UNITS | 685MW - Supercritical PC, Bituminous | 685MW - Supercritical PC, Lignite | 685MW - Supercritical PC, PRB | 726 MW - IGCC, Bituminous | 711MW - IGCC, Lignite | 727MW - IGCC, PRB |
| TOTAL Auxiliary Power | % | 11.08 | 11.84 | 10.07 | 15.95 | 16.24 | 15.75 |
| Net Unit Heat Rate | Btu/kWh | 9,000 | 9,584 | 9,063 | 8,425 | 8,515 | 8,062 |
| Plant Efficiency | % | 37.9 | 35.6 | 37.6 | 40.5 | 40.1 | 42.3 |
| ECONOMIC ANALYSIS INPUT: | | | | | | | |
| 2008 to COD | years | 5 | 5 | 5 | 7 | 7 | 7 |
| Start of Engineering to COD | months | 55 | 55 | 55 | 79 | 79 | 79 |
| Operating Life | years | 35 | 35 | 35 | 35 | 35 | 35 |
| Levelized Fixed Charge Rate | | | | | | | |
| %yr over operating life | %/yr | 17.32% | 17.32% | 17.32% | 17.32% | 17.32% | 17.32% |
| Total Staffing | | 100 | 100 | 100 | 120 | 120 | 120 |
| Average Salary | \$ | 85,563 | 85,563 | 85,563 | 85,563 | 85,563 | 85,563 |
| Fixed Labor Costs | \$ | 8,556,300 | 8,556,300 | 8,556,300 | 10,267,560 | 10,267,560 | 10,267,560 |
| Fixed Non-Labor O&M Costs | \$ | 8,014,500 | 8,014,500 | 8,014,500 | 19,603,437 | 24,031,042 | 19,942,349 |
| Total Fixed O&M Costs | \$ | 16,570,800 | 16,570,800 | 16,570,800 | 29,870,997 | 34,298,602 | 30,209,909 |
| Fixed O&M Costs | \$/net kW-yr | 27.21 | 27.44 | 26.90 | 48.95 | 57.58 | 49.33 |
| Property Taxes | \$/year | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 | 3,000,000 |
| FGD Reagent Cost | | | | | | | |
| \$/ton, delivered | | 15.00 | 15.00 | 95.00 | 0.00 | 0.00 | 0.00 |
| Activated Carbon | | | | | | | |
| \$/ton, delivered | | 2200 | 2200 | 2200 | 10000 | 10000 | 10000 |
| SCR Catalyst | | | | | | | |
| \$/M ³ | | 6000 | 6000 | 6000 | 6000 | 6000 | 6000 |
| Ammonia (Anhydrous) | | | | | | | |
| \$/ton, delivered | | 450 | 450 | 450 | 450 | 450 | 450 |
| Water Cost | | | | | | | |
| \$/1000 gallons | | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 | 1.00 |
| Fly Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Fly Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Sales | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 | \$0.00 |
| Bottom Ash Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$0.00 | \$0.00 | \$0.00 |
| Activated Carbon waste | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$800.00 | \$800.00 | \$800.00 |
| FGD Waste Sale | \$/ton | \$0.00 | \$0.00 | \$0.00 | \$100.00 sulfur | \$100.00 sulfur | \$100.00 sulfur |
| FGD Waste Disposal | \$/ton | \$20.00 | \$20.00 | \$20.00 | \$0.00 | \$0.00 | \$0.00 |
| Other Variable O&M Costs | \$/net-MWh | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| SO2 Allowance Market Cost | | | | | | | |
| \$/ton | | \$500 | \$500 | \$500 | \$500 | \$500 | \$500 |
| NOX Allowance Market Cost | | | | | | | |
| \$/ton | | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 | \$3,000 |
| Sulfur Byproduct | | | | | | | |
| \$/ton | | \$0 | \$0 | \$0 | \$100 | \$100 | \$100 |
| Equivalent Availability Factor | % | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% | 90.00% |
| Replacement Power cost | \$/gross-kWh | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 | 0.065 |
| Fuel Cost Delivered | \$/mmBtu | 1.70 | 1.50 | 1.40 | 1.70 | 1.50 | 1.40 |
| \$/ton, delivered | | 39.55 | 17.90 | 23.47 | 39.55 | 17.90 | 23.47 |
| ECONOMIC ANALYSIS OUTPUT: | | | | | | | |
| Annual Capacity Factor | %/yr | 90.00% | 90.00% | 90.00% | 85.00% | 85.00% | 85.00% |
| Equivalent Full Load Hours | Hrs | 7,880 | 7,880 | 7,880 | 7,450 | 7,450 | 7,450 |
| Used for Potential to Emit (MW-hours@100%CF & Availability) | Mw-Hr/yr | 4,799,572 | 4,758,478 | 4,854,401 | 4,546,232 | 4,438,115 | 4,562,121 |

**PQA Study
Technology Spreadsheet
Efficiency/Heat Rate for New Coal-Fired Power Plants
Supercritical and IGCC**

| | | Supercritical | Supercritical | Supercritical | subCritical | subCritical | subCritical |
|---|-----------|--|---|-------------------------------------|------------------------------|--------------------------|----------------------|
| <u>Base set-up for meeting Target BACT limits for NOX & SO2</u> | UNITS | 685MW - Supercritical PC, Bituminous | 685MW - Supercritical PC, Lignite | 685MW - Supercritical PC, PRB | 726 MW - IGCC, Bituminous | 711MW - IGCC, Lignite | 727MW - IGCC, PRB |
| Capital costs | \$1,000 | | | | | | |
| Direct & Indirect Costs \$1000 | \$1,000 | 2,217,840 | 2,461,143 | 2,090,180 | 2,800,491 | 3,433,006 | 2,848,907 |
| \$/kW Capital Cost based on net | \$/net-kw | 3,641 | 4,076 | 3,393 | 4,589 | 5,763 | 4,652 |
| Capital Costs | | | | | | | |
| Costs in year 2008 dollars | \$1,000 | 2,217,840 | 2,461,143 | 2,090,180 | 2,800,491 | 3,433,006 | 2,848,907 |
| Fixed O&M Costs | | | | | | | |
| Fixed O&M Costs | \$1,000 | 16,571 | 16,571 | 16,571 | 29,871 | 34,299 | 30,210 |
| Variable O&M Costs (\$/yr) | | | | | | | |
| Limestone Reagent | \$1,000 | 2,455 | 1,276 | 0 | 0 | 0 | 0 |
| Lime Reagent, dryFGD, MDEA,Catalysts | \$1,000 | 0 | 0 | 1,174 | 1,593 | 1,415 | 1,340 |
| Activated Carbon | \$1,000 | 0 | 1,751 | 1,593 | 296 | 1,068 | 296 |
| Water | \$1,000 | 440 | 440 | 440 | 451 | 407 | 440 |
| Bottom Ash Sale/Disposal | \$1,000 | 721 | 2,740 | 473 | 0 | 0 | 0 |
| Fly ash sale/Disposal | \$1,000 | 2,877 | 10,954 | 1,884 | 0 | 0 | 0 |
| Gypsum sale/Disposal | \$1,000 | 5,051 | 2,635 | 617 | 0 | 0 | 0 |
| AC Waste Disposal | \$1,000 | 0 | 16 | 14 | 24 | 85 | 24 |
| Ammonia | \$1,000 | 577 | 609 | 587 | 186 | 186 | 186 |
| SCR-Catalyst Replacement | \$1,000 | 1,153 | 1,153 | 1,153 | 399 | 399 | 399 |
| Bags for Baghouse | \$1,000 | 367 | 415 | 378 | 33 | 61 | 42 |
| SO2 Allowances | \$1,000 | 1,080 | 913 | 880 | 191 | 189 | 184 |
| NOx Allowances | \$1,000 | 3,241 | 3,422 | 3,301 | 431 | 425 | 414 |
| Other | \$1,000 | 2,401 | 2,380 | 2,428 | 2,272 | 2,218 | 2,280 |
| Sulfur Sale | \$1,000 | N/A | N/A | N/A | 555 | 272 | 65 |
| Total | \$1,000 | 20,364 | 28,705 | 14,924 | 6,430 | 6,725 | 5,668 |
| Variable O&M Costs | \$/MWh | 3.73 | 5.76 | 3.07 | 1.42 | 1.52 | 1.24 |
| Total Non-Fuel O&M Cost | \$1,000 | 36,935 | 45,276 | 31,495 | 36,301 | 41,023 | 35,878 |
| Total Non-Fuel O&M Cost | \$/MWh | 7.69 | 9.51 | 6.48 | 7.99 | 9.25 | 7.87 |

APPENDIX F

IGCC POWER PLANT COST ESTIMATE DETAILS

PQA
Greenfield IGCC Plant Study
Order of Magnitude Cost Study
Summary of Estimated Project Costs

| Unit Size, MW Net | 610 | 612 | 596 |
|--|--|----------------------------------|--|
| Configuration | Greenfield Shell Design with Illinois Bituminous # 6 | Greenfield Shell Design with PRB | Greenfield Shell Design with Texas Lignite |
| Coal & Sorbent Handling | 36,007,000 | 42,023,000 | 34,171,000 |
| Coal & Sorbent Prep & Feec | 159,390,000 | 173,908,000 | 252,127,000 |
| Feedwater & Misc. BOP Systems | 48,779,000 | 48,865,000 | 47,104,000 |
| Gasifier & Accessories | | | |
| Gasifier, Syngas Cooler, & Auxiliaries | 378,962,000 | 450,206,000 | 581,514,000 |
| ASU / Oxidant Compression | 170,396,000 | 168,704,000 | 154,933,000 |
| Other Gasification Equipment | 65,182,000 | 70,114,000 | 78,962,000 |
| Subtotal Gasifier & Accessories | 614,540,000 | 689,024,000 | 815,409,000 |
| Gas Cleanup & Piping | 145,163,000 | 87,368,000 | 130,083,000 |
| Combustion Turbine & Accessories | | | |
| Combustion Turbine & Generator | 124,519,000 | 124,519,000 | 124,519,000 |
| Combustion Turbine, Other | 2,648,000 | 2,648,000 | 2,648,000 |
| Subtotal Combustion Turbine & Accessories | 127,167,000 | 127,167,000 | 127,167,000 |
| HRSG, Ducting, & Stack | | | |
| Heat Recovery Steam Generato | 52,218,000 | 52,218,000 | 52,218,000 |
| Ductwork & Stack | 15,850,000 | 15,850,000 | 15,850,000 |
| Subtotal HRSG, Ducting, & Stack | 68,068,000 | 68,068,000 | 68,068,000 |
| Steam Turbine Generator | | | |
| Steam Turbine Generator & Accessories | 50,783,000 | 50,796,000 | 50,515,000 |
| Turbine Plant Auxiliaries & Steam Piping | 32,575,000 | 32,632,000 | 31,457,000 |
| Subtotal Steam Turbine Generator | 83,358,000 | 83,428,000 | 81,972,000 |
| Cooling Water System | 36,331,000 | 36,395,000 | 35,084,000 |
| ASH / Spent Sorbent Handling System | 48,704,000 | 37,794,000 | 119,767,000 |
| Accessory Electric Plant | 67,228,000 | 67,099,000 | 66,389,000 |
| Instrumentation & Controls | 33,073,000 | 33,073,000 | 33,073,000 |
| Improvements to Site | 23,287,000 | 23,287,000 | 23,287,000 |
| Buildings & Structures | 24,743,000 | 24,743,000 | 24,743,000 |
| Subtotal Direct Project Costs | 1,515,838,000 | 1,542,242,000 | 1,858,444,000 |
| Indirect Project Costs | \$125,972,000 | \$127,871,000 | \$154,084,000 |
| Contingency @ 20% | 328,362,000 | 334,023,000 | 402,506,000 |
| Owner's Costs @ 3% | 49,254,000 | 50,103,000 | 60,376,000 |
| Operating Spare Parts @ 1% | 16,418,000 | 16,701,000 | 20,125,000 |
| Escalation (4% Annual Rate) | 346,098,000 | 352,127,000 | 424,322,000 |
| Interest During Construction (6% Annual Rate) | 418,549,000 | 425,840,000 | 513,149,000 |
| Total Project Costs | 2,800,491,000 | 2,848,907,000 | 3,433,006,000 |
| \$/kW Net | 4,589 | 4,652 | 5,763 |

Notes:

1. The contracting scheme is assumed to be multiple lump sum. EPC contracting, if obtainable, would warrant additional fees.
2. Total Project Cost represents cost at completion for a project started 01/09 and completing 12/15, a 7 year overall schedule.
3. Labor costs are based on the Gulf Coast region of the U.S. Adjustments will be required for other regions of the country.
4. Owner's Costs are highly variable. Included here as an allowance at 3% of Subtotal Project Costs.
5. Escalation calculated at 4% annual rate, compounded annually and based on projected 7-year cash flow.
6. IDC calculated at 6% annual rate, compounded annually and based on projected 7-year cash flow.


APPENDIX G

SC AND IGCC POWER PLANT HEAT BALANCES

Note:
 Expected Plant Performance, Not Guaranteed.
 Calculation based 1997 ASME Steam Table

ELEP = Expansion Line End Point
 UEET = Used Energy End Point

Steam Turbine LSB = 33.5 In.
 Exhaust Loss = 12.6 Btu/lb
 Annulus Velocity = 844.3 ft/sec





Ambient Dry Bulb = 59.0 T
 Ambient Wet Bulb = 51.4 T
 Relative Humidity = 60.0%
 Site Elevation (AMSL) = 1 ft
 Steam Turbine Gross = 685.0 MW

Gross Turbine Heat Rate = Heat Input / Generator Output = 7,005 Btu/kWh
 Net Turbine Heat Rate = Heat Input / (Generator Output - Power to Motor) = 7,255 Btu/kWh

PRELIMINARY
For Information Only

| Legend: | Drawing Release Record | | | | | Project No.: | PQA STUDY SUPERCRITICAL 685 MW | Sargent & Lundy |
|--|------------------------|------------|----------------|----------|----------|----------------------|--------------------------------------|-----------------|
| | Rev. | Date | Prepared | Reviewed | Approved | | | |
| W= Flow, lb/hr P= Pressure, Psia T= Temperature, °F H= Enthalpy, Btu/lb | 0 | 12/10/2008 | L.Papadopoulos | | | 12301-003 | 3690 P / 1050 T / 1100 T | |
| | | | | | | GateCycle Model/Case | | |





- # Notes
- All flows are water/steam unless otherwise indicated.
 - LP ST is a 2-flow end unit with 40" last stage blades.
 - Heat rate is calculated on basis of HHV.
 - Both CTs and HRSGs are currently modeled as a single unit.
 - ST generator efficiency is 98.4%
 - Cooling tower drift rate is set at 0.0005%
 - Gasification plant components and flows printed in red.
 - All flows for SGT6-5000F are for two turbines, corrected for alt. and temp.
 - Cooling tower operates at 6 cycles of concentration.
 - Steam / Feedwater to SRS returned to cycle through makeup system.
 - Maximizing CT Power Output, Adjusting Air Extraction

| | |
|------------------------|--|
| W [Flow] in lb/hr | 1 lb/hr = 0.000126 kg/sec = 0.001997 US gpm (water) |
| P [Pressure] in psi(a) | 1 psi = 0.068947 bar 1 psi = 2.036 in Hg |
| T [Temperature] in °F | (°F - 32) * 5/9 = °C (°C * 9/5) + 32 = °F |
| H [Enthalpy] in Btu/lb | 1 Btu/lb = 2.326122 kJ/kg |

| PLANT PERFORMANCE SUMMARY | |
|------------------------------------|----------------------|
| Ambient Dry Bulb Temperature | 59.00 F |
| | 15.00 C |
| Ambient Wet Bulb Temperature | 51.47 F |
| | 10.82 C |
| Ambient Relative Humidity | 60.00% |
| Ambient Site Pressure | 14.70 psia |
| | 1.013 bar |
| Site Equivalent Elevation, AMSL | 0 ft |
| | 0 m |
| Gas Turbine Gross Output | 464,030 kW |
| Steam Turbine Gross Output | 247,208 kW |
| Plant Auxiliary Loads | 115,518 kW |
| Net Plant Electrical Output | 595,720 kW |
| IGCC Plant Heat Input(10,200 t/day | 5,072,800,000 Btu/hr |
| Coal AR@5,968 BTU/lb HHV) | 5,352,088,009 kJ/hr |
| GROSS IGCC Plant Heat Rate, HHV | 7,132.3 Btu/kWhr |
| | 7,525.0 kJ/kWhr |
| NET IGCC Plant Heat Rate, HHV | 8,515.4 Btu/kWhr |
| | 8,984.2 kJ/kWhr |

| DRAWING RELEASE RECORD | | | | |
|------------------------|------------|----------------|-------------|-------------|
| REV. | DATE | PREPARED BY | REVIEWED BY | APPROVED BY |
| 0 | 11/26/2008 | L.Papadopoulos | D. Hasler | R. Gaikwad |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

| REV. | Purpose |
|------|---------|
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

| | | |
|--|-----------------------------------|-----------------------------|
| Unit System US CUSTOMARY | GateCycle Model/Case NWCARL EX | Project - Part 12301-003 |
| PQA STUDY | | |
| PERFORMANCE HEAT BALANCE | | |
| Fuel: Texas Lignite Low Moisture Dried to 7% wt. | | |

Sargent & Lundy LLC