

# Appendix C

## Modeling Protocols/Reports

This page left intentionally blank.

---

***Dispersion Modeling Report***  
***1-Hour SO<sub>2</sub> NAAQS Area Designation***  
***D.E. Karn Generating Station***  
***Consumers Energy Company***

***Prepared for:***

***Consumers Energy Company***  
***1945 W. Parnall Road***  
***Jackson, Michigan 49201***

***Prepared by:***

***Horizon Environmental Corporation***  
***4771 50<sup>th</sup> Street SE, Suite One***  
***Grand Rapids, Michigan 49512***

---

***July 15, 2015***

## TABLE OF CONTENTS

|          |  |          |
|----------|--|----------|
| <b>1</b> | <b>INTRODUCTION.....</b>                                       | <b>1</b> |
| 1.1      | REGULATORY FRAMEWORK FOR SO <sub>2</sub> AREA DESIGNATION..... | 1        |
| <b>2</b> | <b>FACILITY DESCRIPTION .....</b>                              | <b>3</b> |
| 2.1      | INVENTORY OF COMBUSTION SOURCES .....                          | 3        |
| 2.2      | EMISSIONS CHARACTERIZATION .....                               | 4        |
| 2.2.1    | <i>Coal-Fired Units (DEK1 and DEK2)</i> .....                  | 4        |
| 2.2.2    | <i>Proposed 1-Hour Critical Emission Values</i> .....          | 5        |
| 2.2.3    | <i>Natural Gas/Fuel Oil-Fired Units (DEK3 and DEK4)</i> .....  | 6        |
| <b>3</b> | <b>DISPERSION MODEL AND MODELING DATABASES .....</b>           | <b>8</b> |
| 3.1      | DISPERSION MODEL.....  | 8        |
| 3.2      | LAND USE CLASSIFICATION AND DISPERSION MODE.....               | 8        |
| 3.3      | AERODYNAMIC DOWNWASH EFFECTS .....                             | 9        |
| 3.4      | RECEPTOR POINTS AND TERRAIN ELEVATION .....                    | 10       |
| 3.5      | METEOROLOGICAL DATA .....                                      | 11       |
| 3.6      | DISPERSION MODELING METHODOLOGY AND RESULTANT IMPACTS.....     | 12       |

## LIST OF FIGURES

|          |   |
|----------|---|
| FIGURE 1 | LOCATION OF THE D.E. KARN GENERATING COMPLEX  |
| FIGURE 2 | 3D VIEW OF STRUCTURES CONSIDERED IN THE PLUME DOWNWASH ANALYSIS                         |
| FIGURE 3 | FENCELINE AND NEARBY RECEPTORS  |
| FIGURE 4 | RECEPTOR GRID USED IN THE SO <sub>2</sub> AREA DESIGNATION ANALYSIS                     |
| FIGURE 5 | NESTED RECEPTOR GRID USED IN THE SO <sub>2</sub> AREA DESIGNATION ANALYSIS              |
| FIGURE 6 | THREE YEAR COMPOSITE WIND ROSE FOR SAGINAW, MICHIGAN                                    |
| FIGURE 7 | LOCATION OF THE 99 <sup>TH</sup> PERCENTILE DAILY 1-HOUR MAXIMUM SO <sub>2</sub> IMPACT |

## LIST OF TABLES

|         |   |
|---------|---|
| TABLE 1 | SUMMARY OF SO <sub>2</sub> EMISSION LIMITS  |
| TABLE 2 | SUMMARY OF CRITICAL 1-HOUR SO <sub>2</sub> EMISSION RATES                                   |
| TABLE 3 | AUER'S LAND USE CLASSIFICATION SCHEME   |
| TABLE 4 | STACK EXHAUST PARAMETERS  |
| TABLE 5 | COMPARISON OF MODELED SO <sub>2</sub> CONCENTRATIONS TO THE 1-HOUR SIGNIFICANT IMPACT LEVEL |
| TABLE 6 | COMPARISON OF MODELED SO <sub>2</sub> CONCENTRATIONS TO THE 1-HOUR NAAQS                    |

## **LIST OF ATTACHMENTS**

|              |  |
|--------------|--|
| ATTACHMENT A | CONTINUOUS EMISSIONS MONITORING DATA FOR DEK34 AND<br>DISPERSION MODELING INPUT/OUTPUT FILES (DVD-ROM) |
| ATTACHMENT B | SUMMARY OF DEK34 CEMS MISSING HOURLY SO <sub>2</sub> AND/OR FLOW<br>DATA DURING THE 2012-2014 PERIOD   |

# 1 INTRODUCTION

On behalf of the Consumers Energy Company (“Consumers”), Horizon Environmental Corporation (“Horizon”) has conducted ambient air quality dispersion modeling analyses to demonstrate that the area surrounding the D.E. Karn Generating Complex (SRN: B2840) is in attainment with the 1-hour sulfur dioxide (“SO<sub>2</sub>”) national ambient air quality standard (“NAAQS”). The dispersion modeling analyses were conducted in accordance with the relevant provisions of the draft *SO<sub>2</sub> NAAQS Designations Modeling Technical Assistance Document* (the “Modeling TAD”, U.S. EPA, December 2013), the *Updated Guidance for Area Designations for the 2010 Primary Sulfur Dioxide National Ambient Air Quality Standard* (U.S. EPA, March 20, 2015), and *Guidance for 1-Hour SO<sub>2</sub> Nonattainment Area SIP Submissions* (U.S. EPA, April 23, 2014). Moreover, the dispersion modeling analyses were conducted consistent with a protocol submitted to the Michigan Department of Environmental Quality, Air Quality Division (“AQD”) on May 28, 2015 and subsequently approved by the U.S. EPA, Region 5.

This submittal constitutes the technical report summarizing the methodology and results of the dispersion model simulations that Consumers conducted in support of the 1-hour SO<sub>2</sub> NAAQS attainment designation. A description of the D.E. Karn (“Karn”) Generating Complex, including a discussion of the SO<sub>2</sub> emissions data that were analyzed in support of the attainment designation, is provided in **Section 2**. The dispersion model, databases, and methodology employed in the analysis, as well as resultant model-predicted impacts, are detailed in **Section 3**.

## 1.1 REGULATORY FRAMEWORK FOR SO<sub>2</sub> AREA DESIGNATION

On June 2, 2010, the U.S. EPA established for the first time a primary 1-hour SO<sub>2</sub> NAAQS,<sup>1</sup> while at the same time revoking both the existing 24-hour and annual primary SO<sub>2</sub> NAAQS. Attainment with the new standard in an airshed is demonstrated when the 3-year average of the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations does not exceed 75 ppb. To date, attainment designations have been established for 29 areas in 16 states. On March 2, 2015, the U.S. District Court for the Northern District of California entered a Consent Decree (“1-hour SO<sub>2</sub> NAAQS CD”) and

---

<sup>1</sup> The 1-hour standard became effective on August 23, 2010.

issued an enforceable order for the U.S. EPA to complete its area designations according to a specified time schedule.

Based on current SO<sub>2</sub> emission levels, an attainment designation for the area surrounding the Karn Generating Complex must be completed no later than July 2, 2016. The U.S. EPA has requested that the states, including Michigan, submit their designation recommendations by September 18, 2015. Considering the accelerated submittal schedule and limited representative ambient monitoring data, designation recommendations for the area surrounding the Karn Generating Complex will be based on source modeling.

In contrast to a typical 1-hour SO<sub>2</sub> NAAQS compliance demonstration, the Modeling TAD recommends that an area designation request follow an ambient monitoring approach by conducting the modeling analyses as follows:

- Use actual emissions as an input for assessing violations to provide results that reflect current actual air quality;
- Conduct three years of modeling to calculate a simulated design value consistent with the 3-year monitoring period required to develop a design value;
- Place receptors only in locations where a monitor could be reasonably placed; and
- When simulating actual emission rates, use actual stack heights rather than stack heights based on good engineering practice (if different).

Upon the request of the AQD and in order to support them with their area designation recommendations, Consumers conducted air quality dispersion modeling analyses to assess compliance with the 1-hour SO<sub>2</sub> NAAQS in the area surrounding the Karn Generating Complex. Consumers followed the approach recommended in the Modeling TAD, deviating only to the extent that more site-specific guidance was provided by the U.S. EPA Region 5 or the AQD, or an emissions strategy more conservative than one based on actual emissions is sufficient to demonstrate attainment with the standard.

## 2 FACILITY DESCRIPTION

The Karn Generating Complex is located at 2742 North Weadock Highway, Essexville, Michigan. Emission units operating at the Karn Generating Complex are covered under ROP No. MI-ROP-B2840-2014, and Permit to Install No. 40-15. The location of the Karn Generating Complex in relation to the surrounding area is illustrated in **Figure 1**.

### 2.1 INVENTORY OF COMBUSTION SOURCES

It should be noted that the Karn Generating Complex is co-located with the JC Weadock Generating Complex (“JCW”), which is comprised of coal-fired utility boiler Units 7 and 8 and ancillary equipment. In November 2014, Consumers entered into a Consent Decree (“Consumers CD”) with the Environmental Protection Agency (EPA) and Department of Justice (“DOJ”) which requires JCW Units 7 and 8 be retired no later than April 15, 2016. Therefore, consistent with the 1-hour SO<sub>2</sub> NAAQS CD, no SO<sub>2</sub> emission sources associated with JCW were included in this modeling analysis.

The primary steam-generating units for electric generation at the Karn Generating Complex are identified as DEK1, DEK2, DEK3, and DEK4. These combustion units as well as other smaller combustion units operating at the Karn Generating Complex that have the potential to emit SO<sub>2</sub> (i.e., excluding units which are limited to firing natural gas only via enforceable restriction) are summarized as follows:

- One 2,500 MMBtu/hr coal-fired boiler with fuel oil startup (“DEK1”);
- One 2,540 MMBtu/hr coal-fired boiler with fuel oil startup (“DEK2”);
- One 7,290 MMBtu/hr dual fuel-fired boiler (fuel oil and natural gas) (“DEK3”);
- One 8,030 MMBtu/hr dual fuel-fired boiler (fuel oil and natural gas) (“DEK4”);
- One <500 Hp diesel-fired AC emergency generator engine;
- One <500 Hp diesel-fired DC emergency generator engine; and
- One <9 MMBtu/hr diesel-fired emergency generator engine.

Considering their heat input capacity, fuel type, and historical and projected operations, the area designation modeling analyses included emissions from DEK1, DEK2, DEK3, and DEK4. The three diesel-fired emergency generator engines are intermittent sources that operate only during emergency situations (or readiness testing). Readiness testing of the diesel-fired emergency generator engines generally occurs for a few minutes on a



weekly basis. Actual operation of the three diesel-fired emergency generator engines for the previous two years (including approximately 7 hours of emergency run time in 2014 due to a station power trip) is summarized as follows:

### 2013

<500 HP AC Emergency Generator Engine – 13 hours  
<500 HP DC Emergency Generator Engine – 24 hours  
<9 MMBtu/hr Emergency Generator Engine – 4 hours

### 2014

<500 Hp AC Emergency Generator Engine – 25 hours  
<500 Hp DC Emergency Generator Engine – 35 hours  
<9 MMBtu/hr Emergency Generator Engine – 11 hours

Consistent with Section 5.4 of the Modeling TAD, modeling of intermittent sources was not conducted as part of the area designation analysis. Consumers also operates two 300 MMBtu/hr auxiliary natural gas-fired boilers that have no backup fuel capability. Consequently, the two boilers do not have the potential to emit significant quantities of SO<sub>2</sub> and were not included in the area designation analysis.

## **2.2 EMISSIONS CHARACTERIZATION**

Pursuant to the Modeling TAD, area designation modeling may be conducted following an “actual emissions” approach or, if sufficient to demonstrate compliance with the 1-hour standard, a more conservative approach based on allowable emissions. Actual emissions data is beneficial for assessing whether an area has been in attainment with the 1-hour SO<sub>2</sub> NAAQS, but may have limited benefit looking forward if a source is in the process of implementing an emissions control strategy. In that event, future actual emissions will likely be much lower than recent historical actual emissions. Similarly, federally-enforceable allowable emission limits for the source are also typically lower after implementation of the control strategy.

### **2.2.1 Coal-Fired Units (DEK1 and DEK2)**

Such is the case with the two coal-fired units, DEK1 and DEK2. On April 30, 2015, the AQD issued Permit to Install No. 40-15, which contains federally-enforceable emission limits and operating restrictions for the two coal-fired units based on the implementation of an enhanced SO<sub>2</sub> emissions control strategy mandated by the Consumers CD. As

stipulated by the permit, DEK1 and DEK2 have each been equipped with a spray dry absorber (“SDA”), operation of which commenced on June 6, 2014 for DEK1 and May 20, 2015 for DEK2.

Historically, the only SO<sub>2</sub> emission limits for DEK Units 1-4 consisted of lb/mmBtu emission limits (calendar month average) which originated from Michigan Air Pollution Control Rule 336.1401. For DEK1 and DEK2, the Consumers CD introduces additional 30-day and 365-day rolling average SO<sub>2</sub> lb/mmBtu emission limits for each unit (there are no additional SO<sub>2</sub> limits for DEK3 and DEK4). For purposes of assessing the allowable SO<sub>2</sub> emission rates for DEK1 and DEK2, the 30-day rolling average SO<sub>2</sub> emission limits in the Consumers CD were simulated.

The historic SO<sub>2</sub> lb/mmBtu emission limits (based on Rule 336.1401) and the new 30-day rolling SO<sub>2</sub> emission limits for DEK 1 and 2 and resultant allowable mass emission rates for DEK1 and DEK2, as well as DEK3 and DEK4, are shown in **Table 1**. The effect of the emissions control strategy on the two coal-fired units is to reduce the SO<sub>2</sub> combined potential to emit of the four units from 25,422 pounds per hour to 17,459 pounds per hour (a 31% reduction).

### **2.2.2 Proposed 1-Hour Critical Emission Values**

As shown in **Table 1**, the current permit-allowable emission limits for DEK1 and DEK2 are based on a monthly/30-day averaging period. Though there are currently no federally-enforceable hourly emission limits for the two units, the U.S. EPA’s *Guidance for 1-Hour SO<sub>2</sub> Nonattainment Area SIP Submissions* provides a procedure for developing a 1-hour “critical emission value” from a longer-term average emission limit. After consultation with the AQD and the U.S. EPA Region 5, Consumers estimated 1-hour critical emission values for DEK1 and DEK2 following the U.S. EPA guidance.

Conceptually, the U.S. EPA guidance suggests that a determination of the variability in SO<sub>2</sub> emissions over longer-term averaging periods should be based on the final control configuration coupled with the emission limits. In this regard, historic CEMS data for DEK1 and DEK2 are unusable as these units have only limited actual emission data with the required SDA controls in place. However, an alternative approach based on a review of actual emissions data from similarly controlled emission units is provided in the guidance. Following the guidance, the proposed basis for developing a 1-hour critical emission value for each unit is described below.

## DEK1 and DEK2 (Equipped with SDA Control)

Appendix D of the guidance provides useful information for translating between 30-day rolling average and 1-hour average emissions for units equipped with a SDA. Specifically, based upon a review of 90 different units equipped with a SDA, the U.S. EPA arrived at a ratio of 0.63 when comparing the 99<sup>th</sup> percentile of the 30-day rolling average SO<sub>2</sub> emission rates to the 99<sup>th</sup> percentile of the associated 1-hour average emission rates. Using the preceding ratio, the permit-allowable 30-day SO<sub>2</sub> emission limit for DEK1 and DEK2 can be translated to 1-hour critical emission values, as shown in **Table 2**.

### **2.2.3 Natural Gas/Fuel Oil-Fired Units (DEK3 and DEK4)**

The two natural gas/fuel oil-fired units, DEK3 and DEK4, serve as peaker units that are rarely called upon for electric generation purposes. Moreover, the units rarely fired fuel oil during the 3-year study period (2012-2014). As noted previously, Units 3 and 4 share a common stack. During the 3-year study period, there were only a total of 1,450 clock hours during which the common stack was operating while Units 3 and/or 4 were in service. Of the preceding hours, only 191 were associated with some level of oil-firing in Units 3 and/or 4.

To model an emission rate based on the allowable SO<sub>2</sub> emission limit (or its equivalent 1-hour critical emission value) for these two units would not be representative of the SO<sub>2</sub> impact being created by the Karn Generating Complex during the 3-year period. Therefore, the area designation modeling analyses were conducted using the actual SO<sub>2</sub> emissions for the two units, as recorded by continuous emissions monitoring systems (“CEMS”) installed on the common stack shared by these units, during the 3-year period. Initial model simulations to designate the area in attainment were conducted using the peak 1-hour SO<sub>2</sub> emission rate during the 3-year period<sup>2</sup>. This approach is a conservative representation of the DEK3 and DEK4 impact on SO<sub>2</sub> concentrations in the area and sufficient to support the 1-hour SO<sub>2</sub> NAAQS designation for the area. Consumers fully expects that modeling of actual hour-by-hour SO<sub>2</sub> emissions from the Karn Units 3 and 4 common stack would have yielded substantially lower overall SO<sub>2</sub> impacts for the facility.

---

<sup>2</sup> The peak 1-hour emission rate recorded by the CEMS during the period 2012-2014 is 6,481.1 lbs/hr for the common stack shared by DEK3 and DEK4 (corresponds to 08/14/2012, Hour 18:00).

Although modeling of hour-by-hour actual emissions has not been conducted, **Attachment A** includes an electronic spreadsheet containing the hourly CEMS data for the DEK3 and DEK4 common stack, while **Attachment B** summarizes any SO<sub>2</sub> or Flow CEMS missing hourly data associated with the three year period. The standard missing data substitution procedures contained in Subpart D of 40 CFR Part 75 was used for any periods of missing SO<sub>2</sub> mass emission rate or flow rate CEMS data. However, there was no CEMS missing data during the hour associated with the peak 1-hour SO<sub>2</sub> emission rate used in the modeling analysis.

### 3 DISPERSION MODEL AND MODELING DATABASES

Ambient air quality dispersion modeling analyses were conducted to demonstrate that the area surrounding the Karn Generating Complex should be designated in attainment with the 1-hour SO<sub>2</sub> NAAQS. The following sections summarize the dispersion model that was employed in the analysis, site area characteristics, modeling databases developed in support of the analysis, the methodology for conducting the compliance demonstration, and resultant modeled impacts.

#### 3.1 DISPERSION MODEL

Model simulations in support of the 1-hour SO<sub>2</sub> NAAQS area designation were conducted using the AMS/EPA Regulatory Model (“AERMOD”, Release No. 14134)<sup>3</sup>. AERMOD is currently recommended and approved for use in near-field SO<sub>2</sub> modeling applications by both the U.S. EPA and the AQD. AERMOD is designed to simulate conditions associated with this area designation, including:

- Rural dispersion conditions;
- Both windy and calm meteorological conditions;
- Flat and simple terrain;
- Elevated point sources influenced by building downwash;
- Transport less than 50 kilometers; and
- Concentration estimates over a one-hour averaging period.

The AERMOD simulations were conducted in the Regulatory Default mode.

#### 3.2 LAND USE CLASSIFICATION AND DISPERSION MODE

Atmospheric conditions affecting the downwind dispersion of air contaminants may be influenced by localized land use. Further, an exponential decay of SO<sub>2</sub> may occur during dispersion in an urban environment. As a result, AERMOD has been designed to

---

<sup>3</sup> In their review of the dispersion modeling protocol, the U.S. EPA Region 5 noted the imminent release of a new version of AERMOD. As of the date of this submittal, the new version of AERMOD has not been released to the public and was, therefore, not available to be used in the analysis.

simulate the downwind dispersion of SO<sub>2</sub> under both rural and urban conditions. To assess whether to run AERMOD in rural or urban mode for a particular application, the U.S. EPA's Guideline on Air Quality Models suggests using either a population density procedure or a land use classification procedure employing a typing scheme developed by Auer<sup>4</sup>. Of the two methods, the U.S. EPA considers the land use procedure to be the more definitive.

The Auer land use classification procedure is conducted as follows:

- 1) Classify the land use within the total area, A<sub>o</sub>, circumscribed by a three kilometer radius circle around the source using Auer's land use typing scheme;
- 2) If land use types I1, I2, C1, R2, and R3 account for 50 percent or more of A<sub>o</sub>, use urban dispersion coefficients; otherwise, use appropriate rural dispersion coefficients.

Consistent with U.S. EPA guidance, Auer's land use typing scheme was utilized to assess localized land use for the Karn Generating Complex. The land use typing scheme is summarized in **Table 3**.

The Karn Generating Complex is located in Essexville, a town with a population of 3,478 (2010 Census) located between Bay City and Saginaw Bay. Utilizing satellite imagery, shown in **Figure 1**, land use within a three kilometer radius around the complex has been assessed and clearly exhibits rural characteristics (e.g., agricultural, common residential, and water surfaces). As a result, AERMOD simulations in support of the SO<sub>2</sub> NAAQS area designation for the Karn Generating Complex were conducted in rural mode.

### **3.3 AERODYNAMIC DOWNWASH EFFECTS**

As described in Section 2.1, the SO<sub>2</sub> NAAQS area designation analysis for the Karn Generating Complex included the following emission units:

- Two coal-fired boilers (DEK1 and DEK2) that vent to individual 350 foot tall stacks; and

---

<sup>4</sup> Correlation of Land Use and Cover with Meteorological Anomalies, Journal of Applied Meteorology, 1978.

- Two natural gas and fuel oil-fired boilers (DEK3 and DEK4) that vent to a common stack with a height of 450 feet.

The three Karn stacks are each lower than Good Engineering Practice (“GEP”) height. Plumes emitted from stacks with heights less than GEP design may be influenced by nearby buildings or other structures. In accordance with Section 6.1 of the Modeling TAD, the BPIP-PRIME aerodynamic downwash pre-processor (Release No. 04274) was utilized to estimate the maximum projected lateral and vertical dimensions of those buildings or structures that could influence the boiler stacks on a wind direction-specific basis.

BPIP-PRIME requires as input the dimensions of buildings or structures that could potentially influence emissions from a stack that is located at a distance less than five times the lesser dimension of height or projected width of the nearby structure. Maximum projected lateral and vertical dimensions of influencing structures, as calculated by BPIP-PRIME, are subsequently input to AERMOD. Two existing Boiler Houses and related structures have the potential to influence the plumes emitted from the boilers.

A three dimensional depiction of the two existing Boiler Houses and related structures that may influence plumes emitted from the modeled emission points is provided in **Figure 2**.

### **3.4 RECEPTOR POINTS AND TERRAIN ELEVATION**

AERMOD-predicted concentrations may be estimated at discrete receptor locations. A discrete cartesian-based receptor grid was developed in support of the area designation analysis according to the following methodology:

- Receptors were located along the secured property boundary at distances not exceeding 50 meters.
- Receptors were located off-property at 100 meter spacing out to a distance of approximately 2 kilometers from the facility.
- Additional receptors were located off-property at 200 meter spacing out to a distance of approximately 10 kilometers from the facility.
- Additional receptors were located off-property at 500 meter spacing out to a distance of approximately 20 kilometers from the facility.
- Additional receptors were located off-property at 1 kilometer spacing out to a distance of approximately 50 kilometers from the facility.
- Consistent with the Modeling TAD, receptors were located only where a monitor could reasonably be placed. Therefore, receptors were not located over Saginaw

Bay or the inlet to the Saginaw River. Though not likely a reasonable location for an ambient monitor, receptors were located over Shelter/Channel Island.

In addition to the preceding receptor grids, an additional “nested” receptor grid at 100 meter spacing was placed in the area of the maximum impacts based on the form of the 1-hour SO<sub>2</sub> NAAQS (i.e., 3-year average of the 99<sup>th</sup> percentile daily 1-hour maximum concentrations) as these impacts were occurring beyond 2 kilometers from the facility.

Fenceline and nearby receptors are shown in **Figure 3**. The receptor grid used in the SO<sub>2</sub> NAAQS area designation analysis consisted of 15,240 discrete receptor points and is illustrated in **Figure 4**. The nested receptor grid, which was sufficient to identify the maximum impact based on the form of the 1-hour SO<sub>2</sub> NAAQS, consisted of 121 discrete receptor points and is illustrated in **Figure 5**.

Elevated terrain features may affect the transport of atmospheric contaminants as well as serve as areas of potentially higher pollutant impacts. Where appropriate, terrain features should be included in the modeling analysis. A review of topographic projection data reveals minor fluctuations in terrain elevations around the Karn Generating Complex. In accordance with U.S. EPA guidance, terrain elevations for each modeled stack and receptor point were included in the dispersion modeling analysis.

Terrain elevations at stack locations and discrete receptor points were obtained using the U.S. EPA’s AERMAP preprocessor (Release No. 11103)<sup>5</sup> in conjunction with U.S.G.S National Elevation Dataset (“NED”) terrain files in NAD83 format.

### 3.5 METEOROLOGICAL DATA

The form of the SO<sub>2</sub> NAAQS is based on a 3-year average of the annual 99<sup>th</sup> percentile of the 1-hour daily maximum concentrations. Consistent with the Modeling TAD, the area designation analysis was conducted using the most spatially representative and readily available meteorological database that coincides with the period covering the emissions data for the Karn Generating Complex (2012-2014).

The Karn Generating Complex is located approximately 14 miles northeast of the National Weather Service (“NWS”) Automated Surface Observing System station in

---

<sup>5</sup> Terrain processing was conducted using the AERMAP module of the AERMODView software system, Version 8.8.9, developed by Lakes Environmental.



Saginaw (“MBS”, Station No. 14845). A three-year composite wind rose for MBS, covering the years 2012-2014, is provided in **Figure 6**. The wind frequency distribution revealed in the figure shows wind flow patterns that would be expected to occur at a facility located along the southwestern shoreline of Saginaw Bay (i.e., predominate wind flow from the west, southwest, south, as well as northeast along the fetch of the bay).

Using the AERMET preprocessor, the AQD has compiled surface observations from MBS for the period 2012-2014 with coincident upper air observations measured at NWS station at White Lake, Michigan (Station No. 72632). Consumers used the MBS/White Lake meteorological database, as processed and provided by the AQD in a 1-minute format, in the SO<sub>2</sub> NAAQS area designation analysis.

### 3.6 DISPERSION MODELING METHODOLOGY AND RESULTANT IMPACTS

Dispersion model simulations of the Karn Generating Complex were conducted to provide the information necessary to designate the area in attainment with the 1-hour SO<sub>2</sub> NAAQS. The model simulations were conducted with AERMOD using a three-year meteorological database (2012-2014 MBS/White Lake). As described in **Section 2.2**, the simulations were based on the critical 1-hour allowable emission rate for the two primary boilers (DEK1 and DEK2) and the peak 1-hour actual emission rate measured in the common stack serving the two peaker boilers (DEK3 and DEK4) during the three-year period. Stack exhaust parameters for the modeled emission units is provided in **Table 4**.

The first step in the modeling analysis was to compare maximum predicted 1-hour impacts at each receptor point against the interim 1-hour significant impact level (“SIL”) of 3 ppb (7.8 µg/m<sup>3</sup>) published in the “*General Guidance for Implementing the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard in Prevention of Significant Deterioration Permits, Including an Interim 1-hour SO<sub>2</sub> Significant Impact Level*” (U.S. EPA, August 23, 2010). Maximum predicted 1-hour SO<sub>2</sub> impacts across the three-year meteorological database are summarized in **Table 5**. As shown in the table, the maximum of the three-year average of the maximum 1-hour SO<sub>2</sub> concentrations is 122.2 µg/m<sup>3</sup>, which is well above the SIL.

Cumulative modeling analyses, taking into account additional sources that could contribute to the area of significant impacts (i.e., receptor points where model-predicted impacts are greater than the SIL) generated by the facility are typically conducted for each receptor point contained within the significant impact area (“SIA”). The AQD has conducted an analysis of additional sources in the area around the Karn Generating Complex and has determined

that none of the sources is expected to have a significant impact within the Karn Generating Complex SIA. Therefore, no additional sources were included in the area designation modeling.

In order to assess compliance with the 1-hour SO<sub>2</sub> NAAQS, the model calculates the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations across the three-year meteorological database. As part of a cumulative modeling analysis, this design concentration is subsequently combined with a representative background design concentration. If this combined impact is less than 75 ppb (196 µg/m<sup>3</sup>), then the area is designated as being in attainment with the 1-hour SO<sub>2</sub> NAAQS.

The AQD has provided a background design concentration of 17.9 ppb (46.9 µg/m<sup>3</sup>). This value represents the 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentration measured at the Lansing ambient monitor for the period 2012-2014. As a conservative “first tier” approach, this background design concentration was combined with the modeled design concentration.

Adhering to the form of the standard, the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations across the three-year meteorological database was predicted by AERMOD at 75.7 µg/m<sup>3</sup>. Summing the model-predicted impact with the AQD-provided background concentration results in a combined impact of 122.5 µg/m<sup>3</sup>, which is well under the 1-hour SO<sub>2</sub> NAAQS of 196 µg/m<sup>3</sup> (75 ppb). Therefore, dispersion modeling analyses have demonstrated that the area surrounding the Karn Generating Complex is in attainment with the 1-hour SO<sub>2</sub> NAAQS.

Modeled impacts are compared against the 1-hour SO<sub>2</sub> NAAQS in **Table 6**. The location of the 99<sup>th</sup> percentile daily 1-hour maximum concentration is shown in **Figure 7**. An electronic copy of all AERMOD and model preprocessor input/output files is submitted along with this technical report on DVD-ROM.

## ***FIGURES***

---




**Location of  
D.E. Karn - J.C. Weadock  
Generating Complex**

**Legend**


- D.E. Karn - J.C. Weadock Generating Complex
- Interstate
- Highway
- Ramp
- City Boundary

**Figure 1  
Location of  
D.E. Karn – J.C. Weadock Generating Complex  
Essexville, Michigan**







**Figure 2**  
3D View of D.E. Karn Structures Considered in the Plume Downwash Analysis  
D.E. Karn – J.C. Weadock Generating Complex  
Essexville, Michigan





**Figure 3**  
**Fenceline and Nearby Receptors**  
**D. E. Karn - J. C. Weadock Generating Complex**






**Figure 4**  
**Receptor Grid Used in the**  
**SO<sub>2</sub> Area Designation Analysis**  
**D. E. Karn - J. C. Weadock Generating Complex**





**Figure 5**  
**Nested Receptor Grid Used in the**  
**SO<sub>2</sub> Area Designation Analysis**  
**D. E. Karn - J. C. Weadock Generating Complex**



July 2015




WIND ROSE PLOT:

**Figure 6 - Three Year Composite Wind Rose  
Saginaw (2012-2014)**

DISPLAY:

**Wind Speed  
Direction (blowing from)**



COMMENTS:

DATA PERIOD:

**Start Date: 1/1/2012 - 00:00  
End Date: 12/31/2014 - 22:00**

COMPANY NAME:

**Horizon Environmental Corporation**

CALM WINDS:

**0.36%**

TOTAL COUNT:

**26260 hrs.**

AVG. WIND SPEED:

**8.59 Knots**


DATE:

**7/15/2015**

PROJECT NO.:



**Figure 7**  
**Location of the 99<sup>th</sup> Percentile**  
**Daily 1-Hour Maximum SO<sub>2</sub> Impact**  
**D. E. Karn - J. C. Weadock Generating Complex**



## *TABLES*

---

**TABLE 1  
SUMMARY OF SO<sub>2</sub> EMISSION LIMITS  
CONSUMERS ENERGY COMPANY - D.E. KARN GENERATING COMPLEX**

| Emission Unit ID | Nominal Heat Input Rating (MMBtu/hr) | Primary Fuel | Alternate Fuel | Maximum Allowable Emissions (lbs/MMBtu) |                  |                                 |                  | Potential to Emit (lbs/hr) |                             |
|------------------|--------------------------------------|--------------|----------------|---|------------------|---------------------------------|------------------|----------------------------|-----------------------------|
|                  |                                      |              |                | Historic Limit <sup>1</sup>             |                  | Consumers CD Limit <sup>2</sup> |                  | Based on Historic Limit    | Based on Consumers CD Limit |
|                  |                                      |              |                | Numerical Limit                         | Averaging Period | Numerical Limit                 | Averaging Period |                            |                             |
| EUKARN1 (DEK1)   | 2,500                                | Coal         | Fuel Oil       | 1.67                                    | Monthly          | 0.090                           | 30-day rolling   | 4,175                      | 225.0                       |
| EUKARN2 (DEK2)   | 2,540                                | Coal         | Fuel Oil       | 1.67                                    | Monthly          | 0.090                           | 30-day rolling   | 4,242                      | 228.6                       |
| EUKARN3 (DEK3)   | 7,290                                | Fuel Oil     | Natural Gas    | 1.11                                    | Monthly          | NA                              | NA               | 8,092                      | NA                          |
| EUKARN4 (DEK4)   | 8,030                                | Fuel Oil     | Natural Gas    | 1.11                                    | Monthly          | NA                              | NA               | 8,913                      | NA                          |
| <b>Total:</b>    |                                      |              |                |   |                  |                                 |                  | <b>25,422</b>              | <b>454</b>                  |

**Notes:**

1. The historic SO<sub>2</sub> emission limits for DEK 1-4 are based upon Michigan Air Pollution Control Rule 336.1401.
2. The Consumers CD Limits for DEK1 and DEK2 are stipulated under Permit to Install No. 40-15 and mandated by a federal Consent Decree. If the Consent Decree contains more than one SO<sub>2</sub> emission limit for a given boiler, this table reflects the SO<sub>2</sub> emission limit with the shortest averaging period.

**TABLE 2**  
**DEVELOPMENT OF CRITICAL 1-HOUR SO<sub>2</sub> EMISSION RATES <sup>1</sup>**  
**CONSUMERS ENERGY COMPANY - D.E. KARN GENERATING COMPLEX**

| <b>Emission Unit ID</b> | <b>Nominal Heat Input Rating (MMBtu/hr)</b> | <b>Permit-allowable Emission Limit Per Consumers CD (lb/MMBtu)</b> | <b>Associated Averaging Period</b> | <b>Equivalent SO<sub>2</sub> Mass Emission Rate for the Specified Averaging Period (lbs/hr)</b> | <b>Ratio Between the Averaging Period Associated with the Consumers CD Limit and a 1-hr Averaging Period <sup>2</sup></b> | <b>Equivalent SO<sub>2</sub> Mass Emission Rate Based on a 1-hour Averaging Period (lbs/hr)</b> |
|-------------------------|---|--|------------------------------------|---|---|---|
| EUKARN1 (DEK1)          | 2,500                                       | 0.090  | 30-day rolling                     | 225.0   | 0.630   | 357.1   |
| EUKARN2 (DEK2)          | 2,540                                       | 0.090  | 30-day rolling                     | 228.6   | 0.630   | 362.9   |

**Notes:**

1. Analysis conducted in accordance with the Guidance for 1-Hour SO<sub>2</sub> Nonattainment Area SIP Submissions (U.S. EPA, April 23, 2014).
2. Ratio for DEK1 and DEK2, which are each equipped with SDA control, was obtained from data provided in Appendix D of the U.S. EPA guidance.

**TABLE 3  
AUER LAND USE CLASSIFICATION SCHEME  
CONSUMERS ENERGY COMPANY**

| Type | Use                       | Description  |  |
|------|---------------------------|--|--|
|      |                           | Structures   | Vegetation   |
| I1   | Heavy Industrial          | Major chemical, steel and fabrication industries; generally 3-5 story buildings, flat roofs.   | Grass and tree growth extremely rare; <5% vegetation.              |
| I2   | Light-Moderate Industrial | Rail yards, truck depots, warehouses, industrial parks, minor fabrications; generally 1-3 story buildings, flat roofs.                                   | Very limited grass, trees almost total absent; <5% vegetation.     |
| C1   | Commercial                | Office and apartment buildings, hotels; >10 story heights, flat roofs.   | Limited grass and trees; <15% vegetation <15% vegetation.          |
| R1   | Common Residential        | Single family dwelling with normal easements; generally one story, pitched roof structures; frequent driveways.  | Abundant grass lawns and light-moderately wooded; >30% vegetation. |
| R2   | Compact Residential       | Single, some multiple, family dwelling with close spacing; generally <2 story, pitched roof structures; garages (via alley), no driveways.               | Limited lawn sizes and shade trees; <30% vegetation.               |
| R3   | Compact Residential       | Old multi-family dwellings with close (<2 m) lateral separation; generally 2 story, flat roof structures; garages (via alley) and ashpits, no driveways. | Limited lawn sizes, old established shade trees; <35% vegetation.  |
| R4   | Estate Residential        | Expansive family dwelling on multi-acre tracts.  | Abundant grass lawns and lightly wooded; >80% vegetation.          |
| A1   | Metropolitan Natural      | Major municipal, state, or federal parks, golf courses, cemeteries, campuses; occasional single story structures.  | Nearly total grass and lightly wooded; >95% vegetation.            |
| A2   | Agricultural Rural        |  | Local crops (e.g., corn, soybean); >95% vegetation.                |
| A3   | Undeveloped               | Uncultivated; wasteland.   | Mostly wild grasses and weeds, lightly wooded; >90% vegetation.    |
| A4   | Undeveloped Rural         |  | Heavily wooded; >95% vegetation.                                   |
| A5   | Water Surfaces            | Rivers, lakes.   |  |

**Notes:**

1. Land use typing scheme recommended by Auer for use in assessing the most applicable dispersion coefficient.

**TABLE 4**  
**STACK EXHAUST PARAMETERS AND MODELED EMISSION RATES**  
**CONSUMERS ENERGY COMPANY - D.E. KARN GENERATING COMPLEX**

| Source ID               | Stack Coordinate <sup>1</sup><br>(UTM) |           | Emission Rate |       | Stack Height <sup>2</sup> |       | Stack Diameter <sup>2</sup> |       | Exit Gas Temperature |       | Exhaust Flow Rate<br>(acfm) | Exit Velocity<br>(m/s) |
|-------------------------|--|-----------|---------------|-------|---------------------------|-------|-----------------------------|-------|----------------------|-------|-----------------------------|------------------------|
|                         | Easting                                | Northing  | (lbs/hr)      | (g/s) | (ft)                      | (m)   | (in)                        | (m)   | (F)                  | (K)   |                             |                        |
| EUKARN1-S1 <sup>3</sup> | 270869.8                               | 4836365.2 | 357.1         | 45.0  | 350                       | 106.7 | 216                         | 5.49  | 160                  | 344.3 | 910,400                     | 18.17                  |
| EUKARN2-S1 <sup>3</sup> | 270867.3                               | 4836323.3 | 362.9         | 45.7  | 350                       | 106.7 | 216                         | 5.49  | 160                  | 344.3 | 910,400                     | 18.17                  |
| EUKARN3-S2 <sup>4</sup> | 270844.0                               | 4836215.3 | 6,481.1       | 816.6 | 450                       | 137.2 | 414                         | 10.52 | 541                  | 555.9 | 6,228,810                   | 33.85                  |

**Notes:**

1. UTM Coordinates obtained using aerial imagery in NAD 83 format.
2. Stack height and diameter for each emission unit limited under the ROP.
3. Stack temperature and exhaust flow data for DEK1 and DEK2 are based upon SDA design values at full load on the typical coal blend.
4. Stack temperature and exhaust flow data for the DEK3 and DEK4 common stack are based upon CEMS data for 08/14/2012, Hour 18:00 which corresponds to the maximum observed common stack SO<sub>2</sub> mass emission rate (6,481.1 lbs/hr) for the period 2012-2014.

**TABLE 5**  
**COMPARISON OF MODELED SO<sub>2</sub> CONCENTRATIONS TO THE 1-HOUR SIGNIFICANT IMPACT LEVEL**  
**CONSUMERS ENERGY COMPANY - D.E. KARN GENERATING COMPLEX**

| Averaging Period | Year  | Modeled Receptor Location UTM Coordinate (m) |          | 1 <sup>st</sup> Highest 1-Hour SO <sub>2</sub> Impact <sup>1</sup> (ug/m <sup>3</sup> ) | SIL <sup>2</sup> (ug/m <sup>3</sup> ) |
|------------------|---|--|----------|---|---------------------------------------|
|                  |   | Easting                                      | Northing |   |                                       |
| 1-Hour           | 2014  | 265525                                       | 4835077  | 143.4   | 7.9                                   |
|                  | 2013  | 261525                                       | 4838477  | 143.0   |                                       |
|                  | 2012  | 266925                                       | 4834077  | 180.9   |                                       |
|                  | <b>Maximum of the Three Year Average of the Maximum 1-Hour Concentrations (ug/m<sup>3</sup>):</b> |  |          | <b>122.2</b>  |                                       |

**Notes:**

1. Model simulations conducted using AERMOD over a three-year meteorological dataset (MBS Airport Surface/White Lake Upper Air).
2. The Significant Impact Level (SIL) is an interim value published in the "General Guidance for Implementing the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard in Prevention of Significant Deterioration Permits, Including an Interim 1-hour SO<sub>2</sub> Significant Impact Level" (U.S. EPA, August 23, 2010).



**TABLE 6  
COMPARISON OF MODELED SO<sub>2</sub> CONCENTRATIONS TO THE 1-HOUR NAAQS  
CONSUMERS ENERGY COMPANY - D.E. KARN GENERATING COMPLEX**

| Averaging Period   | Year | Modeled Receptor Location UTM Coordinate (m) |          | 4 <sup>th</sup> Highest Daily Max. 1-Hour SO <sub>2</sub> Impact <sup>1</sup> (ug/m <sup>3</sup> ) | Background Concentration <sup>2</sup> (ug/m <sup>3</sup> ) | Combined SO <sub>2</sub> Impact (ug/m <sup>3</sup> ) | NAAQS (ug/m <sup>3</sup> ) |
|--|------|--|----------|--|--|--|----------------------------|
|  |      | Easting                                      | Northing |  |  |  |                            |
| 1-Hour   |      |  |          |  |  |  |                            |
| Maximum of the Three Year Average of the 4 <sup>th</sup> Highest (99 <sup>th</sup> Percentile) Daily 1-Hour Maximum Concentrations (ug/m <sup>3</sup> ): |      |  |          | 75.7   | 46.9   | 122.6  | 196                        |

**Notes:**

1. Model simulations conducted using AERMOD over a three-year meteorological dataset (MBS Airport Surface/White Lake Upper Air).
2. A background concentration of 46.9 ug/m<sup>3</sup> (17.9 ppb) was provided by the MDEQ-AQD.

*ATTACHMENT A*

---

**CONTINUOUS EMISSIONS MONITORING DATA  
AND DISPERSION MODELING INPUT/OUTPUT FILES  
(DVD-ROM)**

*ATTACHMENT B*

---

**SUMMARY OF CEMS MISSING HOURLY SO<sub>2</sub> AND/OR FLOW DATA  
DURING THE 2012-2014 PERIOD (MODELED HOURLY VALUES BASED  
ON THE STANDARD 40 CFR PART 75, SUBPART D, MISSING DATA  
SUBSTITUTION PROCEDURES)**

# Missing Data Substitution Hours

Plant: KARN34

Report Period: 01/01/2012 00:00 Through 12/31/2014 23:59

Source: KARN34

Units: SCFH

Parameter: FLOW

| Date       | Hour | Avg Value  | MC | Load Range | PMA  | QA Hours |
|------------|------|------------|----|------------|------|----------|
| 09/11/2012 | 15   | 40971158.3 | 2  | 2          | 99.7 | 6751     |

Number of Missing Hours for KARN34 FLOW: 1

Source: KARN34

Units: PPM

Parameter: SO2

| Date       | Hour | Avg Value | MC | Load Range | PMA  | QA Hours |
|------------|------|-----------|----|------------|------|----------|
| 12/26/2012 | 07   | 2         | 6  | 1          | 99.6 | 6949     |
| 02/26/2013 | 17   | 2         | 6  | 1          | 99.7 | 8005     |
| 02/26/2013 | 18   | 2         | 6  | 1          | 99.7 | 8005     |
| 11/27/2013 | 04   | 2         | 6  | 1          | 99.7 | 8654     |
| 11/27/2013 | 05   | 2         | 6  | 1          | 99.7 | 8654     |
| 12/06/2013 | 11   | 2         | 6  | 1          | 99.7 | 8645     |
| 12/06/2013 | 12   | 2         | 6  | 1          | 99.7 | 8645     |
| 05/28/2014 | 22   | 2         | 6  | 1          | 99.7 | 8670     |
| 05/28/2014 | 23   | 2         | 6  | 1          | 99.7 | 8670     |
| 10/30/2014 | 22   | 2         | 6  | 1          | 99.9 | 7780     |
| 10/30/2014 | 23   | 2         | 6  | 1          | 99.9 | 7780     |

Number of Missing Hours for KARN34 SO2: 11

Total Number of Missing Hours for KARN34: 12

Grand Total Number of Missing Hours: 12

# Sulfur Dioxide (SO<sub>2</sub>) NAAQS Designation Dispersion Modeling

*Support Document*

**Lansing Board of Water and Light  
Lansing, Michigan**

**NTH Project No. 73-150188-01  
July 7, 2015  
Revised: July 22, 2015**

**NTH Consultants, Ltd.**  
608 S. Washington Avenue  
Lansing, MI 48933



# Table of Contents



|      |  |    |
|------|--|----|
| 1.0  | INTRODUCTION                               | 1  |
| 2.0  | FACILITY DESCRIPTION                       | 1  |
| 2.1  | Eckert Station.....                        | 2  |
| 2.2  | Erickson Station.....                      | 2  |
| 3.0  | MODEL                                      | 3  |
| 3.1  | Proprietary Model Information.....         | 4  |
| 4.0  | EMISSIONS CHARACTERIZATION                 | 4  |
| 5.0  | SITE DESCRIPTION                           | 6  |
| 5.1  | Stack Parameters.....                      | 6  |
| 5.2  | Rural/Urban Dispersion Options.....        | 7  |
| 6.0  | BACKGROUND CONCENTRATION                   | 7  |
| 7.0  | METEOROLOGY                                | 7  |
| 8.0  | MODELING DOMAIN                            | 8  |
| 9.0  | OFF-SITE EMISSIONS INVENTORY               | 10 |
| 10.0 | AMBIENT IMPACT ANALYSIS (SO <sub>2</sub> ) | 11 |
| 10.1 | Results.....                               | 11 |
| 10.2 | Dispersion Modeling Description.....       | 11 |
| 10.3 | Dispersion Modeling Files.....             | 12 |



# Table of Contents (continued)



## TABLES

|   |    |
|---|----|
| Table 1 Summary of 3-Year (2012-2014) Variable Emissions.....           | 5  |
| Table 2 Summary of Continuous Emission Rates at the REO Town Plant..... | 5  |
| Table 3 Stack Parameters.....   | 6  |
| Table 4 Erickson and Eckert Modeling Results.....                       | 11 |

## APPENDICIES

|                  |                                  |
|------------------|----------------------------------|
| Appendix A ..... | Eckert and Erickson Site Layouts |
| Appendix B.....  | Offsite Source Inventory         |
| Appendix C ..... | Modeling Files                   |





## 1.0 INTRODUCTION

Lansing Board of Water and Light (BWL) has retained NTH Consultants, Ltd. (NTH) to assist in conducting dispersion modeling for sulfur dioxide (SO<sub>2</sub>) from the existing BWL Eckert and Erickson Power Stations. Specifically, the U.S. Environmental Protection Agency (U.S. EPA) is addressing areas within multiple states that have larger sources of SO<sub>2</sub> emissions and determining if those areas are designated as in attainment or nonattainment with the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard (NAAQS). State air agencies can use either monitoring or dispersion modeling to characterize the SO<sub>2</sub> air quality.

For Lansing, Michigan, preliminary dispersion modeling performed by the Michigan Department of Environmental Quality (MDEQ) Air Quality Division (AQD) utilizing actual SO<sub>2</sub> emissions shows that individual facilities in the area meet the 1-hour SO<sub>2</sub> NAAQS. Additionally, the nearby SO<sub>2</sub> ambient monitor supports attainment designation for the area. However, there is concern that multi-source allowable emissions may contribute to localized “hot spots” that do not meet the 1-hour SO<sub>2</sub> NAAQS. U.S. EPA has indicated that they would consider “weight of evidence” material if combined impact hot spots are close to the standard when using allowable emissions and all emission reductions have been vetted.

This compliance demonstration is being submitted for the purpose of refined dispersion modeling of SO<sub>2</sub> emissions from the BWL Erickson and Eckert facilities for comparison to the 1-hour SO<sub>2</sub> NAAQS. The modeling was conducted pursuant to the U.S. EPA DRAFT SO<sub>2</sub> NAAQS Designations Modeling Technical Assistance Document (TAD), dated December 2013.

The following sections provide a detailed description of the compliance demonstration.

## 2.0 FACILITY DESCRIPTION

The following sub-sections contain descriptions of the Eckert and Erickson stations.





## 2.1 Eckert Station

BWL Eckert facility consists of six (6) pulverized coal and fuel oil-fired boilers with electric generator units. Three (3) of the units are capable of producing steam for sale in addition to electric generation. One of the six (6) units (EUBOILER2) was permanently retired on March 31, 2014 and, therefore, was not included in the modeling pursuant to the letter entitled “Update on the EPA’s next steps to implement the primary National Ambient Air Quality Standard for sulfur dioxide set in 2010,” dated March 20, 2015 from U.S. EPA’s Acting Assistant Administrator Janet McCabe. The five (5) remaining units were included in the model. Each of the remaining units utilize an electrostatic precipitator (ESP) to control emissions of particulate matter (PM), and utilize overfire air and low NO<sub>x</sub> burners for control of nitrogen oxides (NO<sub>x</sub>). BWL also has four (4) coal-fired stoker boilers adjacent to the Eckert units on the same property (i.e. the Moores Park Station); however these units have been decommissioned and were not included in the modeling.

The Eckert Station is located in Ingham County along the Grand River in central Lansing. See Appendix A, Figure 1 for a site layout showing the location of the Eckert boiler units, including a fenced property boundary.

Located adjacent to the existing Eckert and Moores Park Station is Lansing BWL’s new REO Town combined heat and power (CHP) plant. The CHP plant is designed as a combined-cycle, cogeneration facility consisting of two natural gas-fired turbines, two heat recovery steam generators with duct burners, steam turbines, a natural gas-fired auxiliary boiler and a four cell mechanical draft cooling tower. The CHP plant has replaced the four coal-fired stoker boilers and steam production capacity that was formally supplied by the Moores Park Station.

## 2.2 Erickson Station

BWL Erickson facility consists of one (1) pulverized coal-fired boiler with a turbine generator unit. The boiler is equipped with an ESP to control emissions of PM, and utilizes overfire air and low NO<sub>x</sub> burners for control of NO<sub>x</sub> emissions. The coal boiler was the only unit modeled from the Erickson Station; however, the facility also contains ash handling equipment and an ultra-low sulfur diesel fired auxiliary boiler (EUAUXBLR) rated at 20.9 million British thermal units per hour (MMBtu/hr) that is used to maintain building temperature if the large boiler is offline.



The auxiliary boiler is not fired unless the main unit is not operating for long stretches and if the outside temperature is too cold to create problems in the building. The auxiliary boiler has been permitted as a limited-use boiler under the Boiler MACT in Permit to Install (PTI) No. 71-15. It now has an enforceable capacity factor 10% by heat input. The unit has fuel sulfur content restrictions (1 percent maximum) in the facility Renewable Operating Permit (ROP) to reduce potential emissions of SO<sub>2</sub>. The unit uses ultra-low sulfur diesel fuel, and actual fuel sulfur content was below 0.02 percent each year for 2012-2014. Total fuel usage during this time was less than 25,000 gallons per year. This means that during the worst case year (2014) the unit emitted 31 pounds of sulfur based on the U.S. EPA AP-42 emission factor (0.015 tons per year). The unit is rated at 149 gallons per hour, and could emit at most, approximately 0.4 pounds per hour (lb/hr) of SO<sub>2</sub> based on the maximum 0.017 percent fuel sulfur content. Therefore, the auxiliary boiler was not included in the model since SO<sub>2</sub> emissions are very small in comparison to the coal boiler.

Additionally, the ash handling equipment was not modeled since it does not produce SO<sub>2</sub> emissions.

The facility is located in Eaton County on the southwest side of Lansing. See Appendix A, Figure 2 for a site layout including a fenced property boundary.

The following sections outline the model and methodologies used for the SO<sub>2</sub> modeling demonstration.

### **3.0 MODEL**

On November 9, 2005, the U.S. Environmental Protection Agency (U.S. EPA) promulgated the use of the AMS/EPA Regulatory Model Improvement Committee (AERMIC) Model (AERMOD) for all regulatory applications requiring an ambient impact demonstration.

AERMOD is a steady-state Gaussian model capable of handling multiple source inputs and producing concentration impacts from point, area, volume, and open-pit sources. AERMOD is also capable of handling numerous source configurations, building inputs, receptor grids and elevated terrain.

The most current version of the AERMOD source code (version 14134) was used for this compliance demonstration. Also included in the current version are the most recent versions of AERMET and AERMAP (refer to Sections 7 and 8 for more detail on these features). In addition, AERMOD includes the U.S. EPA BPIP-PRIME program, which is based on the design building configurations and stack heights. Therefore, all impacts due to plume downwash, including impacts occurring within cavity regions of any building, were directly addressed within the AERMOD modeling system.

Only regulatory default options within AERMOD for the dispersion modeling analysis were used.

### **3.1 Proprietary Model Information**

NTH has a license agreement with Lakes Environmental Software, Inc. for the AERMOD model. Lakes Environmental's ISC-AERMOD View was used for this compliance demonstration. This software is a graphical user interface (GUI) to the AERMOD model and provides the user with input screens for ease in setting up the model run stream, and viewing inputs and outputs through a graphical viewer. AERMOD View uses the U.S. EPA build of the AERMOD model. It produces results equivalent to running the model without a software interface. The textual input and output files, as well as the ISC-AERMOD View file (\*.isc) are provided electronically to the MDEQ.

## **4.0 EMISSIONS CHARACTERIZATION**

Pursuant to the TAD, the dispersion model utilized the three (3) most recent years of variable actual emissions data (2012-2014). Emissions have been obtained from the Eckert and Erickson boilers continuous emissions monitoring systems (CEMS). Emissions data was provided by BWL.

The variable emission rates were incorporated into the model utilizing the HOUREMIS keyword in the source pathway of the AERMOD input file. Specifically, CEMS data was uploaded via the Source Pathway and processed into an hourly emission file (i.e. filename.emi). For proper model execution, the file contains the exact hours matching the meteorology data file (meteorology is discussed further in Section 7). The variable emissions override any emission rate entered for SRCPARAM in the AERMOD input file. Table 1 summarizes variable emission rates that were used in the model.



**Table 1. Summary of 3-Year (2012-2014) Variable Emissions at the Eckert and Erickson Power Stations**

| Source                       | Maximum 3-Year Emissions (lb/hr) | Average 3-Year Emissions (lb/hr) | Total 3-Year Emissions (lb) |
|------------------------------|----------------------------------|----------------------------------|-----------------------------|
| <b>EUBOILER1<sup>1</sup></b> | 535                              | 34                               | 873,932                     |
| <b>EUBOILER3<sup>1</sup></b> | 497                              | 68                               | 1,773,919                   |
| <b>EUBOILER4<sup>1</sup></b> | 932                              | 163                              | 4,268,261                   |
| <b>EUBOILER5<sup>1</sup></b> | 976                              | 109                              | 2,872,925                   |
| <b>EUBOILER6<sup>1</sup></b> | 843                              | 235                              | 6,157,544                   |
| <b>EU001<sup>2</sup></b>     | 5,484                            | 788                              | 20,450,596                  |

<sup>1</sup> Boiler is located at the Eckert Power Station.

<sup>2</sup> Boiler is located at the Erickson Power Station.

Missing data was obtained using standard U.S. EPA data substitution procedures from 40 CFR Part 75. Hourly temperature and velocity data are not available.

Table 2 summarizes the continuous emission rates that were used in the model for units emitting SO<sub>2</sub> from the combined heat and power (CHP) REO Town plant located adjacent to the Eckert and Moores Park Station.

**Table 2. Summary of Continuous Emission Rates at the REO Town Plant**

| Source                        | Continuous Emissions (lb/hr) |
|-------------------------------|------------------------------|
| <b>EUAUXBOILER</b>            | 0.1                          |
| <b>EUNGINE</b>                | 0.0075                       |
| <b>EUTURBINE1<sup>1</sup></b> | 0.7                          |
| <b>EUTURBINE2<sup>1</sup></b> | 0.7                          |
| <b>EUHRSG1<sup>2</sup></b>    | 0.7                          |
| <b>EUHRSG2<sup>2</sup></b>    | 0.7                          |

<sup>1</sup> EUTURBINE1 and EUTURBINE2 are in the model as BYPASS1 and BYPASS2.

<sup>2</sup> EUHRSG1 and EUHRSG2 are in the model MAIN1 and MAIN2.



## 5.0 SITE DESCRIPTION

The following sub-sections contain stack parameters and description of the surrounding area.

### 5.1 Stack Parameters

Table 3 displays the stack parameters from the Eckert and Erickson boilers as well as the REO Town units that were included in the model.

Table 3. Stack Parameters

| Boiler ID                       | Height (ft) | Diameter (inches) | Exhaust Temperature (°F) | Exhaust Flowrate (acfm) |
|---------------------------------|-------------|-------------------|--------------------------|-------------------------|
| <b>EUBOILER1<sup>1</sup></b>    | 619         | 72                | 415                      | 243,377                 |
| <b>EUBOILER2<sup>1</sup></b>    | 619         | 72                | 415                      | 243,377                 |
| <b>EUBOILER3<sup>1</sup></b>    | 619         | 72                | 415                      | 243,377                 |
| <b>EUBOILER4<sup>1</sup></b>    | 619         | 96                | 350                      | 429,870                 |
| <b>EUBOILER5<sup>1</sup></b>    | 619         | 96                | 350                      | 429,870                 |
| <b>EUBOILER6<sup>1</sup></b>    | 619         | 96                | 350                      | 429,870                 |
| <b>EU001<sup>2</sup></b>        | 475         | 204               | 285                      | 348,567                 |
| <b>EUAUXBOILER<sup>3</sup></b>  | 120         | 72                | 300                      | 70,033                  |
| <b>EUNGINE<sup>3</sup></b>      | 120         | 15                | 875                      | 8,537                   |
| <b>EUTURBINE1<sup>3,4</sup></b> | 160         | 120               | 877                      | 510,573                 |
| <b>EUTURBINE2<sup>3,4</sup></b> | 160         | 120               | 877                      | 510,573                 |
| <b>EUHRSG1<sup>3,5</sup></b>    | 160         | 120               | 336                      | 313,387                 |
| <b>EUHRSG2<sup>3,5</sup></b>    | 160         | 120               | 336                      | 313,387                 |

<sup>1</sup> Boiler is located at the Eckert Power Station.

<sup>2</sup> Boiler is located at the Erickson Power Station.

<sup>3</sup> Unit is located at the REO Town Station.

<sup>4</sup> EUTURBINE1 and EUTURBINE2 are in the model as BYPASS1 and BYPASS2.

<sup>5</sup> EUHRSG1 and EUHRSG2 are in the model as MAIN1 and MAIN2.

Stack parameters used for modeling Erickson and Eckert are from historic modeling supporting previous permits. They are representative of operations at typical maximum operating loads during stack testing. Stack parameters for the REO Town plant were based on vendor specifications from the original design.

## 5.2 Rural/Urban Dispersion Options

Land use within a three-kilometer radius circle surrounding the facility was considered in making the determination on use of the RURAL or URBAN dispersion options. Based on an analysis of land use / land cover surrounding Eckert Station, approximately 53 percent of land use around the facility was of urban land use types including high intensity residential and commercial / industrial / transportation. This is greater than the 50 percent value considered to be the minimum for the use of urban dispersion coefficients; however, per historic modeling analysis for the Eckert Station and in consultation with MDEQ modeling staff, it was concluded that the use of rural dispersion coefficients was preferred for this location. The RURAL dispersion option was selected for Eckert Station, since the area is very borderline urban at most.

The area around the Erickson facility is neither heavily industrialized nor heavily populated. Therefore, based upon these observations, all modeling analyses utilized the RURAL dispersion option.

## 6.0 BACKGROUND CONCENTRATION

The most representative SO<sub>2</sub> background monitor in the area is located in Ingham County (monitor ID No. 260650012) located at 220 N. Pennsylvania Ave. The monitor is roughly 1.5 miles northeast of the Eckert Power Station, and about 6.8 miles northeast of the Erickson Power Station.

The SO<sub>2</sub> background concentration as determined by the monitor is 17.9 parts per billion (ppb), or 46.9 micrograms per cubic meter (µg/m<sup>3</sup>). This information has been provided by the MDEQ.

## 7.0 METEOROLOGY

Meteorological data for use in AERMOD must be processed through the AERMET pre-processing program available from U.S. EPA. As part of processing the meteorological data files, the user must specify certain site-specific surface features and characteristics and can, therefore, tailor any meteorological data file to the site-specific conditions at the facility site. The MDEQ recently completed the process of determining representative surface characteristics for use in preparing pre-processed “AERMOD-ready” meteorological

data. The MDEQ has provided the meteorological data for use in the SO<sub>2</sub> model. The meteorological data supplied by MDEQ was processed using the Region 5 meteorological processing protocol.

The surface data used for the modeling analyses was taken from the Capitol City Airport (LAN), Surface Station No. 14836, with a mean surface station elevation of 264 meters above mean sea level (MSL). The upper air station data are from the National Weather Service (NWS) White Lake Station No. 72632. The LAN meteorological data is the most representative data in the area, and is taken at 1-minute intervals averaged over the course of an hour.

Pursuant to the TAD, the most recent three (3) years of meteorological data were incorporated into the model (2012 – 2014). This corresponds to the most recent three (3) years of SO<sub>2</sub> data from both the Eckert and Erickson facilities via the boilers CEMS (as discussed in Section 4).

## 8.0 MODELING DOMAIN

The modeling analysis completed for this project incorporates a receptor grid sufficient to identify the point of maximum impact during dispersion modeling. An extensive receptor grid was utilized to determine areas of higher concentration, and then more refined grid(s) were used in those areas to ensure capture of “hotspot” impacts. In general, the grid is most dense within close proximity to the facility site and gradually becomes less dense traveling out from the source. Pursuant to the TAD, receptors were only placed in locations where it is feasible to place monitors.

The secured property boundary was used to define the receptor grid in the modeling. MDEQ Modeling guidance discusses the difference between ambient air and secured property as follows:

*Ambient air is defined in 40 CFR Part 50.1(e) as “... that portion of the atmosphere, external to buildings, to which the general public has access ...,” which would include areas such as unsecured plant property, railroad tracks, waterways, and roadways. This definition was further clarified in a letter dated December 19, 1980, from Douglas Costle to Senator Jennings Randolph that stated the exemption from ambient air is available only for the atmosphere over land owned or controlled by the source and to which public*



*access is precluded by a fence or other physical barriers. Receptors generally do not need to be placed within secured property. A “secured property line” means a boundary that prevents general public access to property owned by a facility. In certain circumstances, one or more combinations of other barriers and measures such as ones listed below may adequately deem an area as being “secured”; however, this would be subject to the approval of the Department on a case-by-case basis.*

*A body of water, such as a ditch, of sufficient size to preclude public access to the property. The body of water must not be available for recreational activities, such as boating, fishing or swimming.*

*Regular patrols by staff that are responsible for not allowing unauthorized personnel onto the property. The patrol must be conducted at least several times a day.*

*Continuous monitoring by surveillance cameras where staff is assigned to view video monitors and report any unauthorized access.*

*All boundaries using the above methods must be clearly posted to communicate private property/no public access.*

The following receptor grid was used for this modeling analysis:

|                               |  |
|-------------------------------|--|
| <b>Fence-Line:</b>            | Receptors were placed along the secured property line at 25-meter spacing.   |
| <b>Near-Field:</b>            | Receptors were placed at 100-meter spacing in the near-field, from facility’s source “center” out to a distance of 2 km.       |
| <b>Mid-Field:</b>             | Receptors were placed at 250-meter spacing in a far-field from a distance of 2 km to 10 km.                                    |
| <b>Far-Field:</b>             | A polar receptor grid was placed at 5,000-meter spacing in a far-field from a distance of 15 km to 35 km.                      |
| <b>Refined Receptor Grid:</b> | Receptors were placed in a grid with 50-meter spacing near the location of maximum impact, as determined with the fixed grids. |





The center of each facility is located at approximately:

- Erickson    **UTM Easting (m):** 691,940    **UTM Northing (m):** 4,729,089
- Eckert    **UTM Easting (m):** 699,967    **UTM Northing (m):** 4,732,268

Within this grid, receptors were placed at 50-meter spacing in areas of “hotspots” as mentioned above. This ensures that the maximum impact is captured without creating an overly concentrated receptor grid resulting in long model runtimes. Additionally, a polar receptor grid using 36 radials at 10 degrees each was also added, from 15 km from the midpoint of the modeling domain out to 35 km to verify that hotspots were not occurring at distances beyond the square receptor grid. Addition of the polar grid did not change the maximum modeled impacts, nor are any hotspots expected beyond the first few kilometers of any facility.

The modeling domain also incorporates terrain features. AERMOD requires the use of an elevated terrain data file for establishing elevations for all sources, buildings and receptors. The AERMAP pre-processor is used to process digital elevation maps with location points for all sources, structures, and receptors. North American Datum 1927 (NAD27) based Digital Elevation Models (DEM) 7.5-minute digitized topographic files, available via the United States Geological Survey (USGS) website, for the area surrounding the Eckert and Erickson facilities was used to obtain elevations and hill heights as required by the AERMOD model. This terrain information was incorporated into the AERMOD model via the AERMAP pre-processor.

## 9.0 OFF-SITE EMISSIONS INVENTORY

For this modeling analysis, off-site sources are included. Recent U.S. EPA guidance requires an emission inventory for emissions of all existing sources which have a “significant concentration gradient” overlapping the source being modeled. U.S. EPA guidance also suggests that *“the number of such [nearby] sources is expected to be small except in unusual situations”* and that most off-site sources should not be explicitly modeled but should be considered part of the background concentration. The MDEQ has conducted an emissions analysis for the area and provided an off-site source listing according to the most recent U.S. EPA guidance. These sources were incorporated into the model.

The offsite inventory resulting from MDEQ’s emissions analysis for the area is provided in Appendix B.

## 10.0 AMBIENT IMPACT ANALYSIS (SO<sub>2</sub>)

The U.S. EPA has deemed BWL Erickson and Eckert as large sources of SO<sub>2</sub> emissions and, therefore, subject to a compliance demonstration via monitoring or dispersion modeling to characterize the SO<sub>2</sub> air quality.

The following subsections summarize the ambient impact analysis of SO<sub>2</sub> emissions from the BWL Erickson and Eckert facilities for comparison to the 1-hour SO<sub>2</sub> NAAQS.

### 10.1 Dispersion Model Description

The modeling follows the protocol submitted to MDEQ on May 28, 2015 and accepted by MDEQ and U.S. EPA. The dispersion modeling protocol ensures that the analyses have been conducted in a manner consistent with MDEQ's Air Dispersion Modeling Guidance Document (September 2009 revision), AQD's September 2013 PSD Workbook, TAD, and U.S. EPA guidance and standard practices. Guidance for the use and application of dispersion models is presented in the U.S. EPA document, *Guidance on Air Quality Models*, as published in Appendix W of 40 CFR Part 51 (updated as of November 9, 2005 to include the promulgation of AERMOD).

### 10.2 Results

Table 4 below summarizes the modeling results from the combined impacts from the BWL Erickson and Eckert facilities against the SIP attainment threshold (1-hour SO<sub>2</sub> NAAQS) of 196 µg/m<sup>3</sup>.

**Table 4. Erickson and Eckert Modeling Results**

| Pollutant       | Averaging Time Period | 1-Hour NAAQS (µg/m <sup>3</sup> ) | Maximum Modeled Impact <sup>1</sup> (µg/m <sup>3</sup> ) | Background Concentration (µg/m <sup>3</sup> ) | Impact + Background (µg/m <sup>3</sup> ) | % of NAAQS (µg/m <sup>3</sup> ) |
|-----------------|-----------------------|-----------------------------------|--|---|--|---------------------------------|
| SO <sub>2</sub> | 1-hour                | 196                               | 92.7   | 46.9  | 139.6                                    | 71%                             |

<sup>1</sup> Modeled results are based on the average highest 4th high (H4H) impact from actual variable emissions over a 3-Year (2012-2014) period



Table 4 shows that the maximum modeled impacts from the Erickson and Eckert facilities combined with the background concentrations are below the 1-hour NAAQS. Therefore, based on this demonstration, the BWL Erickson and Eckert facilities do not cause any SO<sub>2</sub> “hot spots” within the area in question. Additionally, the modeling does not indicate any location that a monitor could be placed that would register impacts above the NAAQS.

### **10.3 Dispersion Modeling Files**

The complete Lakes Environmental ISC-AERMOD View modeling project files are provided in Appendix C on compact disc for modeling analysis conducted with AERMOD.



# **APPENDIX A**

## **ECKERT AND ERICKSON SITE LAYOUTS**

PROJECT TITLE:

**Lansing Board of Water & Light  
Figure 1. Eckert Power Station**



COMMENTS:

SOURCES:

**17**

COMPANY NAME:

**NTH Consultants, Ltd.**

RECEPTORS:

**13615**

MODELER:

**COO**

SCALE:

1:8,176

0

0.3 km

DATE:


**5/18/2015**

PROJECT NO.:



PROJECT TITLE:

**Lansing Board of Water & Light  
Figure 2. Erickson Power Station**



COMMENTS:

SOURCES:

**17**

COMPANY NAME:

**NTH Consultants, Ltd.**

RECEPTORS:

**13615**

MODELER:

**COO**

SCALE:

1:21,675

0  0.5 km



DATE:

**5/18/2015**

PROJECT NO.:



---

## **APPENDIX B**

### **OFFSITE SOURCE INVENTORY**



Appendix B - MDEQ Offsite Source Inventory

| SRN   | COMPANY                   | POL | Facility Emissions |       | TYPE    | UTM EAST | UTM NORTH | Stack Information |            |              |             |                |                |
|-------|---------------------------|-----|--------------------|-------|---------|----------|-----------|-------------------|------------|--------------|-------------|----------------|----------------|
|       |                           |     | (pph)              | (tpy) |         |          |           | Hgt. (ft)         | Dia (feet) | Temp (deg F) | Flow (ACFM) | Velocity (m/s) | Discharge Type |
| N1502 | THOMPSON-MCCULLY COMPANY  | SO2 | 55.0               | 240.9 | Allowed | 690,715  | 4,725,692 | 42.0              | 2.25       | 240.0        | 63000.0     | 80.5           | Upward         |
| P0198 | SUPERIOR ASPHALT, INC     | SO2 | 18.4               | 80.6  | Allowed | 691419   | 4729485   | 60.0              | 3.92       | 221.0        | 61391.0     | 25.9           | Upward         |
| K3249 | Michigan State University | SO2 | 357.1              | 473.3 | Actuals | 706040   | 4732960   | 275               | 11.77      | 325          | 284865.81   | 13.391147      | Vertical       |





---

## **APPENDIX C**

### **MODELING FILES**

This page left intentionally blank.



12445 55th Street North | Suite A2 | Lake Elmo, MN 55042 | P (651) 275-9900 | F (651) 351-3987

trinityconsultants.com



VIA E-MAIL: [haywoodj@michigan.gov](mailto:haywoodj@michigan.gov)

June 26, 2015

Mr. Jim Haywood  
Senior Meteorologist  
Air Quality Division  
Michigan Department of Environmental Quality  
525 West Allegan Street  
P.O. Box 30473  
Lansing, MI 48909

RE: *SO<sub>2</sub> State Implementation Plan (SIP) Modeling Results for the We Energies Presque Isle Power Plant*

Dear Mr. Haywood:

In response to a request by the Michigan Department of Environmental Quality (MDEQ), Trinity Consultants, Inc. (Trinity), on behalf of Wisconsin Electric Power Company, doing business as We Energies, respectfully submits the sulfur dioxide (SO<sub>2</sub>) SIP dispersion modeling results for the Presque Isle Power Plant (PIPP). This submittal follows the air dispersion modeling protocol submitted to MDEQ on May 22, 2015.

## FACILITY DESCRIPTION

We Energies owns and operates PIPP in Marquette, Michigan, which is located along Lake Superior in Michigan's Upper Peninsula. Figures 1 and 2 below show aerial views of the facility; Figure 2 includes a depiction of the fenceline.<sup>1</sup>

The plant was originally constructed in 1955. Boilers 1-4 were installed by Cleveland Cliffs to provide power to the nearby mines. The plant was later sold to Upper Peninsula Power Company (UPPCo), and Boilers 5-9 were installed. We Energies acquired PIPP in the late 1980's after the construction of Boilers 5-9 was complete. In recent years, Boilers 1-4 were retired and removed, although the original structure which housed the boilers remains at the plant. The remaining units, Boilers 5-9, are pulverized coal wall fired dry bottom utility units each with a 90 Megawatt generating capacity. Boilers 5-6 have historically burned both Colorado bituminous and subbituminous Powder River Basin (PRB) coal over the years, but are currently burning subbituminous PRB coal, which is consistent with the fuel combusted in Boilers 7-9.

Other SO<sub>2</sub> emission sources at the plant include two emergency diesel generators, one emergency diesel fire pump, and small natural gas fired comfort heaters. The modeling focused on the coal-fired boilers, which are the

---

<sup>1</sup> The fenceline shown in Figure 2 represents the fenceline modeled in the 2013 PSD permit application submitted to MDEQ. MDEQ subsequently issued a PSD permit based on this application.

principal sources of SO<sub>2</sub>, and are the reason the facility has been requested to conduct SO<sub>2</sub> 1-hour SIP modeling. The small size and infrequent use of this equipment yields a small contribution to the annual distribution of the maximum daily 1-hour SO<sub>2</sub> concentrations. Pursuant to the March 2011 Intermittent Source Policy, these small emissions units have been excluded from the 1-hour SO<sub>2</sub> SIP modeling analysis.<sup>2</sup>

**Figure 1. Presque Isle Power Plant**



**Figure 2. Presque Isle Power Plant Fenceline**



---

<sup>2</sup> Exclusion of the intermittent sources in the 1-hour SO<sub>2</sub> SIP modeling analysis is consistent with MDEQ's internal policy and is appropriate for this analysis due to the infrequent use of this equipment and the small overall contribution to SO<sub>2</sub> as discussed between Jim Haywood, MDEQ, and Angie Wanger, Trinity, on 6/23/2015.

## MODELING ANALYSIS

We Energies prepared a modeling analysis addressing SO<sub>2</sub> SIP dispersion modeling as requested by MDEQ and the United States Environmental Protection Agency (EPA). A discussion of the modeling analysis requirements and modeling methodology is included in the sections below.

### Modeling Requirements

A modeling protocol approach specific to the 1-hour SO<sub>2</sub> SIP modeling analysis for PIPP was submitted to MDEQ in accordance with the MDEQ Modeling Protocol Template.<sup>3</sup> As actual hourly emissions data were used in the modeling analysis, the stack temperature and exit velocity were also varied on an hourly basis, which is a change from the previously submitted modeling protocol. Further, the effective stack diameter was also revised when compared to the previously submitted modeling protocol. These changes are described in a later section of this letter. The modeled impacts of the facility were compared to the 1-hour SO<sub>2</sub> National Ambient Air Quality Standards (NAAQS) of 196 µg/m<sup>3</sup>.

### Selection of Model

We Energies has conducted the dispersion modeling analysis using the latest version of AERMOD (version 14134) along with Trinity's *BREEZE™ AERMOD Suite* software to estimate maximum ground-level concentrations. All regulatory default options were used in the modeling. The pollutant ID was set to SO<sub>2</sub>, and the output options were configured such that the model predicted an SO<sub>2</sub> design value based on the 3-year average of the 99<sup>th</sup> percentile of the annual distribution of the daily maximum 1-hour concentrations.

### Coordinate System

In all modeling input and output files, the locations of emission sources, structures, and receptors were represented in the Universal Transverse Mercator (UTM) coordinate system using North American Datum 1983 (NAD83).<sup>4</sup> The UTM grid divides the world into coordinates that are measured in north meters (measured from the equator) and east meters (measured from the central meridian of a particular zone, which is set at 500 km). PIPP is approximately centered at UTM, Zone 16, coordinates 469,725 meters East and 5,158,475 meters North. The base elevation of the facility is approximately 185 meters above mean sea level.

### Building Downwash and GEP Stack Height Analysis

The Building Profile Input Program (BPIP) with Plume Rise Model Enhancements (PRIME) (version 04274) was used to determine the building downwash characteristics for each stack in 10 degree directional intervals. The

---

<sup>3</sup> Modeling protocol template sent from Jim Haywood, MDEQ, to Bob Greco, We Energies, on 5/13/2015. A modeling protocol specific to PIPP was developed using this template and sent to MDEQ for approval on 5/22/2015. Comments on this protocol were sent from Randall Robinson, EPA, to Jim Haywood on 6/5/2015, and responses were sent from Jim Haywood on 6/8/2015 and Clay Raasch, Trinity, on 6/11/2015.

<sup>4</sup> Google Earth was referenced for the model digitization. According to the Google Earth User Guide, the axes of the World Geodetic System 1984 (WGS84) and NAD83 coordinate systems differ by a very small amount. Therefore, the NAD83 and WGS84 datums are roughly equivalent.

PRIME version of BPIP features enhanced plume dispersion coefficients due to turbulent wake and reduced plume rise caused by a combination of the descending streamlines in the lee of the building and the increased entrainment in the wake. For PRIME downwash analyses, the building downwash data include the following parameters for the dominant building:

- Building height
- Building width
- Building length
- X-dimension building adjustment
- Y-dimension building adjustment

We Energies utilized BPIP PRIME to calculate building downwash parameters for the SO<sub>2</sub> SIP modeling analysis.

### **Land-Use/Land Cover Data**

We Energies used pre-processed meteorological data provided by the MDEQ. Therefore, the land use/land cover (LULC) analysis required as part of the AERMET meteorological data processing was completed by the MDEQ.

### **Meteorological Data**

The meteorological data utilizes minute-reported information which were pre-processed and provided by MDEQ for download using the AERMOD meteorological preprocessor AERMET (version 14134) for the years 2012 through 2014 (consistent with the three years of actual emissions data that was relied upon for PIPP). Meteorological data for the Munising Lakeshore surface station (Surface Station No. 54813) and Gaylord, Michigan upper air station (Station No. 4837) were used due to its proximity to the facility, the availability of 1-minute meteorological data, and its placement on Lake Superior, which is similar to PIPP.<sup>5</sup>

### **Receptor Grids**

We Energies used a combination of a Cartesian grid system centered on PIPP and discrete receptor points along the PIPP fenceline. Receptors were placed at 25 meter intervals along the fenceline, 100 meter intervals out to a distance of 2.5 kilometers (km) and at 500 meter intervals out to 15 km. Based on the EPA's draft 2013 Technical Assistance Document and the 2015 SO<sub>2</sub> Area Designation Guidance, the receptor grid only included receptors at those locations where it is feasible to place a monitor (i.e., not over water). Therefore, no receptors were placed over Lake Superior.

---

<sup>5</sup> MDEQ recommended the use of Munising data which was used by We Energies in the 2013 PSD application submitted to MDEQ.

## Terrain Elevations

The terrain elevation for each receptor, building, and emission source<sup>6</sup> was determined using USGS 1/3 arc-second National Elevation Dataset (NED) data. The data, obtained from the USGS, has terrain elevations at 10-meter intervals. The terrain height for each individual modeled receptor was determined by assigning the interpolated height from the digital terrain elevations surrounding each modeled receptor.

In addition, the AERMOD terrain processor, AERMAP (version 11103), was used to compute the hill height scales for each receptor. AERMAP searches all NED points for the terrain height and location that has the greatest influence on each receptor to determine the hill height scale for that receptor. AERMOD then uses the hill height scale in order to select the correct critical dividing streamline and concentration algorithm for each receptor.

## Modeled Source Parameters

As noted in past correspondence with the MDEQ, the five boilers at PIPP were modeled as two separate stacks due to the flues sharing two chimney stacks: one stack represented Boilers 5 and 6 (modeled source ID B56), while a second stack represented Boilers 7, 8, and 9 (modeled source ID B789). The merged flue exhaust parameters were recalculated for the 1-hour SO<sub>2</sub> SIP modeling analysis and were updated as compared to the exhaust parameters which were previously submitted in the modeling protocol. Modeled stack parameters and emission rate reference information can be found in Table 1.

**Table 1: PIPP Emission Source Modeling Parameters**

| Source ID | UTM NAD83 X Coord. (m) | UTM NAD83 Y Coord. (m) | Elevation (ft) | Stack Height (ft) | Effective Stack Temp.* (F) | Effective Exit Velocity* (m/s) | Effective Stack Diameter† (m) | SO <sub>2</sub> Emission Rate Basis |
|-----------|------------------------|------------------------|----------------|-------------------|----------------------------|--------------------------------|-------------------------------|-------------------------------------|
| B56       | 469,722                | 5,158,443              | 606.5          | 400               | --                         | --                             | 3.59                          | CEMS                                |
| B789      | 469,725                | 5,158,504              | 606.5          | 410               | --                         | --                             | 4.53                          | CEMS                                |

\*Effective stack temperature and exit velocity parameters are calculated utilizing CEMS data, using a weighted average of each flue's stack temperature and exit velocity based on its contribution to the overall airflow rate.

†Effective diameter is calculated utilizing CEMS data, using the sum of each flue's airflow rate and the calculated effective velocity.

We Energies used actual emissions data from the SO<sub>2</sub> continuous emission monitoring system (CEMS) for each of the five boilers. Pursuant to EPA's draft 2013 Technical Assistance Document, SO<sub>2</sub> designations are intended to address current actual air quality (i.e., modeling simulates a monitor) and EPA recommends modeling the most recent three years of actual emissions. Therefore, CEMS data for 2012 through 2014 were used to generate the hourly varying emissions input file. The SO<sub>2</sub> CEMS data were obtained from the Clean Air Market Database (CAMD).<sup>7</sup> In order to match the hourly varying emission rates on the same time scale, the hourly

<sup>6</sup> Base elevation of 606.5 ft was utilized for the boiler stacks as specified in the modeling protocol submitted to MDEQ on May 22, 2015. All other facility elevations were determined through use of AERMAP.

<sup>7</sup> CAMD data for PIPP from 2012-2014, including SO<sub>2</sub> hourly emission rates and hourly heat inputs, was queried on 6/17/2015.

varying stack temperature and airflow data for each of the five boilers as measured by the CEMS were also included in the development of the hourly varying emissions input file.

## Nearby Source Inventory

As provided by MDEQ, SO<sub>2</sub> emissions from Marquette Board of Light & Power (MBLP) and Northern Michigan University (NMU) were included in the modeling analysis.<sup>8</sup> The modeling parameters and emission rates for these sources can be found in Table 2.

**Table 2: Neighboring Source Modeling Parameters**

| Source ID | UTM NAD83 X Coord. (m) | UTM NAD83 Y Coord. (m) | Elevation (ft) | Stack Height (ft) | Stack Temp. (F) | Exit Velocity (m/s) | Stack Diameter (m) | SO <sub>2</sub> Emission Rate* (lb/hr) |
|-----------|------------------------|------------------------|----------------|-------------------|-----------------|---------------------|--------------------|--|
| MBLP      | 469,900                | 5,153,000              | 616.24         | 301.8             | 239.4           | 18.3                | 2.52               | 264.9                                  |
| NMU       | 468,889                | 5,156,615              | 640.22         | 150.0             | 260.0           | 4.8                 | 2.50               | 22.8                                   |

\*MBLP SO<sub>2</sub> emission rates reflect actual emissions. NMU SO<sub>2</sub> emission rates reflect allowable emissions.

## MODELING RESULTS

This section summarizes the results of the 1-hour SO<sub>2</sub> SIP modeling analyses. An electronic zip archive containing all modeling input and output files, building downwash files, and meteorological data is included.

### Tabular Modeling Results

The 1-hour SO<sub>2</sub> modeling results are shown in Table 3 below. These results consider the combined impact of PIPP and the two neighboring sources, adding the modeled results to the background concentration to yield the total modeled impacts. The total modeled impacts were then compared to the NAAQS.

**Table 3: Summary of 1-hour SO<sub>2</sub> NAAQS Results**

| Pollutant       | Averaging Period | Modeled Impacts (µg/m <sup>3</sup> ) | Background Concentration* (µg/m <sup>3</sup> ) | Total Impacts (µg/m <sup>3</sup> ) | NAAQS (µg/m <sup>3</sup> ) | % of NAAQS |
|-----------------|------------------|--------------------------------------|--|------------------------------------|----------------------------|------------|
| SO <sub>2</sub> | 1-hour           | 111.19                               | 17.9   | 129.09                             | 196                        | 66%        |

\*The 1-hour SO<sub>2</sub> background concentration was sent by Jim Haywood, MDEQ, to Bob Greco, We Energies, on 5/13/2015. Background concentrations for Forest County, Wisconsin were used in this analysis as it is the most representative monitor for the site as described in the modeling protocol submitted 5/22/2015.

<sup>8</sup> Neighboring source guidance sent from Stephanie Hengesbach, MDEQ, to Kathleen Standen, We Energies, on 5/15/2015. Additional clarification on elevation parameters for these sources sent from Stephanie Hengesbach to Angie Wanger, Trinity, on 6/15/2015.




As shown in Table 3, the combined impact from PIPP, the neighboring sources, and the background concentration are less than the NAAQS. Graphical illustrations depicting the areas of impact are shown in the next section.

### Graphical Results

The locations of the maximum impacts of the 1-hour SO<sub>2</sub> SIP modeling analysis were plotted using BREEZE® 3D Analyst. As illustrated in Figure 3, the highest modeled concentrations are located southwest of PIPP. Results in the figures are shown in units of  $\mu\text{g}/\text{m}^3$ .

Figure 3. SO<sub>2</sub> H4H 1-hour Concentration for All Sources (2012-2014)



## CONCLUSION

When utilizing the source parameters and emission rates discussed in the modeling methodology section of this letter, the results shown above demonstrate that the predicted ambient impacts of PIPP and its two neighboring sources are less than the 1-hour SO<sub>2</sub> NAAQS.

If you have any questions or comments about the information presented in this letter, please do not hesitate to call Bob Greco with We Energies at (414) 221-5441 or me at (651) 275-9900.

Sincerely,

TRINITY CONSULTANTS

A handwritten signature in purple ink that reads "Angela Wanger". The signature is written in a cursive, flowing style.

Angie Wanger  
Managing Consultant

Enclosure

cc: Robert A. Greco, P.E. (We Energies)  
Stephanie Hengesbach (MDEQ)  
Bob Irvine (MDEQ)  
Clay Raasch (Trinity)

Enclosure 1

**Modeling Files**

This page left intentionally blank.

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
Monroe, Michigan  
Dispersion Modeling Protocol  
July 6, 2015

Introduction

The United States Environmental Protection Agency (EPA) promulgated a revised primary sulfur dioxide (SO<sub>2</sub>) national ambient air quality standard (NAAQS) in June 2010. The averaging time for this new NAAQS is 1 hour, which is much shorter than the previous primary NAAQS averaging period, 24 hours. The new NAAQS is the 99<sup>th</sup> percentile maximum daily 1-hour average, averaged over the most recent three years of monitoring data. The level of the new SO<sub>2</sub> NAAQS (75 ppb) is much lower than the previous 24-hour SO<sub>2</sub> NAAQS (140 ppb). EPA is requiring states to determine whether areas within their borders meet or exceed this new NAAQS to provide designation recommendations to EPA.

Initially, EPA recommended that states use dispersion modeling for identifying locations where this NAAQS is not met. However, there was an outcry to this proposal from many state air quality agencies and other affected parties. EPA decided to proceed designating new nonattainment areas where at least one SO<sub>2</sub> monitoring site violates this NAAQS with the last 3 years of monitoring data. Michigan has been working with source operators that contribute to the monitored violation in Wayne County, and will soon submit their state implementation plan (SIP) for EPA to review. However, EPA decided to delay designations for other portions of the country.

In response to a lawsuit that was brought against EPA by the Sierra Club, and others, to force EPA to designate other areas on an expedited schedule, the parties settled and additional NAAQS designations are being undertaken. The judge issued the settlement order finalizing the agreed upon details on March 2, 2015. The next phase where SO<sub>2</sub> NAAQS designations must be finalized by July 2016 includes areas around 68 large SO<sub>2</sub> sources listed in the settlement agreement between the parties. **This dispersion modeling protocol describes the methodology that will be used to determine whether this revised NAAQS is met in Monroe County, Michigan, where DTE Energy's Monroe Power Plant (Monroe PP) is located. Also, Monroe PP has been included in AERMOD runs for the Wayne County SIP, but this upcoming analysis is confined to Monroe County. This plant is listed in the table of sources meeting the criteria of large SO<sub>2</sub> sources in the settlement document.**

## Facility Description

Monroe PP is DTE Energy's largest electric generating facility in its generating fleet with 3,280 (Gross) MW of combined generating capacity. It has four main units (Units 1-4) that burn bituminous coal, sub-bituminous coal and petroleum coke as their primary fuels. All four units have low-NO<sub>x</sub> burners, over-fired air (OFA) and selective catalytic reduction (SCR) systems operating for NO<sub>x</sub> control. Each unit employs dry-wire electrostatic precipitators (ESP) and sulfur trioxide and ammonia injection for particulate matter control. Also, Units 1 and 2 finished installing wet flue gas desulfurization (FGD) systems for controlling SO<sub>2</sub> emissions in 2014. Wet FGD systems have been operating continuously on Units 3 and 4 before the base year, 2012. Monroe PP likely made it on the list for expedited 1-hour SO<sub>2</sub> NAAQS designations because two of its four main units were operating in 2012, and 2013, without FGD systems. Therefore, the plant met the criteria established in the settlement agreement, previously cited in this protocol.

Monroe PP is located along the western shore of Lake Erie, just south of the mouth of the River Raisin. It is about four miles southeast of downtown Monroe, between Interstate-75 and Lake Erie, about 12 miles north of the Michigan-Ohio border. One of Michigan's state parks, Sterling State Park, is located just north of this facility. There are a few industrial businesses west of the plant, and the City of Monroe's Water Treatment Plant. There is quite an expanse of wetlands northwest from Monroe PP as well. Figure 1 is an aerial photograph of the plant from 2006, prior to installation of FGD systems at the facility.

A rigorous impact assessment was performed for Monroe Power Plant as part of the Permit to Install (PTI No. 93-09A) application package to establish Best Available Control Technology (BACT) SO<sub>2</sub> limits for each of its four main units (0.107 lbs/MMBtu & 815.8 lbs/hour). The 1-hour SO<sub>2</sub> modeling runs predicted Monroe PP impacts below the NAAQS with these limits. With nearby sources included there were predicted excursions, with nearly all of the impact from the J. R. Whiting Plant, owned by Consumers Energy. However, Monroe Power Plant did not significantly contribute to the receptors during the hours the high SO<sub>2</sub> concentrations were predicted. Since the J. R. Whiting plant will be retired by April 2016, at the latest, it will not be modeled in the upcoming impact assessment. EPA staff has agreed that this exclusion is appropriate.

**Table 1-A**

| <b>Actual Monroe PP SO<sub>2</sub> Emissions (2012-2014)</b> |               |               |               |
|--|---------------|---------------|---------------|
|  | <b>2012</b>   | <b>2013</b>   | <b>2014</b>   |
|  | <b>(tons)</b> | <b>(tons)</b> | <b>(tons)</b> |
| <b>Monroe PP</b>   |               |               |               |
| Unit 1   | 25,267        | 18,189        | 383           |
| Unit 2   | 22,859        | 24,377        | 4,654         |
| Unit 3   | 619           | 509           | 621           |
| Unit 4   | 405           | 691           | 629           |
| Auxiliary Boilers  | 0.002         | 0.026         | 0.065         |
| Diesel Gen No. 11-1  | 0.001         | 0.000         | 0.001         |
| Diesel Gen No. 11-2  | 0.000         | 0.000         | 0.001         |
| Diesel Gen No. 11-3  | 0.001         | 0.000         | 0.001         |
| Diesel Gen No. 11-4  | 0.001         | 0.000         | 0.001         |
| Diesel Gen No. 11-5  | 0.001         | 0.001         | 0.001         |
| Diesel Quench Pumps  | 0.004         | 0.005         | 0.009         |
| <b>Monroe Main Units</b>                                     | <b>49,150</b> | <b>43,766</b> | <b>6,287</b>  |
| <b>Monroe Other Sources</b>                                  | <b>0.010</b>  | <b>0.032</b>  | <b>0.079</b>  |
| <b>Site Total</b>  | <b>49,150</b> | <b>43,766</b> | <b>6,287</b>  |

Table 1-A lists actual SO<sub>2</sub> emissions from point sources at Monroe PP from the last three operating years (2012-2014). It clearly shows that nearly all of the SO<sub>2</sub> is emitted by the four coal-fired units at this plant for the most recent three year period (2012-2014). Previously submitted modeling analyses showed that these other small SO<sub>2</sub> sources only contributed 0.03 ug/m<sup>3</sup> to the highest predicted 99<sup>th</sup> percentile 5-year average impact, which was 86.54 ug/m<sup>3</sup>. This extremely small impact is inconsequential when compared to the main units' combined peak short-term impact. The following table identifies which Monroe PP SO<sub>2</sub> sources will be included in the impact modeling, and those that will be excluded and the reason(s) for this decision.

**Table 1-B**  
**Basis for Including or Excluding SO<sub>2</sub> Source from Impact Assessment**


| <b>SO<sub>2</sub> Source(s)</b>       | <b>Include / Exclude</b> | <b>Reason(s)</b>                               |
|---------------------------------------|--------------------------|--|
| <b>Unit Nos. 1-4</b>                  | <b>Include</b>           | <b>Main units, Large SO<sub>2</sub> source</b> |
| <b>Auxiliary Boilers</b>              | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm Sulfur Oil</b> |
| <b>Diesel Generator Nos. 11-(1-5)</b> | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm Sulfur Oil</b> |
| <b>Diesel Quench Pumps</b>            | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm Sulfur Oil</b> |

The secured property line for this modeling study is assumed to be the actual property line of the Monroe PP complex. Its boundaries are primarily water bodies with: Lake Erie to the east, River Raisin to the north and its discharge canal to the west and south. This power plant, also, has its own wet fly ash storage basin to the southwest of the main plant buildings that is surrounded by a security fence. This basin runs all the way west to the edge of the northbound I-75 freeway right-of-way. There is security staff at the site at all times maintaining an adequate security presence for the plant.

DTE Energy staff will make the 1-hour SO<sub>2</sub> AERMOD runs using the allowable SO<sub>2</sub> emission rates for Unit Nos. 1-4 with the appropriate other nearby SO<sub>2</sub> sources identified by the Air Quality Division Modeling staff. This option was chosen because we believe design 1-hour SO<sub>2</sub> predicted impacts, including background concentrations will be well below the NAAQS. Also, if the actual emission option was chosen, Units 1 and 2 would have at least two years of operation without the FGD system, and part of 2014 with this control device operational. The SO<sub>2</sub> emission rates are very different with this scenario, as well as most of the stack parameters, which would make the AERMOD runs even more complicated. Our best estimate of the date for the modeling to be completed is by July 10, which is about two weeks after the draft schedule submittal date (June 26).

### Model Selection

The version of AERMOD and its support files is shown in the following picture: DTE Energy staff use the BEEST software package, and receive updated versions as EPA makes changes to the AERMOD programs.



The structures that were included in the previous dispersion modeling analysis will be included in these AERMOD runs for the 1-hour SO<sub>2</sub> NAAQS. They include all of the tall buildings near the four main units at Monroe PP, including the relatively new structures associated with the SCR and FGD control systems to reduce NO<sub>x</sub> and SO<sub>2</sub> emissions from this facility. Detailed building profile data is shown in Table 2. The latest version of BPIP (Version dated 04274) will be used to develop building height and width values for each 10 degree wind direction category used in AERMOD.



## Emissions Characterization

DTE Energy will model SO<sub>2</sub> impacts from Monroe PP using allowable emission rates for each of its four main units (0.107 lbs/MMBtu & 815.8 lbs/hour). Stack parameters for these units will remain constant representing full load operation, which corresponds with highest SO<sub>2</sub> emission rates for each unit, and the highest combined impact from all four units. Other small SO<sub>2</sub> point sources are not modeled from this plant, as detailed in the Facility Description. Table 1-A lists the most recent 3 years of actual SO<sub>2</sub> emissions.

## Source Description

The detailed plant description is provided in the Facility Description Section of this modeling protocol, including the justification for including only the main units from Monroe PP in this impact analysis. Table 2 lists the UTM coordinates for the large SO<sub>2</sub> sources that will be modeled as well as the stack data and structure data (height, tiers, corners or tank center/diameter details).

Rural dispersion coefficients are utilized in this model. The area surrounding the power plant is predominantly rural with: Lake Erie dominating its eastern boundary, Sterling State park to the north, and wetlands to the south. The small acreage of industrial property to the west-northwest of Monroe PP is overshadowed by land cover having a rural character. Figure 2 illustrates the area surrounding Monroe PP with the various land use types. Therefore, rural dispersion is appropriate for this large power plant.

## Background Concentration

Identifying a representative SO<sub>2</sub> concentration for this site is much less difficult than for the previous SO<sub>2</sub> impact assessment. The MDEQ-AQD sited a new SO<sub>2</sub> monitor at Sterling State Park, just over a mile due north of the main unit stacks, late in 2012. It began collecting data in January 2013. Two years of SO<sub>2</sub> data are available to calculate a background concentration. Hours when the wind direction is from Monroe PP's main unit stacks towards this new monitoring site were not eliminated from the calculation, leading to a conservative background concentration. MDEQ-AQD staff calculated a SO<sub>2</sub> background concentration of 47.6 ug/m<sup>3</sup> or 18.2ppb to add to the impact from the modeled sources. The previous background concentrations were based on data from Michigan City, Indiana, about 200 miles from Monroe PP.

## Meteorology

The most appropriate meteorological data set for this 1-hour SO<sub>2</sub> NAAQS designation analysis in Monroe County utilizes 2012-2014 data, with surface data from the Monroe Custer Airport. This airport is only six miles away from Monroe PP, just north of the City of Monroe. Upper air data from White Lake Township will also be used. The Monroe Custer Airport site does not have 1-minute wind data, but it is most representative for Monroe County, especially the portion including Monroe PP. The dataset has 404 (1.54%) missing hours and 2,530 (9.61%) calm hours identified. This data set has been compiled, and is available from the Air Quality Division staff.

## Modeling Domain

The receptor grid modeled follows the MDEQ guidance for receptors around a large point source. The receptor grid that was used in the previous air permit met the requirements for a Prevention of Significant Deterioration (PSD) permit. Therefore, it will be reused in the upcoming 1-hour SO<sub>2</sub> NAAQS designation modeling, but only out to a distance of 10 kilometers from the main units' stacks. Note, that receptors over the following areas will not be included in the impact analysis:

- DTE Energy Monroe PP property
- US waters (i.e., Lake Erie, River Raisin, Plum Creek)
- Landfills (On-Site Storage Basin & Sterling State Park Dredge Spoils Area)
- On roadways (i.e., I-75 & other local roads)
- On modeled SO<sub>2</sub> source secured property

Receptor elevation data will be used in the analysis.

## Off-Site Emission Inventory

The other Michigan SO<sub>2</sub> sources that will be included in the AERMOD runs are: IKO Monroe, Guardian Industries, and Gerdau MacSteel-Monroe. These three sources will be included in the AERMOD impact assessment using their actual or allowable emission rate, whichever is provided by MDEQ-AQD. The provided emission rates are shown in Table 2. As previously mentioned, Consumers Energy's J. R. Whiting Plant will not be modeled since it will be retired by April 2016, at the latest.

Table 2

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
SO<sub>2</sub> Source Emission Data

Source Data

| Source                  | Load (%) | Sulfur Dioxide Allowable Emission Rate |   |
|-------------------------|----------|--|---|
|                         |          | Short-term (lb/hr)                     | Notes                                   |
| *Monroe PP Unit 1       | 100      | 815.8                                  | Emission limit – 0.107 lbs/MMBtu        |
| *Monroe PP Unit 2       | 100      | 815.8                                  | Emission limit – 0.107 lbs/MMBtu        |
| *Monroe PP Unit 3       | 100      | 815.8                                  | Emission limit – 0.107 lbs/MMBtu        |
| *Monroe PP Unit 4       | 100      | 815.8                                  | Emission limit – 0.107 lbs/MMBtu        |
| Monroe PP Aux. Blrs.    | 100      | 0.65                                   | 15 ppm sulfur oil                       |
| Monroe PP DG 11-1       | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil & < 100 hrs/yr        |
| Monroe PP DG 11-2       | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil & < 100 hrs/yr        |
| Monroe PP DG 11-3       | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil & < 100 hrs/yr        |
| Monroe PP DG 11-4       | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil & < 100 hrs/yr        |
| Monroe PP DG 11-5       | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil & < 100 hrs/yr        |
| Quench Pump Engine 1    | 100      | 0.0032                                 | 15 ppm sulfur oil                       |
| Quench Pump Engine 2    | 100      | 0.0032                                 | 15 ppm sulfur oil                       |
| Quench Pump Engine 3    | 100      | 0.0032                                 | 15 ppm sulfur oil                       |
| Quench Pump Engine 4    | 100      | 0.0032                                 | 15 ppm sulfur oil                       |
| *IKO Monroe             | 100      | 20.0                                   | Allowable SO <sub>2</sub> emission rate |
| *Guardian Industries    | NA       | 132.6                                  | Actual SO <sub>2</sub> emission rate    |
| *Gerdau MacSteel Monroe | NA       | 6.1                                    | Actual SO <sub>2</sub> emission rate    |

\*Note: The only sources that will be modeled are the four main units at Monroe PP (Nos. 1-4) and the three interaction sources provided by MDEQ-AQD staff

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
SO<sub>2</sub> Source Stack Data

| Stack Data                  | Stack           |              |                     |                  |          |
|-----------------------------|-----------------|--------------|---------------------|------------------|----------|
|                             | UTM Coordinates |              | Base                |                  | Type     |
|                             | East<br>(m)     | North<br>(m) | Elevation<br>(feet) | Height<br>(feet) |          |
| <b>MONPP Sources</b>        |                 |              |                     |                  |          |
| *Monroe Unit 1              | 305544          | 4640266      | 580                 | 579              | Vertical |
| *Monroe Unit 2              | 305535          | 4640261      | 580                 | 579              | Vertical |
| *Monroe Unit 3              | 305380          | 4640194      | 580                 | 579              | Vertical |
| *Monroe Unit 4              | 305370          | 4640192      | 580                 | 579              | Vertical |
| Auxiliary Boilers           | 305482          | 4640400      | 580                 | 231              | Vertical |
| Diesel Gen 11-1             | 305568          | 4640562      | 580                 | 20               | Vertical |
| Diesel Gen 11-2             | 305575          | 4640564      | 580                 | 20               | Vertical |
| Diesel Gen 11-3             | 305581          | 4640566      | 580                 | 20               | Vertical |
| Diesel Gen 11-4             | 305587          | 4640569      | 580                 | 20               | Vertical |
| Diesel Gen 11-5             | 305593          | 4640572      | 580                 | 20               | Vertical |
| Quench Pump Engine 1        | 305516          | 4640205      | 580                 | 34.1             | Vertical |
| Quench Pump Engine 2        | 305518          | 4640200      | 580                 | 34.1             | Vertical |
| Quench Pump Engine 3        | 305349          | 4640140      | 580                 | 34.1             | Vertical |
| Quench Pump Engine 4        | 305351          | 4640137      | 580                 | 34.1             | Vertical |
| <b>Other Nearby Sources</b> |                 |              |                     |                  |          |
| *IKO Monroe                 | 300200          | 4644200      | 600                 | 56.0             | Vertical |
| *Guardian Industries        | 304915          | 4662490      | 620                 | 199              | Vertical |
| *Gerdau MacSteel Monroe     | 304524          | 4640317      | 580                 | 133.7            | Vertical |

\*Note: The only sources that will be modeled are the four main units at Monroe PP (Nos. 1-4) and the three interaction sources provided by MDEQ-AQD staff

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
SO<sub>2</sub> Source Stack Data

Refined Modeling Inputs

| <u>Point Source Data</u>          | <u>Stack</u>             |                                    |                                     |                                       |                               |
|-----------------------------------|--------------------------|------------------------------------|-------------------------------------|---------------------------------------|-------------------------------|
|                                   | <u>Height<br/>(feet)</u> | <u>Inside<br/>Diam.<br/>(feet)</u> | <u>Exit Gas<br/>Flow<br/>(acfm)</u> | <u>Exit<br/>Velocity<br/>(ft/sec)</u> | <u>Exit<br/>Temp.<br/>(F)</u> |
| <b>MONPP Sources</b>              |                          |                                    |                                     |                                       |                               |
| *Monroe Unit 1                    | 579                      | 28.0                               | 2.15 E6                             | 58.2                                  | 120                           |
| *Monroe Unit 2                    | 579                      | 28.0                               | 2.15 E6                             | 58.2                                  | 120                           |
| *Monroe Unit 3                    | 579                      | 28.0                               | 2.15 E6                             | 58.2                                  | 120                           |
| *Monroe Unit                      | 579                      | 28.0                               | 2.15 E6                             | 58.2                                  | 120                           |
| Auxiliary Boilers                 | 231                      | 9.0                                | 5.41 E3                             | 14.2                                  | 900                           |
| Diesel Generator 11-1             | 20                       | 2.67                               | 2.5 E3                              | 74.4                                  | 750                           |
| Diesel Generator 11-2             | 20                       | 2.67                               | 2.5 E3                              | 74.4                                  | 750                           |
| Diesel Generator 11-3             | 20                       | 2.67                               | 2.5 E3                              | 74.4                                  | 750                           |
| Diesel Generator 11-4             | 20                       | 2.67                               | 2.5 E3                              | 74.4                                  | 750                           |
| Diesel Generator 11-5             | 20                       | 2.67                               | 2.5 E3                              | 74.4                                  | 750                           |
| Quench Pump Engine 1              | 34.1                     | 0.5                                | 1.6 E3                              | 136                                   | 850                           |
| Quench Pump Engine 2              | 34.1                     | 0.5                                | 1.6 E3                              | 136                                   | 850                           |
| Quench Pump Engine 3              | 34.1                     | 0.5                                | 1.6 E3                              | 136                                   | 850                           |
| Quench Pump Engine 4              | 34.1                     | 0.5                                | 1.6 E3                              | 136                                   | 850                           |
| <b>Other Nearby Point Sources</b> |                          |                                    |                                     |                                       |                               |
| *IKO Monroe                       | 56.0                     | 4.00                               | 3.05 E4                             | 40.4                                  | 480                           |
| *Guardian Industries              | 199.0                    | 8.50                               | 1.11 E5                             | 32.5                                  | 790                           |
| *Gerdau MacSteel Monroe           | 133.7                    | 7.32                               | 2.01 E5                             | 64.0                                  | 403                           |

\*Note: The only sources that will be modeled are the four main units at Monroe PP (Nos. 1-4) and the three interaction sources provided by MDEQ-AQD staff

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
Structure Data

| Monroe Power Plant - Critical Buildings Affecting Main Unit / Aux Boiler / Diesel Gen Stack Downwash |            |           |        |   |           |          |           |          |           |          |           |
|--|------------|-----------|--------|---|-----------|----------|-----------|----------|-----------|----------|-----------|
| Monroe Power Plant Structure   | Unit No(s) | Base      |        | Corner 1  |           | Corner 2 |           | Corner 3 |           | Corner 4 |           |
|  |            | Elevation | Height | UTME  | UTMN      | UTME     | UTMN      | UTME     | UTMN      | UTME     | UTMN      |
|  |            | (feet)    | (feet) | (m)   | (m)       | (m)      | (m)       | (m)      | (m)       | (m)      | (m)       |
| SCR Roof   | 1          | 580       | 231.5  | 305436  | 4640358   | 305476   | 4640373   | 305483   | 4640358   | 305443   | 4640342   |
| SCR Roof   | 2          | 580       | 231.5  | 305497  | 4640386   | 305537   | 4640401   | 305544   | 4640386   | 305504   | 4640371   |
| SCR Roof   | 3          | 580       | 231.5  | 305345  | 4640322   | 305383   | 4640337   | 305392   | 4640320   | 305352   | 4640304   |
| SCR Roof   | 4          | 580       | 231.5  | 305277  | 4640293   | 305314   | 4640309   | 305322   | 4640293   | 305284   | 4640278   |
| Boiler House Roof  | 3 & 4      | 580       | 209.7  | 305244  | 4640361   | 305380   | 4640416   | 305386   | 4640403   | 305376   | 4640399   |
|  |            |           |        | 305390  | 4640366   | 305263   | 4640313   |          |           |          |           |
| Boiler House Roof  | 1 & 2      | 580       | 207.5  | 305391  | 4640421   | 305545   | 4640483   | 305549   | 4640469   | 305544   | 4640466   |
|  |            |           |        | 305558  | 4640432   | 305421   | 4640378   | 305406   | 4640416   | 305395   | 4640411   |
| Turbine Building   | 1 - 4      | 580       | 108    | 305222  | 4640399   | 305366   | 4640458   | 305359   | 4640472   | 305391   | 4640485   |
|  |            |           |        | 305397  | 4640471   | 305526   | 4640523   | 305542   | 4640483   | 305237   | 4640359   |
| Limestone Silo   | 1 - 4      | 580       | 142    | 305448  | 4640192   | 305485   | 4640207   | 305489   | 4640197   | 305452   | 4640182   |
| Limestone Prep Building  | 1 - 4      | 580       | 66     | 305460  | 4640161   | 305452   | 4640182   | 305489   | 4640197   | 305497   | 4640176   |
| Gypsum Dewatering Building   | 1 - 4      | 580       | 73     | 305412  | 4640167   | 305444   | 4640180   | 305462   | 4640133   | 305430   | 4640120   |
| Gypsum Storage Building  | 1 - 4      | 580       | 60     | 305314  | 4639981   | 305350   | 4640008   | 305410   | 4639928   | 305374   | 4639900   |
| Water Treatment Bldg. 1 (Top Tier)   | 1 - 4      | 580       | 102    | 305354  | 4640163   | 305382   | 4640174   | 305381   | 4640179   | 305399   | 4640186   |
|  |            |           |        | 305398  | 4640189   | 305351   | 4640170   |          |           |          |           |
| Water Treatment Bldg. 1 (Middle Tier)  | 1 - 4      | 580       | 44     | 305384  | 4640168   | 305403   | 4640176   | 305397   | 4640189   | 305352   | 4640170   |
|  |            |           |        | 305354  | 4640163   | 305382   | 4640174   |          |           |          |           |
| Water Treatment Bldg. 1 (Lowest Tier)  | 1 - 4      | 580       | 28     | 305355  | 4640137   | 305386   | 4640150   | 305383   | 4640158   | 305406   | 4640168   |
|  |            |           |        | 305398  | 4640189   | 305351   | 4640170   | 305355   | 4640159   | 305347   | 4640156   |
| Water Treatment Bldg. 2 (Top Tier)   | 1 - 4      | 580       | 102    | 305520  | 4640228   | 305548   | 4640239   | 305547   | 4640243   | 305565   | 4640250   |
|  |            |           |        | 305564  | 4640253   | 305518   | 4640234   |          |           |          |           |
| Water Treatment Bldg. 2 (Middle Tier)  | 1 - 4      | 580       | 44     | 305550  | 4640233   | 305569   | 4640240   | 305564   | 4640253   | 305517   | 4640234   |
|  |            |           |        | 305520  | 4640228   | 305548   | 4640239   |          |           |          |           |
| Water Treatment Bldg. 2 (Lowest Tier)  | 1 - 4      | 580       | 28     | 305521  | 4640201   | 305552   | 4640214   | 305549   | 4640223   | 305573   | 4640233   |
|  |            |           |        | 305564  | 4640253   | 305517   | 4640235   | 305522   | 4640223   | 305513   | 4640220   |
| Wastewater Treatment - Hydrated Lime   | 1 - 4      | 580       | 65     | 305231  | 4639903   | 305254   | 4639958   | 305279   | 4639947   | 305257   | 4639892   |
| North Hydrated Lime Tank   | 1 - 4      | 580       | 81.7   | Center = 305251, 4639956, Diameter = 13.92 feet |           |          |           |          |           |          |           |
| South Hydrated Lime Tank   | 1 - 4      | 580       | 81.7   | Center = 305249, 4639952, Diameter = 13.92 feet |           |          |           |          |           |          |           |
| Chem Waste Tank  | 1 - 4      | 580       | 35     | Center = 305320, 4639889, Diameter = 203.4 feet |           |          |           |          |           |          |           |
| Diesel Gen No. 11-1  | DG 11-1    | 580       | 13     | 305564  | 4640568   | 305567   | 4640569   | 305572   | 4640555   | 305569   | 4640554   |
| Diesel Gen No. 11-2  | DG 11-2    | 580       | 13     | 305571  | 4640570   | 305574   | 4640572   | 305579   | 4640558   | 305576   | 4640556   |
| Diesel Gen No. 11-3  | DG 11-3    | 580       | 13     | 305576  | 4640572   | 305579   | 4640573   | 305584   | 4640559   | 305581   | 4640558   |
| Diesel Gen No. 11-4  | DG 11-4    | 580       | 13     | 305582  | 4640575   | 305586   | 4640577   | 305591   | 4640563   | 305587   | 4640561   |
| Diesel Gen No. 11-5  | DG 11-5    | 580       | 13     | 305588  | 4640578   | 305592   | 4640579   | 305597   | 4640565   | 305593   | 4640564   |
| Makeup Water Building 1  | 1 - 4      | 580       | 65     | 305370.4  | 4640133.4 | 305370.2 | 4640134.9 | 305369.8 | 4640136.4 | 305369.1 | 4640137.8 |
|  |            |           |        | 305368.1  | 4640139   | 305366.9 | 4640140   | 305365.5 | 4640140.7 | 305364   | 4640141.1 |
|  |            |           |        | 305362.5  | 4640141.3 | 305360.9 | 4640141.1 | 305359.4 | 4640140.7 | 305358.1 | 4640140   |
|  |            |           |        | 305356.9  | 4640139   | 305355.9 | 4640137.8 | 305355.2 | 4640136.4 | 305354.7 | 4640134.9 |
|  |            |           |        | 305354.6  | 4640133.4 | 305354.7 | 4640131.8 | 305355.2 | 4640130.3 | 305355.9 | 4640129   |
|  |            |           |        | 305356.9  | 4640127.8 | 305358.1 | 4640126.8 | 305359.4 | 4640126   | 305360.9 | 4640125.6 |
|  |            |           |        | 305362.5  | 4640125.4 | 305364   | 4640125.6 | 305365.5 | 4640126   | 305366.9 | 4640126.8 |
|  |            |           |        | 305368.1  | 4640127.8 | 305369.1 | 4640129   | 305369.8 | 4640130.3 | 305370.2 | 4640131.8 |

Note: Other buildings in the area are not modeled because the proposed source's stacks are outside of the wake zone of these structures.

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
Structure Data

| Monroe Power Plant - Critical Buildings Affecting Main Unit / Aux Boiler / Diesel Gen Stack Downwash |             |                  |               |          |           |          |           |          |           |          |           |
|--|-------------|------------------|---------------|----------|-----------|----------|-----------|----------|-----------|----------|-----------|
| Monroe Power Plant Structure   | Unit No(s). | Base             |               | Corner 1 |           | Corner 2 |           | Corner 3 |           | Corner 4 |           |
|  |             | Elevation (feet) | Height (feet) | UTME (m) | UTMN (m)  | UTME (m) | UTMN (m)  | UTME (m) | UTMN (m)  | UTME (m) | UTMN (m)  |
| Makeup Water Building 2  | 1 - 4       | 580              | 65            | 305542.6 | 4640196.8 | 305542.4 | 4640198.3 | 305542.0 | 4640199.8 | 305541.2 | 4640201.2 |
|  |             |                  |               | 305540.2 | 4640202.4 | 305539.0 | 4640203.4 | 305537.7 | 4640204.1 | 305536.2 | 4640204.5 |
|  |             |                  |               | 305534.6 | 4640204.7 | 305533.1 | 4640204.5 | 305531.6 | 4640204.1 | 305530.2 | 4640203.4 |
|  |             |                  |               | 305529.0 | 4640202.4 | 305528.1 | 4640201.2 | 305527.3 | 4640199.8 | 305526.9 | 4640198.3 |
|  |             |                  |               | 305526.7 | 4640196.8 | 305526.9 | 4640195.2 | 305527.3 | 4640193.7 | 305528.1 | 4640192.4 |
|  |             |                  |               | 305529.0 | 4640191.2 | 305530.2 | 4640190.2 | 305531.6 | 4640189.4 | 305533.1 | 4640189.0 |
|  |             |                  |               | 305534.6 | 4640188.8 | 305536.2 | 4640189.0 | 305537.7 | 4640189.4 | 305539.0 | 4640190.2 |
|  |             |                  |               | 305540.2 | 4640191.2 | 305541.2 | 4640192.4 | 305542.0 | 4640193.7 | 305542.4 | 4640195.2 |
|  |             |                  |               | 305569.8 | 4640267.8 | 305569.6 | 4640269.9 | 305569.0 | 4640271.9 | 305568.0 | 4640273.8 |
|  |             |                  |               | 305566.6 | 4640275.4 | 305565.0 | 4640276.7 | 305563.1 | 4640277.7 | 305561.1 | 4640278.3 |
| 305559.0   | 4640278.5   | 305556.9         | 4640278.3     | 305554.9 | 4640277.7 | 305553.1 | 4640276.7 |          |           |          |           |
| 305551.4   | 4640275.4   | 305550.1         | 4640273.8     | 305549.1 | 4640271.9 | 305548.5 | 4640269.9 |          |           |          |           |
| 305548.3   | 4640267.8   | 305548.5         | 4640265.7     | 305549.1 | 4640263.7 | 305550.1 | 4640261.8 |          |           |          |           |
| 305551.4   | 4640260.2   | 305553.1         | 4640258.9     | 305554.9 | 4640257.9 | 305556.9 | 4640257.3 |          |           |          |           |
| 305559.0   | 4640257.1   | 305561.1         | 4640257.3     | 305563.1 | 4640257.9 | 305565.0 | 4640258.9 |          |           |          |           |
| 305566.6   | 4640260.2   | 305568.0         | 4640261.8     | 305569.0 | 4640263.7 | 305569.6 | 4640265.7 |          |           |          |           |
| FGD Absorber   | 2           | 580              | 126           | 305533.3 | 4640250.3 | 305533.1 | 4640252.5 | 305532.5 | 4640254.6 | 305531.5 | 4640256.5 |
|  |             |                  |               | 305530.1 | 4640258.2 | 305528.4 | 4640259.5 | 305526.5 | 4640260.6 | 305524.4 | 4640261.2 |
|  |             |                  |               | 305522.2 | 4640261.4 | 305520.1 | 4640261.2 | 305518.0 | 4640260.6 | 305516.1 | 4640259.5 |
|  |             |                  |               | 305514.4 | 4640259.2 | 305513.0 | 4640256.5 | 305512.0 | 4640254.6 | 305511.4 | 4640252.5 |
|  |             |                  |               | 305511.2 | 4640250.3 | 305511.4 | 4640248.2 | 305512.0 | 4640246.1 | 305513.0 | 4640244.2 |
|  |             |                  |               | 305514.4 | 4640242.5 | 305516.1 | 4640241.1 | 305518.0 | 4640240.1 | 305520.1 | 4640239.5 |
|  |             |                  |               | 305522.2 | 4640239.2 | 305524.4 | 4640239.5 | 305526.5 | 4640240.1 | 305528.4 | 4640241.1 |
|  |             |                  |               | 305530.1 | 4640242.5 | 305531.5 | 4640244.2 | 305532.5 | 4640246.1 | 305533.1 | 4640248.2 |
| FGD Absorber   | 3           | 580              | 126           | 305413.0 | 4640204.0 | 305412.8 | 4640206.1 | 305412.2 | 4640208.1 | 305411.2 | 4640209.9 |
|  |             |                  |               | 305409.9 | 4640211.6 | 305408.2 | 4640212.9 | 305406.4 | 4640213.9 | 305404.4 | 4640214.5 |
|  |             |                  |               | 305402.3 | 4640214.7 | 305400.2 | 4640214.5 | 305398.2 | 4640213.9 | 305396.3 | 4640212.9 |
|  |             |                  |               | 305394.7 | 4640211.6 | 305393.4 | 4640209.9 | 305392.4 | 4640208.1 | 305391.8 | 4640206.1 |
|  |             |                  |               | 305391.6 | 4640204.0 | 305391.8 | 4640201.9 | 305392.4 | 4640199.9 | 305393.4 | 4640198.0 |
|  |             |                  |               | 305394.7 | 4640196.4 | 305396.3 | 4640195.0 | 305398.2 | 4640194.0 | 305400.2 | 4640193.4 |
|  |             |                  |               | 305402.3 | 4640193.2 | 305404.4 | 4640193.4 | 305406.4 | 4640194.0 | 305408.2 | 4640195.0 |
|  |             |                  |               | 305409.9 | 4640196.4 | 305411.2 | 4640198.0 | 305412.2 | 4640199.9 | 305412.8 | 4640201.9 |
|  |             |                  |               | 305375.5 | 4640188.1 | 305375.3 | 4640190.2 | 305374.6 | 4640192.3 | 305373.6 | 4640194.2 |
|  |             |                  |               | 305372.2 | 4640195.9 | 305370.6 | 4640197.3 | 305368.6 | 4640198.3 | 305366.6 | 4640199.0 |
| 305364.4   | 4640199.2   | 305362.2         | 4640199.0     | 305360.2 | 4640198.3 | 305358.2 | 4640197.3 |          |           |          |           |
| 305356.6   | 4640195.9   | 305355.2         | 4640194.2     | 305354.2 | 4640192.3 | 305353.5 | 4640190.2 |          |           |          |           |
| 305353.3   | 4640188.1   | 305353.5         | 4640185.9     | 305354.2 | 4640183.8 | 305355.2 | 4640181.9 |          |           |          |           |
| 305356.6   | 4640180.2   | 305358.2         | 4640178.9     | 305360.2 | 4640177.8 | 305362.2 | 4640177.2 |          |           |          |           |
| 305364.4   | 4640177.0   | 305366.6         | 4640177.2     | 305368.6 | 4640177.8 | 305370.6 | 4640178.9 |          |           |          |           |
| 305372.2   | 4640180.2   | 305373.6         | 4640191.9     | 305374.6 | 4640183.8 | 305375.3 | 4640185.9 |          |           |          |           |

Note: Other buildings in the area are not modeled because the proposed source's stacks are outside of the wake zone of these structures.

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Monroe Power Plant  
Modeling Input Parameters

Building Data

Building Influence Model: BPIP (Version 8.80, dated 04274)

Refined Model: AERMOD (BEE-Line Version 11.00, dated 14134)

Model Options: Terrain elevations considered - Yes  
Dispersion coefficients - Rural  
Default wind exponents - Yes  
Default vertical temperature gradients - Yes  
Emissions scaled - No  
Final plume rise - Yes  
Stack tip downwash - Yes  
Buoyancy induced dispersion - Yes  
Calm processing routine - Yes  
Regulatory default option - Yes  
Type of pollutant – SO<sub>2</sub>

Meteorological Data: Surface – Monroe Custer Airport (TTF)  
Upper Air – White Lake NWS Office (DTX)  
Dates – 2012-2014  
Anemometer height – 10 m

Property Line Receptor Grid

Grid: 25 m spacing at the fence line

Receptor Grid (1<sup>st</sup> Grid)

Grid Type: Rectangular

Grid: 50m spacing outside of the fence line out to 2 km from the facility

Receptor Grid (2<sup>nd</sup> Grid)

Grid Type: Rectangular

Grid: 250 m spacing outside of the 1st Grid to 5 km from the facility

Receptor Grid (3<sup>rd</sup> Grid)

Grid Type: Rectangular

Grid: 500 m spacing outside of the 2<sup>nd</sup> Grid to 10 km from the facility



Figure 1

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

Monroe Power Plant

Aerial Photograph from 2006  
(Prior to FGD Installation on all Four Units)







This page left intentionally blank.

---

***Dispersion Modeling Report***

***1-Hour SO<sub>2</sub> NAAQS Area Designation  
J.H. Campbell Generating Station  
Consumers Energy Company***

***Prepared for:***

***Consumers Energy Company  
1945 W. Parnall Road  
Jackson, Michigan 49201***

***Prepared by:***

***Horizon Environmental Corporation  
4771 50<sup>th</sup> Street SE, Suite One  
Grand Rapids, Michigan 49512***

---

***July 15, 2015***

## TABLE OF CONTENTS

|          |  |          |
|----------|--|----------|
| <b>1</b> | <b>INTRODUCTION.....</b>                                       | <b>1</b> |
| 1.1      | REGULATORY FRAMEWORK FOR SO <sub>2</sub> AREA DESIGNATION..... | 1        |
| <b>2</b> | <b>FACILITY DESCRIPTION .....</b>                              | <b>3</b> |
| 2.1      | INVENTORY OF COMBUSTION SOURCES .....                          | 3        |
| 2.1.1    | <i>Emergency Generators and Pumps</i> .....                    | 4        |
| 2.1.2    | <i>Auxiliary Boilers</i> .....                                 | 4        |
| 2.2      | EMISSIONS CHARACTERIZATION .....                               | 5        |
| 2.2.1    | <i>Modeled Emission Rates for Area Designation</i> .....       | 6        |
| <b>3</b> | <b>DISPERSION MODEL AND MODELING DATABASES .....</b>           | <b>8</b> |
| 3.1      | DISPERSION MODEL.....  | 8        |
| 3.2      | LAND USE CLASSIFICATION AND DISPERSION MODE.....               | 8        |
| 3.3      | AERODYNAMIC DOWNWASH EFFECTS .....                             | 9        |
| 3.4      | RECEPTOR POINTS AND TERRAIN ELEVATION .....                    | 10       |
| 3.5      | METEOROLOGICAL DATA .....                                      | 11       |
| 3.6      | DISPERSION MODELING METHODOLOGY .....                          | 12       |

## LIST OF FIGURES

|          |   |
|----------|---|
| FIGURE 1 | LOCATION OF THE J.H. CAMPBELL GENERATING COMPLEX  |
| FIGURE 2 | 3D VIEW OF STRUCTURES CONSIDERED IN THE PLUME DOWNWASH ANALYSIS                         |
| FIGURE 3 | FENCELINE AND NEARBY RECEPTORS  |
| FIGURE 4 | RECEPTOR GRID USED IN THE SO <sub>2</sub> AREA DESIGNATION ANALYSIS                     |
| FIGURE 5 | NESTED RECEPTOR GRID USED IN THE SO <sub>2</sub> AREA DESIGNATION ANALYSIS              |
| FIGURE 6 | THREE YEAR COMPOSITE WIND ROSE FOR MUSKEGON, MICHIGAN                                   |
| FIGURE 7 | LOCATION OF THE 99 <sup>TH</sup> PERCENTILE DAILY 1-HOUR MAXIMUM SO <sub>2</sub> IMPACT |

## LIST OF TABLES

|         |   |
|---------|---|
| TABLE 1 | AUXILIARY BOILER MONTHLY FUEL USAGE AND EQUIVALENT HOURS OF OPERATION                       |
| TABLE 2 | CURRENT AND FORMER SO <sub>2</sub> EMISSION LIMITS  |
| TABLE 3 | AUER'S LAND USE CLASSIFICATION SCHEME   |
| TABLE 4 | STACK EXHAUST PARAMETERS  |
| TABLE 5 | COMPARISON OF MODELED SO <sub>2</sub> CONCENTRATIONS TO THE 1-HOUR SIGNIFICANT IMPACT LEVEL |
| TABLE 6 | COMPARISON OF MODELED SO <sub>2</sub> CONCENTRATIONS TO THE 1-HOUR NAAQS                    |

## LIST OF ATTACHMENTS

|              |  |
|--------------|--|
| ATTACHMENT A | CONTINUOUS EMISSIONS MONITORING DATA AND DISPERSION MODELING INPUT/OUTPUT FILES (DVD-ROM)        |
| ATTACHMENT B | SUMMARY OF CEMS MISSING HOURLY SO <sub>2</sub> AND/OR FLOW RATE DATA DURING THE 2012-2014 PERIOD |

# 1 INTRODUCTION

On behalf of the Consumers Energy Company (“Consumers”), Horizon Environmental Corporation (“Horizon”) has conducted ambient air quality dispersion modeling analyses to demonstrate that the area surrounding the J.H. Campbell Generating Complex (SRN: B2835) is in attainment with the 1-hour sulfur dioxide (“SO<sub>2</sub>”) national ambient air quality standard (“NAAQS”). The dispersion modeling analyses were conducted in accordance with the relevant provisions of the draft *SO<sub>2</sub> NAAQS Designations Modeling Technical Assistance Document* (the “Modeling TAD”, U.S. EPA, December 2013), the *Updated Guidance for Area Designations for the 2010 Primary Sulfur Dioxide National Ambient Air Quality Standard* (U.S. EPA, March 20, 2015), and *Guidance for 1-Hour SO<sub>2</sub> Nonattainment Area SIP Submissions* (U.S. EPA, April 23, 2014). Moreover, the dispersion modeling analyses were conducted consistent with a protocol submitted to the Michigan Department of Environmental Quality, Air Quality Division (“AQD”) on May 28, 2015 and subsequently approved by the U.S. EPA, Region 5.

This submittal constitutes the technical report summarizing the methodology and results of the dispersion model simulations that Consumers conducted in support of the 1-hour SO<sub>2</sub> NAAQS attainment designation. A description of the J.H. Campbell (“Campbell”) Generating Complex, including a discussion of the SO<sub>2</sub> emissions data that were analyzed in support of the attainment designation, is provided in **Section 2**. The dispersion model, databases, and methodology employed in the analysis, as well as resultant model-predicted impacts, are detailed in **Section 3**.

## 1.1 REGULATORY FRAMEWORK FOR SO<sub>2</sub> AREA DESIGNATION

On June 2, 2010, the U.S. EPA established for the first time a primary 1-hour SO<sub>2</sub> NAAQS,<sup>1</sup> while at the same time revoking both the existing 24-hour and annual primary SO<sub>2</sub> NAAQS. Attainment with the new standard in an airshed is demonstrated when the 3-year average of the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations does not exceed 75 ppb. To date, attainment designations have been established for 29 areas in 16 states. On March 2, 2015, the U.S. District Court for the Northern District of California entered a Consent Decree and issued an enforceable order for the U.S. EPA to complete its area designations according to a specified time schedule.

---

<sup>1</sup> The 1-hour standard became effective on August 23, 2010.



Based on current SO<sub>2</sub> emission levels, an attainment designation for the area surrounding the Campbell Generating Complex must be completed no later than July 2, 2016. The U.S. EPA has requested that the states, including Michigan, submit their designation recommendations by September 18, 2015. Considering the accelerated submittal schedule and limited representative ambient monitoring data, designation recommendations for the area surrounding the Campbell Generating Complex will be based on source modeling.

In contrast to a typical 1-hour SO<sub>2</sub> NAAQS compliance demonstration, the Modeling TAD recommends that an area designation request follow an ambient monitoring approach by conducting the modeling analyses as follows:

- Use actual emissions as an input for assessing violations to provide results that reflect current actual air quality;
- Conduct three years of modeling to calculate a simulated design value consistent with the 3-year monitoring period required to develop a design value;
- Place receptors only in locations where a monitor could be reasonably placed; and
- When simulating actual emission rates, use actual stack heights rather than stack heights based on good engineering practice (if different).

Upon the request of the AQD and in order to support them with their area designation recommendations, Consumers conducted air quality dispersion modeling analyses to assess compliance with the 1-hour SO<sub>2</sub> NAAQS in the area surrounding the Campbell Generating Complex. Consumers followed the approach recommended in the Modeling TAD, deviating only to the extent that more site-specific guidance was provided by the U.S. EPA Region 5 or the AQD, or an emissions strategy more conservative than one based on actual emissions is sufficient to demonstrate attainment with the standard.

## 2 FACILITY DESCRIPTION

The Campbell Generating Complex is located at 17000 Croswell, West Olive, Michigan. Emission units operating at the Campbell Generating Complex are covered under ROP No. MI-ROP-B2835-2013, and Permit to Install Nos. 39-15 and 18-15. The location of the Campbell Generating Complex in relation to the surrounding area is illustrated in **Figure 1**.

### 2.1 INVENTORY OF COMBUSTION SOURCES

The primary steam-generating units for electric generation at the Campbell Generating Complex are identified as JHC1, JHC2 and JHC3. Though not often used, the Campbell Generating Complex also has the capacity to generate electricity from a small capacity combustion turbine. These combustion units as well as other smaller combustion units operating at the Campbell Generating Complex that have the potential to emit SO<sub>2</sub> (i.e., excluding units which are limited to firing natural gas or propane only via enforceable restriction/design) are summarized as follows:

- One 2,490 MMBtu/hr coal-fired boiler with fuel oil startup (“JHC1”);
- One 3,560 MMBtu/hr coal-fired boiler with fuel oil startup (“JHC2”);
- One 8,240 MMBtu/hr coal-fired boiler with fuel oil startup (“JHC3”);
- One 233 MMBtu/hr distillate oil-fired combustion turbine;
- One auxiliary distillate oil-fired boiler, rated at 17 MMBtu/hr;
- Two auxiliary distillate oil-fired boilers, each rated at 9.8 MMBtu/hr;
- One 380 Hp diesel-fired emergency fire water pump engine;
- Three diesel-fired emergency boiler house water pump engines (each <10 MMBtu/hr); and
- Four diesel-fired emergency generators of various sizes (each <10 MMBtu/hr).

Considering their heat input capacity, fuel type, and historical and projected operations, the area designation modeling analyses included emissions from JHC1, JHC2, JHC3, and the combustion turbine.

### 2.1.1 Emergency Generators and Pumps

The four diesel-fired emergency generator engines and four diesel-fired emergency water pump engines listed in the last three bullet points above in 2.1 are intermittent sources that operate only during emergency situations (or readiness testing). Actual operation of the emergency engines for the previous two years, as recorded by an hour meter, is summarized as follows<sup>2</sup>:

#### 2013

EUCATDIESEL – 16 hours  
EUHPHSWP15001 – 1.5 hours  
EUHPHSWP15002 – 1.8 hours  
EUHPHSWP3000 – 1.3 hours  
EUCAT3DIESEL – 6.9 hours  
EUCUMMINSDIESEL – 59.6 hours  
2000KW Generator – 13.4 hours  
890 KWh Generator – 14.4 hours

#### 2014

EUCATDIESEL – 28 hours  
EUHPHSWP15001 – 6.2 hours  
EUHPHSWP15002 – 9.2 hours  
EUHPHSWP3000 – 14.4 hours  
EUCAT3DIESEL – 12.4 hours  
EUCUMMINSDIESEL – 24.5 hours  
2000 KW Generator – 10.9 hours  
890 KWh Generator – 19.8 hours

As shown above, the emergency generators and pumps operate as intermittent sources. Therefore, consistent with Section 5.4 of the Modeling TAD, modeling of these intermittent sources was not conducted as part of the area designation analysis.

### 2.1.2 Auxiliary Boilers

The 17 MMBtu/hr auxiliary boiler services JHC1 and JHC2, providing necessary heat during unit startup and shut down conditions or for general building heat when both utility boilers are offline. Accordingly, the auxiliary boiler is not operated concurrently with JHC1 and JHC2 when those units are operating at typical load conditions. It should

---

<sup>2</sup> The last two emergency generators do not yet have official Emission Unit designations as they have not yet been incorporated into the facility Renewable Operating Permit.

be further noted that recently issued Permit to Install No. 18-15 imposes a 10% capacity factor limitation on the JHC 1 and 2 auxiliary boiler, and that this boiler was also used to supply steam to a flue gas conditioning system which was retired in early 2013. The two 9.8 MMBtu/hr auxiliary boilers are also limited in their use as they also provide heat to facilitate startup and shutdown or for general building heating purposes when Unit 3 is offline. Fuel usage in the three auxiliary boilers during the three-year period covered by the area designation analysis (2012-2014) has been limited to ultra-low sulfur diesel (“ULSD”) even though the station’s Renewable Operating Permit (“ROP”) allows for a higher sulfur content distillate.

Actual fuel usage for the three year period has been tracked and is summarized in **Table 1**. Using the heat input rating of the boilers and the heating value of ULSD (138,000 Btu/gallon), the actual monthly fuel usage has been converted to an equivalent monthly hours of operation. As shown in **Table 1**, the boilers are rarely used more than 100 hours in any given month.

Considering their low heat input rating, fuel sulfur content, and intermittent use, modeling of the three auxiliary boilers was not conducted as part of the area designation analysis.

## **2.2 EMISSIONS CHARACTERIZATION**

Pursuant to the Modeling TAD, area designation modeling may be conducted following an “actual emissions” approach or, if sufficient to demonstrate compliance with the 1-hour standard, a more conservative approach based on allowable emissions. Actual emissions data is beneficial for assessing whether an area has been in attainment with the 1-hour SO<sub>2</sub> NAAQS, but may have limited benefit looking forward if a source is in the process of implementing an emissions control strategy. In that event, future actual emissions will likely be much lower than recent historical actual emissions. Similarly, federally-enforceable allowable emission limits for the source are also typically lower after implementation of the control strategy.

Such is the case with JHC1, JHC2 and JHC3. In November 2014, Consumers entered into a Consent Decree (“Consumers CD”) with the Environmental Protection Agency (EPA) and Department of Justice (DOJ). On April 16, 2015, the AQD issued Permit to Install No. 39-15, which contains federally-enforceable emission limits and operating restrictions for the three units based on the implementation of an enhanced SO<sub>2</sub> emissions control strategy mandated by the Consumers CD. As stipulated by the permit, JHC1 and

JHC2 will be equipped with dry sorbent injection (“DSI”) systems, operation of which must commence no later than June 30, 2016; JHC3 will be equipped with a spray dry absorber (“SDA”), operation of which must commence no later than December 31, 2016.

Historically, the only SO<sub>2</sub> emission limits for JHC Units 1 and 2 consisted of lb/mmBtu emission limits (calendar month average) which originated from Michigan Air Pollution Control Rule 336.1401, while the SO<sub>2</sub> emission limit for Unit 3 consisted of a lb/mmBtu emission limit (3-hour average) originating from 40 CFR Part 60, Subpart D. For each of the JHC units, the Consumers CD introduces the following additional SO<sub>2</sub> emission limits based on application of the required DSI/SDA controls: JHC1 = 30-day and 90-day rolling lb/mmBtu limits; JHC2 = 365-day rolling lb/mmBtu limit; JHC3 = 30-day and 365-day rolling lb/mmBtu limits.

The historic SO<sub>2</sub> lb/mmBtu emission limits (based on Michigan Air Pollution Control Rule 336.1401/40 CFR 60, Subpart D) and the new 30-day (JHC1 & 3) and 365-day (JHC2) rolling SO<sub>2</sub> emission limits and resultant allowable mass emission rates for the three units and the combustion turbine, are shown in **Table 2**. The effect of the emissions control strategy is to reduce the SO<sub>2</sub> combined potential to emit of the four emission units from 20,381 pounds per hour to 3,100 pounds per hour (an 85% reduction).

### **2.2.1 Modeled Emission Rates for Area Designation**

Considering the enhanced SO<sub>2</sub> emissions control strategy mandated by the Consumers CD, now stipulated in a Permit to Install, substantial reductions in the SO<sub>2</sub> emissions profile for the Campbell Generating Complex will commence in 2016. Under this future operating scenario, SO<sub>2</sub> impacts due to the Campbell Generating Complex (modeled or otherwise measured at a recently installed ambient monitor located adjacent to the facility) are expected to be well under the NAAQS over all regulated averaging periods.

However, by court order an attainment designation for the area surrounding the Campbell Generating Complex must be completed no later than July 2, 2016. This precedes the date that implementation of the enhanced SO<sub>2</sub> emissions control strategy at the Campbell Generating Complex may be completed, and for which a sufficient amount of actual emissions data with the required DSI/SDA controls in place will have been recorded. Therefore, to demonstrate that the area surrounding the Campbell Generating Complex is currently in attainment with the 1-hour SO<sub>2</sub> NAAQS, model simulations of actual hourly emissions from Units 1-3 for the three-year period of 2012-2014, as measured with continuous emissions monitoring systems (“CEMS”) that comply with the procedures

contained in 40 CFR Part 75, were conducted. This methodology is more conservative than using allowable emission rates as future emissions will be substantially reduced with the additional pollution control equipment to be installed and operated.

Actual hourly SO<sub>2</sub> emissions data utilized for the modeling analyses was coupled with hourly actual exhaust velocity and temperature data also gathered using the CEMS. The standard missing data substitution procedures contained in Subpart D of 40 CFR Part 75 was used for any periods of missing SO<sub>2</sub> mass emission rate or flow rate CEMS data. The hourly CEMS data input to AERMOD is provided in electronic format in **Attachment A**, while **Attachment B** summarizes any SO<sub>2</sub> or Flow CEMS missing hourly data associated with the three year period. Please note that CEMS for JHC3 are located in separate “A” and “B” ducts located upstream of the stack, so missing data is assessed for each duct-level monitoring system.

For the combustion turbine, Consumers modeled a SO<sub>2</sub> emission rate consistent with continuous operation at rated capacity, but based upon a sulfur content of 15 ppm (consistent with the diesel fuel currently being used at the plant). Based on the SO<sub>2</sub> emission factor in AP-42 Table 3.1-2a, the SO<sub>2</sub> emission rate for 15 ppm sulfur is 1.515E-03 lb/mmBtu or 0.353 lbs/hour at the rated heat input of 233 mmBtu/hr. Based on the limited operating hours of this unit in the past few years, this is a very conservative approach as the unit operates very intermittently.

### 3 DISPERSION MODEL AND MODELING DATABASES

Ambient air quality dispersion modeling analyses were conducted to demonstrate that the area surrounding the Campbell Generating Complex should be designated in attainment with the 1-hour SO<sub>2</sub> NAAQS. The following sections summarize the dispersion model that was employed in the analysis, site area characteristics, modeling databases developed in support of the analysis, the methodology for conducting the compliance demonstration, and resultant modeled impacts.

#### 3.1 DISPERSION MODEL

Model simulations in support of the 1-hour SO<sub>2</sub> NAAQS area designation were conducted using the AMS/EPA Regulatory Model (“AERMOD”, Release No. 14134)<sup>3</sup>. AERMOD is currently recommended and approved for use in near-field SO<sub>2</sub> modeling applications by both the U.S. EPA and the AQD. AERMOD is designed to simulate conditions associated with this area designation, including:

- Rural dispersion conditions;
- Both windy and calm meteorological conditions;
- Flat and simple terrain;
- Elevated point sources influenced by building downwash;
- Transport less than 50 kilometers; and
- Concentration estimates over a one-hour averaging period.

The AERMOD simulations were conducted in the Regulatory Default mode.

#### 3.2 LAND USE CLASSIFICATION AND DISPERSION MODE

Atmospheric conditions affecting the downwind dispersion of air contaminants may be influenced by localized land use. Further, an exponential decay of SO<sub>2</sub> may occur during dispersion in an urban environment. As a result, AERMOD has been designed to

---

<sup>3</sup> In their review of the dispersion modeling protocol, the U.S. EPA Region 5 noted the imminent release of a new version of AERMOD. As of the date of this submittal, the new version of AERMOD has not been released to the public and was, therefore, not available to be used in the analysis.

simulate the downwind dispersion of SO<sub>2</sub> under both rural and urban conditions. To assess whether to run AERMOD in rural or urban mode for a particular application, the U.S. EPA's Guideline on Air Quality Models suggests using either a population density procedure or a land use classification procedure employing a typing scheme developed by Auer<sup>4</sup>. Of the two methods, the U.S. EPA considers the land use procedure to be the more definitive.

The Auer land use classification procedure is conducted as follows:

- 1) Classify the land use within the total area, A<sub>o</sub>, circumscribed by a three kilometer radius circle around the source using Auer's land use typing scheme;
- 2) If land use types I1, I2, C1, R2, and R3 account for 50 percent or more of A<sub>o</sub>, use urban dispersion coefficients; otherwise, use appropriate rural dispersion coefficients.

Consistent with U.S. EPA guidance, Auer's land use typing scheme was utilized to assess localized land use for the Campbell Generating Complex. The land use typing scheme is summarized in **Table 3**.

The Campbell Generating Complex is located in West Olive, a low population density area between Grand Haven and Holland. Utilizing satellite imagery, shown in **Figure 1**, land use within a three kilometer radius around the complex has been assessed and clearly exhibits rural characteristics (e.g., agricultural, undeveloped, and water surfaces). As a result, AERMOD simulations in support of the SO<sub>2</sub> NAAQS area designation for the Campbell Generating Complex were conducted in rural mode.

### 3.3 AERODYNAMIC DOWNWASH EFFECTS

As described in Section 2.1, the SO<sub>2</sub> NAAQS area designation analysis for the Campbell Generating Complex will include the following emission units:

- Two coal-fired boilers (JHC1 and JHC2) that vent to a common stack with a height of 400 feet;
- One coal-fired boiler (JHC3) that vents to a 642 foot tall stack; and

---

<sup>4</sup> Correlation of Land Use and Cover with Meteorological Anomalies, Journal of Applied Meteorology, 1978.



- One ULSD combustion turbine that vents to a 17 foot tall stack.

The coal-fired boiler stacks and the turbine stack are each lower than Good Engineering Practice (“GEP”) height. Plumes emitted from stacks with heights less than GEP design may be influenced by nearby buildings or other structures. In accordance with Section 6.1 of the Modeling TAD, the BPIP-PRIME aerodynamic downwash pre-processor (Release No. 04274) was utilized to estimate the maximum projected lateral and vertical dimensions of those buildings or structures that could influence the boiler and turbine stacks on a wind direction-specific basis.

BPIP-PRIME requires as input the dimensions of buildings or structures that could potentially influence emissions from a stack that is located at a distance less than five times the lesser dimension of height or projected width of the nearby structure. Maximum projected lateral and vertical dimensions of influencing structures, as calculated by BPIP-PRIME, are subsequently input to AERMOD. Two existing Boiler Houses and related structures, the turbine housing and a large fuel oil storage tank have the potential to influence the plumes emitted from the boiler and/or turbine stacks.

A three dimensional depiction of the preceding structures in relation to modeled emission points is provided in **Figure 2**.

### **3.4 RECEPTOR POINTS AND TERRAIN ELEVATION**

AERMOD-predicted concentrations may be estimated at discrete receptor locations. A discrete cartesian-based receptor grid was developed in support of the area designation analysis according to the following methodology:

- Receptors were located along the secured property boundary at distances not exceeding 50 meters.
- Receptors were located off-property at 100 meter spacing out to a distance of approximately 2 kilometers from the facility.
- Additional receptors were located off-property at 200 meter spacing out to a distance of approximately 10 kilometers from the facility.
- Additional receptors were located off-property at 500 meter spacing out to a distance of approximately 20 kilometers from the facility.
- Additional receptors were located off-property at 1 kilometer spacing out to a distance of approximately 50 kilometers from the facility.

- Consistent with the Modeling TAD, receptors were located only where a monitor could reasonably be placed. Therefore, receptors were not located over Lake Michigan or Pigeon Lake, both of which are adjacent to the facility.

In addition to the preceding receptor grids, an additional “nested” receptor grid at 100 meter spacing was placed in the area of the maximum impacts based on the form of the 1-hour SO<sub>2</sub> NAAQS (i.e., 3-year average of the 99<sup>th</sup> percentile daily 1-hour maximum concentrations) as these impacts were occurring beyond 2 kilometers from the facility.

Fenceline and nearby receptors are shown in **Figure 3**. The full receptor grid used in the SO<sub>2</sub> NAAQS area designation analysis consisted of 12,447 discrete receptor points and is illustrated in **Figure 4**. The nested receptor grid, which was sufficient to identify the maximum impact based on the form of the 1-hour SO<sub>2</sub> NAAQS, consisted of 121 discrete receptor points and is illustrated in **Figure 5**.

Elevated terrain features may affect the transport of atmospheric contaminants as well as serve as areas of potentially higher pollutant impacts. Where appropriate, terrain features should be included in the modeling analysis. A review of topographic projection data reveals fluctuations in terrain elevations around the Campbell Generating Complex. In accordance with U.S. EPA guidance, terrain elevations for each modeled stack and receptor point were included in the dispersion modeling analysis.

Terrain elevations at stack locations and discrete receptor points were obtained using the U.S. EPA’s AERMAP preprocessor (Release No. 11103)<sup>5</sup> in conjunction with U.S.G.S National Elevation Dataset (“NED”) terrain files in NAD83 format.

### 3.5 METEOROLOGICAL DATA

The form of the SO<sub>2</sub> NAAQS is based on a 3-year average of the annual 99<sup>th</sup> percentile of the 1-hour daily maximum concentrations. Consistent with the Modeling TAD, the area designation analysis was conducted using the most spatially representative and readily available meteorological database for the most recent three calendar years (2012-2014).

The Campbell Generating Complex is located along the Lake Michigan shoreline nearly equidistant from two National Weather Service (“NWS”) Automated Surface Observing

---

<sup>5</sup> Terrain processing was conducted using the AERMAP module of the AERMODView software system, Version 8.8.9, developed by Lakes Environmental.

System stations: the Muskegon County Airport (Station No. 14840) and the Tulip City Airport in Holland (Station No. 12636). Both stations have recorded 1-minute surface observations for the period 2012-2014. Using the AERMET preprocessor, the AQD compiled the Muskegon station observations along with coincident upper air observations measured at the NWS station in Green Bay, Wisconsin (Station No. 72645), while the Holland station observations were compiled along with coincident upper air observations measured at the NWS station in White Lake, Michigan (Station No. 72632). Because upper air observations measured at Green Bay may better represent atmospheric conditions approaching the Campbell Generating Complex, versus the White Lake station which is located over 150 miles downwind of the facility, the model simulations supporting the SO<sub>2</sub> NAAQS area designation were conducted using the Muskegon/Green Bay meteorological database, as processed and provided by the AQD in a 1-minute format.

A three-year composite wind rose for Muskegon, covering the years 2012-2014, is provided in **Figure 6**. The wind frequency distribution revealed in the figure exhibits seasonal variation in wind flow patterns as well as the likely variable influence of the sea breeze circulation, which would be expected to occur at a facility located along the Lake Michigan shoreline.

### 3.6 DISPERSION MODELING METHODOLOGY

Dispersion model simulations of the Campbell Generating Complex were conducted to provide the information necessary to designate the area in attainment with the 1-hour SO<sub>2</sub> NAAQS. The model simulations were conducted with AERMOD using over a three-year meteorological database (2012-2014 Muskegon/Green Bay). As described in **Section 2.2.1**, the simulations were based on hourly actual emissions, temperature, and flow rate data for the three primary boilers (JHC1, JHC2 and JHC3) during the three-year period and representative emissions for the combustion turbine. The hourly emissions and operating data was simulated in AERMOD using the HOUREMIS command. Stack exhaust parameters for the modeled emission units is provided in **Table 4**.

The first step in the modeling analysis was to compare maximum predicted 1-hour impacts at each receptor point against the interim 1-hour significant impact level (“SIL”) of 3 ppb (7.8 µg/m<sup>3</sup>) published in the “*General Guidance for Implementing the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard in Prevention of Significant Deterioration Permits, Including an Interim 1-hour SO<sub>2</sub> Significant Impact Level*” (U.S. EPA, August 23, 2010). Maximum predicted 1-hour SO<sub>2</sub> impacts across the three-year meteorological

database are summarized in **Table 5**. As shown in the table, the maximum of the three-year average of the maximum 1-hour SO<sub>2</sub> concentrations is 222.3 µg/m<sup>3</sup>, which is well above the SIL.

Cumulative modeling analyses, taking into account additional sources that could contribute to the area of significant impacts (i.e., receptor points where model-predicted impacts are greater than the SIL) generated by the facility are typically conducted for each receptor point contained within the significant impact area (“SIA”). The AQD has conducted an analysis of additional sources in the area around the Campbell Generating Complex and has determined that none of the sources is expected to have a significant impact within the Campbell Generating Complex SIA. Therefore, no additional sources were included in the area designation modeling.

In order to assess compliance with the 1-hour SO<sub>2</sub> NAAQS, the model calculates the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations across the three-year meteorological database. As part of a cumulative modeling analysis, this design concentration is subsequently combined with a representative background design concentration. If this combined impact is less than 75 ppb (196 µg/m<sup>3</sup>), then the area is designated as being in attainment with the 1-hour SO<sub>2</sub> NAAQS.

The AQD has provided a background design concentration of 10.3 ppb (27 µg/m<sup>3</sup>). This value represents the 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentration measured at the Grand Rapids ambient monitor for the period 2012-2014. As a conservative “first tier” approach, this background design concentration was combined with the modeled design concentration.

Adhering to the form of the standard, the 99<sup>th</sup> percentile of the annual distribution of daily maximum 1-hour average SO<sub>2</sub> concentrations across the three-year meteorological database was predicted by AERMOD at 112.0 µg/m<sup>3</sup>. Summing the model-predicted impact with the AQD-provided background concentration results in a combined impact of 139 µg/m<sup>3</sup>, which is well under the 1-hour SO<sub>2</sub> NAAQS of 196 µg/m<sup>3</sup> (75 ppb). Therefore, dispersion modeling analyses have demonstrated that the area surrounding the Campbell Generating Complex is in attainment with the 1-hour SO<sub>2</sub> NAAQS.


Consumers also notes that the AQD has installed a SO<sub>2</sub> ambient air quality monitoring station in West Olive, just north/northeast of the JH Campbell Plant. This station has been collecting data since January 24, 2015 and the highest observed 1-hour average SO<sub>2</sub> concentration as of July 13, 2014 has been 53 ppb (06/10/2015), or the equivalent of 138.5 µg/m<sup>3</sup>. Although limited SO<sub>2</sub> ambient data has been collected thus far and a maximum 1-

hour average concentration is not directly comparable to the form of the 1-hour SO<sub>2</sub> NAAQS, this limited monitoring data further supports the concept that the JH Campbell Plant is not causing or contributing to an exceedance of the 1-hour SO<sub>2</sub> NAAQS.

Modeled impacts are compared against the 1-hour SO<sub>2</sub> NAAQS in **Table 6**. The location of the 99<sup>th</sup> percentile daily 1-hour maximum concentration is shown in **Figure 7**. An electronic copy of all AERMOD and model preprocessor input/output files is submitted along with this technical report on DVD-ROM.

## ***FIGURES***

---



**Location of  
J.H. Campbell Generating Complex**

- Legend**
- J.H. Campbell Generating Complex
  - Interstate
  - Highway
  - Ramp
  - City Boundary

**Figure 1  
Location of  
J. H. Campbell Generating Complex  
West Olive, Michigan**

0 1,250 2,500 5,000 7,500 10,000 Meters

**HORIZON ENVIRONMENTAL**





Campbell Stack 3


Campbell Stack 1&2

Turbine Stack



**Figure 2**  
**3D View of Structures Considered in the Plume Downwash Analysis**  
**J. H. Campbell Generating Complex**  
West Olive, Michigan








Source: Esri, DigitalGlobe, GeoEye, Earthstar Geographics, CNES/Airbus DS, USDA, USGS, AEX, Getmapping, Aerogrid, IGN, IGP, swisstopo, and the GIS User Community

**Figure 3**  
**Fenceline and Nearby Receptors**  
**J. H. Campbell Generating Complex**


0 1.5 3 6 9 Kilometers








July 2015




**Figure 4**  
**Receptor Grid Used in the**  
**SO<sub>2</sub> Area Designation Analysis**  
**J. H. Campbell Generating Complex**





**Figure 5**  
**Nested Receptor Grid Used in the**  
**SO<sub>2</sub> Area Designation Analysis**  
**J. H. Campbell Generating Complex**



July 2015




WIND ROSE PLOT:

**Figure 6 - Three Year Composite Wind Rose  
Muskegon County Airport (2012-2014)**

DISPLAY:

**Wind Speed  
Direction (blowing from)**



COMMENTS:

DATA PERIOD:

**Start Date: 1/1/2012 - 00:00  
End Date: 12/31/2014 - 22:00**

COMPANY NAME:

**Horizon Environmental Corporation**

CALM WINDS:

**0.72%**

TOTAL COUNT:

**26236 hrs.**


AVG. WIND SPEED:

**8.54 Knots**

DATE:

**7/15/2015**

PROJECT NO.:



**Figure 7**  
**Location of the 99<sup>th</sup> Percentile**  
**Daily 1-Hour Maximum SO<sub>2</sub> Impact**  
**J. H. Campbell Generating Complex**



July 2015

**H**ORIZON ENVIRONMENTAL

## *TABLES*

---

**TABLE 1**  
**AUXILIARY BOILER MONTHLY FUEL USAGE AND EQUIVALENT HOURS OF OPERATION<sup>1</sup>**  
**CONSUMERS ENERGY COMPANY - J.H. CAMPBELL GENERATING COMPLEX**

| <b>Calendar Month</b> | <b>JHC1&amp;2 Aux Blr<br/>Fuel Usage<sup>2,3</sup><br/>(gallons)</b> | <b>JHC3 Aux Blrs<br/>Fuel Usage<br/>(gallons)</b> | <b>JHC1&amp;2 Aux Blr<br/>Equiv. Op<br/>Hrs/Month<sup>2,3</sup></b> | <b>JHC3 Aux Blrs<br/>Equiv. Op<br/>Hrs/Month</b> |
|-----------------------|--|---|---|--|
| 12-Jan                | 1,840  | 543   | 15  | 4  |
| 12-Feb                | 6,740  | 15,083  | 55  | 106  |
| 12-Mar                | 7,190  | 5,107   | 58  | 36   |
| 12-Apr                | 8,490  | 56,035  | 69  | 395  |
| 12-May                | 9,470  | 10,585  | 77  | 75   |
| 12-Jun                | 6,290  | 0   | 51  | 0  |
| 12-Jul                | 6,350  | 0   | 52  | 0  |
| 12-Aug                | 2,880  | 0   | 23  | 0  |
| 12-Sep                | 1,050  | 34  | 9   | 0  |
| 12-Oct                | 14,230   | 14  | 116   | 0  |
| 12-Nov                | 880  | 0   | 7   | 0  |
| 12-Dec                | 930  | 438   | 8   | 3  |
| 13-Jan                | 1,550  | 16,651  | 13  | 117  |
| 13-Feb                | 1,810  | 447   | 15  | 3  |
| 13-Mar                | 10,040   | 15,599  | 82  | 110  |
| 13-Apr                | 5,430  | 18,798  | 44  | 132  |
| 13-May                | 2,400  | 0   | 20  | 0  |
| 13-Jun                | 1,120  | 0   | 9   | 0  |
| 13-Jul                | 880  | 0   | 7   | 0  |
| 13-Aug                | 160  | 18  | 1   | 0  |
| 13-Sep                | 180  | 21  | 2   | 0  |
| 13-Oct                | 1,330  | 2   | 11  | 0  |
| 13-Nov                | 840  | 236   | 7   | 2  |
| 13-Dec                | 850  | 0   | 7   | 0  |
| 14-Jan                | 1,010  | 2   | 8   | 0  |
| 14-Feb                | 650  | 0   | 5   | 0  |
| 14-Mar                | 830  | 0   | 7   | 0  |
| 14-Apr                | 750  | 0   | 6   | 0  |
| 14-May                | 740  | 0   | 6   | 0  |
| 14-Jun                | 710  | 0   | 6   | 0  |
| 14-Jul                | 680  | 0   | 6   | 0  |
| 14-Aug                | 270  | 0   | 2   | 0  |
| 14-Sep                | 780  | 0   | 6   | 0  |
| 14-Oct                | 940  | 0   | 8   | 0  |
| 14-Nov                | 850  | 0   | 7   | 0  |
| 14-Dec                | 890  | 22,192  | 7   | 156  |

**Notes:**

1. Actual fuel usage was converted to equivalent hours of operation based on the heat input rating of the boiler and a typical heating value for No. 2 fuel oil (138,000 Btu/gallon).
2. Utilization of the JHC 1 and 2 Auxiliary Boilers dropped off substantially in 2013 as a flue gas conditioning system that relied upon steam from the boilers was decommissioned.
3. Permit to Install No. 18-15, issued April 23, 2015, limits the capacity of the JHC1 and 2 Auxiliary Boiler to no greater than 10% on an annual basis.

**TABLE 2  
SUMMARY OF SO<sub>2</sub> EMISSION LIMITS  
CONSUMERS ENERGY COMPANY - J.H. CAMPBELL GENERATING COMPLEX**

| Emission Unit ID        | Nominal Heat Input Rating (MMBtu/hr) | Primary Fuel   | Alternate Fuel | Maximum Allowable Emissions (lbs/MMBtu) |                  |                                 |                  | Potential to Emit (lbs/hr) |                             |
|-------------------------|--------------------------------------|----------------|----------------|---|------------------|---------------------------------|------------------|----------------------------|-----------------------------|
|                         |                                      |                |                | Historic Limit <sup>1</sup>             |                  | Consumers CD Limit <sup>2</sup> |                  | Based on Historic Limit    | Based on Consumers CD Limit |
|                         |                                      |                |                | Numerical Limit                         | Averaging Period | Numerical Limit                 | Averaging Period |                            |                             |
| EUBOILER1 (JHC1)        | 2,490                                | Coal           | Fuel Oil       | 1.67                                    | 31-day           | 0.350                           | 30-day rolling   | 4,158                      | 872                         |
| EUBOILER2 (JHC2)        | 3,560                                | Coal           | Fuel Oil       | 1.67                                    | 31-day           | 0.320                           | 365-day rolling  | 5,945                      | 1,139                       |
| EUBOILER3 (JHC3)        | 8,240                                | Coal           | Fuel Oil       | 1.20                                    | 3-hour           | 0.085                           | 30-day rolling   | 9,888                      | 700                         |
| EUCOMBTURB <sup>3</sup> | 233                                  | No. 2 Fuel Oil | -              | 1.67                                    | Instantaneous    | NA                              | NA               | 389                        | NA                          |
| <b>Total:</b>           |                                      |                |                |   |                  |                                 |                  | <b>20,381</b>              | <b>2,711</b>                |

**Notes:**

1. The historic SO<sub>2</sub> emission limits for JHC 1&2 are based upon Michigan Air Pollution Control Rule 336.1401, while the historic SO<sub>2</sub> limit for JHC3 is based upon 40 CFR Part 60, Subpart D.
2. The Consumers CD Limits are stipulated under Permit to Install No. 39-15 and mandated by a federal Consent Decree. If the Consent Decree contains more than one SO<sub>2</sub> emission limit for a given boiler, this table reflects the SO<sub>2</sub> emission limit with the shortest averaging period.
3. Though not reflected in the Renewable Operating Permit, Fuel usage in EUCOMBTURB is now limited to ultra low sulfur diesel (15 ppm sulfur content). Using the emission factor provided in Section 1.3 of AP-42, the hourly potential to emit from EUCOMBTURB is 0.353 lbs/hr.



**TABLE 3  
AUER LAND USE CLASSIFICATION SCHEME  
CONSUMERS ENERGY COMPANY**

| Type | Use                       | Description  |  |
|------|---------------------------|--|--|
|      |                           | Structures   | Vegetation   |
| I1   | Heavy Industrial          | Major chemical, steel and fabrication industries; generally 3-5 story buildings, flat roofs.   | Grass and tree growth extremely rare; <5% vegetation.              |
| I2   | Light-Moderate Industrial | Rail yards, truck depots, warehouses, industrial parks, minor fabrications; generally 1-3 story buildings, flat roofs.                                   | Very limited grass, trees almost total absent; <5% vegetation.     |
| C1   | Commercial                | Office and apartment buildings, hotels; >10 story heights, flat roofs.   | Limited grass and trees; <15% vegetation <15% vegetation.          |
| R1   | Common Residential        | Single family dwelling with normal easements; generally one story, pitched roof structures; frequent driveways.  | Abundant grass lawns and light-moderately wooded; >30% vegetation. |
| R2   | Compact Residential       | Single, some multiple, family dwelling with close spacing; generally <2 story, pitched roof structures; garages (via alley), no driveways.               | Limited lawn sizes and shade trees; <30% vegetation.               |
| R3   | Compact Residential       | Old multi-family dwellings with close (<2 m) lateral separation; generally 2 story, flat roof structures; garages (via alley) and ashpits, no driveways. | Limited lawn sizes, old established shade trees; <35% vegetation.  |
| R4   | Estate Residential        | Expansive family dwelling on multi-acre tracts.  | Abundant grass lawns and lightly wooded; >80% vegetation.          |
| A1   | Metropolitan Natural      | Major municipal, state, or federal parks, golf courses, cemeteries, campuses; occasional single story structures.  | Nearly total grass and lightly wooded; >95% vegetation.            |
| A2   | Agricultural Rural        |  | Local crops (e.g., corn, soybean); >95% vegetation.                |
| A3   | Undeveloped               | Uncultivated; wasteland.   | Mostly wild grasses and weeds, lightly wooded; >90% vegetation.    |
| A4   | Undeveloped Rural         |  | Heavily wooded; >95% vegetation.                                   |
| A5   | Water Surfaces            | Rivers, lakes.   |  |

**Notes:**

1. Land use typing scheme recommended by Auer for use in assessing the most applicable dispersion coefficient.

**TABLE 4  
STACK EXHAUST PARAMETERS  
CONSUMERS ENERGY COMPANY - J.H. CAMPBELL GENERATING COMPLEX**

| Source ID                     | Stack Coordinate <sup>1</sup><br>(UTM) |           | Stack Height <sup>2</sup> |       | Stack Diameter <sup>2</sup> |      | Exit Gas Temperature |       | Exhaust Flow Rate<br>(acfm) | Exit Velocity<br>(m/s) |
|-------------------------------|--|-----------|---------------------------|-------|-----------------------------|------|----------------------|-------|-----------------------------|------------------------|
|                               | Easting                                | Northing  | (ft)                      | (m)   | (in)                        | (m)  | (F)                  | (K)   |                             |                        |
| EUBOILER1 (JHC1) <sup>3</sup> | 565030.7                               | 4751165.3 | 400                       | 121.9 | 228                         | 5.79 | -                    | -     | -                           | -                      |
| EUBOILER2 (JHC2) <sup>3</sup> |  |           |                           |       |                             |      |                      |       |                             |                        |
| EUBOILER3 (JHC3) <sup>3</sup> | 565009.7                               | 4751360.8 | 642                       | 195.7 | 327                         | 8.31 | -                    | -     | -                           | -                      |
| EUCOMBTURB <sup>4</sup>       | 565283.1                               | 4751199.9 | 17                        | 5.2   | 162                         | 4.11 | 850                  | 727.6 | 460,000                     | 16.33                  |

**Notes:**

1. UTM Coordinates obtained using aerial imagery in NAD 83 format.
2. Stack height and diameter of each emission unit limited under the ROP, except for EUCOMBTURB, which was obtained from MAERS.
3. Stack temperature and exhaust flow data for JHC1, JHC2, and JHC3 vary by hour, as measured by continuous emissions monitoring systems.
4. Stack temperature and exhaust flow data for EUCOMBTURB obtained from MAERS.

**TABLE 5**  
**COMPARISON OF MODELED SO<sub>2</sub> CONCENTRATIONS TO THE 1-HOUR SIGNIFICANT IMPACT LEVEL**  
**CONSUMERS ENERGY COMPANY - J.H. CAMPBELL GENERATING COMPLEX**

| Averaging Period | Year  | Modeled Receptor Location UTM Coordinate (m) |          | 1 <sup>st</sup> Highest 1-Hour SO <sub>2</sub> Impact <sup>1</sup> (ug/m <sup>3</sup> ) | SIL <sup>2</sup> (ug/m <sup>3</sup> ) |
|------------------|---|--|----------|---|---------------------------------------|
|                  |   | Easting                                      | Northing |   |                                       |
| 1-Hour           | 2014  | 564970                                       | 4755068  | 424.9   | <b>7.9</b>                            |
|                  | 2013  | 564070                                       | 4750968  | 157.4   |                                       |
|                  | 2012  | 563970                                       | 4754068  | 209.5   |                                       |
|                  | <b>Maximum of the Three Year Average of the Maximum 1-Hour Concentrations (ug/m<sup>3</sup>):</b> |  |          | <b>223.2</b>  |                                       |

**Notes:**

1. Model simulations conducted using AERMOD over a three-year meteorological dataset (MKG Airport Surface/Green Bay Upper Air).
2. The Significant Impact Level (SIL) is an interim value published in the "*General Guidance for Implementing the 1-hour SO<sub>2</sub> National Ambient Air Quality Standard in Prevention of Significant Deterioration Permits, Including an Interim 1-hour SO<sub>2</sub> Significant Impact Level*" (U.S. EPA, August 23, 2010).

**TABLE 6  
COMPARISON OF MODELED SO<sub>2</sub> CONCENTRATIONS TO THE 1-HOUR NAAQS  
CONSUMERS ENERGY COMPANY - J.H. CAMPBELL GENERATING COMPLEX**

| Averaging Period  | Year | Modeled Receptor Location UTM Coordinate (m) |          | 4 <sup>th</sup> Highest Daily Max. 1-Hour SO <sub>2</sub> Impact <sup>1</sup> (ug/m <sup>3</sup> ) | Background Concentration <sup>2</sup> (ug/m <sup>3</sup> ) | Combined SO <sub>2</sub> Impact (ug/m <sup>3</sup> ) | NAAQS (ug/m <sup>3</sup> ) |
|---|------|--|----------|--|--|--|----------------------------|
|   |      | Easting                                      | Northing |  |  |  |                            |
| 1-Hour  |      |  |          |  |  |  |                            |
| <b>Maximum of the Three Year Average of the 4<sup>th</sup> Highest (99<sup>th</sup> Percentile) Daily 1-Hour Maximum Concentrations (ug/m<sup>3</sup>):</b> |      |  |          | <b>112.0</b>   | <b>27.0</b>  | <b>139.0</b>   | <b>196</b>                 |

**Notes:**

1. Model simulations conducted using AERMOD over a three-year meteorological dataset (MKG Airport Surface/Green Bay Upper Air).
2. A background concentration of 27 ug/m<sup>3</sup> (10.3 ppb) was provided by the MDEQ-AQD.

*ATTACHMENT A*

---

**CONTINUOUS EMISSIONS MONITORING DATA  
AND DISPERSION MODELING INPUT/OUTPUT FILES  
(DVD-ROM)**

*ATTACHMENT B*

---

**SUMMARY OF CEMS MISSING HOURLY SO<sub>2</sub> AND/OR FLOW DATA  
DURING THE 2012-2014 PERIOD (MODELED HOURLY VALUES BASED  
ON THE STANDARD 40 CFR PART 75, SUBPART D, MISSING DATA  
SUBSTITUTION PROCEDURES)**

# Missing Data Substitution Hours

Plant: J.H. CAMPBELL

Report Period: 01/01/2012 00:00 Through 12/31/2014 23:59

Source: CAMP12

Units: PPM

Parameter: SO2PPM

| Date       | Hour | Avg Value | MC | Load Range | PMA   | QA Hours |
|------------|------|-----------|----|------------|-------|----------|
| 06/03/2012 | 06   | 65.9      | 6  | 2          | 99.9  | 8747     |
| 06/03/2012 | 07   | 65.9      | 6  | 2          | 99.8  | 8746     |
| 09/25/2012 | 11   | 152.8     | 6  | 8          | 99.9  | 8748     |
| 01/30/2013 | 14   | 236.5     | 6  | 7          | 100.0 | 8756     |
| 02/11/2013 | 09   | 192.8     | 6  | 7          | 99.9  | 8755     |
| 03/15/2013 | 06   | 173.9     | 6  | 3          | 99.9  | 8754     |
| 03/15/2013 | 07   | 173.9     | 6  | 3          | 99.9  | 8753     |
| 03/15/2013 | 08   | 173.9     | 6  | 3          | 99.9  | 8752     |
| 10/18/2013 | 11   | 172.5     | 6  | 7          | 99.9  | 8754     |
| 10/18/2013 | 12   | 172.5     | 6  | 7          | 99.9  | 8753     |
| 03/05/2014 | 12   | 224.7     | 6  | 9          | 99.9  | 8754     |
| 03/05/2014 | 13   | 224.7     | 6  | 9          | 99.9  | 8753     |
| 03/05/2014 | 14   | 224.7     | 6  | 9          | 99.9  | 8752     |
| 03/05/2014 | 15   | 224.7     | 6  | 9          | 99.9  | 8751     |
| 03/05/2014 | 16   | 224.7     | 6  | 9          | 99.9  | 8750     |
| 03/05/2014 | 17   | 224.7     | 6  | 9          | 99.9  | 8749     |
| 03/05/2014 | 18   | 224.7     | 6  | 9          | 99.9  | 8748     |
| 03/05/2014 | 19   | 224.7     | 6  | 8          | 99.9  | 8747     |
| 03/05/2014 | 20   | 224.7     | 6  | 8          | 99.8  | 8746     |
| 03/05/2014 | 21   | 224.7     | 6  | 8          | 99.8  | 8745     |
| 03/05/2014 | 22   | 224.7     | 6  | 6          | 99.8  | 8744     |
| 03/05/2014 | 23   | 224.7     | 6  | 4          | 99.8  | 8743     |
| 03/06/2014 | 00   | 224.7     | 6  | 4          | 99.8  | 8742     |
| 03/06/2014 | 01   | 224.7     | 6  | 4          | 99.8  | 8741     |
| 03/06/2014 | 02   | 224.7     | 6  | 5          | 99.8  | 8740     |
| 03/06/2014 | 03   | 224.7     | 6  | 5          | 99.8  | 8739     |
| 03/06/2014 | 04   | 224.7     | 6  | 4          | 99.7  | 8738     |
| 03/06/2014 | 05   | 224.7     | 6  | 4          | 99.7  | 8737     |
| 03/06/2014 | 06   | 224.7     | 6  | 7          | 99.7  | 8736     |
| 05/19/2014 | 10   | 162.8     | 6  | 8          | 99.7  | 8738     |
| 12/11/2014 | 12   | 299.2     | 6  | 9          | 99.8  | 8739     |
| 12/11/2014 | 13   | 299.2     | 6  | 9          | 99.7  | 8738     |

**Number of Missing Hours for CAMP12 SO2PPM: 32**

**Total Number of Missing Hours for CAMP12: 32**

**Grand Total Number of Missing Hours: 32**

# Missing Data Substitution Hours

Plant: J.H. CAMPBELL

Report Period: 01/01/2012 00:00 Through 12/31/2014 23:59

**Source:** CAMP3A

**Units:** SCFH

**Parameter:** FLOWA

| Date       | Hour | Avg Value | MC | Load Range | PMA   | QA Hours |
|------------|------|-----------|----|------------|-------|----------|
| 06/21/2012 | 04   | 59127000  | 11 | 10         | 100.0 | 8759     |
| 06/21/2012 | 05   | 59127000  | 11 | 10         | 100.0 | 8758     |
| 06/21/2012 | 08   | 59121000  | 11 | 10         | 100.0 | 8757     |
| 06/21/2012 | 09   | 59121000  | 11 | 10         | 100.0 | 8756     |
| 07/17/2013 | 17   | 60262000  | 11 | 10         | 99.9  | 8755     |
| 07/17/2013 | 18   | 60262000  | 11 | 10         | 99.9  | 8754     |
| 07/17/2013 | 19   | 60262000  | 11 | 10         | 99.9  | 8753     |
| 07/17/2013 | 20   | 60262000  | 11 | 10         | 99.9  | 8752     |
| 07/17/2013 | 21   | 60262000  | 11 | 10         | 99.9  | 8751     |
| 07/17/2013 | 22   | 60262000  | 11 | 10         | 99.9  | 8750     |
| 07/17/2013 | 23   | 60262000  | 11 | 10         | 99.9  | 8749     |
| 07/18/2013 | 00   | 60262000  | 11 | 10         | 99.9  | 8748     |
| 05/19/2014 | 17   | 45256000  | 11 | 7          | 99.9  | 8751     |
| 05/19/2014 | 18   | 47531000  | 11 | 8          | 99.9  | 8750     |

**Number of Missing Hours for CAMP3A FLOWA: 14**

**Source:** CAMP3A

**Units:** PPM

**Parameter:** SO2A

| Date       | Hour | Avg Value | MC | Load Range | PMA   | QA Hours |
|------------|------|-----------|----|------------|-------|----------|
| 09/17/2012 | 09   | 282.6     | 6  | 0          | 100.0 | 8758     |
| 05/01/2013 | 09   | 205.5     | 6  | 0          | 100.0 | 8758     |
| 05/01/2013 | 10   | 205.5     | 6  | 0          | 100.0 | 8757     |
| 12/18/2013 | 09   | 171.2     | 6  | 0          | 100.0 | 8757     |
| 03/07/2014 | 13   | 193.8     | 6  | 0          | 100.0 | 8756     |
| 03/07/2014 | 14   | 193.8     | 6  | 0          | 99.9  | 8755     |
| 03/07/2014 | 15   | 193.8     | 6  | 0          | 99.9  | 8754     |
| 03/07/2014 | 16   | 193.8     | 6  | 0          | 99.9  | 8753     |
| 03/07/2014 | 17   | 193.8     | 6  | 0          | 99.9  | 8752     |
| 03/07/2014 | 18   | 193.8     | 6  | 0          | 99.9  | 8751     |
| 03/07/2014 | 19   | 193.8     | 6  | 0          | 99.9  | 8750     |
| 03/07/2014 | 20   | 193.8     | 6  | 0          | 99.9  | 8749     |
| 03/07/2014 | 21   | 193.8     | 6  | 0          | 99.9  | 8748     |
| 03/07/2014 | 22   | 193.8     | 6  | 0          | 99.9  | 8747     |
| 03/07/2014 | 23   | 193.8     | 6  | 0          | 99.8  | 8746     |
| 03/08/2014 | 00   | 193.8     | 6  | 0          | 99.8  | 8745     |
| 03/08/2014 | 01   | 193.8     | 6  | 0          | 99.8  | 8744     |
| 03/08/2014 | 02   | 193.8     | 6  | 0          | 99.8  | 8743     |
| 03/08/2014 | 03   | 193.8     | 6  | 0          | 99.8  | 8742     |
| 03/08/2014 | 04   | 193.8     | 6  | 0          | 99.8  | 8741     |
| 03/08/2014 | 05   | 193.8     | 6  | 0          | 99.8  | 8740     |
| 03/08/2014 | 06   | 193.8     | 6  | 0          | 99.8  | 8739     |
| 03/08/2014 | 07   | 193.8     | 6  | 0          | 99.7  | 8738     |
| 03/08/2014 | 08   | 193.8     | 6  | 0          | 99.7  | 8737     |



# Missing Data Substitution Hours

Plant: J.H. CAMPBELL

Report Period: 01/01/2012 00:00 Through 12/31/2014 23:59

Source: CAMP3A

Units: PPM

Parameter: SO2A

| Date       | Hour | Avg Value | MC | Load Range | PMA  | QA Hours |
|------------|------|-----------|----|------------|------|----------|
| 03/08/2014 | 09   | 193.8     | 6  | 0          | 99.7 | 8736     |
| 03/08/2014 | 10   | 193.8     | 6  | 0          | 99.7 | 8735     |
| 03/08/2014 | 11   | 193.8     | 6  | 0          | 99.7 | 8734     |
| 12/03/2014 | 09   | 156.3     | 6  | 0          | 99.7 | 8735     |
| 12/03/2014 | 10   | 156.3     | 6  | 0          | 99.7 | 8734     |
| 12/03/2014 | 11   | 156.3     | 6  | 0          | 99.7 | 8733     |
| 12/03/2014 | 12   | 156.3     | 6  | 0          | 99.7 | 8732     |
| 12/03/2014 | 13   | 156.3     | 6  | 0          | 99.7 | 8731     |
| 12/03/2014 | 14   | 156.3     | 6  | 0          | 99.7 | 8730     |
| 12/03/2014 | 15   | 156.3     | 6  | 0          | 99.6 | 8729     |
| 12/03/2014 | 16   | 156.3     | 6  | 0          | 99.6 | 8728     |
| 12/03/2014 | 17   | 156.3     | 6  | 0          | 99.6 | 8727     |
| 12/03/2014 | 18   | 156.3     | 6  | 0          | 99.6 | 8726     |
| 12/03/2014 | 19   | 156.3     | 6  | 0          | 99.6 | 8725     |
| 12/03/2014 | 20   | 156.3     | 6  | 0          | 99.6 | 8724     |
| 12/03/2014 | 21   | 156.3     | 6  | 0          | 99.6 | 8723     |
| 12/03/2014 | 22   | 156.3     | 6  | 0          | 99.6 | 8722     |
| 12/03/2014 | 23   | 156.3     | 6  | 0          | 99.6 | 8721     |

Number of Missing Hours for CAMP3A SO2A: 42

Total Number of Missing Hours for CAMP3A: 56

Source: CAMP3B

Units: PPM

Parameter: SO2B

| Date       | Hour | Avg Value | MC | Load Range | PMA   | QA Hours |
|------------|------|-----------|----|------------|-------|----------|
| 05/01/2012 | 04   | 9.7       | 6  | 0          | 100.0 | 8759     |
| 09/09/2013 | 08   | 274.5     | 6  | 0          | 100.0 | 8759     |
| 12/18/2013 | 11   | 185.6     | 6  | 0          | 100.0 | 8758     |

Number of Missing Hours for CAMP3B SO2B: 3

Total Number of Missing Hours for CAMP3B: 3

Grand Total Number of Missing Hours: 59

This page left intentionally blank.

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Belle River & St. Clair Power Plants  
East China Township, Michigan  
Dispersion Modeling Protocol  
July 10, 2015

Introduction

The United States Environmental Protection Agency (EPA) promulgated a revised primary sulfur dioxide (SO<sub>2</sub>) national ambient air quality standard (NAAQS) in June 2010. The averaging time for this new NAAQS is 1 hour, which is much shorter than the previous primary NAAQS averaging period, 24 hours. The new NAAQS is the 99<sup>th</sup> percentile maximum daily 1-hour average, averaged over the most recent three years of monitoring data. The level of the new SO<sub>2</sub> NAAQS (75 ppb) is much lower than the previous 24-hour SO<sub>2</sub> NAAQS (140 ppb). EPA is requiring states to determine whether areas within their borders meet or exceed this new NAAQS to provide designation recommendations to EPA.

Initially, EPA recommended that states use dispersion modeling for identifying locations where this NAAQS is not met. However, there was an outcry to this proposal from many state air quality agencies and other affected parties. EPA decided to proceed designating new nonattainment areas where at least one SO<sub>2</sub> monitoring site violates this NAAQS with the last 3 years of monitoring data. Michigan has been working with source operators that contribute to this monitored violation in Wayne County, and will soon submit their state implementation plan (SIP) for EPA to review. However, EPA decided to delay designations for other portions of the country.

In response to a lawsuit that was brought against EPA by the Sierra Club, and others, to force EPA to designate other areas on an expedited schedule, the parties settled and additional NAAQS designations are being undertaken. The judge issued the settlement order finalizing the agreed upon details on March 2, 2015. The next phase where SO<sub>2</sub> NAAQS designations must be finalized by July 2016 includes areas around 68 large SO<sub>2</sub> sources listed in the settlement agreement between the parties. **This dispersion modeling protocol describes the methodology that will be used to determine whether this revised NAAQS is met in St. Clair County, Michigan, where DTE Energy's Belle River and St. Clair Power Plants are located. Both of these plants are listed in the table of sources meeting the criteria of large SO<sub>2</sub> source in the settlement document.**

Facility Description

Belle River and St. Clair power plants are located in St. Clair County, along the St. Clair River about three miles north of Marine City in East China Township (Part of Belle River Power Plant is actually located in China Township). Belle River Power Plant (BRPP) is directly west of St. Clair Power Plant (SCPP) which is along the west shore of the St. Clair River which forms the international border between Michigan and Ontario.

BRPP is a coal-fired power plant with two coal-fired units, five diesel generators and three combustion turbine generators. The two main units (each rated at 697 MW gross) at this plant burn low-sulfur western (sub-bituminous) coal, with distillate oil as an ignition fuel. Both Unit 1 and Unit 2 are, equipped with large electrostatic precipitators (ESPs), plus each boiler has been retrofitted with low-NO<sub>x</sub> burners and over-fired air (OFA) to reduce NO<sub>x</sub> emissions. This facility meets its SO<sub>2</sub> air permit limit (1.2 lbs/MMBtu) by firing sub-bituminous coal with an emission rate well below its emission limit.

Also, BRPP has five (2.75 MW) diesel generators located southeast of the main power buildings, next to areas used for coal storage; close to the middle of the power plant site. Figure 1 illustrates the location of these structures at BRPP, with the main power block and coal handling enclosed conveyors in the background.

There are three large (82.4 MW each) combustion turbine generators (CTGs) at BRPP. These units were installed in 1999. They, exclusively, fire pipeline quality natural gas. In addition, four identical CTGs are located east of the BRPP main units. These generators are owned and operated by DTE Energy Services (DTE East China CTGs). Figure 2 is a recent aerial photograph of the BRPP site with labels showing the location of these point sources.

SCPP has seven coal-fired units, one natural gas-fired CTG (CTG 11-1) and two 2.75MW diesel generators (DG 12-1 & 12-2). Units 1 through 4 were built in the early 1950s. Each one of these units was originally designed to produce, approximately, 164 MW of power using bituminous coal. The current nominal rating for each of these units is 150 MW. Units 1 to 4, originally, had their own separate 250-foot tall stack. Air quality monitoring sites near SCPP measured very high SO<sub>2</sub> levels in the early 1970s. Therefore, new ESPs were installed, and a much taller stack was built to eliminate the previous building downwash problem. Wind tunnel studies indicated that the replacement stack needed to be just under 600-feet tall to eliminate the building downwash situation at this power plant. The replacement stack contains the gas flow from each of these four units in its own separate inner stack. A key aspect of the BRPP air permit that was finalized in 1978 was changing the type of coal used at SCPP. Rather than, exclusively, using bituminous coal, all operating units at SCPP were required to burn a blend of sub-bituminous and bituminous coals to meet the statewide 1 percent sulfur-in-fuel limit (1.67 lbs SO<sub>2</sub>/MMBtu).

SCPP Unit 5 is a cyclone boiler that came on-line in 1957. It has been in extended cold standby mode since 1980. It will not be modeled in this impact assessment. SCPP Unit 6 is a coal-fired unit, rated at 350 MW. It began operation in 1959. This unit was designed to operate using bituminous coal, but currently uses a blend of sub-bituminous and bituminous coals. It has large electrostatic precipitators (ESPs) and has been retrofitted with low-NO<sub>x</sub> burners and OFA to reduce NO<sub>x</sub> emissions. SCPP Unit 6 has a 425-foot tall stack which is below its GEP formula height. Therefore, it is affected by building downwash from the SCPP main unit structures. SCPP Unit 7 is the newest of the main units at this power plant. It began operating in 1967. This unit was also designed to operate on bituminous coal, but currently uses a blend of sub-bituminous and bituminous coals. It has electrostatic precipitators (ESPs) for particulate matter control, and has been retrofitted with low-NO<sub>x</sub> burners and OFA to reduce NO<sub>x</sub> emissions. This unit's stack is 600 feet above grade. The SCPP site is illustrated in Figure 3.

Table 1-A lists the actual SO<sub>2</sub> emissions from point sources at both of these large power plants from the last three operating years (2012-2014). It clearly shows that nearly all of the SO<sub>2</sub> is emitted by the eight operating coal-fired units at these facilities for the three years which will be analyzed to project actual SO<sub>2</sub> concentrations around the site.

**Table 1-A**

| <b>Actual Belle River &amp; St. Clair PP SO<sub>2</sub> Emissions (2012-2014)</b> |               |               |               |
|---|---------------|---------------|---------------|
|   | <b>2012</b>   | <b>2013</b>   | <b>2014</b>   |
|   | <b>(tons)</b> | <b>(tons)</b> | <b>(tons)</b> |
| <b>Belle River PP</b>   |               |               |               |
| Unit 1  | 13,127        | 10,752        | 11,691        |
| Unit 2  | 11,741        | 14,034        | 12,775        |
| Auxiliary Boiler Stack  | 0.05          | 0.04          | 0.00          |
| Diesel Gen No. 11-1   | 0.01          | 0.00          | 0.00          |
| Diesel Gen No. 11-2   | 0.01          | 0.00          | 0.00          |
| Diesel Gen No. 11-3   | 0.02          | 0.00          | 0.00          |
| Diesel Gen No. 11-4   | 0.02          | 0.00          | 0.00          |
| Diesel Gen No. 11-5   | 0.02          | 0.00          | 0.00          |
| CTG No. 12-1  | 0.19          | 0.27          | 0.21          |
| CTG No. 12-2  | 0.16          | 0.32          | 0.25          |
| CTG No. 13-1  | 0.13          | 0.40          | 0.28          |
| East China CTG No. 1  | 0.11          | 0.07          | 0.01          |
| East China CTG No. 2  | 0.11          | 0.08          | 0.01          |
| East China CTG No. 3  | 0.11          | 0.07          | 0.01          |
| East China CTG No. 4  | 0.11          | 0.04          | 0.01          |
| <b>St. Clair PP</b>   |               |               |               |
| Unit 1  | 2,750         | 2,336         | 2,493         |
| Unit 2  | 2,848         | 2,329         | 2,627         |
| Unit 3  | 2,917         | 2,580         | 2,518         |
| Unit 4  | 3,219         | 2,746         | 2,600         |
| Unit 5  | 0             | 0             | 0             |
| Unit 6  | 5,487         | 9,477         | 7,970         |
| Unit 7  | 10,988        | 10,643        | 9,245         |
| CTG No. 11-1  | 0.00          | 0.00          | 0.01          |
| Diesel Gen No. 12-1   | 0.01          | 0.00          | 0.00          |
| Diesel Gen No. 12-2   | 0.01          | 0.00          | 0.00          |
| <b>BR/SC Main Units</b>   | <b>53,077</b> | <b>54,897</b> | <b>51,920</b> |
| <b>BR/SC Other Sources</b>  | <b>1.04</b>   | <b>1.26</b>   | <b>0.77</b>   |
| <b>Site Total</b>   | <b>53,078</b> | <b>54,898</b> | <b>51,920</b> |

The following table identifies which SO<sub>2</sub> sources will be included in the impact modeling, and those that will be excluded and the reason(s) for this decision.

**Table 1-B**  
**Basis for Including or Excluding SO<sub>2</sub> Source from Impact Assessment**

| <b>Power Plant</b> | <b>SO<sub>2</sub> Source(s)</b>   | <b>Include / Exclude</b> | <b>Reason(s)</b>                                       |
|--------------------|-----------------------------------|--------------------------|--|
| <b>Belle River</b> | <b>Unit Nos. 1-2</b>              | <b>Include</b>           | <b>Main units with high SO<sub>2</sub> emissions</b>   |
| <b>Belle River</b> | <b>Aux. Blrs (N&amp;S)</b>        | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm S oil</b>              |
| <b>Belle River</b> | <b>DG Nos. 11-(1-5)</b>           | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm S oil</b>              |
| <b>Belle River</b> | <b>CTG Nos. 12-(1-2)&amp;13-1</b> | <b>Exclude</b>           | <b>Pipeline natural gas, Low annual SO<sub>2</sub></b> |
| <b>East China</b>  | <b>CTG Nos. 1-4</b>               | <b>Exclude</b>           | <b>Pipeline natural gas, Low annual SO<sub>2</sub></b> |
| <b>St. Clair</b>   | <b>Unit Nos. 1-4 &amp; 6-7</b>    | <b>Include</b>           | <b>Main units with high SO<sub>2</sub> emissions</b>   |
| <b>St. Clair</b>   | <b>CTG No. 11-1</b>               | <b>Exclude</b>           | <b>Pipeline natural gas, Low annual SO<sub>2</sub></b> |
| <b>St. Clair</b>   | <b>DG Nos. 12-(1-2)</b>           | <b>Exclude</b>           | <b>Infrequent operation, 15 ppm S oil</b>              |

The secured property line for this modeling study is assumed to be the actual property line of the BRPP / SCPP complex. There are a number of non-DTE Energy areas that are adjacent to and run through the site. State Highway, M-29 (River Road), separates SCPP from BRPP. Also, pieces of the BRPP property are owned by non-DTE Energy owners. Along the southern edge of BRPP, there is a sewage treatment facility. There is a small business on the south side of Puttygut Road, along the northern fringe of the BRPP site. The biggest area owned by outsiders is at the intersection of M-29 and Puttygut Road, where a medical complex is located. Also, a railroad runs through the BRPP property. However, no receptors will be placed along this right-of-way, due to the infrequent usage of this railroad link for outside rail traffic.

The SCPP site has a 6-foot high cyclone fence around all property lines, except for the riverfront, where coal is offloaded. The main power buildings at BRPP are surrounded by a 6-foot high cyclone fence as well as the material handling areas. However, the portion of the site east of King Road, and south of Puttygut Road do not have security fence lines. These sections of BRPP's property have a number of "No trespassing" signs, approximately, every 200 yards, to address unauthorized access. For this modeling study, I assume that these provide adequate site protection. Receptors are placed along and outside of these respective property lines. The primary AERMOD run will only include off-site receptors. However, a separate model run will include receptors along the western and northern edges of BRPP's property, outside of the fence line around the main units and nearby supporting structures to verify that peak predicted SO<sub>2</sub> impacts are outside of the property line.


DTE Energy staff will make the 1-hour SO<sub>2</sub> AERMOD runs to simulate what peak 1-hour average concentrations would have been measured had one or more monitoring sites been actively measuring the air quality near these power plants. Our best estimate of the date for the modeling to be completed is by July 17, which is about three weeks after the draft schedule submittal date (June 26). There are a couple of very important concerns (i.e., appropriate background SO<sub>2</sub> concentrations and Canadian SO<sub>2</sub> source impacts) that will make it much more difficult to avoid double-counting impacts. This may require additional time to accurately assess the current air quality around these DTE Energy power plants.

**DTE Energy remains concerned that the dispersion modeling methodology overestimates actual SO<sub>2</sub> concentrations, especially regarding use of a 99<sup>th</sup> percentile background concentration for all modeled hours and surface meteorological data from Oakland County International Airport, in Waterford. DTE Energy may request to locate SO<sub>2</sub> and meteorological monitors at appropriately sited locations to provide straightforward data regarding the attainment status of this area for the 1-hour SO<sub>2</sub> NAAQS. We realize that allowing this option would delay St. Clair County's designation, but we feel that a number of background and Canadian source complications make the modeling option biased high. This could result in designating this area nonattainment when actual air quality meets the NAAQS, and force the State to develop a SIP when measured SO<sub>2</sub> levels are below the NAAQS.**

#### Model Selection

AERSCREEN will **not** be run to predict maximum ground-level 1-hour average SO<sub>2</sub> impacts for each key source at BRPP and SCPP. It is a foregone conclusion that the maximum predicted impacts from nearly all relevant SO<sub>2</sub> sources will be above the 1-hour SO<sub>2</sub> significant impact level (SIL). Therefore, this step is less critical than the refined model analysis that will use the most recent version of AERMOD.

The version of AERMOD and its support files is shown in the following picture:



Point source and building tables are provided to identify which structures are nearby from a building downwash perspective and list allowable SO<sub>2</sub> emission rates for the relevant power plant sources. Table 2 identifies the key structures at these two power plants, and lists which buildings are nearby each relevant SO<sub>2</sub> source. Data are included for the SO<sub>2</sub> sources included in the impact assessment as well as the auxiliary boiler at BRPP and the diesel generators at SCPP.

### Emissions Characterization

DTE Energy will model SO<sub>2</sub> impacts from BRPP and SCPP using **actual** emission data. Hourly SO<sub>2</sub> data from our CEMS will be formatted for use in AERMOD for all eight coal-fired units modeled. Monitored hourly stack exit temperature and exit velocity data for these units will also be utilized in the modeling analysis to predict source impacts from these units. Emission data from 2012 through 2014 will be utilized to mesh with the most recent 3-year meteorological data set.

### Source Description

The detailed plant description is provided in the Introduction Section of this modeling protocol, including the justification for including only the main units from both of these DTE Energy power plants. Table 3 and Table 4 list the UTM coordinates for the large SO<sub>2</sub> sources that will be modeled as well as the structure data (height, tiers, corners or tank center/diameter details). The latest version of BPIP (Version dated 04274) will be used to develop building height and width values for each 10-degree wind direction category used in AERMOD.



The area surrounding these power plants is predominantly rural with: large residential properties, a city park, Belle River flood plain and the St. Clair River dominating the area around these facilities. There are a few industrial facilities on the Michigan side and also across the St. Clair River, in Canada, but the site is considered rural in the upcoming dispersion modeling runs.

### Background Concentration

Identifying a representative background SO<sub>2</sub> concentration for this site is a very difficult task. The closest SO<sub>2</sub> monitor is located in Port Huron, approximately, 13 miles north of these two power plants. BRPP is directly upwind of this monitor with wind directions of 191 degrees. SCPP's main units are upwind of it with a wind direction from 185 degrees. This monitor just completed obtaining three full years of SO<sub>2</sub> data at the end of 2014, with a design concentration of 69 ppb. The highest 1-hour SO<sub>2</sub> concentrations have usually been measured with winds from the south, where BRPP, SCPP and a Canadian refinery on the south side of Sarnia are upwind of this monitor.

The other Michigan SO<sub>2</sub> sources that will be included in the AERMOD runs are: Cargill Salt (in St. Clair south of the monitor) and E.B. Eddy Paper (north of the monitor). The, tentative, procedure to calculate a background concentration would be to eliminate any high SO<sub>2</sub> values when a modeled source is upwind of the monitor, and use the 99th percentile SO<sub>2</sub> value based on the rest of the 2012-2014 data set. However, this would result in an extremely high background value of 64 ppb. These "other" high SO<sub>2</sub> observations occur when the wind direction at the Port Huron monitor is measuring winds from the east-southeast (105°). There is a second refinery on the south side of Sarnia that is upwind of the monitor with this wind direction. Somehow, the impact of these Canadian sources needs to be quantified, but at their real location, 12 miles north of the DTE Energy operating power plants, and **not** directly across the St. Clair River! Figures 4A through 4D illustrate the MDEQ's Port Huron monitoring site and the Canadian refinery sources' locations with respect to this monitor.

DTE Energy proposes to use the following technique to appropriately estimate the impact of the modeled and SO<sub>2</sub> sources not modeled:


- Calculate the 99th percentile SO<sub>2</sub> concentration at the Port Huron monitor using data only when winds are **not** impacted by any of the Michigan and Ontario sources identified, above. This would use 2012-2014 data when winds are, generally, from the west at the Port Huron monitor. MDEQ staff informed me that a value of 15 ppb was calculated using the SO<sub>2</sub> data only when winds are coming from the west.

### Meteorology

The most representative, readily available, meteorological data set for this 1-hour SO<sub>2</sub> NAAQS designation analysis is the 2012-2014 data set, with surface data from the St. Clair County International Airport (Port Huron). However, EPA Region V staff are concerned that there are too many hours with calm winds, approximately 25 percent of the hours. Therefore, MDEQ has proposed to incorporate surface data from Oakland County International Airport (Pontiac) that has 1-minute wind data, and calm winds less than 2 percent of the time. Upper air data from White Lake Township will be used in this impact assessment.

However, DTE Energy staff remains concerned that Oakland County International Airport is too far away from the BRPP/SCPP site to be representative. Not only is Oakland County International Airport farther away from the power plants than St. Clair International Airport (77 kilometers versus 15kilometers),it is too far west to account for the influence that Lake St. Clair and Lake Huron have on the flow patterns around the power plant site. This is especially an issue when synoptic scale winds are light, and mesoscale effects from these large lakes influence the wind speed and direction near their shorelines. These conditions are, generally, when the highest impacts are predicted from sources with tall stacks, which applies to all of the units at BRPP and SCPP. The following graphic shows the two possible meteorological data sites with the BRPP/SCPP site indicated by a triangle. We believe that air quality monitoring data near the site is the most appropriate methodology for designating these areas close to large SO<sub>2</sub> sources, rather than relying on modeling using weather data from a site that may not adequately represent the meteorology at the plant site.

## Location of BRPP/SCPP Site and Two NWS Meteorological Data Sites



### Modeling Domain

The receptor grid modeled will follow MDEQ guidance for receptors around a large point source. The receptor grid includes:

- Property line receptor grid with 50-meter receptor separation
- Rectangular grid with 50-meter receptor separation out to 500 meters beyond the property line
- Rectangular grid with 100-meter receptor separation out to 4 kilometers beyond the property line
- Rectangular grid with 250-meter receptor separation out to 10 kilometers beyond the property line

Note, that receptors over the following areas will not be included in the impact analysis:

- DTE Energy BRPP / SCPP property
- Canadian waters and land
- US waters (i.e., St. Clair River & Belle River)
- Landfills (Range Road north of BRPP)
- On roadways (i.e., M-29 & other local roads)
- On modeled SO<sub>2</sub> source secured property

Receptor elevation data will be used in the analysis. A separate AERMOD run will be performed to identify whether receptors outside of the fenced in part of the BRPP site would be expected to measure peak 1-hour SO<sub>2</sub> impacts higher than those predicted off-site.

## Off-Site Emission Inventory

The MDEQ has identified two additional SO<sub>2</sub> sources that should be modeled. They are Cargill Salt in St. Clair and E.B. Eddy Paper in Port Huron. These two sources will be included in the AERMOD impact assessment using their actual emission rate (provided by MDEQ).

Also, the Lambton Generating Station is located across the St. Clair River from BRPP and SCPP, in Ontario. However, this large coal-fired generating station burned coal for the last time in 2013. It did have wet flue gas desulfurization operational on its coal-fired units, prior to eliminating coal from its fuel mix. The following citation from the Ontario Power Generation (OPG) web site summarizes their reduction in coal use at their large thermal generating stations:

“Lambton GS and Nanticoke GS stopped using coal as fuel in 2013. These stations served Ontario for more than 40 years, providing reliable electricity when it was needed most. Two units at Lambton and four units at Nanticoke are being preserved so that they are available in future to be converted to alternate fuels if required.”

Therefore, Lambton Generating Station likely had some impact at the Port Huron monitor, especially in 2012, but it will not contribute any amount in the foreseeable future. **This adds further support for possibly installing new, properly sited, SO<sub>2</sub> monitors to determine the current air quality; rather than relying on Port Huron monitoring data that had impacts from a large, and now retired SO<sub>2</sub> source.**

Table 2

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Belle River & St. Clair Power Plants

| Belle River Power Plant - Buildings That May Cause Main Unit / Aux Boiler Stack Downwash |          |                             |                      |                       |                 |                    |                     |      |  |  |             |
|--|----------|-----------------------------|----------------------|-----------------------|-----------------|--------------------|---------------------|------|--|--|-------------|
| Belle River<br>Power Plant<br>Structure  | Unit No. | Important Structure Data    |                      |                       |                 |                    |                     |      | Structure<br>Influential<br>Distance<br>(feet) | Stacks<br>Within<br>Structure<br>Wake Zone |             |
|  |          | Base<br>Elevation<br>(feet) | Height<br>(feet)     | Length<br>(feet)      | Width<br>(feet) | Diameter<br>(feet) | Minimum Distance to |      |  |  |             |
|  |          | Unit 1 Stk<br>(feet)        | Unit 2 Stk<br>(feet) | Aux Blr Stk<br>(feet) |                 |                    |                     |      |  |  |             |
| Boiler House   | 1        | 591.5                       | 262.5                | 193.3                 | 176             | NA                 | 360                 | 425  | 87   | 880  | U1, U2, Aux |
| Combustion Air Duct Roof   | 1        | 591.5                       | 241.2                | 107                   | 46              | NA                 | 312                 | 412  | 132  | 535  | U1, U2, Aux |
| Coal Conveyor Gallery Roof (N)   | 1        | 591.5                       | 236.5                | 43                    | 27              | NA                 | 346                 | 406  | 104  | 270  | Aux         |
| Coal Conveyor Gallery Roof (NW)  | 1        | 591.5                       | 236.5                | 43                    | 27              | NA                 | 346                 | 394  | 57   | 270  | Aux         |
| Coal Conveyor Gallery Roof (NE)  | 1        | 591.5                       | 210.3                | 46                    | 31.8            | NA                 | 351                 | 539  | 251  | 159  | None        |
| Coal Conveyor Gallery Roof (E)   | 1        | 591.5                       | 193.5                | 155.2                 | 31.8            | NA                 | 384                 | 560  | 250  | 159  | None        |
| Coal Conveyor Gallery Roof (W)   | 1        | 591.5                       | 193.5                | 155.2                 | 32              | NA                 | 409                 | 416  | 57   | 160  | Aux         |
| Coal Conv Gallery Roof (N Edge)  | 1        | 591.5                       | 174                  | 43                    | 46              | NA                 | 321                 | 500  | 208  | 215  | Aux         |
| Boiler House   | 2        | 591.5                       | 262.5                | 193.3                 | 176             | NA                 | 440                 | 360  | 43   | 880  | U1, U2, Aux |
| Combustion Air Duct Roof   | 2        | 591.5                       | 255                  | 107                   | 46              | NA                 | 410                 | 315  | 96   | 535  | U1, U2, Aux |
| Coal Conveyor Gallery Roof (N)   | 2        | 591.5                       | 236.5                | 43                    | 27              | NA                 | 356                 | 340  | 53   | 285  | Aux         |
| Coal Conveyor Gallery Roof (NE)  | 2        | 591.5                       | 236.5                | 63                    | 30              | NA                 | 365                 | 346  | 14   | 285  | Aux         |
| Coal Conveyor Gallery Roof (NW)  | 2        | 591.5                       | 193.5                | 43                    | 27              | NA                 | 510                 | 318  | 210  | 215  | Aux         |
| Coal Conveyor Gallery Roof (E)   | 2        | 591.5                       | 193.5                | 153.8                 | 31.8            | NA                 | 390                 | 425  | 13   | 159  | Aux         |
| Coal Conveyor Gallery Roof (W)   | 2        | 591.5                       | 193.5                | 201                   | 33.8            | NA                 | 560                 | 375  | 206  | 169  | None        |
| Fan Room Roof (Turbine Bdg)  | 1        | 591.5                       | 134                  | 193                   | 56.5            | NA                 | 600                 | 646  | 233  | 670  | U1, U2, Aux |
| Turbine Building   | 1        | 591.5                       | 110.5                | 259                   | 150.3           | NA                 | 495                 | 532  | 145  | 552  | U1, U2, Aux |
| Fan Room Roof (Turbine Bdg)  | 2        | 591.5                       | 134                  | 193                   | 58              | NA                 | 646                 | 600  | 220  | 670  | U1, U2, Aux |
| Turbine Building   | 2        | 591.5                       | 110.5                | 255                   | 150.3           | NA                 | 532                 | 495  | 145  | 552  | U1, U2, Aux |
| Auxiliary Area (NE Section)  | 1 & 2    | 591.5                       | 236.5                | 47.3                  | 33              | NA                 | 362                 | 369  | 12   | 350  | Aux         |
| Auxiliary Area (NW Section)  | 1 & 2    | 591.5                       | 236.5                | 66.3                  | 37              | NA                 | 362                 | 330  | 10   | 350  | U2, Aux     |
| Auxiliary Area (Between Blr Hses)  | 1 & 2    | 591.5                       | 193.5                | 153.8                 | 70              | NA                 | 391                 | 387  | 0  | 350  | Aux         |
| Auxiliary Area (Between Turb Bdgs)   | 1 & 2    | 591.5                       | 110.5                | 153.5                 | 70              | NA                 | 513                 | 510  | 144  | 350  | Aux         |
| HVAC Fan Room  | 1        | 591.5                       | 72.7                 | 139                   | 72              | NA                 | 360                 | 560  | 310  | 360  | U1, Aux     |
| HVAC Fan Room  | 2        | 591.5                       | 72.7                 | 139                   | 72              | NA                 | 560                 | 360  | 261  | 360  | U2, Aux     |
| Service Building   | NA       | 591.5                       | 31.8                 | 183.2                 | 261             | NA                 | 672                 | 510  | 280  | 159  | None        |
| Administration Building  | NA       | 591.5                       | 28                   | 120                   | 96              | NA                 | 838                 | 728  | 402  | 140  | None        |
| Electrostatic Precipitator   | 1        | 591.5                       | 90                   | 291                   | 117             | NA                 | 95                  | 204  | 195  | 450  | U1, U2, Aux |
| Electrostatic Precipitator   | 2        | 591.5                       | 90                   | 291                   | 117             | NA                 | 204                 | 95   | 186  | 450  | U1, U2, Aux |
| Bottom & Fly Ash Bdg. /Collector   | 1        | 590.5                       | 124                  | NA                    | NA              | 40                 | 144                 | 218  | 526  | 200  | U1          |
| Bottom & Fly Ash Bdg. /Collector   | 2        | 590.5                       | 124                  | NA                    | NA              | 40                 | 222                 | 142  | 517  | 200  | U2          |
| Economizer / Mill Rejects Building   | 1 & 2    | 590.5                       | 116                  | NA                    | NA              | 28                 | 416                 | 466  | 794  | 140  | None        |
| Breaker House 3-TH-7   | 1 & 2    | 590                         | 173                  | 83                    | 68              | NA                 | 835                 | 1160 | 1055   | 340  | None        |
| Transfer House 3-TH-8  | 1 & 2    | 590                         | 74.1                 | 73                    | 34              | NA                 | 945                 | 1260 | 1090   | 170  | None        |
| Transfer House 3-TH-9  | 1 & 2    | 590                         | 67                   | 90                    | 70              | NA                 | 778                 | 1084 | 1165   | 335  | None        |
| Fuel Oil Storage Tank  | 1 & 2    | 590                         | 32                   | NA                    | NA              | 80                 | 356                 | 658  | 542  | 160  | None        |
| Warehouse  | NA       | 591.6                       | 35                   | 201                   | 101             | NA                 | 1263                | 1156 | 828  | 175  | None        |
| Condensate Storage Tanks (2)   | 1 & 2    | 591                         | 30                   | NA                    | NA              | 46                 | 624                 | 765  | 403  | 150  | None        |
| Fire Water Pump House  | 1 & 2    | 591                         | 30                   | 75                    | 30              | NA                 | 880                 | 1058 | 700  | 150  | None        |
| Construction Shop  | NA       | 590                         | 30                   | 200                   | 150             | NA                 | 1134                | 813  | 1000   | 150  | None        |
| Water Storage Tank   | NA       | 591                         | 25                   | NA                    | NA              | 44                 | 904                 | 1096 | 740  | 125  | None        |
| Changehouse  | NA       | 591.5                       | 25                   | 200                   | 50              | NA                 | 1090                | 1065 | 680  | 125  | None        |
| Document Control Office  | NA       | 592.3                       | 25                   | 200                   | 80              | NA                 | 992                 | 942  | 564  | 125  | None        |
| Clubhouse / Recreation Building  | NA       | 582                         | 25                   | 200                   | 40              | NA                 | 1228                | 1046 | 806  | 125  | None        |
| Maintenance Shop   | NA       | 590                         | 25                   | 60                    | 40              | NA                 | 1030                | 709  | 835  | 125  | None        |
| Chemical Canopy  | 1 & 2    | 591.5                       | 24                   | 72                    | 56              | NA                 | 605                 | 788  | 466  | 120  | None        |
| Neutralization Sump Pump House   | 1 & 2    | 591.5                       | 20                   | 52                    | 26              | NA                 | 526                 | 721  | 416  | 100  | None        |
| Material Test Lab  | 1 & 2    | 591                         | 20                   | 50                    | 30              | NA                 | 1046                | 1175 | 788  | 100  | None        |
| Switchyard Relay Control House   | 1 & 2    | 589                         | 20                   | 70                    | 36              | NA                 | 1014                | 1052 | 652  | 100  | None        |
| Waste Water Pump House   | 1 & 2    | 590                         | 18                   | 58                    | 32              | NA                 | 1300                | 1446 | 1055   | 90   | None        |
| Fuel Oil / Foam Sump Pump House  | 1 & 2    | 591.5                       | 15                   | 56                    | 32              | NA                 | 420                 | 684  | 476  | 75   | None        |
| Gatehouse  | NA       | 591                         | 12                   | 29                    | 29              | NA                 | 1033                | 806  | 655  | 60   | None        |

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Belle River & St. Clair Power Plants

| St Clair Power Plant - Buildings That May Cause Main Unit Stack Downwash |             |                             |                  |                  |                 |                    |                        |                      |                      |                     |                                   |                                  |
|--|-------------|-----------------------------|------------------|------------------|-----------------|--------------------|------------------------|----------------------|----------------------|---------------------|-----------------------------------|----------------------------------|
| St Clair<br>Power Plant<br>Structure                                     | Unit No(s). | Important Structure Data    |                  |                  |                 |                    |                        |                      |                      |                     | Structure                         | Stacks                           |
|  |             | Base<br>Elevation<br>(feet) | Height<br>(feet) | Length<br>(feet) | Width<br>(feet) | Diameter<br>(feet) | Minimum Distance to    |                      |                      |                     | Influential<br>Distance<br>(feet) | Within<br>Structure<br>Wake Zone |
|  |             |                             |                  |                  |                 |                    | Unit 1-4 Stk<br>(feet) | Unit 6 Stk<br>(feet) | Unit 7 Stk<br>(feet) | DG 12 Stk<br>(feet) |                                   |                                  |
| Boiler House (Middle Section)  | 1 - 4       | 585                         | 150.3            | 482              | 65              | NA                 | 246                    | 215                  | 426                  | 397                 | 752                               | All                              |
| Boiler House (West Section)  | 1 - 4       | 585                         | 138.4            | 458              | 60              | NA                 | 291                    | 258                  | 457                  | 407                 | 692                               | All                              |
| Boiler House (East Section)  | 1 - 4       | 585                         | 73.7             | 458              | 26              | NA                 | 231                    | 200                  | 415                  | 523                 | 368                               | U1-4 & U6                        |
| Boiler House (Middle Section)  | 5           | 585                         | 215.8            | 110.5            | 62              | NA                 | 663                    | 148                  | 337                  | 763                 | 553                               | U6-7                             |
| Boiler House (2nd West Section)  | 5           | 585                         | 149.8            | 110.5            | 30              | NA                 | 680                    | 204                  | 369                  | 748                 | 553                               | U6-7                             |
| Boiler House (1st West Section)  | 5           | 585                         | 138              | 110.5            | 35              | NA                 | 692                    | 226                  | 387                  | 735                 | 553                               | U6-7                             |
| Boiler House (East Section)  | 5           | 585                         | 172.1            | 110.5            | 25              | NA                 | 658                    | 128                  | 325                  | 799                 | 553                               | U6-7                             |
| Boiler House (Scrubber Extension)  | 5           | 583                         | 150              | 100              | 28              | NA                 | 660                    | 107                  | 315                  | 818                 | 500                               | U6-7                             |
| Boiler House (East Section)  | 6           | 585                         | 178.2            | 145              | 138             | NA                 | 755                    | 42                   | 190                  | 858                 | 725                               | U6-7                             |
| Boiler House (West Section)  | 6           | 585                         | 138              | 138              | 35              | NA                 | 784                    | 190                  | 277                  | 842                 | 690                               | U6-7                             |
| Boiler House (East Section)  | 7           | 584.5                       | 212.2            | 150              | 144             | NA                 | 991                    | 156                  | 65                   | 1080                | 720                               | U6-7                             |
| Boiler House (North Section)   | 7           | 584.5                       | 154              | 53               | 28              | NA                 | 1111                   | 317                  | 197                  | 1154                | 265                               | U7                               |
| Boiler House (West Section)  | 6 - 7       | 584.5                       | 120.8            | 202              | 53              | NA                 | 911                    | 170                  | 207                  | 967                 | 604                               | U6-7                             |
| Turbine Building   | 1 - 7       | 585                         | 106              | 956              | 122             | NA                 | 311                    | 222                  | 307                  | 260                 | 530                               | All                              |
| ID Fan Building (West)   | 1 - 4       | 583                         | 38.5             | 510              | 32              | NA                 | 224                    | 180                  | 446                  | 537                 | 192                               | U6                               |
| ID Fan Building (East)   | 1 - 4       | 583                         | 18               | 510              | 21              | NA                 | 211                    | 177                  | 441                  | 545                 | 90                                | None                             |
| Electrostatic Precipitator (N Section)                                   | 1 - 4       | 582                         | 80               | 175              | 106             | NA                 | 441                    | 194                  | 415                  | 741                 | 400                               | U6                               |
| Electrostatic Precipitator (S Section)                                   | 1 - 4       | 582                         | 80               | 175              | 106             | NA                 | 201                    | 427                  | 658                  | 623                 | 400                               | U1-4                             |
| Electrostatic Precip (N-S Ductwork)                                      | 1 - 4       | 582                         | 100              | 410              | 20              | NA                 | 216                    | 254                  | 427                  | 750                 | 500                               | U1-4 & U6-7                      |
| Electrostatic Precip (NE-SW Ductwork)                                    | 1 - 4       | 582                         | 100              | 165              | 25              | NA                 | 25                     | 644                  | 846                  | 628                 | 500                               | U1-4                             |
| Electrostatic Precipitator   | 6           | 582                         | 186              | 106              | 75              | NA                 | 910                    | 146                  | 88                   | 1109                | 530                               | U6-7                             |
| Electrostatic Precipitator   | 7           | 582.5                       | 137              | 85               | 26              | NA                 | 1006                   | 182                  | 50                   | 1136                | 425                               | U6-7                             |
| Shops Building (New)   | 1 - 7       | 585                         | 71               | 126.5            | 62.5            | NA                 | 170                    | 680                  | 922                  | 387                 | 355                               | U1-4                             |
| Shops Building (Original)  | 1 - 7       | 585                         | 51.3             | 152              | 52              | NA                 | 191                    | 624                  | 858                  | 369                 | 256                               | U1-4                             |
| Office Building  | All         | 585                         | 47               | 110              | 69              | NA                 | 252                    | 762                  | 1000                 | 319                 | 235                               | None                             |

Table 2 (Continued)

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Belle River & St. Clair Power Plants

| St Clair Power Plant - Outlying Buildings That May Cause Main Unit Stack Downwash |                              |                             |                  |                  |                 |                    |                        |                      |                      |                     |                                   |                                  |
|---|------------------------------|-----------------------------|------------------|------------------|-----------------|--------------------|------------------------|----------------------|----------------------|---------------------|-----------------------------------|----------------------------------|
| St Clair<br>Power Plant<br>Structure  | Section of<br>Power<br>Plant | Important Structure Data    |                  |                  |                 |                    |                        |                      |                      |                     | Structure                         | Stacks                           |
|   |                              | Base<br>Elevation<br>(feet) | Height<br>(feet) | Length<br>(feet) | Width<br>(feet) | Diameter<br>(feet) | Minimum Distance to    |                      |                      |                     | Influential<br>Distance<br>(feet) | Within<br>Structure<br>Wake Zone |
|   |                              |                             |                  |                  |                 |                    | Unit 1-4 Stk<br>(feet) | Unit 6 Stk<br>(feet) | Unit 7 Stk<br>(feet) | DG 12 Stk<br>(feet) |                                   |                                  |
| Screen House No. 1  | East                         | 582                         | 35               | 117              | 69              | NA                 | 358                    | 399                  | 594                  | 844                 | 175                               | None                             |
| Screen House No. 2  | East                         | 582                         | 25               | 126              | 69              | NA                 | 635                    | 192                  | 306                  | 989                 | 125                               | None                             |
| Screen House No. 3  | East                         | 582                         | 25               | 57               | 54              | NA                 | 1037                   | 292                  | 122                  | 1283                | 125                               | U7                               |
| Bottom Ash Polymer Treatment Bdg.   | East                         | 582                         | 20               | 30               | 30              | NA                 | 114                    | 877                  | 1109                 | 531                 | 100                               | None                             |
| South Flyash Silo   | East                         | 582                         | 70               | NA               | NA              | 40                 | 152                    | 625                  | 855                  | 597                 | 200                               | U1 - U4                          |
| Nitrogen Tank   | East                         | 583                         | 20               | NA               | NA              | 8                  | 205                    | 634                  | 870                  | 560                 | 40                                | None                             |
| Acid Tank / Caustic Tank  | East                         | 582                         | 12               | 25               | 15              | NA                 | 648                    | 157                  | 389                  | 868                 | 60                                | None                             |
| Slurry Storage Tank   | East                         | 583                         | 15               | NA               | NA              | 32                 | 794                    | 35                   | 225                  | 1005                | 75                                | U6                               |
| No. 2 Oil Barge Unloading Station   | East                         | 582                         | 12               | 24               | 20              | NA                 | 834                    | 236                  | 260                  | 1149                | 60                                | None                             |
| No. 6 Oil Barge Unloading Station   | East                         | 582                         | 10               | 10               | 10              | NA                 | 817                    | 243                  | 285                  | 1145                | 50                                | None                             |
| South Dewatering Bin (Unit 6)   | East                         | 583                         | 60               | NA               | NA              | 30                 | 651                    | 126                  | 356                  | 891                 | 150                               | U6                               |
| North Dewatering Bin (Unit 6)   | East                         | 583                         | 60               | NA               | NA              | 30                 | 690                    | 92                   | 317                  | 921                 | 150                               | U6                               |
| SO2 Building  | East                         | 582                         | 40               | 64               | 55              | NA                 | 906                    | 91                   | 88                   | 1087                | 200                               | U6 - U7                          |
| South Dewatering Bin (Unit 7)   | East                         | 583                         | 60               | NA               | NA              | 30                 | 1009                   | 227                  | 32                   | 1221                | 150                               | U7                               |
| North Dewatering Bin (Unit 7)   | East                         | 583                         | 60               | NA               | NA              | 30                 | 1044                   | 259                  | 30                   | 1244                | 150                               | U7                               |
| Transfer House 3TH1   | South                        | 583                         | 70               | 120              | 50              | NA                 | 671                    | 1480                 | 1701                 | 988                 | 250                               | None                             |
| Transfer House 3TH2 (Dock Hopper)   | South                        | 583                         | 65               | 120              | 88              | NA                 | 410                    | 1228                 | 1741                 | 796                 | 325                               | None                             |
| Storage Building (near 3TH1)  | South                        | 583                         | 15               | 12               | 12              | NA                 | 567                    | 1379                 | 1604                 | 896                 | 60                                | None                             |
| Junction House  | South                        | 585                         | 30               | 32               | 99              | NA                 | 358                    | 1113                 | 1339                 | 456                 | 150                               | None                             |
| Coal Breaker House  | South                        | 585                         | 100              | 120              | 72              | NA                 | 424                    | 1124                 | 1345                 | 384                 | 360                               | None                             |
| Fuel Supply Admin Building  | South                        | 587                         | 25-35            | 102              | 70              | NA                 | 519                    | 1164                 | 1398                 | 295                 | 175                               | None                             |
| Electrical Distribution Building  | South                        | 580                         | 15               | 80               | 36              | NA                 | 635                    | 1396                 | 1632                 | 571                 | 75                                | None                             |
| Club House / Rec Building   | South                        | 589.5                       | 15               | 86               | 35              | NA                 | 599                    | 1066                 | 1284                 | 104                 | 75                                | None                             |
| Motorcycle Shed   | South                        | 588                         | 15               | 80               | 15              | NA                 | 571                    | 1090                 | 1303                 | 139                 | 75                                | None                             |
| Combustion Turbine No. 11-1   | South                        | 590                         | 24               | 65               | 11              | NA                 | 668                    | 1094                 | 1329                 | 92                  | 55                                | None                             |
| Gas Compression Building (CTG 11-1)   | South                        | 589                         | 15               | 27               | 24              | NA                 | 691                    | 1161                 | 1396                 | 158                 | 75                                | None                             |
| Diesel Fuel Storage Tanks   | South                        | 589                         | 12               | 38               | 28              | NA                 | 770                    | 1177                 | 1400                 | 158                 | 60                                | None                             |
| Water Pretreatment Plant  | South                        | 587                         | 30               | 72               | 40              | NA                 | 500                    | 931                  | 1158                 | 52                  | 150                               | DGs                              |
| Water Tank  | South                        | 589                         | 25               | NA               | NA              | 40                 | 500                    | 863                  | 1097                 | 104                 | 125                               | DGs                              |
| Diesel Generator No. 12-1   | South                        | 587                         | 12               | 50               | 10              | NA                 | 627                    | 995                  | 1230                 | 0                   | 60                                | DGs                              |
| Diesel Generator No. 12-2   | South                        | 587                         | 12               | 50               | 10              | NA                 | 627                    | 977                  | 1211                 | 0                   | 60                                | DGs                              |
| No. 2 Fuel Oil Foam & Pumphouse   | South                        | 587                         | 15               | 21               | 18              | NA                 | 1186                   | 1778                 | 2024                 | 801                 | 75                                | None                             |
| Used Oil & No. 6 Oil Tank (N)   | South                        | 587                         | 34               | NA               | NA              | 90                 | 1177                   | 1710                 | 1914                 | 670                 | 170                               | None                             |
| No. 2 Oil Tank (S)  | South                        | 587                         | 34               | NA               | NA              | 90                 | 1392                   | 1997                 | 2206                 | 964                 | 170                               | None                             |
| Oil Transfer House  | South                        | 589.5                       | 20               | 35               | 18              | NA                 | 1077                   | 1532                 | 1756                 | 545                 | 100                               | None                             |
| East Tractor House  | South                        | 589.5                       | 25               | 174              | 56.5            | NA                 | 946                    | 1228                 | 1438                 | 290                 | 125                               | None                             |
| Storage Building  | South                        | 589.5                       | 30               | 130              | 60              | NA                 | 1268                   | 1480                 | 1645                 | 603                 | 150                               | None                             |
| Transfer House #1   | South                        | 589.5                       | 80               | 32               | 25              | NA                 | 1315                   | 1666                 | 1848                 | 670                 | 125                               | None                             |
| Transfer House #2   | South                        | 588.5                       | 80               | 31               | 28              | NA                 | 1541                   | 1839                 | 2010                 | 886                 | 155                               | None                             |
| Transfer House #3   | South                        | 588.5                       | 80               | 33               | 25              | NA                 | 1912                   | 2145                 | 2299                 | 1250                | 125                               | None                             |
| Transfer House #4   | South                        | 588.5                       | 80               | 24               | 20              | NA                 | 2265                   | 2441                 | 2579                 | 1600                | 100                               | None                             |
| Relay House #1  | West                         | 589.5                       | 20               | 37.3             | 22              | NA                 | 887                    | 717                  | 895                  | 510                 | 100                               | None                             |
| Relay House #2  | West                         | 591                         | 12               | 32               | 22              | NA                 | 1156                   | 824                  | 943                  | 719                 | 60                                | None                             |
| Relay House #3  | West                         | 594                         | 20               | 50               | 30              | NA                 | 1288                   | 635                  | 633                  | 1115                | 100                               | None                             |
| Hydrogen Tank   | North                        | 590                         | 30               | NA               | NA              | 10                 | 1338                   | 565                  | 456                  | 1307                | 50                                | None                             |
| Building Cleaners Office / Gym  | North                        | 587                         | 15               | 162              | 60              | NA                 | 1384                   | 578                  | 393                  | 1413                | 75                                | None                             |
| Garage  | North                        | 587                         | 25               | 62               | 50              | NA                 | 1470                   | 701                  | 577                  | 1396                | 125                               | None                             |
| Waste Water Building  | North                        | 594                         | 18               | 98               | 80              | NA                 | 2096                   | 1619                 | 1625                 | 1656                | 90                                | None                             |
| North Gate House  | North                        | 594                         | 10               | 10               | 10              | NA                 | 1634                   | 987                  | 943                  | 1391                | 50                                | None                             |
| North Storage Building  | North                        | 591                         | 30               | 110              | 50              | NA                 | 2254                   | 1631                 | 1540                 | 1980                | 150                               | None                             |
|   |                              |                             |                  |                  |                 |                    |                        |                      |                      |                     |                                   |                                  |
|   |                              |                             |                  |                  |                 |                    |                        |                      |                      |                     |                                   |                                  |

Table 3

Outstate Michigan 1-Hour SO<sub>2</sub> NAAQS Designations  
For Specified Large SO<sub>2</sub> Sources (Round 1 Sources)

DTE Energy Belle River & St. Clair Power Plants

Source Data

| Source                  | Load (%) | Sulfur Dioxide Allowable Emission Rate |   |
|-------------------------|----------|--|---|
|                         |          | Short-term (lb/hr)                     | Notes                                     |
| Belle River PP Unit 1   | 100      | 8,177                                  | Emission limit – 1.2 lbs/MMBtu            |
| Belle River PP Unit 2   | 100      | 8,177                                  | Emission limit – 1.2 lbs/MMBtu            |
| Belle River PP Aux Blrs | 100      | 0.00683                                | 15 ppm sulfur oil                         |
| Belle River PP DG 11-1  | 100      | 4.88 x 10 <sup>-6</sup>                | 15 ppm sulfur oil & < 100 hrs/yr          |
| Belle River PP DG 11-2  | 100      | 4.88 x 10 <sup>-6</sup>                | 15 ppm sulfur oil & < 100 hrs/yr          |
| Belle River PP DG 11-3  | 100      | 4.88 x 10 <sup>-6</sup>                | 15 ppm sulfur oil & < 100 hrs/yr          |
| Belle River PP DG 11-4  | 100      | 4.88 x 10 <sup>-6</sup>                | 15 ppm sulfur oil & < 100 hrs/yr          |
| Belle River PP DG 11-5  | 100      | 4.88 x 10 <sup>-6</sup>                | 15 ppm sulfur oil & < 100 hrs/yr          |
| St. Clair PP Unit 1     | 100      | 2,355                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP Unit 2     | 100      | 2,355                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP Unit 3     | 100      | 2,355                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP Unit 4     | 100      | 2,355                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP Unit 6     | 100      | 5,187                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP Unit 7     | 100      | 7,841                                  | State 1.67 lb/MMBtu SO <sub>2</sub> limit |
| St. Clair PP DG 12-1    | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil                         |
| St. Clair PP DG 12-2    | 100      | 4.27 x 10 <sup>-4</sup>                | 15 ppm sulfur oil                         |

Note: Belle River PP CTG Nos. 12-1, 12-2 & 13-1 and DTE East China CTG Nos. 1-4 were not modeled since they only combust pipeline-quality natural gas



Table 3 (Continued)

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Stack Parameters

| <u>Source</u>      | <u>Load (%)</u> | <u>Height (feet)</u> | <u>Stack</u>               |                             |                               |                       | <u>Minimum Property Line Distance</u> |                  |
|--------------------|-----------------|----------------------|----------------------------|-----------------------------|-------------------------------|-----------------------|---------------------------------------|------------------|
|                    |                 |                      | <u>Inside Diam. (feet)</u> | <u>Exit Gas Flow (acfm)</u> | <u>Exit Velocity (ft/sec)</u> | <u>Exit Temp. (F)</u> | <u>Distance (feet)</u>                | <u>Direction</u> |
| Belle River Unit 1 | 100             | 665                  | 25.5                       | 2.76 E6                     | 90                            | 290                   | 1,959                                 | North            |
| Belle River Unit 2 | 100             | 665                  | 25.5                       | 2.76 E6                     | 90                            | 290                   | 1,898                                 | North            |
| St. Clair Unit 1-4 | 100             | 599                  | 13.32                      | 765,000                     | 91.5                          | 300                   | 216                                   | East             |
| St. Clair Unit 6   | 100             | 425                  | 13.3                       | 1.35 E6                     | 161.5                         | 300                   | 266                                   | East             |
| St. Clair Unit 7   | 100             | 600                  | 16.0                       | 1.59 E6                     | 132                           | 275                   | 191                                   | East             |

Notes:

1. Belle River Units 1 & 2 were installed after promulgation of the Good Engineering Practice (GEP) Stack Height Regulations. However, since this impact analysis is to project past actual monitoring SO<sub>2</sub> levels, each unit's actual stack height (665 feet) is modeled.
2. St. Clair Units 1-4 have an actual stack height greater than their GEP formula height. Units 1-4 have a common 599-foot tall outer stack with four separate liners for each unit. These units will be modeled with their actual stack height.
3. St. Clair Unit 7 has a stack height that is above its formula height. However, it was in existence before the GEP stack height regulation was finalized. Therefore, its actual stack height is modeled in this impact analysis.
4. St. Clair Unit 6's stack is below its GEP formula height, and will be modeled at its actual stack height.

Table 4

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Modeling Input Parameters

Refined Modeling Inputs  
Source Emission & Stack Data

|                       |             | Stack<br>Base       | Stack<br>Height  | Stack Coordinates (NAD83) |             | SO <sub>2</sub> Max<br>Emission<br>Rate | Stack<br>Inside<br>Diameter | Stack<br>Exit<br>Temperature | Stack<br>Exit<br>Velocity | Stack<br>Orientation |
|-----------------------|-------------|---------------------|------------------|---------------------------|-------------|---|-----------------------------|------------------------------|---------------------------|----------------------|
| <b>Belle River PP</b> | Source No.  | Elevation<br>(feet) | Height<br>(feet) | UTME<br>(m)               | UTMN<br>(m) | (lbs/hour)                              | (feet)                      | (deg F)                      | (ft/sec)                  |                      |
| Unit 1 Stack          | 1           | 591.5               | 665              | 377804                    | 4736933     | 8177                                    | 25.5                        | 290                          | 90                        | Vertical             |
| Unit 2 Stack          | 2           | 591.5               | 665              | 377713                    | 4736972     | 8177                                    | 25.5                        | 290                          | 90                        | Vertical             |
| Aux Boiler Stack      | Aux. Boiler | 591.5               | 268.5            | 377706                    | 4736849     | 209.1                                   | 9.0                         | 350                          | 20                        | Vertical             |
| DG 11-1               | DG 11-1     | 590                 | 20               | 378133                    | 4736554.5   | 19.9                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| DG 11-2               | DG 11-2     | 590                 | 20               | 378133                    | 4736545.5   | 19.9                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| DG 11-3               | DG 11-3     | 590                 | 20               | 378133                    | 4736537.5   | 19.9                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| DG 11-4               | DG 11-4     | 590                 | 20               | 378133                    | 4736528.5   | 19.9                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| DG 11-5               | DG 11-5     | 590                 | 20               | 378133                    | 4736519.5   | 19.9                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| <b>St Clair PP</b>    | Source No.  | Elevation<br>(feet) | Height<br>(feet) | UTME<br>(m)               | UTMN<br>(m) | (lbs/hour)                              | (feet)                      | (deg F)                      | (ft/sec)                  | Stack<br>Orientation |
| Unit 1 - 4 Stack      | 1           | 583                 | 599              | 379538                    | 4735415     | 2355                                    | 13.32                       | 300                          | 91.5                      | Vertical             |
| Unit 1 - 4 Stack      | 2           | 583                 | 599              | 379538                    | 4735415     | 2355                                    | 13.32                       | 305                          | 105.1                     | Vertical             |
| Unit 1 - 4 Stack      | 3           | 583                 | 599              | 379538                    | 4735415     | 2355                                    | 13.32                       | 300                          | 99.3                      | Vertical             |
| Unit 1 - 4 Stack      | 4           | 583                 | 599              | 379538                    | 4735415     | 2355                                    | 13.32                       | 305                          | 90.9                      | Vertical             |
| Unit 6 Stack          | 6           | 583                 | 425              | 379597                    | 4735659     | 5187                                    | 13.3                        | 300                          | 161.5                     | Vertical             |
| Unit 7 Stack          | 7           | 583                 | 600              | 379629                    | 4735718     | 7841                                    | 16.0                        | 275                          | 132                       | Vertical             |
| DG 12-1               | DG 12-1     | 589                 | 20               | 379347                    | 4735464     | 28.5                                    | 2.67                        | 770                          | 68.45                     | Vertical             |
| DG 12-2               | DG 12-2     | 589                 | 20               | 379349                    | 4735471     | 28.5                                    | 2.67                        | 770                          | 68.45                     | Vertical             |

Table 4 (Continued)

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Modeling Input Parameters

Refined Modeling Inputs

Building Data

Building Influence Model: BPIP (Version 8.80, dated 04112)

| Belle River Power Plant - Critical Buildings Affecting Main Unit / Aux Boiler / Diesel Gen Stack Downwash |             |                  |               |  |           |          |           |          |           |          |           |
|---|-------------|------------------|---------------|--|-----------|----------|-----------|----------|-----------|----------|-----------|
| Belle River Power Plant Structure   | Unit No.    | Base             |               | Corner 1                                       |           | Corner 2 |           | Corner 3 |           | Corner 4 |           |
|   |             | Elevation (feet) | Height (feet) | UTME (m)                                       | UTMN (m)  | UTME (m) | UTMN (m)  | UTME (m) | UTMN (m)  | UTME (m) | UTMN (m)  |
| Boiler House  | 1           | 591.5            | 262.5         | 377713   | 4736795   | 377733   | 4736845   | 377788   | 4736823   | 377768   | 4736773   |
| Boiler House  | 2           | 591.5            | 262.5         | 377622   | 4736830   | 377641   | 4736882   | 377696   | 4736860   | 377676   | 4736810   |
| Combustion Air Duct Roof  | 2           | 591.5            | 255           | 377653   | 4736877   | 377658   | 4736890   | 377691   | 4736877   | 377686   | 4736864   |
| Combustion Air Duct Roof  | 1           | 591.5            | 241.2         | 377745   | 4736840   | 377750   | 4736853   | 377780   | 4736841   | 377775   | 4736828   |
| Coal Conveyor Gallery Roof (North)  | 1           | 591.5            | 236.5         | 377775   | 4736828   | 377778   | 4736836   | 377790   | 4736831   | 377787   | 4736823   |
| North Aux Area & West U1 / East U2  | 1 & 2 & Aux | 591.5            | 236.5         | 377686   | 4736864   | 377691   | 4736877   | 377710   | 4736869   | 377708   | 4736864   |
|   |             |                  |               | 377748   | 4736848   | 377745   | 4736840   | 377733   | 4736845   | 377731   | 4736841   |
|   |             |                  |               | 377694   | 4736856   | 377696   | 4736860   |          |           |          |           |
| Coal Conveyor Gallery Roof (NE)   | 1           | 591.5            | 210.3         | 377785   | 4736817   | 377790   | 4736830   | 377800   | 4736826   | 377795   | 4736813   |
| Coal Conveyor Gallery Roof (East)   | 1           | 591.5            | 193.5         | 377768   | 4736773   | 377785   | 4736817   | 377795   | 4736813   | 377777   | 4736769   |
| Coal Conveyor Gallery Roof (West)   | 2           | 591.5            | 193.5         | 377614   | 4736834   | 377637   | 4736893   | 377644   | 4736891   | 377622   | 4736831   |
| Auxiliary Area (Between Boilers)  | Aux.        | 591.5            | 193.5         | 377676   | 4736810   | 377694   | 4736856   | 377731   | 4736841   | 377713   | 4736795   |
| Turbine Bdg (Fan Room Roof)   | 1           | 591.5            | 134           | 377697   | 4736751   | 377703   | 4736767   | 377756   | 4736747   | 377750   | 4736731   |
| Turbine Bdg (Fan Room Roof)   | 2           | 591.5            | 134           | 377607   | 4736786   | 377613   | 4736802   | 377666   | 4736782   | 377660   | 4736766   |
| Turbine Building  | 1 & 2 & Aux | 591.5            | 110.5         | 377598   | 4736790   | 377614   | 4736834   | 377777   | 4736769   | 377760   | 4736727   |
| HVAC Fan Room   | 1           | 591.5            | 72.7          | 377784   | 4736786   | 377800   | 4736826   | 377821   | 4736819   | 377805   | 4736779   |
| HVAC Fan Room   | 2           | 591.5            | 72.7          | 377600   | 4736858   | 377615   | 4736900   | 377636   | 4736893   | 377621   | 4736851   |
| Service Building  | 1 & 2 & Aux | 591.5            | 31.8          | 377523   | 4736817   | 377542   | 4736870   | 377617   | 4736843   | 377598   | 4736790   |
| Administration Building   | 1 & 2 & Aux | 591.5            | 28            | 377554   | 4736768   | 377565   | 4736795   | 377599   | 4736781   | 377587   | 4736754   |
| Bottom & Fly Ash Bdg. /Collector  | 1           | 590.5            | 124           | Center = 377807E, 4736997N, Diameter = 40 feet |           |          |           |          |           |          |           |
| Bottom & Fly Ash Bdg. /Collector  | 2           | 590.5            | 124           | Center = 377761E, 4737016N, Diameter = 40 feet |           |          |           |          |           |          |           |
| Electrostatic Precipitator  | 1           | 591.5            | 90            | 377740   | 4736891   | 377752   | 4736925   | 377835   | 4736895   | 377823   | 4736861   |
| Electrostatic Precipitator  | 2           | 591.5            | 90            | 377650   | 4736925   | 377662   | 4736959   | 377745   | 4736929   | 377733   | 4736895   |
| Diesel Gen No. 11-1 (Main Bdg.)   | DG 11-1     | 590              | 12            | 378134   | 4736553   | 378134   | 4736556   | 378148   | 4736556   | 378148   | 4736553   |
| Diesel Gen No. 11-1 (Silencer)  | DG 11-1     | 590              | 17            | 378134   | 4736553.7 | 378134   | 4736555.3 | 378142   | 4736555.3 | 378142   | 4736553.7 |
| Diesel Gen No. 11-2 (Main Bdg.)   | DG 11-2     | 590              | 12            | 378134   | 4736544   | 378134   | 4736547   | 378148   | 4736547   | 378148   | 4736544   |
| Diesel Gen No. 11-2 (Silencer)  | DG 11-2     | 590              | 17            | 378134   | 4736544.7 | 378134   | 4736546.3 | 378142   | 4736546.3 | 378142   | 4736544.7 |
| Diesel Gen No. 11-3 (Main Bdg.)   | DG 11-3     | 590              | 12            | 378134   | 4736536   | 378134   | 4736539   | 378148   | 4736539   | 378148   | 4736536   |
| Diesel Gen No. 11-3 (Silencer)  | DG 11-3     | 590              | 17            | 378134   | 4736536.7 | 378134   | 4736538.3 | 378142   | 4736538.3 | 378142   | 4736536.7 |
| Diesel Gen No. 11-4 (Main Bdg.)   | DG 11-4     | 590              | 12            | 378134   | 4736527   | 378134   | 4736530   | 378148   | 4736530   | 378148   | 4736527   |
| Diesel Gen No. 11-4 (Silencer)  | DG 11-4     | 590              | 17            | 378134   | 4736527.7 | 378134   | 4736529.3 | 378142   | 4736529.3 | 378142   | 4736527.7 |
| Diesel Gen No. 11-5 (Main Bdg.)   | DG 11-5     | 590              | 12            | 378134   | 4736518   | 378134   | 4736521   | 378148   | 4736521   | 378148   | 4736518   |
| Diesel Gen No. 11-5 (Silencer)  | DG 11-5     | 590              | 17            | 378134   | 4736518.7 | 378134   | 4736520.3 | 378142   | 4736520.3 | 378142   | 4736518.7 |
| <b>Stack Data</b>   |             |                  |               |  |           |          |           |          |           |          |           |
| Unit 1 Stack  | 1           | 591.5            | 665           | 377804   | 4736933   |          |           |          |           |          |           |
| Unit 2 Stack  | 2           | 591.5            | 665           | 377713   | 4736972   |          |           |          |           |          |           |
| Auxiliary Boiler Stack  | Aux. Boiler | 591.5            | 268.5         | 377706   | 4736849   |          |           |          |           |          |           |
| Diesel Gen No. 11-1   | DG 11-1     | 590              | 20            | 378133   | 4736554.5 |          |           |          |           |          |           |
| Diesel Gen No. 11-2   | DG 11-2     | 590              | 20            | 378133   | 4736545.5 |          |           |          |           |          |           |
| Diesel Gen No. 11-3   | DG 11-3     | 590              | 20            | 378133   | 4736537.5 |          |           |          |           |          |           |
| Diesel Gen No. 11-4   | DG 11-4     | 590              | 20            | 378133   | 4736528.5 |          |           |          |           |          |           |
| Diesel Gen No. 11-5   | DG 11-5     | 590              | 20            | 378133   | 4736519.5 |          |           |          |           |          |           |

Table 4 (Continued)

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

| St Clair Power Plant - Critical Buildings Affecting Main Unit / Diesel Generator Stack Downwash |          |                               |                  |   |             |                |             |                |             |                |             |
|---|----------|-------------------------------|------------------|---|-------------|----------------|-------------|----------------|-------------|----------------|-------------|
| St Clair<br>Power Plant<br>Structure  | Unit No. | Base                          |                  | Corner 1(or 5)  |             | Corner 2(or 6) |             | Corner 3(or 7) |             | Corner 4(or 8) |             |
|   |          | Elevation<br>(feet)           | Height<br>(feet) | UTME<br>(m)   | UTMN<br>(m) | UTME<br>(m)    | UTMN<br>(m) | UTME<br>(m)    | UTMN<br>(m) | UTME<br>(m)    | UTMN<br>(m) |
|   |          | Boiler House (Middle Section) | 5                | 585   | 215.8       | 379526         | 4735622     | 379535         | 4735654     | 379553         | 4735649     |
| Boiler House (East Section)   | 7        | 584.5                         | 212.2            | 379562  | 4735722     | 379572         | 4735755     | 379576         | 4735754     | 379577         | 4735758     |
|   |          |                               |                  | 379617  | 4735747     | 379605         | 4735705     | 379565         | 4735716     | 379566         | 4735720     |
| Electrostatic Precipitator  | 6        | 582                           | 186              | 379635  | 4735670     | 379641         | 4735692     | 379672         | 4735683     | 379666         | 4735661     |
| Boiler House (East Section)   | 6        | 585                           | 178.2            | 379536  | 4735654     | 379548         | 4735694     | 379582         | 4735684     | 379580         | 4735678     |
|   |          |                               |                  | 379588  | 4735676     | 379580         | 4735647     | 379572         | 4735649     | 379570         | 4735643     |
| Boiler House (East Section)   | 5        | 585                           | 172.1            | 379544  | 4735617     | 379553         | 4735649     | 379560         | 4735647     | 379551         | 4735615     |
| Boiler House (North Section)  | 7        | 584.5                         | 154              | 379555  | 4735756     | 379557         | 4735764     | 379577         | 4735758     | 379576         | 4735754     |
|   |          |                               |                  | 379572  | 4735755     | 379571         | 4735752     |                |             |                |             |
| Boiler House (Middle Section)   | 1 - 4    | 585                           | 150.3            | 379469  | 4735486     | 379471         | 4735493     | 379489         | 4735489     | 379527         | 4735623     |
|   |          |                               |                  | 379546  | 4735618     | 379508         | 4735484     | 379501         | 4735486     | 379499         | 4735479     |
| Boiler House (Scrubber Extension)   | 5        | 583                           | 150              | 379552  | 4735616     | 379560         | 4735646     | 379568         | 4735644     | 379560         | 4735615     |
| Boiler House (2nd West Section)   | 5        | 585                           | 149.8            | 379517  | 4735625     | 379526         | 4735657     | 379535         | 4735654     | 379526         | 4735622     |
| Boiler House (West Section)   | 1 - 4    | 585                           | 138.4            | 379471  | 4735493     | 379509         | 4735628     | 379527         | 4735623     | 379489         | 4735489     |
| Boiler House (1st West Section)   | 5        | 585                           | 138              | 379509  | 4735628     | 379518         | 4735660     | 379528         | 4735657     | 379517         | 4735625     |
| Boiler House (West Section)   | 6        | 585                           | 138              | 379526  | 4735657     | 379538         | 4735697     | 379548         | 4735694     | 379536         | 4735654     |
| Electrostatic Precipitator  | 7        | 582.5                         | 137              | 379614  | 4735712     | 379621         | 4735737     | 379629         | 4735735     | 379622         | 4735710     |
| Boiler House (West Section)   | 6 - 7    | 584.5                         | 120.8            | 379538  | 4735697     | 379555         | 4735756     | 379571         | 4735752     | 379562         | 379722      |
|   |          |                               |                  | 379566  | 4735721     | 379557         | 4735692     |                |             |                |             |
| Turbine Building  | 1 - 7    | 585                           | 106              | 379431  | 4735488     | 379511         | 4735772     | 379547         | 4735762     | 379467         | 4735478     |
| Upper Interface Blr Hse to ESP  | 7        | 583                           | 100              | 379608  | 4735713     | 379615         | 4735739     | 379621         | 4735737     | 379614         | 4735711     |
| Electrostatic Precip (N-S Duct Run)   | 1 - 4    |                               | 100              | 379584  | 4735462     | 379615         | 4735582     | 379621         | 4735581     | 379590         | 4735461     |
| Electrostatic Precip (NE-SW Duct Run)   | 1 - 4    |                               | 100              | 379539  | 4735423     | 379584         | 4735462     | 379586         | 4735461     | 379586         | 4735455     |
| Electrostatic Precipitator (South)  | 1 - 4    |                               | 80               | 379543  | 4735476     | 379558         | 4735527     | 379590         | 4735517     | 379575         | 4735466     |
| Electrostatic Precipitator (North)  | 1 - 4    |                               | 80               | 379563  | 4735547     | 379578         | 4735597     | 379609         | 4735588     | 379594         | 4735538     |
| Boiler House (East Section)   | 1 - 4    | 585                           | 73.7             | 379508  | 4735484     | 379546         | 4735618     | 379554         | 4735616     | 379516         | 4735482     |
| Shops Building (South Section)  | 1 - 7    | 585                           | 71               | 379462  | 4735459     | 379467         | 4735478     | 379504         | 4735467     | 379499         | 4735449     |
| South Flyash Silo   | 1 - 7    | 582                           | 70               | Center = 379536E, 4735462N & Diameter = 40 feet (12.2m) |             |                |             |                |             |                |             |
| Lower Interface Blr Hse to ESP  | 7        | 583                           | 61.4             | 379604  | 4735701     | 379617         | 4735747     | 379623         | 4735745     | 379610         | 4735699     |
| South Ash Dewatering Bin  | 6        | 583                           | 60               | Center = 379581E, 4735595N & Diameter = 30 feet (9.14m) |             |                |             |                |             |                |             |
| North Ash Dewatering Bin  | 6        | 583                           | 60               | Center = 379586E, 4735614N & Diameter = 30 feet (9.14m) |             |                |             |                |             |                |             |
| South Ash Dewatering Bin  | 7        | 583                           | 60               | Center = 379641E, 4735700N & Diameter = 30 feet (9.14m) |             |                |             |                |             |                |             |
| North Ash Dewatering Bin  | 7        | 583                           | 60               | Center = 379644E, 4735713N & Diameter = 30 feet (9.14m) |             |                |             |                |             |                |             |
| Shops Building (North Section)  | 1 - 7    | 585                           | 51.3             | 379467  | 4735478     | 379469         | 4735486     | 379499         | 4735479     | 379501         | 4735486     |
|   |          |                               |                  | 379516  | 4735482     | 379512         | 4735467     |                |             |                |             |
| Office Building (North Section)   | 1 - 7    | 585                           | 46.7             | 379446  | 4735441     | 379458         | 4735480     | 379467         | 4735478     | 379462         | 4735459     |
|   |          |                               |                  | 379469  | 4735457     | 379462         | 4735434     |                |             |                |             |
| SO2 Building  | 6 - 7    | 583                           | 40               | 379595  | 4735674     | 379600         | 4735691     | 379617         | 4735685     | 379612         | 4735667     |
| Water Pretreatment Plant  | 1 - 7    | 587                           | 30               | 379356  | 4735458     | 379359         | 4735470     | 379380         | 4735463     | 379377         | 4735451     |
| Screen House #3   | 7        | 582                           | 25               | 379662  | 4735704     | 379667         | 4735721     | 379681         | 4735713     | 379676         | 4735696     |
| Water Tank  | 1 - 7    | 589                           | 25               | Center = 379381E, 4735481N & Diameter = 40 feet (12.2m) |             |                |             |                |             |                |             |
| Office Building (South Section)   | 1 - 7    | 585                           | 18.5             | 379439  | 4735431     | 379449         | 4735464     | 379453         | 4735463     | 379446         | 4735441     |
|   |          |                               |                  | 379462  | 4735434     | 379459         | 4735425     |                |             |                |             |
| Slurry Storage Tank   | 1 - 7    | 583                           | 15               | Center = 379602E, 4735649N & Diameter = 32 feet (9.75m) |             |                |             |                |             |                |             |
| Diesel Generator  | 12-1     | 589                           | 12               | 379333  | 4735465     | 379334         | 4735468     | 379348         | 4735464     | 379347         | 4735461     |
| Diesel Generator  | 12-2     | 589                           | 12               | 379335  | 4735472     | 379336         | 4735475     | 379350         | 4735471     | 379349         | 4735468     |
| <b>Stack Data</b>   |          |                               |                  |   |             |                |             |                |             |                |             |
| Unit 1 - 4 Stack  | 1 - 4    | 583                           | 599              | 379538  | 4735415     |                |             |                |             |                |             |
| Unit 6 Stack  | 6        | 583                           | 423.5            | 379597  | 4735659     |                |             |                |             |                |             |
| Unit 7 Stack  | 7        | 583                           | 599              | 379629  | 4735718     |                |             |                |             |                |             |
| DG 12-1   | DG 12-1  | 589                           | 20               | 379347  | 4735464     |                |             |                |             |                |             |
| DG 12-2   | DG 12-2  | 589                           | 20               | 379349  | 4735471     |                |             |                |             |                |             |

Note: Other buildings in the area are not modeled because the proposed source's stacks are outside of the wake zone of these structures.

Table 4 (Continued)

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Modeling Input Parameters

|   |   |
|---|---|
| Refined Model:                                      | AERMOD (BEE-Line Version 11.00, dated 14134)  |
| Model Options:                                      | Terrain elevations considered - Yes<br>Dispersion coefficients - Rural<br>Default wind exponents - Yes<br>Default vertical temperature gradients - Yes<br>Emissions scaled - No<br>Final plume rise - Yes<br>Stack tip downwash - Yes<br>Buoyancy induced dispersion - Yes<br>Calm processing routine - Yes<br>Regulatory default option - Yes<br>Type of pollutant – SO <sub>2</sub> |
| Meteorological Data:                                | Surface – Oakland County International Airport (PTK)<br>Upper Air – White Lake NWS Office (DTX)<br>Dates – 2012-2014<br>Anemometer height – 10 m  |
| Receptor Grid (Property Line Grid / Innermost Grid) | Grid Type: Rectangular<br>Fence Line Rec.: Yes<br>Grid: 50 m spacing at fence line & outside of the fence line out to 500 m beyond the property line  |
| Receptor Grid (2 <sup>nd</sup> Grid)                | Grid Type: Rectangular<br>Grid: 100 m spacing outside of Innermost Grid to 4 km from the property line  |
| Receptor Grid (3 <sup>rd</sup> Grid)                | Grid Type: Rectangular<br>Grid: 250 m spacing outside of the 2nd Grid to 10 km from the property line   |

Figure 1


Belle River Power Plant  
Diesel Generators 11-1 through 11-5  
With Main Units in the Background



Figure 2

Belle River Power Plant

Aerial Photograph from 2006



↑  
North

Figure 3

St. Clair Power Plant

Aerial Photograph from 2006



North →



Figure 4A

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Port Huron Monitoring Site




Figure 4B

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Canadian Refinery East-southeast of Port Huron Monitor



Figure 4C

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI


Canadian Refinery (Suncor) South-southeast of Port Huron Monitor



Figure 4D

Belle River & St. Clair Power Plant 1-Hour SO<sub>2</sub> Modeling Study  
China Township, MI

Port Huron Monitor & Nearby Canadian Refineries



# **Belle River / St. Clair PP 1-hour SO<sub>2</sub> Designation Modeling Results**


## **With Pontiac Surface Meteorological Data**

**August 10, 2015**

### **AERMOD Modeling Assumptions**

- Use actual 2012-2014 CEMS data (SO<sub>2</sub>, Exit temperature, Exit velocity) for all Belle River PP & St. Clair PP main units
- Did not model smaller SO<sub>2</sub> source impacts (CTGs, DGs, Aux Blrs)
- Used 2012-2014 meteorological data from Oakland County International Airport (Pontiac) instead of closer site (Port Huron)
- Only predict impacts where monitors could be located
  - No receptors in Canada, over water, over landfills, within secured plant property (used property lines not fence lines)
- Modeled impacts from two other “nearby” SO<sub>2</sub> sources (Cargill Salt & E B Eddy Paper Company)
- Included actual source and receptor elevations
- Used most recent version of AERMOD (14134)
- Estimated background SO<sub>2</sub> concentration – 15 ppb

**Figure 1**  
**99<sup>th</sup> Max Daily 1-hour SO<sub>2</sub> Impacts- All Belle River & St. Clair PP Units**  
 Pontiac Surface Met Data  
 (Not Including Background Concentration)



At the peak combined impact receptor, the SO<sub>2</sub> sources' H4H impact is:

| SO <sub>2</sub> Source | Impact (ug/m <sup>3</sup> ) / (ppb) |
|------------------------|-------------------------------------|
| BRPP-Units 1&2         | 60.3 / 23                           |
| SCPP-Unit 1            | 26.9 / 10.3                         |
| SCPP-Unit 2            | 21.6 / 8.2                          |
| SCPP-Unit 3            | 24.7 / 9.4                          |
| SCPP-Unit 4            | 39.7 / 15.2                         |
| SCPP Unit 6            | 117 / 44.6                          |
| SCPP-Unit 7            | 79.8 / 30.4                         |
| SCPP-Total             | 305 / 116.4                         |
| Cargill Salt Inc.      | 21.39 / 8.2                         |
| E B Eddy Paper Inc.    | 17.8 / 6.8                          |

**Total = 306.14 ug/m<sup>3</sup> / 116.8 ppb**

**NAAQS = 75 ppb**

# Belle River / St. Clair PP 1-hour SO<sub>2</sub> Designation Modeling Results


## With Port Huron Surface Meteorological Data

August 10, 2015

### AERMOD Modeling Assumptions

- Use actual 2012-2014 CEMS data (SO<sub>2</sub>, Exit temperature, Exit velocity) for all Belle River PP & St. Clair PP main units
- Did not model smaller SO<sub>2</sub> source impacts (CTGs, DGs, Aux Blrs)
- Used 2012-2014 meteorological data from St. Clair County International Airport (Port Huron) instead of EPA preferred site (Pontiac)
- Only predict impacts where monitors could be located
  - No receptors in Canada, over water, over landfills, within secured plant property (used property lines not fence lines)
- Modeled impacts from two other “nearby” SO<sub>2</sub> sources (Cargill Salt & E B Eddy Paper Company)
- Included actual source and receptor elevations
- Used most recent version of AERMOD (14134)
- Estimated background SO<sub>2</sub> concentration – 15 ppb

**Figure 2**  
**99<sup>th</sup> Max Daily 1-hour SO<sub>2</sub> Impacts- All Belle River & St. Clair PP Units**  
 Port Huron Surface Met Data  
 (Not Including Background Concentration)



At the peak combined impact receptor, the SO<sub>2</sub> sources' H4H impact is:

| SO <sub>2</sub> Source | Impact (ug/m <sup>3</sup> ) / (ppb) |
|------------------------|-------------------------------------|
| BRPP Units 1 & 2       | 77.5 / 29.6                         |
| SCPP Total             | 169 / 64.5                          |
| Cargill Salt Inc.      | 128 / 48.9                          |
| E B Eddy Paper Inc.    | 17.32 / 6.61                        |

**Total = 279 ug/m<sup>3</sup> / 106.5 ppb**

**NAAQS = 75 ppb**



## **H4H Impacts Using Pontiac Versus Port Huron Meteorological Data**

### **Introduction:**

There are challenges predicting the magnitude and location of the 99<sup>th</sup> percentile SO<sub>2</sub> impacts from these large SO<sub>2</sub> sources. This prediction is important for two main reasons:

1. Understanding how each source contributes to the highest combined 1-hour SO<sub>2</sub> impacts is important for reduction strategy development. Accurately predicting the location and magnitude of high SO<sub>2</sub> impacts is essential to develop the most effective strategy to attain the SO<sub>2</sub>.NAAQS
2. Modeling predictions of the location of highest 1-hour SO<sub>2</sub> impacts and how often they occur in the AERMOD runs will be used to determine where to site new air quality monitors. Monitor installation is being proposed to provide critical concentration and meteorological data for SO<sub>2</sub> reduction strategy development.

### **Challenges:**

- The magnitude of differences between predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> impact from the model using Pontiac meteorological data versus Port Huron meteorological data. This discrepancy is very important, especially if the results using Pontiac data are used in the official area designation, and subsequent SIP development.
  - The predicted 99th percentile 1-hour SO<sub>2</sub> impact from these large SO<sub>2</sub> sources is 10 ppb higher when Pontiac meteorological data are modeled (117 ppb) instead of Port Huron data (106 ppb) – This 10 ppb difference is much higher than when an annual average SO<sub>2</sub> emission rate is modeled (3-4 ppb) between the two meteorological data sets.
  - These predicted impacts do NOT include the background concentration (estimated as 15 ppb by MDEQ-AQD staff)
- There are large differences in the location of predicted peak impact areas from AERMOD using Pontiac meteorological data versus Port Huron meteorological data.
  - Port Huron weather data clearly shows some channeling flow along the St. Clair River during meteorological conditions when the highest 1-hour SO<sub>2</sub> impacts are predicted – The highest predicted 1-hour SO<sub>2</sub> impacts are NOT along the St. Clair River when Pontiac surface data are modeled
  - Lobe 1 using Pontiac data is SSW of SCPP versus N of SCPP using Port Huron data – The 2nd peak lobe along the St. Clair River shown with Port Huron data is more realistic, especially with St. Clair Unit No. 6's (Stack Ht.=425 feet) stack being much more affected by building downwash than the other units (Stack Hts.=599-665 feet)
  - The farther inland high impact lobe with BRPP & SCPP impact is NW of BRPP with Pontiac data versus WNW of BRPP with Port Huron data
- Monitor siting is challenged by the variability of modeled high impact locations between the two meteorological data sets.
  - This high impact location discrepancy could lead to locating new SO<sub>2</sub> monitoring sites in the wrong location, too far inland from the St. Clair River

### **Improvements:**

- Installation of SO<sub>2</sub> monitors and meteorological towers to determine the actual magnitude of high SO<sub>2</sub> values and provide accurate site meteorological flow to improve model predicted location of high impact areas. On-site meteorological data should be

acquired, and used to clarify actual power plant site flow during meteorological conditions when the highest 1-hour SO<sub>2</sub> impacts are predicted, and compared to periods when the highest 1-hour average SO<sub>2</sub> concentrations are observed at these critical locations.

- Tentative, SO<sub>2</sub> monitoring sites are:
  - On the west side of River Road (M-29), on the berm just east of East China Township LLC combustion turbine generators (Lobe 2 from Port Huron met data results)
  - At a DTE Energy substation in Marine City (the southern portion of Lobe 3 SSW of SCPP) – This site would provide a much more representative background SO<sub>2</sub> concentration when high SO<sub>2</sub> levels are predicted, or observed at the monitoring site along River Road
  - The following figures (Figures 3-6) illustrate these currently preferred locations
    - Figures 3 and 4 illustrate the monitoring site closest to the peak 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> impact using Port Huron met data
    - Figures 5 and 6 show the recommended monitoring location next to a DTE Energy substation (Marine City Substation) that is amongst the lobe of high 99<sup>th</sup> percentile SO<sub>2</sub> impacts southwest of St. Clair Power Plant. This site would help quantify incoming SO<sub>2</sub> levels when high SO<sub>2</sub> may be observed at the other monitoring site.
    - A monitoring site closer to St. Clair Power Plant than the Marine City Substation would be preferred. However, there are no suitable sites in this area that meet EPA's siting criteria for air quality monitoring sites. This area next to the St. Clair River has a number of subdivisions with canals to access the River, with most parcels also having large trees
    - Figure 7 shows the discrepancy between highest 4<sup>th</sup>-highest (H4H) predicted impacts between the two met data sets. Using Pontiac met data, the orange arrow shows the 1<sup>st</sup> H4H 1-hour SO<sub>2</sub> impact location southwest of St. Clair Power Plant. The blue and red arrows illustrate nearby locations of the second and third H4H 1-hour SO<sub>2</sub> impact locations with Port Huron met data. The highest H4H 1-hour SO<sub>2</sub> location is in downtown area of the City of St. Clair, just north of Cargill Salt Incorporated using Port Huron data. This location is not suitable for a future air quality monitoring site.

**Figure 3**

**Northwest of St. Clair PP (Along River Road)**



**Figure 4**



**Figure 5**

South-southwest of St. Clair PP (Between St. Clair River & Belle River)  
Just north of Marine City at DTE Energy's Marine City Substation



**Figure 6**



**Figure 7 - 99<sup>th</sup> Max Daily 1-hour SO<sub>2</sub> Impacts – Only St. Clair PP Units**

