

NOTES:

1. Year 2032 is the End-Year and should not be used for analysis.

	2010	2015	2020	2025	2032
1. Reserve Margin Capacity WINTER [MW]	886614.	863816.	908740.	965146.	1048362.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In WINTER [MW]	16443.	16603.	11204.	10354.	9797.
Total R.M. Capacity WINTER [MW]	903057.	880419.	919944.	975500.	1058159.
2. Peak Load WINTER [MW]	670761.	658089.	697889.	741276.	805541.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out WINTER [MW]	16778.	16942.	11432.	10566.	9997.
Net Demand WINTER [MW]	687540.	675031.	709321.	751842.	815538.
3. Reserve Margin WINTER [%]	32.	31.	30.	30.	30.
1. Reserve Margin Capacity SUMMER [MW]	886614.	863816.	908740.	965146.	1048362.
Plus Firm Purchases [MW]	0.	0.	0.	0.	0.
Plus Transmission In SUMMER [MW]	56611.	61965.	58940.	53953.	46820.
Total R.M. Capacity SUMMER [MW]	943225.	925781.	967680.	1019099.	1095182.
2. Peak Load SUMMER [MW]	761725.	746114.	790615.	839883.	913636.
Less DSM [MW]	0.	0.	0.	0.	0.
Plus Firm Sales [MW]	0.	0.	0.	0.	0.
Plus Transmission Out SUMMER [MW]	57766.	63229.	60143.	55054.	47776.
Net Demand SUMMER [MW]	819491.	809343.	850758.	894937.	961411.
3. Reserve Margin SUMMER [%]	16.	16.	15.	15.	15.
4. Generation [GWh]	4205723.	4123551.	4365459.	4610494.	4977821.
Inter-Region Transmission [GWh]	-14206.	-10936.	-9588.	-8385.	-7339.
Pumping & Storage Losses [GWh]	25186.	13170.	11651.	9945.	7336.
Plus Purchases [GWh]	0.	0.	0.	0.	0.
Less Sales [GWh]	0.	0.	0.	0.	0.
5. Total Supply for Demand [GWh]	4166331.	4099445.	4344221.	4592164.	4963146.
6. Projected Demand [GWh]	4166331.	4099445.	4344221.	4592164.	4963146.
Energy Not Served [GWh]	0.	0.	0.	0.	0.
Less DSM [GWh]	0.	0.	0.	0.	0.
Net Demand [GWh]	4166331.	4099445.	4344221.	4592164.	4963146.
7. Dumped Energy [GWh]	0.	0.	0.	0.	0.
8. Total Supply for Demand [GWh]	4166331.	4099445.	4344221.	4592164.	4963146.
Less T&D Losses [GWh]	320953.	315801.	334657.	353757.	382336.
9. Total Sales [GWh]	3845378.	3783644.	4009564.	4238407.	4580810.
Capacity Avoided Costs [US\$/kW]	2010	2015	2020	2025	2032
WINTER	0.00	0.00	0.00	0.00	0.00
SUMMER	8.25	6.62	26.45	23.23	24.48

10. Capacity by Plant Type [MW]	2010	2015	2020	2025	2032
New Scrubbed-Dry Coal_SCR_ACI 01	0.	0.	0.	0.	0.
New Scrubbed-Wet Coal_SCR 02	0.	0.	0.	0.	0.
New Comb.Cycle 03	0.	0.	2259.	15033.	34168.
New Comb.Cycle w/Seq 04	0.	0.	0.	0.	0.
New Combustion Turbine 05	0.	0.	0.	0.	0.
New Nuclear 06	0.	4000.	24000.	44000.	64000.
New Biomass 07	0.	0.	0.	6187.	40833.
New Fuel Cell 08	0.	0.	0.	0.	0.
New Geothermal 09	0.	0.	1245.	3030.	4909.
New IGCC 10	0.	0.	0.	0.	0.
New IGCC w/Seq 11	0.	5000.	10060.	20845.	47481.
New Landfill Gas 12	537.	1063.	1235.	4127.	5054.
New Solar 13	0.	0.	0.	0.	0.
New Wind 14	36.	541.	9677.	30082.	41204.
Scrubbed-Wet Coal_SCR 15	75375.	74084.	73923.	73777.	69784.
Scrubbed-Wet Coal_SNCR 16	4250.	3948.	3948.	3223.	2953.
Scrubbed-Wet Coal 17	47956.	43952.	37205.	33517.	18865.
Scrubbed-Dry Coal_SCR 18	3761.	3190.	3190.	3190.	2582.
Scrubbed-Dry Coal_SNCR 19	253.	253.	0.	0.	0.
Scrubbed-Dry Coal 20	10238.	9348.	8931.	8799.	3982.
Unscrubbed Coal_SCR 21	20800.	11111.	11111.	10949.	9981.
Unscrubbed Coal_SNCR 22	6148.	5409.	4767.	4314.	3458.
Unscrubbed Coal 23	103618.	75871.	72603.	65874.	53699.
FB-Unscrubbed Coal 24	3198.	2854.	2549.	2138.	1517.
FB-Unscrubbed Coal_SNCR 25	2201.	2121.	2121.	2121.	2012.
FB-Scrubbed-Dry Coal 26	50.	50.	50.	50.	0.
Oil/Gas Steam 27	22268.	12959.	11925.	10510.	9836.
Oil/Gas Steam_SCR 28	4481.	3266.	1176.	1176.	1176.
Oil/Gas Steam_SNCR 29	721.	721.	721.	721.	721.
Nuclear 30	100942.	101816.	102756.	102756.	96260.
Hydro 31	78225.	78266.	78266.	78266.	78266.
Comb.Cycle 32	146467.	145639.	145639.	143591.	141465.
IGCC 33	1115.	860.	860.	860.	775.
Combustion Turbine 34	130730.	130730.	130730.	130730.	130730.
Biomass 35	1520.	1520.	1520.	1520.	1520.
Geothermal 36	2296.	2371.	2371.	2371.	2371.
Landfill Gas 37	1061.	1086.	1086.	1086.	1086.
Wind 38	16191.	17051.	17051.	17051.	17051.
Fuel Cell 39	2.	2.	2.	2.	2.
Solar 40	531.	614.	713.	824.	933.
Non Fossil_Other 41	2016.	2016.	2016.	2016.	2016.
Fossil_Other 42	161.	161.	161.	161.	161.
Pump Storage 43	20494.	20494.	20494.	20494.	20494.
Int. Imports 44	5550.	5550.	5550.	5550.	5550.
Cgn_CT 45	5202.	5202.	5202.	5202.	5202.
Cgn_CC 46	38029.	38029.	38029.	38029.	36840.
Cgn_Oil/Gas Steam 47	216.	69.	69.	60.	60.
Cgn_Biomass 48	795.	795.	795.	795.	795.
Cgn_Fossil_Other 49	342.	342.	342.	342.	342.
Cgn_NonFossil_Other 50	725.	725.	725.	725.	725.
Rep.Coal-CC 51	120.	1082.	16364.	25141.	47013.
Rep.Coal-CC w/Seq 52	0.	0.	0.	0.	0.
Rep.O/G-CC 53	24734.	24801.	32342.	32898.	34706.
Rep.O/G-CC w/Seq 54	0.	0.	0.	0.	0.
Rep.Coal-IGCC 55	0.	0.	0.	0.	0.
Rep.Coal-IGCC w/Seq 56	0.	0.	0.	0.	0.
Ret.DryScrubber 57	777.	6210.	6210.	6212.	7746.
Ret.WetScrubber 58	3002.	5034.	3562.	3562.	3562.
Ret.ExistSCR & DryScrub 59	0.	0.	0.	0.	0.
Ret.ExistSCR & WetScrub 60	4916.	8936.	8936.	8936.	8936.
Ret.ExistSNCR & DryScrub 61	0.	0.	0.	0.	0.
Ret.ExistSNCR & WetScrub 62	101.	101.	101.	101.	101.
Ret.SCR 63	5063.	2701.	2663.	2663.	2663.
Ret.ExistDryScrub & SCR 64	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SCR 65	6434.	6434.	6434.	6434.	6434.
Ret.SNCR 66	56.	39.	39.	39.	39.
Ret.ExistDryScrub & SNCR 67	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SNCR 68	0.	0.	0.	0.	0.
Ret.FB-SNCR 69	0.	0.	0.	0.	0.
Ret.SCR+DryScrub 70	561.	1727.	1765.	1765.	1765.
Ret.SCR+WetScrub 71	1396.	2271.	2271.	2271.	2271.
Ret.SNCR+DryScrub 72	0.	0.	0.	0.	0.
Ret.SNCR+WetScrub 73	0.	0.	0.	0.	0.
Ret.ACI 74	1719.	6060.	7397.	7397.	7397.
Ret.ExistDryScrub&ACI 75	1215.	1698.	2115.	2115.	2115.
Ret.ExistWetScrub&ACI 76	0.	1319.	2969.	2969.	2969.
Ret.ExistSCR&ACI 77	1844.	5367.	5367.	5367.	5367.
Ret.ExistSNCR&ACI 78	515.	515.	515.	515.	515.
Ret.ACI & SCR 79	0.	414.	414.	414.	414.
Ret.ExistDryScrub&ACI&SNCR 80	363.	363.	363.	363.	363.
Ret.ExistWetScrub&ACI&SNCR 81	0.	0.	0.	0.	0.
Ret.ACI & SNCR 82	0.	16.	16.	16.	16.
Ret.ExistDryScrub&ACI&SNCR 83	0.	0.	0.	0.	0.

Ret.ExistWetScrub&ACI&SNCR	84	0.	0.	0.	0.	0.
Ret.ACI & DryScrub	85	0.	0.	0.	0.	0.
Ret.ACI & WetScrub	86	0.	0.	1472.	1472.	1472.
Ret.ExistSCR&ACI&DryScrub	87	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&WetScrub	88	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&DryScrub	89	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&WetScrub	90	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistDScrub&ACI	91	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistWScrub&ACI	92	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistDScrub&ACI	93	1540.	2111.	2111.	2111.	2111.
Ret.ExistSCR&ExistWScrub&ACI	94	1700.	2310.	2310.	2310.	2310.
Ret.SCR & DryScrub & ACI	95	0.	0.	0.	0.	0.
Ret.SCR & WetScrub & ACI	96	0.	0.	0.	0.	0.
Ret.SNCR & DryScrub & ACI	97	0.	0.	0.	0.	0.
Ret.SNCR & WetScrub & ACI	98	0.	0.	0.	0.	0.
Ret.O/G SCR	99	136.	136.	136.	136.	136.
Ret.O/G SNCR	100	0.	0.	0.	0.	0.
CT Early Retirement	101	1429.	1429.	1429.	1429.	1429.
CC Early Retirement	102	3062.	3890.	3890.	5938.	9253.
O/G Early Retirement	103	82700.	93348.	93755.	94978.	94998.
Coal Early Retirement	104	11345.	34155.	37194.	46580.	76600.
Nuke Early Retirement	105	0.	0.	0.	0.	0.
-----		-----	-----	-----	-----	-----
Total		1013229.	1025545.	1079214.	1160226.	1283562.

11. Capacity Additions and Changes
by Plant Type [MW]

by Plant Type [MW]		2010	2015	2020	2025	2032
New Scrubbed-Dry Coal_SCR_ACI	01	0.	0.	0.	0.	0.
New Scrubbed-Wet Coal_SCR	02	0.	0.	0.	0.	0.
New Comb.Cycle	03	0.	0.	2259.	12774.	19135.
New Comb.Cycle w/Seq	04	0.	0.	0.	0.	0.
New Combustion Turbine	05	0.	0.	0.	0.	0.
New Nuclear	06	0.	4000.	20000.	20000.	20000.
New Biomass	07	0.	0.	0.	6187.	34647.
New Fuel Cell	08	0.	0.	0.	0.	0.
New Geothermal	09	0.	0.	1245.	1785.	1879.
New IGCC	10	0.	0.	0.	0.	0.
New IGCC w/Seq	11	0.	5000.	5060.	10785.	26636.
New Landfill Gas	12	537.	526.	172.	2892.	927.
New Solar	13	0.	0.	0.	0.	0.
New Wind	14	36.	504.	9136.	20405.	11122.
Scrubbed-Wet Coal_SCR	15	0.	0.	0.	0.	0.
Scrubbed-Wet Coal_SNCR	16	0.	0.	0.	0.	0.
Scrubbed-Wet Coal	17	0.	0.	0.	0.	0.
Scrubbed-Dry Coal_SCR	18	0.	0.	0.	0.	0.
Scrubbed-Dry Coal_SNCR	19	0.	0.	0.	0.	0.
Scrubbed-Dry Coal	20	0.	0.	0.	0.	0.
Unscrubbed Coal_SCR	21	0.	0.	0.	0.	0.
Unscrubbed Coal_SNCR	22	0.	0.	0.	0.	0.
Unscrubbed Coal	23	0.	0.	0.	0.	0.
FB-Unscrubbed Coal	24	0.	0.	0.	0.	0.
FB-Unscrubbed Coal_SNCR	25	0.	0.	0.	0.	0.
FB-Scrubbed-Dry Coal	26	0.	0.	0.	0.	0.
Oil/Gas Steam	27	0.	0.	0.	0.	0.
Oil/Gas Steam_SCR	28	0.	0.	0.	0.	0.
Oil/Gas Steam_SNCR	29	0.	0.	0.	0.	0.
Nuclear	30	0.	0.	0.	0.	0.
Hydro	31	0.	0.	0.	0.	0.
Comb.Cycle	32	0.	0.	0.	0.	0.
IGCC	33	0.	0.	0.	0.	0.
Combustion Turbine	34	0.	0.	0.	0.	0.
Biomass	35	0.	0.	0.	0.	0.
Geothermal	36	0.	0.	0.	0.	0.
Landfill Gas	37	0.	0.	0.	0.	0.
Wind	38	0.	0.	0.	0.	0.
Fuel Cell	39	0.	0.	0.	0.	0.
Solar	40	0.	0.	0.	0.	0.
Non Fossil_Other	41	0.	0.	0.	0.	0.
Fossil_Other	42	0.	0.	0.	0.	0.
Pump Storage	43	0.	0.	0.	0.	0.
Int. Imports	44	0.	0.	0.	0.	0.
Cgn_CT	45	0.	0.	0.	0.	0.
Cgn_CC	46	0.	0.	0.	0.	0.
Cgn_Oil/Gas Steam	47	0.	0.	0.	0.	0.
Cgn_Biomass	48	0.	0.	0.	0.	0.
Cgn_Fossil_Other	49	0.	0.	0.	0.	0.
Cgn_NonFossil_Other	50	0.	0.	0.	0.	0.
Rep.Coal-CC	51	120.	962.	15282.	8777.	21872.
Rep.Coal-CC w/Seq	52	0.	0.	0.	0.	0.
Rep.O/G-CC	53	24734.	66.	7541.	556.	1808.
Rep.O/G-CC w/Seq	54	0.	0.	0.	0.	0.
Rep.Coal-IGCC	55	0.	0.	0.	0.	0.
Rep.Coal-IGCC w/Seq	56	0.	0.	0.	0.	0.
Ret.DryScrubber	57	777.	5433.	0.	2.	1534.
Ret.WetScrubber	58	3002.	2032.	0.	0.	0.
Ret.ExistSCR & DryScrub	59	0.	0.	0.	0.	0.
Ret.ExistSCR & WetScrub	60	4916.	4020.	0.	0.	0.
Ret.ExistSNCR & DryScrub	61	0.	0.	0.	0.	0.
Ret.ExistSNCR & WetScrub	62	101.	0.	0.	0.	0.
Ret.SCR	63	5063.	0.	0.	0.	0.
Ret.ExistDryScrub & SCR	64	363.	0.	0.	0.	0.
Ret.ExistWetScrub & SCR	65	6434.	0.	0.	0.	0.
Ret.SNCR	66	56.	0.	0.	0.	0.
Ret.ExistDryScrub & SNCR	67	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SNCR	68	0.	0.	0.	0.	0.
Ret.FB-SNCR	69	0.	0.	0.	0.	0.
Ret.SCR+DryScrub	70	561.	1166.	38.	0.	0.
Ret.SCR+WetScrub	71	1396.	876.	0.	0.	0.
Ret.SNCR+DryScrub	72	0.	0.	0.	0.	0.
Ret.SNCR+WetScrub	73	0.	0.	0.	0.	0.
Ret.ACI	74	1719.	4341.	1337.	0.	0.
Ret.ExistDryScrub&ACI	75	1215.	483.	417.	0.	0.
Ret.ExistWetScrub&ACI	76	0.	1319.	1650.	0.	0.
Ret.ExistSCR&ACI	77	1844.	3523.	0.	0.	0.
Ret.ExistSNCR&ACI	78	515.	0.	0.	0.	0.
Ret.ACI & SCR	79	0.	414.	0.	0.	0.
Ret.ExistDryScrub&ACI&SCR	80	363.	0.	0.	0.	0.
Ret.ExistWetScrub&ACI&SCR	81	0.	0.	0.	0.	0.
Ret.ACI & SNCR	82	0.	16.	0.	0.	0.

Ret.ExistDryScrub&ACI&SNCR	83	0.	0.	0.	0.	0.
Ret.ExistWetScrub&ACI&SNCR	84	0.	0.	0.	0.	0.
Ret.ACI & DryScrub	85	0.	0.	0.	0.	0.
Ret.ACI & WetScrub	86	0.	0.	1472.	0.	0.
Ret.ExistSCR&ACI&DryScrub	87	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&WetScrub	88	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&DryScrub	89	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&WetScrub	90	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistDScrub&ACI	91	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistWScrub&ACI	92	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistDScrub&ACI	93	1540.	571.	0.	0.	0.
Ret.ExistSCR&ExistWScrub&ACI	94	1700.	610.	0.	0.	0.
Ret.SCR & DryScrub & ACI	95	0.	0.	0.	0.	0.
Ret.SCR & WetScrub & ACI	96	0.	0.	0.	0.	0.
Ret.SNCR & DryScrub & ACI	97	0.	0.	0.	0.	0.
Ret.SNCR & WetScrub & ACI	98	0.	0.	0.	0.	0.
Ret.O/G SCR	99	136.	0.	0.	0.	0.
Ret.O/G SNCR	100	0.	0.	0.	0.	0.
CT Early Retirement	101	1429.	0.	0.	0.	0.
CC Early Retirement	102	3062.	828.	0.	2048.	3315.
O/G Early Retirement	103	82700.	10648.	407.	1223.	20.
Coal Early Retirement	104	11345.	22810.	3039.	9386.	30021.
Nuke Early Retirement	105	0.	0.	0.	0.	0.
-----		-----	-----	-----	-----	-----
Total		155665.	70148.	69056.	96819.	172915.

12. Generation by Plant Type [GWh]	2010	2015	2020	2025	2032	
New Scrubbed-Dry Coal_SCR_ACI	01	0.	0.	0.	0.	
New Scrubbed-Wet Coal_SCR	02	0.	0.	0.	0.	
New Comb.Cycle	03	0.	0.	17219.	114588.	260448.
New Comb.Cycle w/Seq	04	0.	0.	0.	0.	0.
New Combustion Turbine	05	0.	0.	0.	0.	0.
New Nuclear	06	0.	31524.	189146.	346767.	504389.
New Biomass	07	0.	0.	0.	44983.	296891.
New Fuel Cell	08	0.	0.	0.	0.	0.
New Geothermal	09	0.	0.	9491.	23095.	37417.
New IGCC	10	0.	0.	0.	0.	0.
New IGCC w/Seq	11	0.	37227.	74901.	155194.	353507.
New Landfill Gas	12	4234.	8381.	9737.	32537.	39846.
New Solar	13	0.	0.	0.	0.	0.
New Wind	14	130.	1942.	34113.	101017.	136325.
Scrubbed-Wet Coal_SCR	15	552746.	537477.	534164.	528104.	451246.
Scrubbed-Wet Coal_SNCR	16	31123.	28638.	27417.	22819.	18674.
Scrubbed-Wet Coal	17	350761.	307099.	257149.	228190.	122816.
Scrubbed-Dry Coal_SCR	18	27684.	22753.	22331.	21402.	17152.
Scrubbed-Dry Coal_SNCR	19	1859.	1455.	0.	0.	0.
Scrubbed-Dry Coal	20	74502.	68109.	64619.	62651.	25024.
Unscrubbed Coal_SCR	21	150049.	78398.	76659.	69307.	58604.
Unscrubbed Coal_SNCR	22	43461.	35753.	29971.	25702.	20599.
Unscrubbed Coal	23	735527.	528752.	480690.	421704.	323941.
FB-Unscrubbed Coal	24	23910.	18886.	16906.	13158.	5662.
FB-Unscrubbed Coal_SNCR	25	16361.	15782.	15688.	15264.	14020.
FB-Scrubbed-Dry Coal	26	376.	376.	376.	376.	0.
Oil/Gas Steam	27	21505.	4981.	2100.	1513.	1085.
Oil/Gas Steam_SCR	28	1362.	0.	0.	0.	0.
Oil/Gas Steam_SNCR	29	0.	0.	0.	0.	0.
Nuclear	30	796986.	805252.	812811.	812811.	761826.
Hydro	31	252772.	252912.	252912.	252912.	252912.
Comb.Cycle	32	507929.	558561.	482478.	329804.	202836.
IGCC	33	8302.	6403.	6403.	6403.	5770.
Combustion Turbine	34	10510.	10972.	8438.	7507.	6814.
Biomass	35	8456.	9061.	9416.	9717.	9782.
Geothermal	36	15885.	16437.	16437.	16437.	16437.
Landfill Gas	37	5222.	5339.	5339.	5339.	5339.
Wind	38	49848.	52794.	52794.	52794.	52794.
Fuel Cell	39	0.	0.	0.	0.	0.
Solar	40	932.	1152.	1413.	1704.	1990.
Non Fossil_Other	41	11630.	11630.	11630.	11630.	11630.
Fossil_Other	42	579.	273.	233.	88.	11.
Pump Storage	43	19302.	10168.	8945.	7636.	5730.
Int. Imports	44	24887.	25005.	21392.	22207.	21453.
Cgn_CT	45	419.	363.	314.	261.	174.
Cgn_CC	46	56828.	50697.	48528.	35228.	28395.
Cgn_Oil/Gas Steam	47	757.	0.	0.	0.	0.
Cgn_Biomass	48	5414.	5565.	5724.	5718.	5604.
Cgn_Fossil_Other	49	1229.	114.	28.	11.	1.
Cgn_NonFossil_Other	50	4089.	4089.	4089.	4089.	4089.
Rep.Coal-CC	51	904.	8235.	118456.	179558.	331883.
Rep.Coal-CC w/Seq	52	0.	0.	0.	0.	0.
Rep.O/G-CC	53	157086.	175074.	229504.	223646.	217592.
Rep.O/G-CC w/Seq	54	0.	0.	0.	0.	0.
Rep.Coal-IGCC	55	0.	0.	0.	0.	0.
Rep.Coal-IGCC w/Seq	56	0.	0.	0.	0.	0.
Ret.DryScrubber	57	5601.	45468.	45549.	45222.	45414.
Ret.WetScrubber	58	21294.	36236.	25413.	25413.	25184.
Ret.ExistSCR & DryScrub	59	0.	0.	0.	0.	0.
Ret.ExistSCR & WetScrub	60	36175.	63629.	64046.	63221.	55563.
Ret.ExistSNCR & DryScrub	61	0.	0.	0.	0.	0.
Ret.ExistSNCR & WetScrub	62	756.	714.	694.	660.	660.
Ret.SCR	63	37240.	19652.	18951.	17290.	14665.
Ret.ExistDryScrub & SCR	64	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SCR	65	47385.	45179.	45523.	43352.	33463.
Ret.SNCR	66	410.	294.	267.	249.	218.
Ret.ExistDryScrub & SNCR	67	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SNCR	68	0.	0.	0.	0.	0.
Ret.FB-SNCR	69	0.	0.	0.	0.	0.
Ret.SCR+DryScrub	70	4143.	12600.	12694.	12180.	7407.
Ret.SCR+WetScrub	71	10272.	16233.	16096.	15697.	12407.
Ret.SNCR+DryScrub	72	0.	0.	0.	0.	0.
Ret.SNCR+WetScrub	73	0.	0.	0.	0.	0.
Ret.ACI	74	12603.	44302.	53646.	53404.	47739.
Ret.ExistDryScrub&ACI	75	8946.	11427.	11963.	11740.	9817.
Ret.ExistWetScrub&ACI	76	0.	9695.	21816.	21816.	16906.
Ret.ExistSCR&ACI	77	13768.	39201.	38424.	36651.	32767.
Ret.ExistSNCR&ACI	78	3807.	3685.	3394.	3047.	2424.
Ret.ACI & SCR	79	1.	2519.	2263.	2263.	1909.
Ret.ExistDryScrub&ACI&SCR	80	2670.	2215.	1058.	1042.	694.
Ret.ExistWetScrub&ACI&SCR	81	0.	0.	0.	0.	0.
Ret.ACI & SNCR	82	0.	88.	98.	88.	77.
Ret.ExistDryScrub&ACI&SNCR	83	0.	0.	0.	0.	0.

Ret.ExistWetScrub&ACI&SNCR	84	0.	0.	0.	0.	0.
Ret.ACI & DryScrub	85	0.	0.	0.	0.	0.
Ret.ACI & WetScrub	86	0.	0.	10823.	10823.	8495.
Ret.ExistSCR&ACI&DryScrub	87	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&WetScrub	88	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&DryScrub	89	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&WetScrub	90	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistDScrub&ACI	91	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistWScrub&ACI	92	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistDScrub&ACI	93	11325.	15520.	15520.	15520.	14989.
Ret.ExistSCR&ExistWScrub&ACI	94	12776.	17263.	17263.	16944.	16313.
Ret.SCR & DryScrub & ACI	95	0.	0.	0.	0.	0.
Ret.SCR & WetScrub & ACI	96	0.	0.	0.	0.	0.
Ret.SNCR & DryScrub & ACI	97	0.	0.	0.	0.	0.
Ret.SNCR & WetScrub & ACI	98	0.	0.	0.	0.	0.
Ret.O/G SCR	99	999.	0.	0.	0.	0.
Ret.O/G SNCR	100	0.	0.	0.	0.	0.
CT Early Retirement	101	0.	0.	0.	0.	0.
CC Early Retirement	102	0.	0.	0.	0.	0.
O/G Early Retirement	103	0.	0.	0.	0.	0.
Coal Early Retirement	104	0.	0.	0.	0.	0.
Nuke Early Retirement	105	0.	0.	0.	0.	0.
-----		-----	-----	-----	-----	-----
Total		4205723.	4123551.	4365459.	4610494.	4977821.

12a. Generation by Fuel Type [GWh]	2010	2015	2020	2025	2032
-----	-----	-----	-----	-----	-----
Coal	2211115.	2019167.	1919423.	1801131.	1555975.
Nuclear	796986.	836776.	1001957.	1159578.	1266215.
Hydro	272074.	263080.	261857.	260548.	258643.
NaturalGas	740008.	806720.	906396.	891602.	1048752.
Non-Fossil	3624.	3624.	3624.	3624.	3624.
None	24887.	25005.	21392.	22207.	21453.
Biomass	13962.	37937.	80854.	202668.	501222.
Fwaste	1808.	387.	261.	98.	12.
Geothermal	15885.	16437.	25928.	39532.	53854.
LF Gas	9456.	13720.	15076.	37876.	45185.
Pet. Coke	18583.	17175.	15700.	14512.	12103.
Waste Coal	16040.	13376.	11937.	9002.	7103.
MSW	12096.	12096.	12096.	12096.	12096.
Oil	18289.	2162.	641.	504.	475.
Wind	49978.	54736.	86907.	153811.	189119.
Solar	932.	1152.	1413.	1704.	1990.
Other	0.	0.	0.	0.	0.
-----	-----	-----	-----	-----	-----
Total	4205723.	4123551.	4365459.	4610494.	4977821.

13. Generation by Plant Type [Tbtu]	2010	2015	2020	2025	2032
New Scrubbed-Dry Coal_SCR_ACI 01	0.	0.	0.	0.	0.
New Scrubbed-Wet Coal_SCR 02	0.	0.	0.	0.	0.
New Comb.Cycle 03	0.	0.	59.	391.	889.
New Comb.Cycle w/Seq 04	0.	0.	0.	0.	0.
New Combustion Turbine 05	0.	0.	0.	0.	0.
New Nuclear 06	0.	108.	645.	1183.	1721.
New Biomass 07	0.	0.	0.	153.	1013.
New Fuel Cell 08	0.	0.	0.	0.	0.
New Geothermal 09	0.	0.	32.	79.	128.
New IGCC 10	0.	0.	0.	0.	0.
New IGCC w/Seq 11	0.	127.	256.	530.	1206.
New Landfill Gas 12	14.	29.	33.	111.	136.
New Solar 13	0.	0.	0.	0.	0.
New Wind 14	0.	7.	116.	345.	465.
Scrubbed-Wet Coal_SCR 15	1886.	1834.	1823.	1802.	1540.
Scrubbed-Wet Coal_SNCR 16	106.	98.	94.	78.	64.
Scrubbed-Wet Coal 17	1197.	1048.	877.	779.	419.
Scrubbed-Dry Coal_SCR 18	94.	78.	76.	73.	59.
Scrubbed-Dry Coal_SNCR 19	6.	5.	0.	0.	0.
Scrubbed-Dry Coal 20	254.	232.	220.	214.	85.
Unscrubbed Coal_SCR 21	512.	267.	262.	236.	200.
Unscrubbed Coal_SNCR 22	148.	122.	102.	88.	70.
Unscrubbed Coal 23	2510.	1804.	1640.	1439.	1105.
FB-Unscrubbed Coal 24	82.	64.	58.	45.	19.
FB-Unscrubbed Coal_SNCR 25	56.	54.	54.	52.	48.
FB-Scrubbed-Dry Coal 26	1.	1.	1.	1.	0.
Oil/Gas Steam 27	73.	17.	7.	5.	4.
Oil/Gas Steam_SCR 28	5.	0.	0.	0.	0.
Oil/Gas Steam_SNCR 29	0.	0.	0.	0.	0.
Nuclear 30	2719.	2748.	2773.	2773.	2599.
Hydro 31	862.	863.	863.	863.	863.
Comb.Cycle 32	1733.	1906.	1646.	1125.	692.
IGCC 33	28.	22.	22.	22.	20.
Combustion Turbine 34	36.	37.	29.	26.	23.
Biomass 35	29.	31.	32.	33.	33.
Geothermal 36	54.	56.	56.	56.	56.
Landfill Gas 37	18.	18.	18.	18.	18.
Wind 38	170.	180.	180.	180.	180.
Fuel Cell 39	0.	0.	0.	0.	0.
Solar 40	3.	4.	5.	6.	7.
Non Fossil_Other 41	40.	40.	40.	40.	40.
Fossil_Other 42	2.	1.	1.	0.	0.
Pump Storage 43	66.	35.	31.	26.	20.
Int. Imports 44	85.	85.	73.	76.	73.
Cgn_CT 45	1.	1.	1.	1.	1.
Cgn_CC 46	194.	173.	166.	120.	97.
Cgn_Oil/Gas Steam 47	3.	0.	0.	0.	0.
Cgn_Biomass 48	18.	19.	20.	20.	19.
Cgn_Fossil_Other 49	4.	0.	0.	0.	0.
Cgn_NonFossil_Other 50	14.	14.	14.	14.	14.
Rep.Coal-CC 51	3.	28.	404.	613.	1132.
Rep.Coal-CC w/Seq 52	0.	0.	0.	0.	0.
Rep.O/G-CC 53	536.	597.	783.	763.	742.
Rep.O/G-CC w/Seq 54	0.	0.	0.	0.	0.
Rep.Coal-IGCC 55	0.	0.	0.	0.	0.
Rep.Coal-IGCC w/Seq 56	0.	0.	0.	0.	0.
Ret.DryScrubber 57	19.	155.	155.	154.	155.
Ret.WetScrubber 58	73.	124.	87.	87.	86.
Ret.ExistSCR & DryScrub 59	0.	0.	0.	0.	0.
Ret.ExistSCR & WetScrub 60	123.	217.	219.	216.	190.
Ret.ExistSNCR & DryScrub 61	0.	0.	0.	0.	0.
Ret.ExistSNCR & WetScrub 62	3.	2.	2.	2.	2.
Ret.SCR 63	127.	67.	65.	59.	50.
Ret.ExistDryScrub & SCR 64	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SCR 65	162.	154.	155.	148.	114.
Ret.SNCR 66	1.	1.	1.	1.	1.
Ret.ExistDryScrub & SNCR 67	0.	0.	0.	0.	0.
Ret.ExistWetScrub & SNCR 68	0.	0.	0.	0.	0.
Ret.FB-SNCR 69	0.	0.	0.	0.	0.
Ret.SCR+DryScrub 70	14.	43.	43.	42.	25.
Ret.SCR+WetScrub 71	35.	55.	55.	54.	42.
Ret.SNCR+DryScrub 72	0.	0.	0.	0.	0.
Ret.SNCR+WetScrub 73	0.	0.	0.	0.	0.
Ret.ACI 74	43.	151.	183.	182.	163.
Ret.ExistDryScrub&ACI 75	31.	39.	41.	40.	33.
Ret.ExistWetScrub&ACI 76	0.	33.	74.	74.	58.
Ret.ExistSCR&ACI 77	47.	134.	131.	125.	112.
Ret.ExistSNCR&ACI 78	13.	13.	12.	10.	8.
Ret.ACI & SCR 79	0.	9.	8.	8.	7.
Ret.ExistDryScrub&ACI&SNCR 80	9.	8.	4.	4.	2.
Ret.ExistWetScrub&ACI&SNCR 81	0.	0.	0.	0.	0.
Ret.ACI & SNCR 82	0.	0.	0.	0.	0.
Ret.ExistDryScrub&ACI&SNCR 83	0.	0.	0.	0.	0.

Ret.ExistWetScrub&ACI&SNCR	84	0.	0.	0.	0.	0.
Ret.ACI & DryScrub	85	0.	0.	0.	0.	0.
Ret.ACI & WetScrub	86	0.	0.	37.	37.	29.
Ret.ExistSCR&ACI&DryScrub	87	0.	0.	0.	0.	0.
Ret.ExistSCR&ACI&WetScrub	88	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&DryScrub	89	0.	0.	0.	0.	0.
Ret.ExistSNCR&ACI&WetScrub	90	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistDScrub&ACI	91	0.	0.	0.	0.	0.
Ret.ExistSNCR&ExistWScrub&ACI	92	0.	0.	0.	0.	0.
Ret.ExistSCR&ExistDScrub&ACI	93	39.	53.	53.	53.	51.
Ret.ExistSCR&ExistWScrub&ACI	94	44.	59.	59.	58.	56.
Ret.SCR & DryScrub & ACI	95	0.	0.	0.	0.	0.
Ret.SCR & WetScrub & ACI	96	0.	0.	0.	0.	0.
Ret.SNCR & DryScrub & ACI	97	0.	0.	0.	0.	0.
Ret.SNCR & WetScrub & ACI	98	0.	0.	0.	0.	0.
Ret.O/G SCR	99	3.	0.	0.	0.	0.
Ret.O/G SNCR	100	0.	0.	0.	0.	0.
CT Early Retirement	101	0.	0.	0.	0.	0.
CC Early Retirement	102	0.	0.	0.	0.	0.
O/G Early Retirement	103	0.	0.	0.	0.	0.
Coal Early Retirement	104	0.	0.	0.	0.	0.
Nuke Early Retirement	105	0.	0.	0.	0.	0.
-----		-----	-----	-----	-----	-----
Total		14350.	14070.	14895.	15731.	16984.

14. Capacity Factor by Plant Type [%]	2010	2015	2020	2025	2032
New Scrubbed-Dry Coal_SCR_ACI	01	N/A	N/A	N/A	N/A
New Scrubbed-Wet Coal_SCR	02	N/A	N/A	N/A	N/A
New Comb.Cycle	03	N/A	N/A	87.0	87.0
New Comb.Cycle w/Seq	04	N/A	N/A	N/A	N/A
New Combustion Turbine	05	N/A	N/A	N/A	N/A
New Nuclear	06	N/A	90.0	90.0	90.0
New Biomass	07	N/A	N/A	N/A	83.0
New Fuel Cell	08	N/A	N/A	N/A	N/A
New Geothermal	09	N/A	N/A	87.0	87.0
New IGCC	10	N/A	N/A	N/A	N/A
New IGCC w/Seq	11	N/A	85.0	85.0	85.0
New Landfill Gas	12	90.0	90.0	90.0	90.0
New Solar	13	N/A	N/A	N/A	N/A
New Wind	14	40.7	41.0	40.2	38.3
Scrubbed-Wet Coal_SCR	15	83.7	82.8	82.5	81.7
Scrubbed-Wet Coal_SNCR	16	83.6	82.8	79.3	80.8
Scrubbed-Wet Coal	17	83.5	79.8	78.9	77.7
Scrubbed-Dry Coal_SCR	18	84.0	81.4	79.9	76.6
Scrubbed-Dry Coal_SNCR	19	83.9	65.7	N/A	N/A
Scrubbed-Dry Coal	20	83.1	83.2	82.6	81.3
Unscrubbed Coal_SCR	21	82.3	80.5	78.8	72.3
Unscrubbed Coal_SNCR	22	80.7	75.5	71.8	68.0
Unscrubbed Coal	23	81.0	79.6	75.6	73.1
FB-Unscrubbed Coal	24	85.4	75.6	75.7	70.3
FB-Unscrubbed Coal_SNCR	25	84.9	84.9	84.4	82.2
FB-Scrubbed-Dry Coal	26	85.8	85.8	85.8	85.8
Oil/Gas Steam	27	11.0	4.4	2.0	1.6
Oil/Gas Steam_SCR	28	3.5	0.0	0.0	0.0
Oil/Gas Steam_SNCR	29	0.0	0.0	0.0	0.0
Nuclear	30	90.1	90.3	90.3	90.3
Hydro	31	36.9	36.9	36.9	36.9
Comb.Cycle	32	39.6	43.8	37.8	26.2
IGCC	33	85.0	85.0	85.0	85.0
Combustion Turbine	34	0.9	1.0	0.7	0.7
Biomass	35	63.5	68.0	70.7	73.0
Geothermal	36	79.0	79.1	79.1	79.1
Landfill Gas	37	56.2	56.1	56.1	56.1
Wind	38	35.1	35.3	35.3	35.3
Fuel Cell	39	0.2	0.2	0.0	0.0
Solar	40	20.0	21.4	22.6	23.6
Non Fossil_Other	41	65.9	65.9	65.9	65.9
Fossil_Other	42	41.0	19.4	16.5	6.2
Pump Storage	43	10.8	5.7	5.0	4.3
Int. Imports	44	51.2	51.4	44.0	45.7
Cgn_CT	45	0.9	0.8	0.7	0.6
Cgn_CC	46	17.1	15.2	14.6	10.6
Cgn_Oil/Gas Steam	47	40.0	0.0	0.0	0.0
Cgn_Biomass	48	77.7	79.9	82.2	82.1
Cgn_Fossil_Other	49	41.0	3.8	0.9	0.4
Cgn_NonFossil_Other	50	64.4	64.4	64.4	64.4
Rep.Coal-CC	51	86.1	86.9	82.6	81.5
Rep.Coal-CC w/Seq	52	N/A	N/A	N/A	N/A
Rep.O/G-CC	53	72.5	80.6	81.0	77.6
Rep.O/G-CC w/Seq	54	N/A	N/A	N/A	N/A
Rep.Coal-IGCC	55	N/A	N/A	N/A	N/A
Rep.Coal-IGCC w/Seq	56	N/A	N/A	N/A	N/A
Ret.DryScrubber	57	82.3	83.6	83.7	83.1
Ret.WetScrubber	58	81.0	82.2	81.4	81.4
Ret.ExistSCR & DryScrub	59	N/A	N/A	N/A	N/A
Ret.ExistSCR & WetScrub	60	84.0	81.3	81.8	80.8
Ret.ExistSNCR & DryScrub	61	N/A	N/A	N/A	N/A
Ret.ExistSNCR & WetScrub	62	85.4	80.7	78.5	74.6
Ret.SCR	63	84.0	83.1	81.2	74.1
Ret.ExistDryScrub & SCR	64	84.1	84.1	84.1	84.1
Ret.ExistWetScrub & SCR	65	84.1	80.2	80.8	76.9
Ret.SNCR	66	84.0	85.4	77.5	72.2
Ret.ExistDryScrub & SNCR	67	N/A	N/A	N/A	N/A
Ret.ExistWetScrub & SNCR	68	N/A	N/A	N/A	N/A
Ret.FB-SNCR	69	N/A	N/A	N/A	N/A
Ret.SCR+DryScrub	70	84.3	83.3	82.1	78.8
Ret.SCR+WetScrub	71	84.0	81.6	80.9	78.9
Ret.SNCR+DryScrub	72	N/A	N/A	N/A	N/A
Ret.SNCR+WetScrub	73	N/A	N/A	N/A	N/A
Ret.ACI	74	83.7	83.5	82.8	82.4
Ret.ExistDryScrub&ACI	75	84.0	76.8	64.6	63.3
Ret.ExistWetScrub&ACI	76	N/A	83.9	83.9	83.9
Ret.ExistSCR&ACI	77	85.2	83.4	81.7	78.0
Ret.ExistSNCR&ACI	78	84.4	81.7	75.2	67.5
Ret.ACI & SCR	79	84.1	69.5	62.4	62.4
Ret.ExistDryScrub&ACI&SCR	80	84.0	69.7	33.3	32.8
Ret.ExistWetScrub&ACI&SCR	81	N/A	N/A	N/A	N/A
Ret.ACI & SNCR	82	N/A	61.6	69.0	61.6
Ret.ExistDryScrub&ACI&SNCR	83	N/A	N/A	N/A	N/A

Ret.ExistWetScrub&ACI&SNCR	84	N/A	N/A	N/A	N/A	N/A
Ret.ACI & DryScrub	85	N/A	N/A	N/A	N/A	N/A
Ret.ACI & WetScrub	86	N/A	N/A	83.9	83.9	65.9
Ret.ExistSCR&ACI&DryScrub	87	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ACI&WetScrub	88	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI&DryScrub	89	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ACI&WetScrub	90	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ExistDScrub&ACI	91	N/A	N/A	N/A	N/A	N/A
Ret.ExistSNCR&ExistWScrub&ACI	92	N/A	N/A	N/A	N/A	N/A
Ret.ExistSCR&ExistDScrub&ACI	93	84.0	83.9	83.9	83.9	81.1
Ret.ExistSCR&ExistWScrub&ACI	94	85.8	85.3	85.3	83.7	80.6
Ret.SCR & DryScrub & ACI	95	N/A	N/A	N/A	N/A	N/A
Ret.SCR & WetScrub & ACI	96	N/A	N/A	N/A	N/A	N/A
Ret.SNCR & DryScrub & ACI	97	N/A	N/A	N/A	N/A	N/A
Ret.SNCR & WetScrub & ACI	98	N/A	N/A	N/A	N/A	N/A
Ret.O/G SCR	99	83.7	0.0	0.0	0.0	0.0
Ret.O/G SNCR	100	N/A	N/A	N/A	N/A	N/A
CT Early Retirement	101	0.0	0.0	0.0	0.0	0.0
CC Early Retirement	102	0.0	0.0	0.0	0.0	0.0
O/G Early Retirement	103	0.0	0.0	0.0	0.0	0.0
Coal Early Retirement	104	0.0	0.0	0.0	0.0	0.0
Nuke Early Retirement	105	N/A	N/A	N/A	N/A	N/A
-----		-----	-----	-----	-----	-----
Average		47.4	45.9	46.2	45.4	44.3

15. Total Annual Production Cost [MMUS\$](*)	2010	2015	2020	2025	2032
Variable O&M	8994.3	9364.4	9791.7	10696.2	13910.2
Fixed O&M	34001.5	33863.0	36117.0	38650.6	42125.9
Fuel	71208.3	64938.1	70188.1	75796.8	88606.2
Capital	2332.0	5670.4	18104.3	38104.6	70774.6
Total	116536.1	113835.8	134201.1	163248.1	215416.8

16. Emissions	2010	2015	2020	2025	2032
CO2 [MMTonnes]	2490.7991	2258.7472	2148.0415	1955.2204	1583.7963
Carbon [MMTonnes]	679.3089	616.0220	585.8295	533.2419	431.9444
MER [Tons]	38.0780	29.7598	25.5402	22.2417	18.6604
NOX [MTons]	2497.3747	2043.1268	1910.4660	1775.6205	1371.6575
SO2 [MTons]	6626.7321	4712.5590	4160.0501	3559.3546	3216.2147
TSP [MTons]	0.0000	0.0000	0.0000	0.0000	0.0000

Fuel Consumption by Fuel and Fuel Type [TBtu]

Fuel	2010	2015	2020	2025	2032
Coal	22777.8	20550.9	19401.7	17986.2	15179.7
Nuclear	8104.8	8516.2	10231.8	11871.1	12995.1
NaturalGas	5323.0	5770.5	6331.9	6084.0	6982.0
Biomass	206.9	456.5	894.0	2070.8	4766.8
Pet. Coke	179.8	161.6	144.7	133.2	107.5
Waste Coal	182.6	148.7	130.9	95.1	74.1
Oil	199.6	22.5	6.8	5.4	5.1

Fuel Costs by Fuel and Fuel Type [MMUS\$]

Fuel	2010	2015	2020	2025	2032
Coal	33720.4	28260.6	25884.3	23527.4	18022.0
Nuclear	4251.8	4835.5	6145.2	7235.4	7746.4
NaturalGas	31491.5	29946.5	34401.8	36382.3	43831.7
Biomass	368.2	1416.5	3395.9	8347.5	18760.6
Pet. Coke	225.5	202.7	181.5	167.1	134.8
Waste Coal	231.9	171.8	143.0	104.6	79.3
Oil	919.0	104.5	36.2	32.4	31.4

Fuel Costs by Fuel and Fuel Type [US\$/MMBtu]

Fuel	2010	2015	2020	2025	2032
Coal	1.48	1.38	1.33	1.31	1.19
Nuclear	0.52	0.57	0.60	0.61	0.60
NaturalGas	5.92	5.19	5.43	5.98	6.28
Biomass	1.78	3.10	3.80	4.03	3.94
Pet. Coke	1.25	1.25	1.25	1.25	1.25
Waste Coal	1.27	1.16	1.09	1.10	1.07
Oil	4.60	4.64	5.33	5.99	6.16

Environmental Measures Report

Constraint Name: #0 - National CO2 Cap - Liebermann-Warner
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 1

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [MTons]	0.000	0.2331E+07	0.2129E+07	0.1922E+07	0.1537E+07
-Less Allowances Purchased [MTons] CO2	0.000	-0.2331E+07	-0.2129E+07	-0.1922E+07	-0.1537E+07
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	-0.4226E-01	-0.3577E-01	-0.1463E-01	-0.1666E-01
TBtu Consumed	0.000	0.1371E+05	5851.	6959.	8377.
Rate - [lb/MMBtu]	0.000	340.2	727.6	552.3	366.9
TWh Generated	0.000	1375.	493.3	629.5	1068.
TWh Generated Qualifying	0.000	-0.2882E+07	-0.2920E+07	-0.2859E+07	-0.2813E+07
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	19.51	24.87	31.70	44.82

Constraint Name: #0 - National CO2 Bonus Cap - Liebermann-Warner Constraint #: 2

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.000	0.2406E+06	0.2171E+06	0.1936E+06	0.1632E+06
-Emissions at Affected Plants [MTons]	0.000	0.1374E+06	0.2171E+06	0.1936E+06	0.1632E+06
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.1374E+06	0.2171E+06	0.1936E+06	0.1632E+06
TBtu Consumed	0.000	0.1319E+05	0.2083E+05	0.1878E+05	0.1586E+05
Rate - [lb/MMBtu]	0.000	20.84	20.84	20.61	20.58
TWh Generated	0.000	1508.	2427.	2230.	1745.
TWh Generated Qualifying	0.000	-0.3723E+05	-0.7490E+05	-0.1180E+06	-0.2786E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	18.76	29.26	44.37

Constraint Name: SO2 CAIR Constraint					
	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Total Title IV Emissions	6331	4561	4013	3426	3141
MTons Banked	2104	0	0	0	0
MTons Withdrawn	0	-786.5	-723.8	-172.9	0
Non CAIR Rate - [lb/MMBtu]	0.25	0.14	0.13	0.11	0.07
CAIR Rate - [lb/MMBtu]	0.51	0.41	0.37	0.32	0.33
Non CAIR - TBtu Consumed	7,144	6,784	6,937	6,678	6,357
CAIR - TBtu Consumed	21,211	19,928	19,584	18,924	17,847
Non-CAIR Shadow Price (US\$/Ton)	124.9	109.2	124.4	161.0	44.5
CAIR Shadow Price (US\$/Ton)	218.5	275.2	355.9	460.4	127.2

Constraint Name: #2 - NOx CAIR Annual Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 6

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	1572.	1370.	1268.	1268.	1268.
-Emissions at Affected Plants [MTons]	1571.	1365.	1272.	1170.	926.9
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	4.141	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	-4.141	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1571.	1370.	1268.	1170.	926.9
TBtu Consumed	0.2121E+05	0.1993E+05	0.1958E+05	0.1892E+05	0.1784E+05
Rate - [lb/MMBtu]	0.1482	0.1370	0.1299	0.1237	0.1039
TWh Generated	2191.	2104.	2103.	2056.	1987.
TWh Generated Qualifying	-0.2191E+07	-0.2115E+07	-0.2131E+07	-0.2136E+07	-0.2130E+07
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2152.	141.8	183.5	0.000	0.000

Constraint Name: #3 - NOx SIP CALL and Summer CAIR Constraint Constraint #: 7
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	568.0	518.2	485.0	485.0	485.0
-Emissions at Affected Plants [MTons]	568.0	501.3	473.7	443.3	351.6
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	11.32	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	568.0	501.3	485.0	443.3	351.6
TBtu Consumed	7864.	7319.	7195.	6929.	6386.
Rate - [lb/MMBtu]	0.1445	0.1370	0.1317	0.1280	0.1101
TWh Generated	814.3	772.0	764.9	738.1	690.8
TWh Generated Qualifying	-0.8143E+06	-0.7760E+06	-0.7726E+06	-0.7597E+06	-0.7465E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2423.	0.000	0.000	0.000	0.000

Constraint Name: #4 - NOx SIPCall Rhode Island Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Constraint #: 8

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.9970	0.9970	0.9970	0.9970	0.9970
-Emissions at Affected Plants [MTons]	0.1629	0.1505	0.1448	0.9513E-01	0.1885E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.8465	0.8522	0.9019	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1629	0.9970	0.9970	0.9970	0.1885E-01
TBTu Consumed	19.89	19.24	18.43	12.92	2.693
Rate - [lb/MMBTu]	0.1638E-01	0.1564E-01	0.1571E-01	0.1472E-01	0.1400E-01
TWh Generated	2.698	2.621	2.510	1.769	0.3703
TWh Generated Qualifying	-2698.	-2621.	-2509.	-1769.	-370.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #5 - MER National Constraint

Constraint #: 9

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	0.7600E+05	0.7600E+05	0.3000E+05	0.3000E+05	0.3000E+05
-Emissions at Affected Plants [Lb]	0.7099E+05	0.5559E+05	0.4618E+05	0.3823E+05	0.3000E+05
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	5010.	0.2041E+05	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	-0.1618E+05	-8231.	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.7600E+05	0.7600E+05	0.3000E+05	0.3000E+05	0.3000E+05
TBtu Consumed	0.2279E+05	0.2093E+05	0.2091E+05	0.2064E+05	0.1933E+05
Rate - [lb/MMBtu]	0.3115E-05	0.2657E-05	0.2209E-05	0.1852E-05	0.1552E-05
TWh Generated	2216.	2061.	2112.	2129.	2088.
TWh Generated Qualifying	-0.2216E+07	-0.2061E+07	-0.2112E+07	-0.2129E+07	-0.2088E+07
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3474E+05	0.4374E+05	0.5658E+05	0.7318E+05	0.1262E+05

Constraint Name: #6 - WRAP SO2 Policy Case Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 10

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.000	0.000	198.9	198.9	198.9
-Emissions at Affected Plants [MTons]	0.000	0.000	136.4	137.7	87.49
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	61.17	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	136.4	198.9	87.49
TBtu Consumed	0.000	0.000	1992.	1954.	1910.
Rate - [lb/MMBtu]	0.000	0.000	0.1370	0.1410	0.9160E-01
TWh Generated	0.000	0.000	225.8	226.4	245.1
TWh Generated Qualifying	0.000	0.000	-0.2471E+06	-0.2746E+06	-0.3526E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (CJN) Constraint #: 11
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4965.	4361.	3438.	3227.

Constraint Name: #7 - BART SO2 Constraint (CJO) Constraint #: 12
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3000.	1905.	1182.	1657.

Constraint Name: #7 - BART SO2 Constraint (CJP) Constraint #: 13
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3028.	2312.	1610.	995.0

Constraint Name: #7 - BART SO2 Constraint (CMZ) Constraint #: 14
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.7631	0.7631	0.6521	0.2437
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.7631	0.7631	0.6521	0.2437
TBtu Consumed	0.000	19.59	19.59	16.74	6.509
Rate - [lb/MMBtu]	0.000	0.7792E-01	0.7792E-01	0.7792E-01	0.7489E-01
TWh Generated	0.000	1.754	1.754	1.499	0.5829
TWh Generated Qualifying	0.000	-1754.	-1754.	-1499.	-582.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (CNB) Constraint #: 15
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.391	1.375	1.375	0.9922
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.391	1.375	1.375	0.9922
TBtu Consumed	0.000	18.55	18.33	18.33	13.23
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	1.643	1.624	1.624	1.172
TWh Generated Qualifying	0.000	-1643.	-1624.	-1624.	-1172.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2022.	3229.	1422.	279.1

Constraint Name: #7 - BART SO2 Constraint (CNC) Constraint #: 16
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.742	2.735	2.746	1.981
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.742	2.735	2.746	1.981
TBtu Consumed	0.000	36.56	36.46	36.61	26.42
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	3.256	3.248	3.261	2.353
TWh Generated Qualifying	0.000	-3256.	-3248.	-3261.	-2353.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2022.	3048.	0.000	132.6

Constraint Name: #7 - BART SO2 Constraint (CON)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 17

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.658	2.679	2.527	0.8804
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.658	2.679	2.527	0.8804
TBtu Consumed	0.000	35.43	35.73	33.70	11.74
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	3.271	3.296	3.109	1.083
TWh Generated Qualifying	0.000	-3271.	-3296.	-3109.	-1083.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1370.	2205.	1940.	411.9

Constraint Name: #7 - BART SO2 Constraint (COX) Constraint #: 18
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	3.794	3.794	3.794	3.020
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.794	3.794	3.794	3.020
TBtu Consumed	0.000	50.59	50.59	50.59	40.27
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	4.769	4.769	4.769	3.798
TWh Generated Qualifying	0.000	-4769.	-4769.	-4769.	-3798.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2246.	1952.	1351.	472.8

Constraint Name: #7 - BART SO2 Constraint (COY) Constraint #: 19
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	4.017	4.039	4.039	2.970
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	4.017	4.039	4.039	2.970
TBtu Consumed	0.000	53.57	53.86	53.86	39.60
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	5.021	5.049	5.049	3.713
TWh Generated Qualifying	0.000	-5021.	-5049.	-5049.	-3713.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2076.	1930.	1309.	564.8

Constraint Name: #7 - BART SO2 Constraint (CPG) Constraint #: 20
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.293	1.295	1.308	1.077
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.293	1.295	1.308	1.077
TBtu Consumed	0.000	17.24	17.27	17.43	14.37
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1498
TWh Generated	0.000	1.635	1.637	1.653	1.363
TWh Generated Qualifying	0.000	-1635.	-1637.	-1653.	-1363.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3418.	2179.	441.5	0.000

Constraint Name: #7 - BART SO2 Constraint (CPI) Constraint #: 21
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	3.591	3.609	3.616	2.928
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.591	3.609	3.616	2.928
TBtu Consumed	0.000	47.88	48.13	48.21	43.37
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1350
TWh Generated	0.000	4.690	4.713	4.722	4.247
TWh Generated Qualifying	0.000	-4690.	-4713.	-4721.	-4247.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1995.	2259.	12.10	0.000

Constraint Name: #7 - BART SO2 Constraint (CPS) Constraint #: 22
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.079	2.079	1.177	1.112
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.079	2.079	1.177	1.112
TBTu Consumed	0.000	27.73	27.73	27.73	26.19
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.8491E-01	0.8491E-01
TWh Generated	0.000	2.722	2.722	2.722	2.571
TWh Generated Qualifying	0.000	-2722.	-2722.	-2722.	-2571.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1516.	1580.	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (CPT)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 23

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2098.	1482.	1578.	770.3

Constraint Name: #7 - BART SO2 Constraint (CPU) Constraint #: 24
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	835.6	995.5	995.9	1114.

Constraint Name: #7 - BART SO2 Constraint (CQC) Constraint #: 25
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.492	1.492	1.492	1.303
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.492	1.492	1.492	1.303
TBtu Consumed	0.000	19.89	19.89	19.89	17.37
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	1.889	1.889	1.889	1.650
TWh Generated Qualifying	0.000	-1889.	-1889.	-1889.	-1650.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2319.	574.6	2095.	902.6

Constraint Name: #7 - BART SO2 Constraint (CQK) Constraint #: 26
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.225	1.225	1.225	1.053
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.225	1.225	1.225	1.053
TBtu Consumed	0.000	16.34	16.34	16.34	14.03
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	1.547	1.547	1.547	1.329
TWh Generated Qualifying	0.000	-1547.	-1547.	-1547.	-1329.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1881.	2507.	1632.	1119.

Constraint Name: #7 - BART SO2 Constraint (CQS)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 27

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.902	2.902	2.902	2.520
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.902	2.902	2.902	2.520
TBtu Consumed	0.000	38.69	38.69	38.69	34.64
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1455
TWh Generated	0.000	3.659	3.659	3.659	3.277
TWh Generated Qualifying	0.000	-3659.	-3659.	-3659.	-3277.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2853.	2471.	1135.	0.000

Constraint Name: #7 - BART SO2 Constraint (CSN) Constraint #: 28
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.386	1.420	1.286	0.4634
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.386	1.420	1.286	0.4634
TBtu Consumed	0.000	18.48	18.93	17.15	6.179
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	1.641	1.682	1.524	0.5491
TWh Generated Qualifying	0.000	-1641.	-1682.	-1524.	-549.1
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3235.	1643.	656.8	918.1

Constraint Name: #7 - BART SO2 Constraint (CSP) Constraint #: 29
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	3.993	3.993	3.993	2.731
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.993	3.993	3.993	2.731
TBtu Consumed	0.000	53.24	53.24	53.24	39.35
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1388
TWh Generated	0.000	4.926	4.926	4.926	3.641
TWh Generated Qualifying	0.000	-4926.	-4926.	-4926.	-3641.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2037.	2051.	12.10	0.000

Constraint Name: #7 - BART SO2 Constraint (CSY) Constraint #: 30
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.868	2.896	2.921	2.350
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.868	2.896	2.921	2.350
TBtu Consumed	0.000	38.24	38.62	38.94	31.33
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	3.691	3.727	3.759	3.024
TWh Generated Qualifying	0.000	-3690.	-3727.	-3759.	-3024.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2831.	2133.	430.2	782.2

Constraint Name: #7 - BART SO2 Constraint (CTG) Constraint #: 31
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.568	2.568	2.360	2.070
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.568	2.568	2.360	2.070
TBtu Consumed	0.000	34.25	34.25	34.25	30.41
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1378	0.1361
TWh Generated	0.000	3.285	3.285	3.285	2.918
TWh Generated Qualifying	0.000	-3285.	-3285.	-3285.	-2918.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2963.	1390.	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (CTH) Constraint #: 32
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.833	2.833	2.833	2.454
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.833	2.833	2.833	2.454
TBtu Consumed	0.000	37.78	37.78	37.78	37.78
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1299
TWh Generated	0.000	3.687	3.687	3.687	3.687
TWh Generated Qualifying	0.000	-3687.	-3687.	-3687.	-3687.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2672.	1677.	12.10	0.000

Constraint Name: #7 - BART SO2 Constraint (CTI) Constraint #: 33
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.952	2.952	2.952	2.378
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.952	2.952	2.952	2.378
TBtu Consumed	0.000	39.36	39.36	39.36	34.95
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1361
TWh Generated	0.000	3.752	3.752	3.752	3.333
TWh Generated Qualifying	0.000	-3752.	-3752.	-3752.	-3333.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2403.	1860.	12.10	0.000

Constraint Name: #7 - BART SO2 Constraint (CTJ) Constraint #: 34
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.950	2.964	2.970	2.170
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.950	2.964	2.970	2.170
TBtu Consumed	0.000	39.34	39.52	39.60	31.62
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1373
TWh Generated	0.000	3.633	3.650	3.658	2.920
TWh Generated Qualifying	0.000	-3633.	-3650.	-3658.	-2920.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2427.	1849.	12.10	0.000

Constraint Name: #7 - BART SO2 Constraint (CTK) Constraint #: 35
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	3.059	3.085	3.106	1.019
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	3.059	3.085	3.106	1.019
TBtu Consumed	0.000	40.79	41.13	41.42	13.58
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	3.695	3.727	3.753	1.231
TWh Generated Qualifying	0.000	-3695.	-3727.	-3753.	-1231.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2106.	1736.	12.10	627.1

Constraint Name: #7 - BART SO2 Constraint (CTL) Constraint #: 36
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	2.573	2.573	2.364	2.073
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.573	2.573	2.364	2.073
TBtu Consumed	0.000	34.31	34.31	34.31	30.47
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1378	0.1361
TWh Generated	0.000	3.285	3.285	3.285	2.918
TWh Generated Qualifying	0.000	-3285.	-3285.	-3285.	-2918.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2931.	1419.	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (DJB) Constraint #: 37
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #7 - BART SO2 Constraint (DPY) Constraint #: 38
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.417	1.841	1.841	1.608
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.417	1.841	1.841	1.608
TBtu Consumed	0.000	24.54	24.54	24.54	21.43
Rate - [lb/MMBtu]	0.000	0.1155	0.1500	0.1500	0.1500
TWh Generated	0.000	2.319	2.319	2.319	2.025
TWh Generated Qualifying	0.000	-2319.	-2319.	-2319.	-2025.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	60.28	128.2	579.8

Constraint Name: #8a - Dummy BART NOx Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 39

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.000	0.1000E+06	0.1000E+06	0.1000E+06	0.1000E+06
-Emissions at Affected Plants [MTons]	0.000	309.8	276.6	259.4	173.3
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	309.8	276.6	259.4	173.3
TBtu Consumed	0.000	2973.	2968.	2831.	2312.
Rate - [lb/MMBtu]	0.000	0.2084	0.1864	0.1833	0.1500
TWh Generated	0.000	285.5	296.2	284.2	260.5
TWh Generated Qualifying	0.000	-0.2855E+06	-0.2962E+06	-0.2842E+06	-0.2605E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #8b - Dummy AR, CT, DE, MA, NH, NJ NOx Constraint Constraint #: 40
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.1000E+06	0.1000E+06	0.1000E+06	0.1000E+06	0.1000E+06
-Emissions at Affected Plants [MTons]	58.55	36.11	28.34	24.46	16.33
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	58.55	36.11	28.34	24.46	16.33
TBtu Consumed	1300.	1075.	937.7	801.3	519.5
Rate - [lb/MMBtu]	0.9004E-01	0.6719E-01	0.6045E-01	0.6105E-01	0.6288E-01
TWh Generated	145.5	128.2	111.5	94.95	61.78
TWh Generated Qualifying	-0.1455E+06	-0.1476E+06	-0.1431E+06	-0.1469E+06	-0.1483E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: #8c - Dummy SCR&SNCR NOx Constraint
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 41

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.1000E+06	0.1000E+06	0.1000E+06	0.1000E+06	0.1000E+06
-Emissions at Affected Plants [MTons]	36.64	33.11	33.04	31.79	24.98
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	36.64	33.11	33.04	31.79	24.98
TBTu Consumed	992.8	876.3	882.8	858.8	702.6
Rate - [lb/MMBtu]	0.7382E-01	0.7557E-01	0.7485E-01	0.7404E-01	0.7110E-01
TWh Generated	98.25	87.14	88.72	86.36	73.06
TWh Generated Qualifying	-0.9825E+05	-0.8714E+05	-0.8872E+05	-0.8636E+05	-0.7306E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - MER Rate Annual (C Constraint #: 42
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06
-Emissions at Affected Plants [Lb]	14.89	12.45	12.52	7.282	6.880
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	14.89	12.45	12.52	7.282	6.880
TBtu Consumed	27.73	27.73	27.73	27.73	26.19
Rate - [lb/MMBtu]	0.5371E-06	0.4489E-06	0.4515E-06	0.2627E-06	0.2627E-06
TWh Generated	2.725	2.722	2.722	2.722	2.571
TWh Generated Qualifying	-2725.	-2722.	-2722.	-2722.	-2571.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - MER Rate Annual (D Constraint #: 43
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06
-Emissions at Affected Plants [Lb]	4.557	4.557	4.512	4.512	3.406
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	4.557	4.557	4.512	4.512	3.406
TBtu Consumed	7.595	7.595	7.595	7.595	6.634
Rate - [lb/MMBtu]	0.6000E-06	0.6000E-06	0.5940E-06	0.5940E-06	0.5134E-06
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.5976
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-597.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3922E+06	0.3173E+06	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - MER Rate Annual (D Constraint #: 44
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06	0.6000E-06
-Emissions at Affected Plants [Lb]	4.460	4.460	4.415	4.415	3.607
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	4.460	4.460	4.415	4.415	3.607
TBtu Consumed	7.433	7.433	7.433	7.433	7.024
Rate - [lb/MMBtu]	0.6000E-06	0.6000E-06	0.5940E-06	0.5940E-06	0.5135E-06
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.6466
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-646.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3922E+06	0.3173E+06	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 45
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2465E-02	0.2465E-02	0.4852E-03	0.4852E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2465E-02	0.2465E-02	0.4852E-03	0.4852E-03	0.000
TBtu Consumed	0.1591	0.1591	0.3130E-01	0.3130E-01	0.000
Rate - [lb/MMBtu]	0.3100E-01	0.3100E-01	0.3100E-01	0.3100E-01	0.000
TWh Generated	0.1767E-01	0.1767E-01	0.3478E-02	0.3478E-02	0.000
TWh Generated Qualifying	-17.67	-17.67	-3.478	-3.478	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 46
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1861E-02	0.1861E-02	0.3662E-03	0.3662E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1861E-02	0.1861E-02	0.3662E-03	0.3662E-03	0.000
TBtu Consumed	0.1378	0.1378	0.2713E-01	0.2713E-01	0.000
Rate - [lb/MMBtu]	0.2700E-01	0.2700E-01	0.2700E-01	0.2700E-01	0.000
TWh Generated	0.1532E-01	0.1532E-01	0.3014E-02	0.3014E-02	0.000
TWh Generated Qualifying	-15.32	-15.32	-3.014	-3.014	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 47
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.5567E-02	0.5567E-02	0.1096E-02	0.1096E-02	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5567E-02	0.5567E-02	0.1096E-02	0.1096E-02	0.000
TBtu Consumed	0.1591	0.1591	0.3130E-01	0.3130E-01	0.000
Rate - [lb/MMBtu]	0.7000E-01	0.7000E-01	0.7000E-01	0.7000E-01	0.000
TWh Generated	0.1767E-01	0.1767E-01	0.3478E-02	0.3478E-02	0.000
TWh Generated Qualifying	-17.67	-17.67	-3.478	-3.478	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 48
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2301E-02	0.2301E-02	0.4528E-03	0.4528E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2301E-02	0.2301E-02	0.4528E-03	0.4528E-03	0.000
TBtu Consumed	0.1485	0.1485	0.2921E-01	0.2921E-01	0.000
Rate - [lb/MMBtu]	0.3100E-01	0.3100E-01	0.3100E-01	0.3100E-01	0.000
TWh Generated	0.1649E-01	0.1649E-01	0.3246E-02	0.3246E-02	0.000
TWh Generated Qualifying	-16.49	-16.49	-3.246	-3.246	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 49
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2757E-02	0.2757E-02	0.5426E-03	0.5426E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2757E-02	0.2757E-02	0.5426E-03	0.5426E-03	0.000
TBtu Consumed	0.1414	0.1414	0.2782E-01	0.2782E-01	0.000
Rate - [lb/MMBtu]	0.3900E-01	0.3900E-01	0.3900E-01	0.3900E-01	0.000
TWh Generated	0.1571E-01	0.1571E-01	0.3092E-02	0.3092E-02	0.000
TWh Generated Qualifying	-15.71	-15.71	-3.091	-3.091	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 50
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 51
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 52
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 53
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 54
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 55
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 56
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 57
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 58
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 59
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 60
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 61
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 62
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 63
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 64
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 65
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 66
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 67
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.000	0.000
TBtu Consumed	0.2492E-01	0.2492E-01	0.2492E-01	0.000	0.000
Rate - [lb/MMBtu]	0.1320	0.1320	0.1320	0.000	0.000
TWh Generated	0.2551E-02	0.2551E-02	0.2551E-02	0.000	0.000
TWh Generated Qualifying	-2.550	-2.550	-2.550	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 68
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1427E-02	0.1427E-02	0.1427E-02	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1427E-02	0.1427E-02	0.1427E-02	0.000	0.000
TBtu Consumed	0.2266E-01	0.2266E-01	0.2266E-01	0.000	0.000
Rate - [lb/MMBtu]	0.1260	0.1260	0.1260	0.000	0.000
TWh Generated	0.2319E-02	0.2319E-02	0.2319E-02	0.000	0.000
TWh Generated Qualifying	-2.319	-2.319	-2.319	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 69
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1522E-02	0.1522E-02	0.1522E-02	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1522E-02	0.1522E-02	0.1522E-02	0.000	0.000
TBtu Consumed	0.2341E-01	0.2341E-01	0.2341E-01	0.000	0.000
Rate - [lb/MMBtu]	0.1300	0.1300	0.1300	0.000	0.000
TWh Generated	0.2396E-02	0.2396E-02	0.2396E-02	0.000	0.000
TWh Generated Qualifying	-2.396	-2.396	-2.396	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (A Constraint #: 70
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1473E-02	0.1473E-02	0.1473E-02	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1473E-02	0.1473E-02	0.1473E-02	0.000	0.000
TBtu Consumed	0.2266E-01	0.2266E-01	0.2266E-01	0.000	0.000
Rate - [lb/MMBtu]	0.1300	0.1300	0.1300	0.000	0.000
TWh Generated	0.2319E-02	0.2319E-02	0.2319E-02	0.000	0.000
TWh Generated Qualifying	-2.319	-2.319	-2.319	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 71
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1509E-01	0.1509E-01	0.1070E-01	0.5021E-02	0.9881E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1509E-01	0.1509E-01	0.1070E-01	0.5021E-02	0.9881E-03
TBtu Consumed	1.509	1.509	1.070	0.5021	0.9881E-01
Rate - [lb/MMBtu]	0.2000E-01	0.2000E-01	0.2000E-01	0.2000E-01	0.2000E-01
TWh Generated	0.1889	0.1889	0.1340	0.6287E-01	0.1237E-01
TWh Generated Qualifying	-188.9	-188.9	-134.0	-62.87	-12.37
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 72
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1659E-01	0.1659E-01	0.6135E-02	0.5523E-02	0.1087E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1659E-01	0.1659E-01	0.6135E-02	0.5523E-02	0.1087E-02
BTtu Consumed	1.509	1.509	0.5577	0.5021	0.9881E-01
Rate - [lb/MMBtu]	0.2200E-01	0.2200E-01	0.2200E-01	0.2200E-01	0.2200E-01
TWh Generated	0.1889	0.1889	0.6984E-01	0.6287E-01	0.1237E-01
TWh Generated Qualifying	-188.9	-188.9	-69.84	-62.87	-12.37
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 73
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1491E-01	0.1491E-01	0.4962E-02	0.4962E-02	0.9765E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1491E-01	0.1491E-01	0.4962E-02	0.4962E-02	0.9765E-03
TBtu Consumed	1.420	1.420	0.4726	0.4726	0.9300E-01
Rate - [lb/MMBtu]	0.2100E-01	0.2100E-01	0.2100E-01	0.2100E-01	0.2100E-01
TWh Generated	0.1778	0.1778	0.5917E-01	0.5917E-01	0.1164E-01
TWh Generated Qualifying	-177.8	-177.8	-59.17	-59.17	-11.64
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 74
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.3128E-01	0.2787E-01	0.2713E-01	0.1937E-01	0.8779E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3128E-01	0.2787E-01	0.2713E-01	0.1937E-01	0.8779E-02
TBtu Consumed	12.51	11.15	10.85	7.747	3.512
Rate - [lb/MMBtu]	0.5000E-02	0.5000E-02	0.5000E-02	0.5000E-02	0.5000E-02
TWh Generated	1.720	1.533	1.492	1.065	0.4828
TWh Generated Qualifying	-1720.	-1533.	-1492.	-1065.	-482.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 75
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.9793E-01	0.8726E-01	0.7345E-01	0.7345E-01	0.2749E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9793E-01	0.8726E-01	0.7345E-01	0.7345E-01	0.2749E-01
TBtu Consumed	12.24	10.91	9.181	9.181	3.436
Rate - [lb/MMBtu]	0.1600E-01	0.1600E-01	0.1600E-01	0.1600E-01	0.1600E-01
TWh Generated	1.683	1.500	1.262	1.262	0.4724
TWh Generated Qualifying	-1683.	-1500.	-1262.	-1262.	-472.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 76
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1100	0.1025	0.9450E-01	0.6812E-01	0.3088E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1100	0.1025	0.9450E-01	0.6812E-01	0.3088E-01
TBtu Consumed	13.75	12.81	11.81	8.515	3.860
Rate - [lb/MMBtu]	0.1600E-01	0.1600E-01	0.1600E-01	0.1600E-01	0.1600E-01
TWh Generated	1.890	1.761	1.624	1.171	0.5306
TWh Generated Qualifying	-1890.	-1761.	-1624.	-1171.	-530.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 77
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2858	0.2858	0.2858	0.2858	0.2143
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2858	0.2858	0.2858	0.2858	0.2143
TBtu Consumed	12.16	12.16	12.16	12.16	9.121
Rate - [lb/MMBtu]	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01
TWh Generated	1.720	1.720	1.720	1.720	1.290
TWh Generated Qualifying	-1720.	-1720.	-1720.	-1720.	-1290.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 78
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2858	0.2858	0.2858	0.2858	0.2143
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2858	0.2858	0.2858	0.2858	0.2143
TBtu Consumed	12.16	12.16	12.16	12.16	9.121
Rate - [lb/MMBtu]	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01
TWh Generated	1.720	1.720	1.720	1.720	1.290
TWh Generated Qualifying	-1720.	-1720.	-1720.	-1720.	-1290.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 79
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2960E-02	0.2960E-02	0.5825E-03	0.5825E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2960E-02	0.2960E-02	0.5825E-03	0.5825E-03	0.000
TBtu Consumed	0.6805E-01	0.6805E-01	0.1339E-01	0.1339E-01	0.000
Rate - [lb/MMBtu]	0.8700E-01	0.8700E-01	0.8700E-01	0.8700E-01	0.000
TWh Generated	0.7397E-02	0.7397E-02	0.1456E-02	0.1456E-02	0.000
TWh Generated Qualifying	-7.396	-7.396	-1.456	-1.456	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 80
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.4736E-02	0.4736E-02	0.2462E-02	0.9320E-03	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4736E-02	0.4736E-02	0.2462E-02	0.9320E-03	0.000
TBtu Consumed	0.1089	0.1089	0.5660E-01	0.2143E-01	0.000
Rate - [lb/MMBtu]	0.8700E-01	0.8700E-01	0.8700E-01	0.8700E-01	0.000
TWh Generated	0.1183E-01	0.1183E-01	0.6152E-02	0.2329E-02	0.000
TWh Generated Qualifying	-11.83	-11.83	-6.152	-2.329	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (B Constraint #: 81
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.1311E-02	0.1311E-02	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1311E-02	0.1311E-02	0.000	0.000	0.000
TBtu Consumed	0.1927E-01	0.1927E-01	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1360	0.1360	0.000	0.000	0.000
TWh Generated	0.1892E-02	0.1892E-02	0.000	0.000	0.000
TWh Generated Qualifying	-1.892	-1.892	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (C Constraint #: 82
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.913	1.913	1.913	1.913	1.807
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.913	1.913	1.913	1.913	1.807
TBtu Consumed	27.73	27.73	27.73	27.73	26.19
Rate - [lb/MMBtu]	0.1380	0.1380	0.1380	0.1380	0.1380
TWh Generated	2.725	2.722	2.722	2.722	2.571
TWh Generated Qualifying	-2725.	-2722.	-2722.	-2722.	-2571.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (C Constraint #: 83
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (C Constraint #: 84
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (C Constraint #: 85
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.9447E+06	0.6140E+06	0.4961E+06	0.4644E+06	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 86
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2962	0.2962	0.2962	0.2962	0.2587
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2962	0.2962	0.2962	0.2962	0.2587
TBtu Consumed	7.595	7.595	7.595	7.595	6.634
Rate - [lb/MMBtu]	0.7800E-01	0.7800E-01	0.7800E-01	0.7800E-01	0.7800E-01
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.5976
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-597.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 87
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.2936	0.2936	0.2936	0.2936	0.2775
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2936	0.2936	0.2936	0.2936	0.2775
TBtu Consumed	7.433	7.433	7.433	7.433	7.024
Rate - [lb/MMBtu]	0.7900E-01	0.7900E-01	0.7900E-01	0.7900E-01	0.7900E-01
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.6466
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-646.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 88
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 89
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 90
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 91
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 92
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 93
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	670.5	0.000	746.2	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 94
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - NOX Rate Annual (D Constraint #: 95
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 96
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1591	0.1591	0.3130E-01	0.3130E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1767E-01	0.1767E-01	0.3478E-02	0.3478E-02	0.000
TWh Generated Qualifying	-17.67	-17.67	-3.478	-3.478	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 97
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1378	0.1378	0.2713E-01	0.2713E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1532E-01	0.1532E-01	0.3014E-02	0.3014E-02	0.000
TWh Generated Qualifying	-15.32	-15.32	-3.014	-3.014	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 98
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1591	0.1591	0.3130E-01	0.3130E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1767E-01	0.1767E-01	0.3478E-02	0.3478E-02	0.000
TWh Generated Qualifying	-17.67	-17.67	-3.478	-3.478	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 99
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1485	0.1485	0.2921E-01	0.2921E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1649E-01	0.1649E-01	0.3246E-02	0.3246E-02	0.000
TWh Generated Qualifying	-16.49	-16.49	-3.246	-3.246	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 100
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1414	0.1414	0.2782E-01	0.2782E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1571E-01	0.1571E-01	0.3092E-02	0.3092E-02	0.000
TWh Generated Qualifying	-15.71	-15.71	-3.091	-3.091	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 101
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 102
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 103
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 104
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 105
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 106
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 107
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 108
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 109
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 110
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 111
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 112
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 113
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 114
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 115
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 116
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 117
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 118
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.2492E-01	0.2492E-01	0.2492E-01	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2551E-02	0.2551E-02	0.2551E-02	0.000	0.000
TWh Generated Qualifying	-2.550	-2.550	-2.550	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 119
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.2266E-01	0.2266E-01	0.2266E-01	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2319E-02	0.2319E-02	0.2319E-02	0.000	0.000
TWh Generated Qualifying	-2.319	-2.319	-2.319	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 120
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.2341E-01	0.2341E-01	0.2341E-01	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2396E-02	0.2396E-02	0.2396E-02	0.000	0.000
TWh Generated Qualifying	-2.396	-2.396	-2.396	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (A Constraint #: 121
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.2266E-01	0.2266E-01	0.2266E-01	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2319E-02	0.2319E-02	0.2319E-02	0.000	0.000
TWh Generated Qualifying	-2.319	-2.319	-2.319	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 122
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	1.509	1.509	1.070	0.5021	0.9881E-01
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1889	0.1889	0.1340	0.6287E-01	0.1237E-01
TWh Generated Qualifying	-188.9	-188.9	-134.0	-62.87	-12.37
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 123
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	1.509	1.509	0.5577	0.5021	0.9881E-01
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1889	0.1889	0.6984E-01	0.6287E-01	0.1237E-01
TWh Generated Qualifying	-188.9	-188.9	-69.84	-62.87	-12.37
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 124
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	1.420	1.420	0.4726	0.4726	0.9300E-01
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1778	0.1778	0.5917E-01	0.5917E-01	0.1164E-01
TWh Generated Qualifying	-177.8	-177.8	-59.17	-59.17	-11.64
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 125
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.51	11.15	10.85	7.747	3.512
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.720	1.533	1.492	1.065	0.4828
TWh Generated Qualifying	-1720.	-1533.	-1492.	-1065.	-482.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 126
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.24	10.91	9.181	9.181	3.436
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.683	1.500	1.262	1.262	0.4724
TWh Generated Qualifying	-1683.	-1500.	-1262.	-1262.	-472.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 127
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	13.75	12.81	11.81	8.515	3.860
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.890	1.761	1.624	1.171	0.5306
TWh Generated Qualifying	-1890.	-1761.	-1624.	-1171.	-530.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 128
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.16	12.16	12.16	12.16	9.121
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.720	1.720	1.720	1.720	1.290
TWh Generated Qualifying	-1720.	-1720.	-1720.	-1720.	-1290.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 129
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.16	12.16	12.16	12.16	9.121
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.720	1.720	1.720	1.720	1.290
TWh Generated Qualifying	-1720.	-1720.	-1720.	-1720.	-1290.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 130)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.6805E-01	0.6805E-01	0.1339E-01	0.1339E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.7397E-02	0.7397E-02	0.1456E-02	0.1456E-02	0.000
TWh Generated Qualifying	-7.396	-7.396	-1.456	-1.456	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 131)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1089	0.1089	0.5660E-01	0.2143E-01	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1183E-01	0.1183E-01	0.6152E-02	0.2329E-02	0.000
TWh Generated Qualifying	-11.83	-11.83	-6.152	-2.329	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (B Constraint #: 132
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.1927E-01	0.1927E-01	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1892E-02	0.1892E-02	0.000	0.000	0.000
TWh Generated Qualifying	-1.892	-1.892	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (C Constraint #: 133
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	4.575	2.079	2.079	1.177	1.112
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.575	2.079	2.079	1.177	1.112
TBtu Consumed	27.73	27.73	27.73	27.73	26.19
Rate - [lb/MMBtu]	0.3300	0.1500	0.1500	0.8491E-01	0.8491E-01
TWh Generated	2.725	2.722	2.722	2.722	2.571
TWh Generated Qualifying	-2725.	-2722.	-2722.	-2722.	-2571.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	578.0	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (C Constraint #: 134
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (C Constraint #: 135
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (C Constraint #: 136
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 137
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.6771	0.5301	0.5241	0.5241	0.3951
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6771	0.5301	0.5241	0.5241	0.3951
TBtu Consumed	7.595	7.595	7.595	7.595	6.634
Rate - [lb/MMBtu]	0.1783	0.1396	0.1380	0.1380	0.1191
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.5976
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-597.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 138

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2025 WINTER SUMMER

Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.7295	0.5188	0.5128	0.5128	0.4183
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7295	0.5188	0.5128	0.5128	0.4183
TBtu Consumed	7.433	7.433	7.433	7.433	7.024
Rate - [lb/MMBtu]	0.1963	0.1396	0.1380	0.1380	0.1191
TWh Generated	0.6841	0.6841	0.6841	0.6841	0.6466
TWh Generated Qualifying	-684.1	-684.1	-684.1	-684.1	-646.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 139)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 140
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 141
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	8140.	2791.	2100.	1169.	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 142)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	8343.	2984.	2306.	1393.	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 143
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 144
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 145
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Connecticut Facility Specific - SO2 Rate Annual (D Constraint #: 146
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3300	0.3300	0.3300	0.3300	0.3300
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	6863.	1569.	800.1	0.000	0.000

Constraint Name: Illinois Facility Average - NOX Rate Summer Constraint #: 147
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	32.47	31.41	29.39	27.52	17.28
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	32.47	31.41	29.39	27.52	17.28
TBtu Consumed	452.7	394.3	380.9	354.2	256.8
Rate - [lb/MMBtu]	0.1434	0.1594	0.1543	0.1554	0.1346
TWh Generated	43.35	37.92	36.68	34.13	24.95
TWh Generated Qualifying	-0.4334E+05	-0.3791E+05	-0.3668E+05	-0.3413E+05	-0.2495E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADG) Constraint #: 148
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADH) Constraint #: 149
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADI) Constraint #: 150
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADJ) Constraint #: 151
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADK) Constraint #: 152
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.7932E-03	0.7932E-03	0.7932E-03	0.7932E-03	0.7932E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7932E-03	0.7932E-03	0.7932E-03	0.7932E-03	0.7932E-03
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.2800E-01	0.2800E-01	0.2800E-01	0.2800E-01	0.2800E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADL) Constraint #: 153
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1303E-02	0.1303E-02	0.1303E-02	0.1303E-02	0.1303E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1303E-02	0.1303E-02	0.1303E-02	0.1303E-02	0.1303E-02
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.4600E-01	0.4600E-01	0.4600E-01	0.4600E-01	0.4600E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADM) Constraint #: 154
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.9066E-03	0.9066E-03	0.9066E-03	0.9066E-03	0.9066E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9066E-03	0.9066E-03	0.9066E-03	0.9066E-03	0.9066E-03
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.3200E-01	0.3200E-01	0.3200E-01	0.3200E-01	0.3200E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADN) Constraint #: 155
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1020E-02	0.1020E-02	0.1020E-02	0.1020E-02	0.1020E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1020E-02	0.1020E-02	0.1020E-02	0.1020E-02	0.1020E-02
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.3600E-01	0.3600E-01	0.3600E-01	0.3600E-01	0.3600E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADO) Constraint #: 156
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1682E-01	0.5595E-02	0.5595E-02	0.5595E-02	0.5595E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1682E-01	0.5595E-02	0.5595E-02	0.5595E-02	0.5595E-02
TBtu Consumed	0.7821	0.2602	0.2602	0.2602	0.2602
Rate - [lb/MMBtu]	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01
TWh Generated	0.7742E-01	0.2576E-01	0.2576E-01	0.2576E-01	0.2576E-01
TWh Generated Qualifying	-77.42	-25.76	-25.76	-25.76	-25.76
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADP) Constraint #: 157
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1901E-01	0.6327E-02	0.6327E-02	0.6327E-02	0.6327E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1901E-01	0.6327E-02	0.6327E-02	0.6327E-02	0.6327E-02
TBtu Consumed	0.7923	0.2636	0.2636	0.2636	0.2636
Rate - [lb/MMBtu]	0.4800E-01	0.4800E-01	0.4800E-01	0.4800E-01	0.4800E-01
TWh Generated	0.7842E-01	0.2609E-01	0.2609E-01	0.2609E-01	0.2609E-01
TWh Generated Qualifying	-78.42	-26.09	-26.09	-26.09	-26.09
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADQ) Constraint #: 158
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADR) Constraint #: 159
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADS) Constraint #: 160
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADT) Constraint #: 161
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADU) Constraint #: 162
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADV) Constraint #: 163
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADW) Constraint #: 164
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADX) Constraint #: 165
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADY) Constraint #: 166
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1332E-02	0.1332E-02	0.1332E-02	0.1332E-02	0.1332E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1332E-02	0.1332E-02	0.1332E-02	0.1332E-02	0.1332E-02
BTtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01	0.4700E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ADZ) Constraint #: 167
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1133E-02	0.1133E-02	0.1133E-02	0.1133E-02	0.1133E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1133E-02	0.1133E-02	0.1133E-02	0.1133E-02	0.1133E-02
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.4000E-01	0.4000E-01	0.4000E-01	0.4000E-01	0.4000E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEA) Constraint #: 168
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1615E-02	0.1615E-02	0.1615E-02	0.1615E-02	0.1615E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1615E-02	0.1615E-02	0.1615E-02	0.1615E-02	0.1615E-02
BTtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.5700E-01	0.5700E-01	0.5700E-01	0.5700E-01	0.5700E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEB) Constraint #: 169
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1813E-02	0.1813E-02	0.1813E-02	0.1813E-02	0.1813E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1813E-02	0.1813E-02	0.1813E-02	0.1813E-02	0.1813E-02
BTtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.6400E-01	0.6400E-01	0.6400E-01	0.6400E-01	0.6400E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEC) Constraint #: 170
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1360E-02	0.1360E-02	0.1360E-02	0.1360E-02	0.1360E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1360E-02	0.1360E-02	0.1360E-02	0.1360E-02	0.1360E-02
TBtu Consumed	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01	0.5666E-01
Rate - [lb/MMBtu]	0.4800E-01	0.4800E-01	0.4800E-01	0.4800E-01	0.4800E-01
TWh Generated	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02	0.4936E-02
TWh Generated Qualifying	-4.936	-4.936	-4.936	-4.936	-4.936
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AED) Constraint #: 171
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.7554E-03	0.3840E-02	0.3840E-02	0.3840E-02	0.3840E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7554E-03	0.3840E-02	0.3840E-02	0.3840E-02	0.3840E-02
TBtu Consumed	0.1526E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEE) Constraint #: 172
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.5361E-02	0.5361E-02	0.5361E-02	0.5361E-02	0.5361E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5361E-02	0.5361E-02	0.5361E-02	0.5361E-02	0.5361E-02
TBtu Consumed	0.2898	0.2898	0.2898	0.2898	0.2898
Rate - [lb/MMBtu]	0.3700E-01	0.3700E-01	0.3700E-01	0.3700E-01	0.3700E-01
TWh Generated	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01
TWh Generated Qualifying	-27.93	-27.93	-27.93	-27.93	-27.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEF) Constraint #: 173
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.6086E-02	0.6086E-02	0.6086E-02	0.6086E-02	0.6086E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6086E-02	0.6086E-02	0.6086E-02	0.6086E-02	0.6086E-02
TBtu Consumed	0.2898	0.2898	0.2898	0.2898	0.2898
Rate - [lb/MMBtu]	0.4200E-01	0.4200E-01	0.4200E-01	0.4200E-01	0.4200E-01
TWh Generated	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01
TWh Generated Qualifying	-27.93	-27.93	-27.93	-27.93	-27.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEG) Constraint #: 174
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.6231E-02	0.6231E-02	0.6231E-02	0.6231E-02	0.6231E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6231E-02	0.6231E-02	0.6231E-02	0.6231E-02	0.6231E-02
TBtu Consumed	0.2898	0.2898	0.2898	0.2898	0.2898
Rate - [lb/MMBtu]	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01
TWh Generated	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01
TWh Generated Qualifying	-27.93	-27.93	-27.93	-27.93	-27.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEH) Constraint #: 175
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3491E-02	0.3491E-02	0.3491E-02	0.3491E-02	0.3491E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3491E-02	0.3491E-02	0.3491E-02	0.3491E-02	0.3491E-02
TBtu Consumed	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.9000E-01	0.9000E-01	0.9000E-01	0.9000E-01	0.9000E-01
TWh Generated	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-7.477	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEI) Constraint #: 176
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3375E-02	0.3375E-02	0.3375E-02	0.3375E-02	0.3375E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3375E-02	0.3375E-02	0.3375E-02	0.3375E-02	0.3375E-02
TBtu Consumed	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.8700E-01	0.8700E-01	0.8700E-01	0.8700E-01	0.8700E-01
TWh Generated	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-7.477	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEJ) Constraint #: 177
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3452E-02	0.3452E-02	0.3452E-02	0.3452E-02	0.3452E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3452E-02	0.3452E-02	0.3452E-02	0.3452E-02	0.3452E-02
TBtu Consumed	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.8900E-01	0.8900E-01	0.8900E-01	0.8900E-01	0.8900E-01
TWh Generated	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-7.477	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEK) Constraint #: 178
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3413E-02	0.3413E-02	0.3413E-02	0.3413E-02	0.3413E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3413E-02	0.3413E-02	0.3413E-02	0.3413E-02	0.3413E-02
TBtu Consumed	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.8800E-01	0.8800E-01	0.8800E-01	0.8800E-01	0.8800E-01
TWh Generated	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-7.477	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEL) Constraint #: 179
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3789E-02	0.3840E-02	0.3840E-02	0.3840E-02	0.3840E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3789E-02	0.3840E-02	0.3840E-02	0.3840E-02	0.3840E-02
TBtu Consumed	0.7655E-01	0.7758E-01	0.7758E-01	0.7758E-01	0.7758E-01
Rate - [lb/MMBtu]	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01
TWh Generated	0.7378E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-7.378	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEM) Constraint #: 180
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.4449E-03	0.4449E-03	0.4449E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.4449E-03	0.4449E-03	0.4449E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEN) Constraint #: 181
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5043E-03	0.5043E-03	0.5043E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5043E-03	0.5043E-03	0.5043E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3400E-01	0.3400E-01	0.3400E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEO) Constraint #: 182
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5339E-03	0.5339E-03	0.5339E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5339E-03	0.5339E-03	0.5339E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3600E-01	0.3600E-01	0.3600E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEP) Constraint #: 183
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5339E-03	0.5339E-03	0.5339E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5339E-03	0.5339E-03	0.5339E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3600E-01	0.3600E-01	0.3600E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEQ) Constraint #: 184
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5636E-03	0.5636E-03	0.5636E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5636E-03	0.5636E-03	0.5636E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3800E-01	0.3800E-01	0.3800E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AER) Constraint #: 185
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5933E-03	0.5933E-03	0.5933E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5933E-03	0.5933E-03	0.5933E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.4000E-01	0.4000E-01	0.4000E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AES) Constraint #: 186
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5784E-03	0.5784E-03	0.5784E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5784E-03	0.5784E-03	0.5784E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3900E-01	0.3900E-01	0.3900E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AET) Constraint #: 187
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.5043E-03	0.5043E-03	0.5043E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.5043E-03	0.5043E-03	0.5043E-03
TBtu Consumed	0.000	0.000	0.2966E-01	0.2966E-01	0.2966E-01
Rate - [lb/MMBtu]	0.000	0.000	0.3400E-01	0.3400E-01	0.3400E-01
TWh Generated	0.000	0.000	0.2336E-02	0.2336E-02	0.2336E-02
TWh Generated Qualifying	0.000	0.000	-2.336	-2.336	-2.336
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEU) Constraint #: 188
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEV) Constraint #: 189
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEW) Constraint #: 190
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEX) Constraint #: 191
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEY) Constraint #: 192
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AEZ) Constraint #: 193
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02	0.1347E-02
TBtu Consumed	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01	0.1796E-01
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TWh Generated Qualifying	-1.645	-1.645	-1.645	-1.645	-1.645
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AFA) Constraint #: 194
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.5651E-02	0.5651E-02	0.5651E-02	0.5651E-02	0.5651E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5651E-02	0.5651E-02	0.5651E-02	0.5651E-02	0.5651E-02
TBtu Consumed	0.2898	0.2898	0.2898	0.2898	0.2898
Rate - [lb/MMBtu]	0.3900E-01	0.3900E-01	0.3900E-01	0.3900E-01	0.3900E-01
TWh Generated	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01	0.2793E-01
TWh Generated Qualifying	-27.93	-27.93	-27.93	-27.93	-27.93
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AFI) Constraint #: 195
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AFJ) Constraint #: 196
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AFK) Constraint #: 197
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AFL) Constraint #: 198
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQJ) Constraint #: 199
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8578E-03	0.8578E-03	0.8578E-03	0.8578E-03	0.8578E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8578E-03	0.8578E-03	0.8578E-03	0.8578E-03	0.8578E-03
TBtu Consumed	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01
Rate - [lb/MMBtu]	0.9800E-01	0.9800E-01	0.9800E-01	0.9800E-01	0.9800E-01
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQK) Constraint #: 200
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8316E-03	0.8316E-03	0.8316E-03	0.8316E-03	0.8316E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8316E-03	0.8316E-03	0.8316E-03	0.8316E-03	0.8316E-03
TBtu Consumed	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01
Rate - [lb/MMBtu]	0.9500E-01	0.9500E-01	0.9500E-01	0.9500E-01	0.9500E-01
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQL) Constraint #: 201
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8928E-03	0.8928E-03	0.8928E-03	0.8928E-03	0.8928E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8928E-03	0.8928E-03	0.8928E-03	0.8928E-03	0.8928E-03
TBtu Consumed	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01
Rate - [lb/MMBtu]	0.1020	0.1020	0.1020	0.1020	0.1020
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQM) Constraint #: 202
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.9016E-03	0.9016E-03	0.9016E-03	0.9016E-03	0.9016E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9016E-03	0.9016E-03	0.9016E-03	0.9016E-03	0.9016E-03
TBtu Consumed	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01	0.1751E-01
Rate - [lb/MMBtu]	0.1030	0.1030	0.1030	0.1030	0.1030
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQN) Constraint #: 203
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1265E-02	0.6431E-02	0.6431E-02	0.6431E-02	0.6431E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1265E-02	0.6431E-02	0.6431E-02	0.6431E-02	0.6431E-02
BTtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1640	0.1640	0.1640	0.1640	0.1640
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQO) Constraint #: 204
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1219E-02	0.6196E-02	0.6196E-02	0.6196E-02	0.6196E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1219E-02	0.6196E-02	0.6196E-02	0.6196E-02	0.6196E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1580	0.1580	0.1580	0.1580	0.1580
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQP) Constraint #: 205
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1165E-02	0.5921E-02	0.5921E-02	0.5921E-02	0.5921E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1165E-02	0.5921E-02	0.5921E-02	0.5921E-02	0.5921E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1510	0.1510	0.1510	0.1510	0.1510
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQQ) Constraint #: 206
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1188E-02	0.6039E-02	0.6039E-02	0.6039E-02	0.6039E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1188E-02	0.6039E-02	0.6039E-02	0.6039E-02	0.6039E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1540	0.1540	0.1540	0.1540	0.1540
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQR) Constraint #: 207
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1242E-02	0.6314E-02	0.6314E-02	0.6314E-02	0.6314E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1242E-02	0.6314E-02	0.6314E-02	0.6314E-02	0.6314E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1610	0.1610	0.1610	0.1610	0.1610
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQS) Constraint #: 208
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1227E-02	0.6235E-02	0.6235E-02	0.6235E-02	0.6235E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1227E-02	0.6235E-02	0.6235E-02	0.6235E-02	0.6235E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1590	0.1590	0.1590	0.1590	0.1590
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQT) Constraint #: 209
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.3534E-03	0.3534E-03	0.3534E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.3534E-03	0.3534E-03	0.3534E-03
TBtu Consumed	0.000	0.000	0.2437E-01	0.2437E-01	0.2437E-01
Rate - [lb/MMBtu]	0.000	0.000	0.2900E-01	0.2900E-01	0.2900E-01
TWh Generated	0.000	0.000	0.1602E-02	0.1602E-02	0.1602E-02
TWh Generated Qualifying	0.000	0.000	-1.602	-1.602	-1.602
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQU) Constraint #: 210
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQV) Constraint #: 211
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQW) Constraint #: 212
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQX) Constraint #: 213
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQY) Constraint #: 214
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (AQZ) Constraint #: 215
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03
TBtu Consumed	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01
Rate - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARA) Constraint #: 216
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03	0.8223E-03
TBtu Consumed	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01
Rate - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARB) Constraint #: 217
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03
TBtu Consumed	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01
Rate - [lb/MMBtu]	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARC) Constraint #: 218
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03	0.8141E-03
TBtu Consumed	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01	0.1645E-01
Rate - [lb/MMBtu]	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01	0.9900E-01
TWh Generated	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02	0.1438E-02
TWh Generated Qualifying	-1.438	-1.438	-1.438	-1.438	-1.438
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARD) Constraint #: 219
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.2893E-03	0.2893E-03	0.2893E-03	0.2893E-03	0.2893E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2893E-03	0.2893E-03	0.2893E-03	0.2893E-03	0.2893E-03
TBtu Consumed	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01
Rate - [lb/MMBtu]	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01	0.4300E-01
TWh Generated	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02
TWh Generated Qualifying	-1.177	-1.177	-1.177	-1.177	-1.177
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARE) Constraint #: 220
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.3028E-03	0.3028E-03	0.3028E-03	0.3028E-03	0.3028E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3028E-03	0.3028E-03	0.3028E-03	0.3028E-03	0.3028E-03
BTtu Consumed	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01
Rate - [lb/MMBtu]	0.4500E-01	0.4500E-01	0.4500E-01	0.4500E-01	0.4500E-01
TWh Generated	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02
TWh Generated Qualifying	-1.177	-1.177	-1.177	-1.177	-1.177
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARF) Constraint #: 221
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.2960E-03	0.2960E-03	0.2960E-03	0.2960E-03	0.2960E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2960E-03	0.2960E-03	0.2960E-03	0.2960E-03	0.2960E-03
BTtu Consumed	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01
Rate - [lb/MMBtu]	0.4400E-01	0.4400E-01	0.4400E-01	0.4400E-01	0.4400E-01
TWh Generated	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02
TWh Generated Qualifying	-1.177	-1.177	-1.177	-1.177	-1.177
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARG) Constraint #: 222
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.2691E-03	0.2691E-03	0.2691E-03	0.2691E-03	0.2691E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2691E-03	0.2691E-03	0.2691E-03	0.2691E-03	0.2691E-03
TBtu Consumed	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01	0.1346E-01
Rate - [lb/MMBtu]	0.4000E-01	0.4000E-01	0.4000E-01	0.4000E-01	0.4000E-01
TWh Generated	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02	0.1177E-02
TWh Generated Qualifying	-1.177	-1.177	-1.177	-1.177	-1.177
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARH) Constraint #: 223
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1095E-02	0.5569E-02	0.5569E-02	0.5569E-02	0.5569E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1095E-02	0.5569E-02	0.5569E-02	0.5569E-02	0.5569E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1420	0.1420	0.1420	0.1420	0.1420
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARI) Constraint #: 224
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.9797E-03	0.4980E-02	0.4980E-02	0.4980E-02	0.4980E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9797E-03	0.4980E-02	0.4980E-02	0.4980E-02	0.4980E-02
TBtu Consumed	0.1543E-01	0.7843E-01	0.7843E-01	0.7843E-01	0.7843E-01
Rate - [lb/MMBtu]	0.1270	0.1270	0.1270	0.1270	0.1270
TWh Generated	0.1471E-02	0.7477E-02	0.7477E-02	0.7477E-02	0.7477E-02
TWh Generated Qualifying	-1.471	-7.477	-7.477	-7.477	-7.477
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ARV) Constraint #: 225
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.2758E-02	0.2758E-02	0.2758E-02	0.2758E-02	0.2758E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2758E-02	0.2758E-02	0.2758E-02	0.2758E-02	0.2758E-02
TBtu Consumed	0.5356E-01	0.5356E-01	0.5356E-01	0.5356E-01	0.5356E-01
Rate - [lb/MMBtu]	0.1030	0.1030	0.1030	0.1030	0.1030
TWh Generated	0.4212E-02	0.4212E-02	0.4212E-02	0.4212E-02	0.4212E-02
TWh Generated Qualifying	-4.212	-4.212	-4.212	-4.212	-4.212
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ASC) Constraint #: 226
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1745E-02	0.1745E-02	0.1745E-02	0.1745E-02	0.1745E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1745E-02	0.1745E-02	0.1745E-02	0.1745E-02	0.1745E-02
TBtu Consumed	0.4849E-01	0.4849E-01	0.4849E-01	0.4849E-01	0.4849E-01
Rate - [lb/MMBtu]	0.7200E-01	0.7200E-01	0.7200E-01	0.7200E-01	0.7200E-01
TWh Generated	0.3817E-02	0.3817E-02	0.3817E-02	0.3817E-02	0.3817E-02
TWh Generated Qualifying	-3.817	-3.817	-3.817	-3.817	-3.817
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (ASD) Constraint #: 227
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.1576E-02	0.1576E-02	0.1576E-02	0.1576E-02	0.1576E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1576E-02	0.1576E-02	0.1576E-02	0.1576E-02	0.1576E-02
TBtu Consumed	0.4849E-01	0.4849E-01	0.4849E-01	0.4849E-01	0.4849E-01
Rate - [lb/MMBtu]	0.6500E-01	0.6500E-01	0.6500E-01	0.6500E-01	0.6500E-01
TWh Generated	0.3817E-02	0.3817E-02	0.3817E-02	0.3817E-02	0.3817E-02
TWh Generated Qualifying	-3.817	-3.817	-3.817	-3.817	-3.817
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (BPP) Constraint #: 228
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02
TBtu Consumed	0.7921	0.7921	0.7921	0.7921	0.7921
Rate - [lb/MMBtu]	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01
TWh Generated	0.1089	0.1089	0.1089	0.1089	0.1089
TWh Generated Qualifying	-108.9	-108.9	-108.9	-108.9	-108.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (BPQ) Constraint #: 229
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.6073E-02	0.6073E-02	0.6073E-02	0.6073E-02	0.6073E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6073E-02	0.6073E-02	0.6073E-02	0.6073E-02	0.6073E-02
TBtu Consumed	0.8097	0.8097	0.8097	0.8097	0.8097
Rate - [lb/MMBtu]	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01
TWh Generated	0.1113	0.1113	0.1113	0.1113	0.1113
TWh Generated Qualifying	-111.3	-111.3	-111.3	-111.3	-111.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Illinois Facility Specific - NOX Rate Summer (BPR) Constraint #: 230
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02	0.5941E-02
TBtu Consumed	0.7921	0.7921	0.7921	0.7921	0.7921
Rate - [lb/MMBtu]	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01	0.1500E-01
TWh Generated	0.1089	0.1089	0.1089	0.1089	0.1089
TWh Generated Qualifying	-108.9	-108.9	-108.9	-108.9	-108.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Maine Facility Specific - NOX 0.18 Rate Annual Constraint #: 231
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1800	0.1800	0.1800	0.1800	0.1800
-Emissions at Affected Plants [MTons]	2.921	0.5848	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.921	0.5848	0.000	0.000	0.000
TBtu Consumed	43.28	8.664	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1350	0.1350	0.000	0.000	0.000
TWh Generated	4.273	0.8555	0.000	0.000	0.000
TWh Generated Qualifying	-4273.	-855.5	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Maine Facility Specific - NOX 0.22 Rate Annual Constraint #: 232
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2200	0.2200	0.2200	0.2200	0.2200
-Emissions at Affected Plants [MTons]	0.5917	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5917	0.000	0.000	0.000	0.000
TBtu Consumed	7.634	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1550	0.000	0.000	0.000	0.000
TWh Generated	0.6844	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-684.4	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Maryland Healthy Air Act - MER Removal Annual Constraint #: 233
 Constraint Type: Required Removal Level
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	269.6	255.5	234.8	214.0	154.5
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	269.6	255.5	234.8	214.0	154.5
TBtu Consumed	344.4	331.1	325.5	319.5	242.1
Rate - [lb/MMBtu]	0.7828E-06	0.7718E-06	0.7214E-06	0.6699E-06	0.6383E-06
TWh Generated	33.42	32.20	31.67	31.12	23.95
TWh Generated Qualifying	-0.3342E+05	-0.3220E+05	-0.3167E+05	-0.3112E+05	-0.2395E+05
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Maryland Healthy Air Act - NOX Cap Annual Constraint #: 234
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	20.20	16.70	16.70	16.70	16.70
-Emissions at Affected Plants [MTons]	17.66	16.70	16.69	16.50	12.35
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	17.66	16.70	16.69	16.50	12.35
TBTu Consumed	344.4	331.1	325.5	319.5	242.1
Rate - [lb/MMBtu]	0.1025	0.1009	0.1026	0.1033	0.1021
TWh Generated	33.42	32.20	31.67	31.12	23.95
TWh Generated Qualifying	-0.3342E+05	-0.3220E+05	-0.3167E+05	-0.3112E+05	-0.2395E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1911.	0.000	0.000	0.000

Constraint Name: Maryland Healthy Air Act - NOX Cap Summer
Constraint Type: Rate Cap [MTons] Constraint #: 235
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	8.900	7.300	7.300	7.300	7.300
-Emissions at Affected Plants [MTons]	7.398	6.981	6.891	6.809	5.670
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.398	6.981	6.891	6.809	5.670
TBTu Consumed	148.5	141.4	137.3	134.6	107.9
Rate - [lb/MMBTu]	0.9967E-01	0.9878E-01	0.1004	0.1012	0.1051
TWh Generated	14.40	13.76	13.38	13.12	10.65
TWh Generated Qualifying	-0.1440E+05	-0.1376E+05	-0.1338E+05	-0.1312E+05	-0.1065E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Maryland Healthy Air Act - SO2 Cap Annual Constraint #: 236
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	48.60	37.20	37.20	37.20	37.20
-Emissions at Affected Plants [MTons]	48.60	37.20	37.20	37.20	37.20
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	48.60	37.20	37.20	37.20	37.20
TBtu Consumed	344.4	331.1	325.5	319.5	242.1
Rate - [lb/MMBtu]	0.2822	0.2247	0.2286	0.2329	0.3073
TWh Generated	33.42	32.20	31.67	31.12	23.95
TWh Generated Qualifying	-0.3342E+05	-0.3220E+05	-0.3167E+05	-0.3112E+05	-0.2395E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	859.6	816.1	655.9	506.1	131.0

Constraint Name: Mass. Plant Level Brayton 1-3 - CO2 Cap Annual Constraint #: 237
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	8585.	8585.	8585.	8585.	8585.
-Emissions at Affected Plants [MTons]	4419.	1848.	1848.	1727.	197.3
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4419.	1848.	1848.	1727.	197.3
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	193.5	152.7	152.7	152.2	117.1
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Plant Level Canal 1-2 - CO2 Cap Annual Constraint #: 238
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	5332.	5332.	5332.	5332.	5332.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Plant Level Mt. Tom 1 - CO2 Cap Annual Constraint #: 239
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	1118.	1118.	1118.	1118.	1118.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Plant Level Mystic All - CO2 Cap Annual Constraint #: 240
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	7596.	7596.	7596.	7596.	7596.
-Emissions at Affected Plants [MTons]	4413.	4337.	3998.	3339.	1517.
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4413.	4337.	3998.	3339.	1517.
TBtu Consumed	75.39	74.08	68.29	57.04	25.91
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	10.36	10.18	9.389	7.841	3.562
TWh Generated Qualifying	-0.1036E+05	-0.1018E+05	-9389.	-7841.	-3562.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Plant Level SalemHarbor 1-4 - CO2 Cap Annual Constraint #: 241
Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	4286.	4286.	4286.	4286.	4286.
-Emissions at Affected Plants [MTons]	2464.	89.57	89.57	89.57	67.18
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2464.	89.57	89.57	89.57	67.18
TBtu Consumed	28.84	1.530	1.530	1.530	1.148
Rate - [lb/MMBtu]	170.9	117.1	117.1	117.1	117.1
TWh Generated	2.738	0.2356	0.2356	0.2356	0.1767
TWh Generated Qualifying	-2738.	-235.6	-235.6	-235.6	-176.7
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Plant Level Somerset 8 - CO2 Cap Annual Constraint #: 242
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	916.6	916.6	916.6	916.6	916.6
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Brayton 1-3 - MER Cap Annual (CPT Constraint #: 243)
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	146.6	146.6	146.6	146.6	146.6
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Brayton 1-3 - MER Cap Annual (CPU Constraint #: 244)
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	146.6	146.6	146.6	146.6	146.6
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Brayton 1-3 - MER Cap Annual (EIK Constraint #: 245)
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	146.6	146.6	146.6	146.6	146.6
-Emissions at Affected Plants [Lb]	32.01	5.104	5.104	4.714	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	32.01	5.104	5.104	4.714	0.000
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	0.7008E-06	0.2110E-06	0.2110E-06	0.2078E-06	0.000
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Mt. Tom 1 - MER Cap Annual Constraint #: 246
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	4.100	4.100	4.100	4.100	4.100
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Salem Harbor 1-3 - MER Cap Annual Constraint #: 247

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	21.20	21.20	21.20	21.20	21.20
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Salem Harbor 1-3 - MER Cap Annual Constraint #: 248

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	21.20	21.20	21.20	21.20	21.20
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Salem Harbor 1-3 - MER Cap Annual Constraint #: 249

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	21.20	21.20	21.20	21.20	21.20
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Mass. Unit Level Somerset 8 - MER Cap Annual Constraint #: 250
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [Lb]	13.10	13.10	13.10	13.10	13.10
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (AZB) Constraint #: 251
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BAD) Constraint #: 252
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BAE) Constraint #: 253
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BAF) Constraint #: 254
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQL) Constraint #: 255
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	681.9	681.9	607.6	422.2	217.6
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	681.9	681.9	607.6	422.2	217.6
TBtu Consumed	11.65	11.65	10.38	7.213	3.717
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.601	1.601	1.427	0.9916	0.5110
TWh Generated Qualifying	-1601.	-1601.	-1427.	-991.5	-511.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQM) Constraint #: 256
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	681.9	681.9	607.6	607.6	191.4
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	681.9	681.9	607.6	607.6	191.4
TBtu Consumed	11.65	11.65	10.38	10.38	3.270
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.601	1.601	1.427	1.427	0.4495
TWh Generated Qualifying	-1601.	-1601.	-1427.	-1427.	-449.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQN) Constraint #: 257
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	704.0	704.0	604.7	528.0	343.8
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	704.0	704.0	604.7	528.0	343.8
TBtu Consumed	12.03	12.03	10.33	9.019	5.873
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.653	1.653	1.420	1.240	0.8074
TWh Generated Qualifying	-1653.	-1653.	-1420.	-1240.	-807.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQQ) Constraint #: 258
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	704.0	627.3	627.3	435.9	408.8
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	704.0	627.3	627.3	435.9	408.8
TBtu Consumed	12.03	10.72	10.72	7.446	6.983
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.653	1.473	1.473	1.024	0.9600
TWh Generated Qualifying	-1653.	-1473.	-1473.	-1024.	-960.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQR) Constraint #: 259
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	808.2	808.2	808.2	720.1	121.1
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	808.2	808.2	808.2	720.1	121.1
TBtu Consumed	13.81	13.81	13.81	12.30	2.069
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.898	1.898	1.898	1.691	0.2845
TWh Generated Qualifying	-1898.	-1898.	-1898.	-1691.	-284.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (BQS) Constraint #: 260
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	833.4	833.4	742.6	625.1	233.9
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	833.4	833.4	742.6	625.1	233.9
TBtu Consumed	14.24	14.24	12.69	10.68	3.996
Rate - [lb/MMBtu]	117.1	117.1	117.1	117.1	117.1
TWh Generated	1.957	1.957	1.744	1.468	0.5494
TWh Generated Qualifying	-1957.	-1957.	-1744.	-1468.	-549.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (CPR) Constraint #: 261
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	100.9	0.000	9.245	19.16	22.80

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (CPT) Constraint #: 262
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	61.33	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (CPU) Constraint #: 263
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	54.78	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DJK) Constraint #: 264
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DJL) Constraint #: 265
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DJT) Constraint #: 266
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	2464.	89.57	89.57	89.57	67.18
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2464.	89.57	89.57	89.57	67.18
TBTu Consumed	28.84	1.530	1.530	1.530	1.148
Rate - [lb/MMBtu]	170.9	117.1	117.1	117.1	117.1
TWh Generated	2.738	0.2356	0.2356	0.2356	0.1767
TWh Generated Qualifying	-2738.	-235.6	-235.6	-235.6	-176.7
Constraint Shadow Price [US\$/Ton]	3.067	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DJU) Constraint #: 267
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DOR) Constraint #: 268
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (DWW) Constraint #: 269
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	114.6	0.000	9.245	13.01	20.65

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (EIK) Constraint #: 270
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	4419.	1848.	1848.	1727.	197.3
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4419.	1848.	1848.	1727.	197.3
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	193.5	152.7	152.7	152.2	117.1
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Constraint Shadow Price [US\$/Ton]	14.03	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (EOH) Constraint #: 271
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	110.7	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (EOI) Constraint #: 272
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	112.5	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - CO2 Output Annual (EOJ) Constraint #: 273
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1800.	1800.	1800.	1800.	1800.
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	128.4	0.000	0.000	18.67	17.84

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (AZB) Constraint #: 274
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BAD) Constraint #: 275
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BAE) Constraint #: 276
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BAF) Constraint #: 277

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQL) Constraint #: 278

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1631E-02	0.1631E-02	0.1453E-02	0.1010E-02	0.5203E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1631E-02	0.1631E-02	0.1453E-02	0.1010E-02	0.5203E-03
TBtu Consumed	11.65	11.65	10.38	7.213	3.717
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.601	1.601	1.427	0.9916	0.5110
TWh Generated Qualifying	-1601.	-1601.	-1427.	-991.5	-511.0
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQM) Constraint #: 279
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1631E-02	0.1631E-02	0.1453E-02	0.1453E-02	0.4577E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1631E-02	0.1631E-02	0.1453E-02	0.1453E-02	0.4577E-03
TBtu Consumed	11.65	11.65	10.38	10.38	3.270
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.601	1.601	1.427	1.427	0.4495
TWh Generated Qualifying	-1601.	-1601.	-1427.	-1427.	-449.5
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQN) Constraint #: 280

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1684E-02	0.1684E-02	0.1446E-02	0.1263E-02	0.8223E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1684E-02	0.1684E-02	0.1446E-02	0.1263E-02	0.8223E-03
TBtu Consumed	12.03	12.03	10.33	9.019	5.873
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.653	1.653	1.420	1.240	0.8074
TWh Generated Qualifying	-1653.	-1653.	-1420.	-1240.	-807.4
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQQ) Constraint #: 281
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1684E-02	0.1500E-02	0.1500E-02	0.1042E-02	0.9777E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1684E-02	0.1500E-02	0.1500E-02	0.1042E-02	0.9777E-03
TBtu Consumed	12.03	10.72	10.72	7.446	6.983
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.653	1.473	1.473	1.024	0.9600
TWh Generated Qualifying	-1653.	-1473.	-1473.	-1024.	-960.0
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQR) Constraint #: 282

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1933E-02	0.1933E-02	0.1933E-02	0.1722E-02	0.2897E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1933E-02	0.1933E-02	0.1933E-02	0.1722E-02	0.2897E-03
TBtu Consumed	13.81	13.81	13.81	12.30	2.069
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.898	1.898	1.898	1.691	0.2845
TWh Generated Qualifying	-1898.	-1898.	-1898.	-1691.	-284.5
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (BQS) Constraint #: 283

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.1993E-02	0.1993E-02	0.1776E-02	0.1495E-02	0.5595E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.1993E-02	0.1993E-02	0.1776E-02	0.1495E-02	0.5595E-03
TBtu Consumed	14.24	14.24	12.69	10.68	3.996
Rate - [lb/MMBtu]	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	1.957	1.957	1.744	1.468	0.5494
TWh Generated Qualifying	-1957.	-1957.	-1744.	-1468.	-549.4
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (CPR) Constraint #: 284
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3318E+07	0.4940E+08	0.4370E+08	0.4308E+08	0.3620E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (CPT) Constraint #: 285
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.1169E+07	0.5701E+08	0.5570E+08	0.5313E+08	0.4802E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (CPU) Constraint #: 286
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.8863E+06	0.6283E+08	0.6257E+08	0.6127E+08	0.5150E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DJK) Constraint #: 287

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DJL) Constraint #: 288
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DJT) Constraint #: 289

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	13.11	0.2142E-03	0.2142E-03	0.2142E-03	0.1607E-03
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	13.11	0.2142E-03	0.2142E-03	0.2142E-03	0.1607E-03
TBtu Consumed	28.84	1.530	1.530	1.530	1.148
Rate - [lb/MMBtu]	0.4545E-06	0.1400E-09	0.1400E-09	0.1400E-09	0.1400E-09
TWh Generated	2.738	0.2356	0.2356	0.2356	0.1767
TWh Generated Qualifying	-2738.	-235.6	-235.6	-235.6	-176.7
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DJU) Constraint #: 290
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DOR) Constraint #: 291
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (DWW) Constraint #: 292
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3586E+07	0.4021E+08	0.4143E+08	0.3715E+08	0.1932E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (EIK) Constraint #: 293

Constraint Type: Rate Limit [lb/MWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	32.01	5.104	5.104	4.714	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	32.01	5.104	5.104	4.714	0.000
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	0.7008E-06	0.2110E-06	0.2110E-06	0.2078E-06	0.000
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Constraint Shadow Price [US\$/Lb]	0.9622E+06	0.6426E+08	0.6422E+08	0.6295E+08	0.6070E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (EOH) Constraint #: 294
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3144E+07	0.4048E+08	0.3528E+08	0.3634E+08	0.3537E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (EOI) Constraint #: 295
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.4165E+07	0.3451E+08	0.2965E+08	0.2402E+08	0.3537E+08

Constraint Name: Massachusetts Fac. Spec. - MER Output Annual (EOJ) Constraint #: 296
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	0.7500E-05	0.2500E-05	0.2500E-05	0.2500E-05	0.2500E-05
-Emissions at Affected Plants [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Lb]	0.3106E+07	0.4829E+08	0.4345E+08	0.4180E+08	0.3999E+08

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (AZB) Constraint #: 297
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BAD) Constraint #: 298
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BAE) Constraint #: 299
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BAF) Constraint #: 300
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQL) Constraint #: 301
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.4077E-01	0.4077E-01	0.3633E-01	0.2524E-01	0.1301E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4077E-01	0.4077E-01	0.3633E-01	0.2524E-01	0.1301E-01
TBtu Consumed	11.65	11.65	10.38	7.213	3.717
Rate - [lb/MMBtu]	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02
TWh Generated	1.601	1.601	1.427	0.9916	0.5110
TWh Generated Qualifying	-1601.	-1601.	-1427.	-991.5	-511.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQM) Constraint #: 302
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.4077E-01	0.4077E-01	0.3633E-01	0.3633E-01	0.1144E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4077E-01	0.4077E-01	0.3633E-01	0.3633E-01	0.1144E-01
TBtu Consumed	11.65	11.65	10.38	10.38	3.270
Rate - [lb/MMBtu]	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02
TWh Generated	1.601	1.601	1.427	1.427	0.4495
TWh Generated Qualifying	-1601.	-1601.	-1427.	-1427.	-449.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQN) Constraint #: 303
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.4810E-01	0.4810E-01	0.4132E-01	0.3608E-01	0.2349E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4810E-01	0.4810E-01	0.4132E-01	0.3608E-01	0.2349E-01
BTtu Consumed	12.03	12.03	10.33	9.019	5.873
Rate - [lb/MMBtu]	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02
TWh Generated	1.653	1.653	1.420	1.240	0.8074
TWh Generated Qualifying	-1653.	-1653.	-1420.	-1240.	-807.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQQ) Constraint #: 304
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.4810E-01	0.4286E-01	0.4286E-01	0.2979E-01	0.2793E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4810E-01	0.4286E-01	0.4286E-01	0.2979E-01	0.2793E-01
TBtu Consumed	12.03	10.72	10.72	7.446	6.983
Rate - [lb/MMBtu]	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02
TWh Generated	1.653	1.473	1.473	1.024	0.9600
TWh Generated Qualifying	-1653.	-1473.	-1473.	-1024.	-960.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQR) Constraint #: 305
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.4832E-01	0.4832E-01	0.4832E-01	0.4305E-01	0.7242E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.4832E-01	0.4832E-01	0.4832E-01	0.4305E-01	0.7242E-02
TBtu Consumed	13.81	13.81	13.81	12.30	2.069
Rate - [lb/MMBtu]	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02	0.7000E-02
TWh Generated	1.898	1.898	1.898	1.691	0.2845
TWh Generated Qualifying	-1898.	-1898.	-1898.	-1691.	-284.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (BQS) Constraint #: 306
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.5695E-01	0.5695E-01	0.5074E-01	0.4271E-01	0.1598E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5695E-01	0.5695E-01	0.5074E-01	0.4271E-01	0.1598E-01
TBtu Consumed	14.24	14.24	12.69	10.68	3.996
Rate - [lb/MMBtu]	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02	0.8000E-02
TWh Generated	1.957	1.957	1.744	1.468	0.5494
TWh Generated Qualifying	-1957.	-1957.	-1744.	-1468.	-549.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (CPR) Constraint #: 307
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (CPT) Constraint #: 308
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	4612.	93.27	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (CPU) Constraint #: 309
Constraint Type: Rate Limit [lb/MWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	8934.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DJK) Constraint #: 310
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DJL) Constraint #: 311
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DJT) Constraint #: 312
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	2.054	0.8415E-02	0.8415E-02	0.8415E-02	0.6311E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.054	0.8415E-02	0.8415E-02	0.8415E-02	0.6311E-02
TBtu Consumed	28.84	1.530	1.530	1.530	1.148
Rate - [lb/MMBtu]	0.1424	0.1100E-01	0.1100E-01	0.1100E-01	0.1100E-01
TWh Generated	2.738	0.2356	0.2356	0.2356	0.1767
TWh Generated Qualifying	-2738.	-235.6	-235.6	-235.6	-176.7
Constraint Shadow Price [US\$/Ton]	2858.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DJU) Constraint #: 313
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DOR) Constraint #: 314
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (DWW) Constraint #: 315
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (EIK) Constraint #: 316
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	3.720	0.6157	0.6157	0.5706	0.1853E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.720	0.6157	0.6157	0.5706	0.1853E-01
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	0.1629	0.5090E-01	0.5090E-01	0.5030E-01	0.1100E-01
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Constraint Shadow Price [US\$/Ton]	557.2	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (EOH) Constraint #: 317
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (EOI) Constraint #: 318
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - NOX Output Annual (EOJ) Constraint #: 319
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	1.500	1.500	1.500	1.500	1.500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (AZB) Constraint #: 320
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BAD) Constraint #: 321
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BAE) Constraint #: 322
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BAF) Constraint #: 323
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQL) Constraint #: 324
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	11.65	11.65	10.38	7.213	3.717
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.601	1.601	1.427	0.9916	0.5110
TWh Generated Qualifying	-1601.	-1601.	-1427.	-991.5	-511.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQM) Constraint #: 325
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	11.65	11.65	10.38	10.38	3.270
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.601	1.601	1.427	1.427	0.4495
TWh Generated Qualifying	-1601.	-1601.	-1427.	-1427.	-449.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQN) Constraint #: 326
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.03	12.03	10.33	9.019	5.873
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.653	1.653	1.420	1.240	0.8074
TWh Generated Qualifying	-1653.	-1653.	-1420.	-1240.	-807.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQQ) Constraint #: 327
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	12.03	10.72	10.72	7.446	6.983
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.653	1.473	1.473	1.024	0.9600
TWh Generated Qualifying	-1653.	-1473.	-1473.	-1024.	-960.0
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQR) Constraint #: 328
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	13.81	13.81	13.81	12.30	2.069
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.898	1.898	1.898	1.691	0.2845
TWh Generated Qualifying	-1898.	-1898.	-1898.	-1691.	-284.5
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (BQS) Constraint #: 329
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	14.24	14.24	12.69	10.68	3.996
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.957	1.957	1.744	1.468	0.5494
TWh Generated Qualifying	-1957.	-1957.	-1744.	-1468.	-549.4
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (CPR) Constraint #: 330
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	3473.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (CPT) Constraint #: 331
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	4054.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (CPU) Constraint #: 332
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	5449.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DJK) Constraint #: 333
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DJL) Constraint #: 334
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DJT) Constraint #: 335
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	1.775	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.775	0.000	0.000	0.000	0.000
TBtu Consumed	28.84	1.530	1.530	1.530	1.148
Rate - [lb/MMBtu]	0.1231	0.000	0.000	0.000	0.000
TWh Generated	2.738	0.2356	0.2356	0.2356	0.1767
TWh Generated Qualifying	-2738.	-235.6	-235.6	-235.6	-176.7
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DJU) Constraint #: 336
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DOR) Constraint #: 337
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1035E+05	5048.	4531.	3841.	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (DWW) Constraint #: 338
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1321.	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (EIK) Constraint #: 339
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	1.222	0.4748	0.4748	0.4386	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.222	0.4748	0.4748	0.4386	0.000
TBtu Consumed	45.68	24.19	24.19	22.69	3.370
Rate - [lb/MMBtu]	0.5351E-01	0.3925E-01	0.3925E-01	0.3866E-01	0.000
TWh Generated	4.960	2.733	2.733	2.578	0.5189
TWh Generated Qualifying	-4960.	-2733.	-2733.	-2578.	-518.9
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (EOH) Constraint #: 340
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (EOI) Constraint #: 341
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Massachusetts Fac. Spec. - SO2 Output Annual (EOJ) Constraint #: 342
 Constraint Type: Rate Limit [lb/MWh]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MWh]	3.000	3.000	3.000	3.000	3.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Missouri - NOX .18 Rate Annual
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1800	0.1800	0.1800	0.1800	0.1800
-Emissions at Affected Plants [MTons]	20.33	18.26	17.68	16.13	12.17
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	9.463	9.210	8.834	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	20.33	27.72	26.89	24.96	12.17
TBtu Consumed	336.6	308.0	298.7	277.4	221.5
Rate - [lb/MMBtu]	0.1208	0.1186	0.1183	0.1163	0.1099
TWh Generated	31.87	29.34	28.47	26.47	21.25
TWh Generated Qualifying	-0.3187E+05	-0.2934E+05	-0.2847E+05	-0.2647E+05	-0.2125E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Missouri - NOX .25 Rate Annual
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 344

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	16.62	17.46	17.08	16.31	13.40
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	4.729	4.762	3.990	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	16.62	22.18	21.84	20.30	13.40
TBtu Consumed	168.8	177.5	174.8	162.4	131.4
Rate - [lb/MMBtu]	0.1969	0.1967	0.1955	0.2009	0.2039
TWh Generated	16.76	17.63	17.49	16.16	13.17
TWh Generated Qualifying	-0.1676E+05	-0.1763E+05	-0.1749E+05	-0.1616E+05	-0.1317E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Missouri - NOX .35 Rate Annual
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 345

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3500	0.3500	0.3500	0.3500	0.3500
-Emissions at Affected Plants [MTons]	44.05	41.16	40.51	33.68	28.84
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	11.70	14.84	10.41	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	44.05	52.85	55.35	44.09	28.84
TBtu Consumed	317.4	302.0	316.3	251.9	214.1
Rate - [lb/MMBtu]	0.2776	0.2725	0.2562	0.2674	0.2695
TWh Generated	30.50	29.37	31.67	25.04	21.39
TWh Generated Qualifying	-0.3050E+05	-0.2937E+05	-0.3167E+05	-0.2504E+05	-0.2139E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MN State Reg Silver Lake 4 - NOX Rate Annual Constraint #: 346
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.5958E+05	0.2780E+05	0.2630E+05	0.2785E+05	0.2907E+05

Constraint Name: NC State Reg Cape Fear 5,6 - SO2 Rate Annual (AO1) Constraint #: 347
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1131E+05	0.1330E+05	0.1612E+05	0.1305E+05

Constraint Name: NC State Reg Cape Fear 5,6 - SO2 Rate Annual (AQ2) Constraint #: 348
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1294E+05	0.1586E+05	0.1891E+05	0.1565E+05

Constraint Name: NC State Reg L V Sutton 3 - SO2 Rate Annual Constraint #: 349
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4782.	5185.	3468.	3101.

Constraint Name: New Hampshire 6 Unit - CO2 Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 350

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	5426.	5426.	5426.	5426.	5426.
-Emissions at Affected Plants [MTons]	4183.	2853.	2504.	2504.	1855.
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	2572.	2922.	2922.	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4183.	5426.	5426.	5426.	1855.
TBTu Consumed	44.24	29.15	25.02	25.02	21.83
Rate - [lb/MMBtu]	189.1	195.8	200.2	200.2	169.9
TWh Generated	3.924	2.685	2.355	2.355	2.056
TWh Generated Qualifying	-3924.	-2685.	-2355.	-2355.	-2056.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: New Hampshire 6 Unit - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 351

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	3.640	3.640	3.640	3.640	3.640
-Emissions at Affected Plants [MTons]	2.091	1.203	0.7970	0.7970	0.6942
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	2.437	2.843	2.843	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.091	3.640	3.640	3.640	0.6942
TBtu Consumed	44.24	29.15	25.02	25.02	21.83
Rate - [lb/MMBtu]	0.9453E-01	0.8257E-01	0.6372E-01	0.6372E-01	0.6360E-01
TWh Generated	3.924	2.685	2.355	2.355	2.056
TWh Generated Qualifying	-3924.	-2685.	-2355.	-2355.	-2056.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: New Hampshire 6 Unit - SO2 Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 352

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	7.290	7.290	7.290	7.290	7.290
-Emissions at Affected Plants [MTons]	7.290	3.899	1.860	1.860	1.624
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	5.430	5.430	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.290	3.899	7.290	7.290	1.624
TBtu Consumed	44.24	29.15	25.02	25.02	21.83
Rate - [lb/MMBtu]	0.3296	0.2676	0.1487	0.1487	0.1487
TWh Generated	3.924	2.685	2.355	2.355	2.056
TWh Generated Qualifying	-3924.	-2685.	-2355.	-2355.	-2056.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2893.	0.000	0.000	0.000	0.000

Constraint Name: New Hampshire State - NOX Cap Summer
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Constraint #: 353

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	2.900	2.900	2.900	2.900	2.900
-Emissions at Affected Plants [MTons]	1.032	0.6848	0.4453	0.4452	0.3259
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	2.215	2.455	2.455	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.032	2.900	2.900	2.900	0.3259
TBtu Consumed	49.93	43.75	34.03	34.03	18.03
Rate - [lb/MMBtu]	0.4134E-01	0.3131E-01	0.2617E-01	0.2616E-01	0.3615E-01
TWh Generated	5.967	5.446	4.217	4.217	2.076
TWh Generated Qualifying	-5967.	-5446.	-4217.	-4217.	-2076.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: New Jersey - MER Removal Annual
Constraint Type: Required Removal Level
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 354

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Emission Floor - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [Lb]	111.3	101.5	93.76	51.10	37.95
-Less Allowances Purchased [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [Lb] MER	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [Lb]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn [Lb]	0.000	0.000	0.000	0.000	0.000
Total [Lb]	111.3	101.5	93.76	51.10	37.95
TBtu Consumed	165.7	157.7	140.9	111.4	73.92
Rate - [lb/MMBtu]	0.6718E-06	0.6438E-06	0.6652E-06	0.4587E-06	0.5134E-06
TWh Generated	15.42	14.68	13.14	10.47	6.987
TWh Generated Qualifying	-0.1542E+05	-0.1468E+05	-0.1314E+05	-0.1047E+05	-6987.
Constraint Shadow Price [US\$/Lb]	0.000	0.000	0.000	0.000	0.000

Constraint Name: New York - NOX Cap Winter
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER
Run Year, Seasons Included: 2015 WINTER
Run Year, Seasons Included: 2020 WINTER
Run Year, Seasons Included: 2025 WINTER
Run Year, Seasons Included: 2032 WINTER

Constraint #: 355

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	39.91	39.91	39.91	39.91	39.91
-Emissions at Affected Plants [MTons]	18.27	8.744	7.244	6.675	3.565
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	31.17	32.67	33.24	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	18.27	39.91	39.91	39.91	3.565
TBTu Consumed	377.7	239.1	230.8	226.0	143.1
Rate - [lb/MMBtu]	0.9674E-01	0.7314E-01	0.6277E-01	0.5908E-01	0.4983E-01
TWh Generated	43.95	29.46	29.33	29.10	19.05
TWh Generated Qualifying	-0.4395E+05	-0.2946E+05	-0.2933E+05	-0.2910E+05	-0.1904E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: New York - SO2 Cap Annual

Constraint #: 356

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	131.4	131.4	131.4	131.4	131.4
-Emissions at Affected Plants [MTons]	128.9	61.07	42.94	37.79	31.98
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	88.42	93.57	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	128.9	61.07	131.4	131.4	31.98
TBTu Consumed	682.0	450.0	433.3	420.2	270.4
Rate - [lb/MMBtu]	0.3781	0.2714	0.1982	0.1799	0.2365
TWh Generated	78.88	54.62	54.07	53.19	35.36
TWh Generated Qualifying	-0.7888E+05	-0.5462E+05	-0.5407E+05	-0.5319E+05	-0.3536E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: North Carolina Duke - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 357

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	31.00	31.00	31.00	31.00	31.00
-Emissions at Affected Plants [MTons]	22.80	19.97	19.72	19.42	18.72
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	22.80	19.97	19.72	19.42	18.72
TBtu Consumed	405.0	373.5	369.8	365.0	355.6
Rate - [lb/MMBtu]	0.1126	0.1070	0.1067	0.1064	0.1053
TWh Generated	42.42	39.51	39.15	38.67	37.64
TWh Generated Qualifying	-0.4242E+05	-0.3951E+05	-0.3915E+05	-0.3867E+05	-0.3764E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: North Carolina Duke - SO2 Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 358

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	150.0	80.00	80.00	80.00	80.00
-Emissions at Affected Plants [MTons]	64.93	44.34	28.07	23.78	24.27
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	64.93	44.34	28.07	23.78	24.27
TBtu Consumed	405.0	373.5	369.8	365.0	355.6
Rate - [lb/MMBtu]	0.3207	0.2375	0.1518	0.1303	0.1365
TWh Generated	42.42	39.51	39.15	38.67	37.64
TWh Generated Qualifying	-0.4242E+05	-0.3951E+05	-0.3915E+05	-0.3867E+05	-0.3764E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: North Carolina Progress - NOX Cap Annual Constraint #: 359
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	25.00	25.00	25.00	25.00	25.00
-Emissions at Affected Plants [MTons]	25.00	11.08	10.42	10.04	8.370
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	25.00	11.08	10.42	10.04	8.370
TBTu Consumed	353.0	266.6	250.3	244.9	204.9
Rate - [lb/MMBtu]	0.1416	0.8310E-01	0.8326E-01	0.8197E-01	0.8169E-01
TWh Generated	34.12	25.94	24.40	23.87	20.09
TWh Generated Qualifying	-0.3412E+05	-0.2594E+05	-0.2440E+05	-0.2387E+05	-0.2009E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1124.	0.000	0.000	0.000	0.000

Constraint Name: North Carolina Progress - SO2 Cap Annual Constraint #: 360
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	100.0	50.00	50.00	50.00	50.00
-Emissions at Affected Plants [MTons]	84.30	40.62	18.49	16.34	13.57
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	84.30	40.62	18.49	16.34	13.57
TBTu Consumed	353.0	266.6	250.3	244.9	204.9
Rate - [lb/MMBTu]	0.4776	0.3048	0.1478	0.1334	0.1324
TWh Generated	34.12	25.94	24.40	23.87	20.09
TWh Generated Qualifying	-0.3412E+05	-0.2594E+05	-0.2440E+05	-0.2387E+05	-0.2009E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Dominion Consent Decree - NOX Cap Annual Constraint #: 361
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	63.00	30.25	30.25	30.25	30.25
-Emissions at Affected Plants [MTons]	32.91	23.49	21.64	18.67	12.72
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	32.91	23.49	21.64	18.67	12.72
TBTu Consumed	375.2	335.2	319.0	293.3	221.5
Rate - [lb/MMBtu]	0.1754	0.1402	0.1357	0.1273	0.1149
TWh Generated	37.86	34.36	32.74	30.05	22.62
TWh Generated Qualifying	-0.3786E+05	-0.3436E+05	-0.3274E+05	-0.3005E+05	-0.2262E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Dominion Consent Decree - NOX Rate Annual Constraint #: 362
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	23.49	21.64	18.67	12.72
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	23.49	21.64	18.67	12.72
TBtu Consumed	0.000	335.2	319.0	293.3	221.5
Rate - [lb/MMBtu]	0.000	0.1402	0.1357	0.1273	0.1149
TWh Generated	0.000	34.36	32.74	30.05	22.62
TWh Generated Qualifying	0.000	-0.3436E+05	-0.3274E+05	-0.3005E+05	-0.2262E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Illinois Power Settlement - NOX Cap Annual Constraint #: 363
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	13.80	13.80	13.80	13.80	13.80
-Emissions at Affected Plants [MTons]	8.990	6.761	6.512	6.166	4.977
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	8.990	6.761	6.512	6.166	4.977
TBtu Consumed	213.8	134.9	131.4	126.3	106.0
Rate - [lb/MMBtu]	0.8410E-01	0.1003	0.9910E-01	0.9766E-01	0.9395E-01
TWh Generated	20.73	13.41	13.08	12.59	10.64
TWh Generated Qualifying	-0.2073E+05	-0.1341E+05	-0.1308E+05	-0.1259E+05	-0.1064E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Illinois Power Settlement - SO2 Cap Summer Constraint #: 364
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	62.00	29.00	29.00	29.00	29.00
-Emissions at Affected Plants [MTons]	62.00	17.72	15.65	14.08	9.582
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	62.00	17.72	15.65	14.08	9.582
TBtu Consumed	213.8	134.9	131.4	126.3	106.0
Rate - [lb/MMBtu]	0.5800	0.2627	0.2382	0.2230	0.1809
TWh Generated	20.73	13.41	13.08	12.59	10.64
TWh Generated Qualifying	-0.2073E+05	-0.1341E+05	-0.1308E+05	-0.1259E+05	-0.1064E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1122.	0.000	0.000	0.000	0.000

Constraint Name: NSR Minnkota Power Settlement - SO2 Cap Annual Constraint #: 365
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	31.00	8.500	8.500	8.500	8.500
-Emissions at Affected Plants [MTons]	9.829	1.732	1.732	1.452	0.5197
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	9.829	1.732	1.732	1.452	0.5197
TBtu Consumed	59.43	53.40	53.40	44.67	16.14
Rate - [lb/MMBtu]	0.3308	0.6487E-01	0.6487E-01	0.6503E-01	0.6439E-01
TWh Generated	5.214	4.674	4.674	3.911	1.415
TWh Generated Qualifying	-5214.	-4674.	-4674.	-3911.	-1415.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Mirant Settlement - NOX Cap Annual

Constraint #: 366

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	16.00	16.00	16.00	16.00	16.00
-Emissions at Affected Plants [MTons]	14.19	12.50	12.70	12.23	7.131
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	14.19	12.50	12.70	12.23	7.131
TBTu Consumed	206.0	191.1	190.8	185.4	126.1
Rate - [lb/MMBTu]	0.1378	0.1309	0.1331	0.1319	0.1131
TWh Generated	19.80	18.61	18.59	18.10	12.65
TWh Generated Qualifying	-0.1980E+05	-0.1861E+05	-0.1859E+05	-0.1810E+05	-0.1265E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Mirant Settlement - NOX Cap Summer
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Constraint #: 367

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	5.200	5.200	5.200	5.200	5.200
-Emissions at Affected Plants [MTons]	5.200	5.200	5.193	5.021	3.301
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	5.200	5.200	5.193	5.021	3.301
TBtu Consumed	84.41	81.02	79.74	78.70	54.98
Rate - [lb/MMBtu]	0.1232	0.1284	0.1302	0.1276	0.1201
TWh Generated	8.180	7.905	7.787	7.686	5.504
TWh Generated Qualifying	-8180.	-7905.	-7787.	-7686.	-5504.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2813.	92.23	0.000	0.000	0.000

Constraint Name: NSR Mirant Settlement - NOX Rate Summer
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Constraint #: 368

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	5.200	5.200	5.193	5.021	3.301
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	5.200	5.200	5.193	5.021	3.301
TBtu Consumed	84.41	81.02	79.74	78.70	54.98
Rate - [lb/MMBtu]	0.1232	0.1284	0.1302	0.1276	0.1201
TWh Generated	8.180	7.905	7.787	7.686	5.504
TWh Generated Qualifying	-8180.	-7905.	-7787.	-7686.	-5504.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Mirant Settlement - Potomac NOX Cap Annual Constraint #: 369
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	3.700	3.700	3.700	3.700	3.700
-Emissions at Affected Plants [MTons]	3.700	2.459	2.459	2.101	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.700	2.459	2.459	2.101	0.000
TBtu Consumed	22.06	14.86	14.86	12.69	0.000
Rate - [lb/MMBtu]	0.3354	0.3310	0.3310	0.3310	0.000
TWh Generated	1.972	1.442	1.442	1.232	0.000
TWh Generated Qualifying	-1972.	-1442.	-1442.	-1232.	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	7322.	0.000	0.000	0.000	0.000

Constraint Name: NSR Mirant Settlement - Potomac NOX Cap Summer Constraint #: 370
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	1.480	1.480	1.480	1.480	1.480
-Emissions at Affected Plants [MTons]	0.8165	0.9883	0.9883	0.8165	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.8165	0.9883	0.9883	0.8165	0.000
TBtu Consumed	4.933	5.972	5.972	4.933	0.000
Rate - [lb/MMBtu]	0.3310	0.3310	0.3310	0.3310	0.000
TWh Generated	0.4789	0.5797	0.5797	0.4789	0.000
TWh Generated Qualifying	-478.9	-579.7	-579.7	-478.9	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Ohio Edison Settlement - NOX Cap Annual Constraint #: 371
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	17.33	11.86	11.86	11.86	11.86
-Emissions at Affected Plants [MTons]	10.98	10.33	10.50	9.860	7.679
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	10.98	10.33	10.50	9.860	7.679
TBTu Consumed	154.6	149.1	151.0	145.6	127.1
Rate - [lb/MMBtu]	0.1420	0.1386	0.1391	0.1355	0.1208
TWh Generated	15.93	15.32	15.51	14.96	13.14
TWh Generated Qualifying	-0.1593E+05	-0.1531E+05	-0.1551E+05	-0.1496E+05	-0.1314E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Ohio Edison Settlement - SO2 Cap Annual Constraint #: 372
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	101.5	29.90	29.90	29.90	29.90
-Emissions at Affected Plants [MTons]	85.76	29.90	29.90	29.90	29.90
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	85.76	29.90	29.90	29.90	29.90
TBTu Consumed	154.6	149.1	151.0	145.6	127.1
Rate - [lb/MMBtu]	1.110	0.4010	0.3959	0.4108	0.4703
TWh Generated	15.93	15.32	15.51	14.96	13.14
TWh Generated Qualifying	-0.1593E+05	-0.1531E+05	-0.1551E+05	-0.1496E+05	-0.1314E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	245.6	193.8	169.2	269.8

Constraint Name: NSR Santee Cooper Settlement - NOX Cap Annual Constraint #: 373
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	20.00	20.00	20.00	20.00	20.00
-Emissions at Affected Plants [MTons]	13.23	11.95	10.94	10.71	10.57
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	13.23	11.95	10.94	10.71	10.57
TBtu Consumed	207.3	193.2	186.2	178.7	173.9
Rate - [lb/MMBtu]	0.1276	0.1238	0.1175	0.1199	0.1216
TWh Generated	20.54	19.17	18.50	17.73	17.27
TWh Generated Qualifying	-0.2054E+05	-0.1917E+05	-0.1850E+05	-0.1773E+05	-0.1727E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Santee Cooper Settlement - NOX Rate Annual Constraint #: 374
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	13.23	11.95	10.94	10.71	10.57
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	13.23	11.95	10.94	10.71	10.57
TBtu Consumed	207.3	193.2	186.2	178.7	173.9
Rate - [lb/MMBtu]	0.1276	0.1238	0.1175	0.1199	0.1216
TWh Generated	20.54	19.17	18.50	17.73	17.27
TWh Generated Qualifying	-0.2054E+05	-0.1917E+05	-0.1850E+05	-0.1773E+05	-0.1727E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Santee Cooper Settlement - SO2 Cap Annual Constraint #: 375
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	70.00	65.00	65.00	65.00	65.00
-Emissions at Affected Plants [MTons]	37.49	27.00	19.66	15.91	15.74
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	37.49	27.00	19.66	15.91	15.74
TBtu Consumed	207.3	193.2	186.2	178.7	173.9
Rate - [lb/MMBtu]	0.3618	0.2796	0.2111	0.1781	0.1810
TWh Generated	20.54	19.17	18.50	17.73	17.27
TWh Generated Qualifying	-0.2054E+05	-0.1917E+05	-0.1850E+05	-0.1773E+05	-0.1727E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Santee Cooper Settlement - SO2 Rate Annual Constraint #: 376
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.5300	0.5000	0.5000	0.5000	0.5000
-Emissions at Affected Plants [MTons]	37.49	27.00	19.66	15.91	15.74
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	37.49	27.00	19.66	15.91	15.74
TBtu Consumed	207.3	193.2	186.2	178.7	173.9
Rate - [lb/MMBtu]	0.3618	0.2796	0.2111	0.1781	0.1810
TWh Generated	20.54	19.17	18.50	17.73	17.27
TWh Generated Qualifying	-0.2054E+05	-0.1917E+05	-0.1850E+05	-0.1773E+05	-0.1727E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Baldwin 1-3 - SO2 Rate Annual (CLM) Constraint #: 377
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	2.229	2.229	2.214	2.117
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.229	2.229	2.214	2.117
TBtu Consumed	0.000	44.59	44.59	44.28	42.33
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	4.532	4.532	4.501	4.304
TWh Generated Qualifying	0.000	-4532.	-4532.	-4501.	-4304.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1134.	1284.	2178.	975.2

Constraint Name: NSR Unit Level Baldwin 1-3 - SO2 Rate Annual (DPP) Constraint #: 378
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	4038.	3721.	3980.	2332.

Constraint Name: NSR Unit Level Baldwin 1-3 - SO2 Rate Annual (DPQ) Constraint #: 379
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	2.228	2.228	2.228	2.123
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.228	2.228	2.228	2.123
TBtu Consumed	0.000	44.56	44.56	44.56	42.47
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	4.516	4.516	4.516	4.304
TWh Generated Qualifying	0.000	-4516.	-4516.	-4516.	-4304.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	2115.	2166.	1658.	830.3

Constraint Name: NSR Unit Level Baldwin 3 - NOX Rate Annual Constraint #: 380
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1200	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	2.011	2.118	2.118	2.103	2.011
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.011	2.118	2.118	2.103	2.011
TBtu Consumed	42.33	44.59	44.59	44.28	42.33
Rate - [lb/MMBtu]	0.9500E-01	0.9500E-01	0.9500E-01	0.9500E-01	0.9500E-01
TWh Generated	4.369	4.532	4.532	4.501	4.304
TWh Generated Qualifying	-4369.	-4532.	-4532.	-4501.	-4304.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Big Bend 1-3 - NOX Rate Annual (EHV Constraint #: 381)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.9957	0.8697	0.8697	0.7846	0.7185
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9957	0.8697	0.8697	0.7846	0.7185
TBtu Consumed	32.65	28.52	28.52	25.72	23.56
Rate - [lb/MMBtu]	0.6100E-01	0.6100E-01	0.6100E-01	0.6100E-01	0.6100E-01
TWh Generated	3.093	2.701	2.701	2.437	2.232
TWh Generated Qualifying	-3093.	-2701.	-2701.	-2437.	-2232.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Big Bend 1-3 - NOX Rate Annual (EHW Constraint #: 382)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.9346	0.8680	0.9346	0.8680	0.8628
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9346	0.8680	0.9346	0.8680	0.8628
TBtu Consumed	30.64	28.46	30.64	28.46	28.29
Rate - [lb/MMBtu]	0.6100E-01	0.6100E-01	0.6100E-01	0.6100E-01	0.6100E-01
TWh Generated	3.019	2.804	3.019	2.804	2.787
TWh Generated Qualifying	-3019.	-2804.	-3019.	-2804.	-2787.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Big Bend 1-3 - NOX Rate Annual (EHX Constraint #: 383)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.9753	0.8519	0.9058	0.9058	0.8519
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.9753	0.8519	0.9058	0.9058	0.8519
TBtu Consumed	32.51	28.40	30.19	30.19	28.40
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	3.144	2.746	2.920	2.920	2.746
TWh Generated Qualifying	-3144.	-2746.	-2920.	-2920.	-2746.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Chesapeake 3,4 - NOX Rate Annual (B Constraint #: 384
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.5692	0.4972	0.4596	0.4108
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.5692	0.4972	0.4596	0.4108
TBtu Consumed	0.000	11.38	9.945	9.193	8.215
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	1.167	1.019	0.9424	0.8422
TWh Generated Qualifying	0.000	-1167.	-1019.	-942.4	-842.2
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1614.	309.1	1256.	537.6

Constraint Name: NSR Unit Level Chesapeake 3,4 - NOX Rate Annual (B Constraint #: 385
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	5774.	3903.	6449.	9514.

Constraint Name: NSR Unit Level Chesterfield 4-6 - NOX Rate Annual Constraint #: 386
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.6262	0.5056	0.4519	0.4519
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.6262	0.5056	0.4519	0.4519
TBtu Consumed	0.000	12.52	10.11	9.037	9.037
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	1.242	1.003	0.8962	0.8962
TWh Generated Qualifying	0.000	-1242.	-1003.	-896.2	-896.2
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	433.6	1564.	920.4	0.000

Constraint Name: NSR Unit Level Chesterfield 4-6 - NOX Rate Annual Constraint #: 387

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2010

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2025 WINTER SUMMER

Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	1.098	1.098	1.025	0.7362
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.098	1.098	1.025	0.7362
TBtu Consumed	0.000	21.96	21.96	20.68	15.55
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.9914E-01	0.9468E-01
TWh Generated	0.000	2.188	2.188	2.060	1.549
TWh Generated Qualifying	0.000	-2188.	-2188.	-2060.	-1549.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1401.	282.7	0.000	0.000

Constraint Name: NSR Unit Level Chesterfield 4-6 - NOX Rate Annual Constraint #: 388
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	2.386	2.284	2.254	1.722
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.386	2.284	2.254	1.722
TBtu Consumed	0.000	47.72	45.69	45.07	34.44
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	4.796	4.591	4.529	3.461
TWh Generated Qualifying	0.000	-4796.	-4591.	-4529.	-3461.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1059.	88.37	57.36	130.3

Constraint Name: NSR Unit Level Chesterfield 5 - SO2 Rate Annual Constraint #: 389
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1300	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	1.428	1.428	1.344	1.011
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.428	1.428	1.344	1.011
TBtu Consumed	0.000	21.96	21.96	20.68	15.55
Rate - [lb/MMBtu]	0.000	0.1300	0.1300	0.1300	0.1300
TWh Generated	0.000	2.188	2.188	2.060	1.549
TWh Generated Qualifying	0.000	-2188.	-2188.	-2060.	-1549.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1663.	1417.	427.6	279.0

Constraint Name: NSR Unit Level Chesterfield 6 - SO2 Rate Annual Constraint #: 390
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1300	0.1300	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	3.102	3.102	2.917	2.514	1.969
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.102	3.102	2.917	2.514	1.969
TBtu Consumed	47.72	47.72	45.69	45.07	34.44
Rate - [lb/MMBtu]	0.1300	0.1300	0.1277	0.1116	0.1144
TWh Generated	4.796	4.796	4.591	4.529	3.461
TWh Generated Qualifying	-4796.	-4796.	-4591.	-4529.	-3461.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	5715.	4358.	0.000	0.000	0.000

Constraint Name: NSR Unit Level Havana 9 - SO2 Rate Annual Constraint #: 391
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	9.845	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	9.845	0.000	0.000	0.000	0.000
TBtu Consumed	33.95	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.5800	0.000	0.000	0.000	0.000
TWh Generated	3.125	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-3125.	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	6343.	5175.	4471.	3877.

Constraint Name: NSR Unit Level Hennepin 1,2 - SO2 Rate Annual (CLL Constraint #: 392)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	1.818	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.818	0.000	0.000	0.000	0.000
TBtu Consumed	6.270	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.5800	0.000	0.000	0.000	0.000
TWh Generated	0.5319	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-531.9	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Hennepin 1,2 - SO2 Rate Annual (CLN Constraint #: 393)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	5.229	5.229	4.731	3.662	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	5.229	5.229	4.731	3.662	0.000
TBtu Consumed	18.03	18.03	16.67	13.77	0.000
Rate - [lb/MMBtu]	0.5800	0.5800	0.5677	0.5319	0.000
TWh Generated	1.698	1.698	1.569	1.296	0.000
TWh Generated Qualifying	-1698.	-1698.	-1569.	-1296.	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Hudson 2 - SO2 Rate Annual

Constraint #: 394

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	3.455	3.263	3.013	1.365	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.455	3.263	3.013	1.365	0.000
TBtu Consumed	47.65	45.01	41.56	34.39	0.000
Rate - [lb/MMBtu]	0.1450	0.1450	0.1450	0.7940E-01	0.000
TWh Generated	4.471	4.223	3.899	3.226	0.000
TWh Generated Qualifying	-4471.	-4223.	-3899.	-3226.	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level James Miller 3,4 - NOX Rate Annual Constraint #: 395

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	1.566	1.368	1.566	1.566	1.234
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.566	1.368	1.566	1.566	1.234
TBtu Consumed	52.19	45.58	52.19	52.19	41.14
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	5.155	4.429	5.070	5.070	3.997
TWh Generated Qualifying	-5155.	-4429.	-5070.	-5070.	-3997.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level James Miller 3,4 - NOX Rate Annual Constraint #: 396
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	1.544	1.404	1.544	1.544	1.349
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.544	1.404	1.544	1.544	1.349
TBtu Consumed	51.48	46.80	51.48	51.48	44.97
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	5.155	4.609	5.070	5.070	4.429
TWh Generated Qualifying	-5155.	-4609.	-5070.	-5070.	-4429.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Mercer 1,2 - SO2 Rate Annual (DPF) Constraint #: 397
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.804	1.678	1.597	1.597
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.804	1.678	1.597	1.597
TBtu Consumed	0.000	24.05	22.37	21.29	21.29
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	2.312	2.150	2.047	2.047
TWh Generated Qualifying	0.000	-2312.	-2150.	-2047.	-2047.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1382.	1630.	268.4	664.2

Constraint Name: NSR Unit Level Mercer 1,2 - SO2 Rate Annual (DPG) Constraint #: 398
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	1.804	1.679	1.597	1.597
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.804	1.679	1.597	1.597
TBtu Consumed	0.000	24.06	22.38	21.29	21.29
Rate - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
TWh Generated	0.000	2.312	2.150	2.047	2.047
TWh Generated Qualifying	0.000	-2312.	-2150.	-2047.	-2047.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1382.	1639.	263.5	658.6

Constraint Name: NSR Unit Level Milton Young 1,2 - NOX Rate Annual Constraint #: 399
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3600	0.3600	0.3600	0.3600	0.3600
-Emissions at Affected Plants [MTons]	0.7359	0.6953	0.6953	0.5941	0.2311
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7359	0.6953	0.6953	0.5941	0.2311
TBtu Consumed	20.73	19.59	19.59	16.74	6.509
Rate - [lb/MMBtu]	0.7101E-01	0.7100E-01	0.7100E-01	0.7100E-01	0.7100E-01
TWh Generated	1.871	1.754	1.754	1.499	0.5829
TWh Generated Qualifying	-1871.	-1754.	-1754.	-1499.	-582.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Milton Young 1,2 - NOX Rate Annual Constraint #: 400
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3600	0.3600	0.3600	0.3600	0.3600
-Emissions at Affected Plants [MTons]	1.374	1.200	1.200	0.9915	0.3420
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.374	1.200	1.200	0.9915	0.3420
TBtu Consumed	38.71	33.81	33.81	27.93	9.634
Rate - [lb/MMBtu]	0.7101E-01	0.7101E-01	0.7101E-01	0.7100E-01	0.7100E-01
TWh Generated	3.342	2.920	2.920	2.412	0.8319
TWh Generated Qualifying	-3342.	-2919.	-2919.	-2412.	-831.9
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Oak Creek 5-8 - NOX Rate Annual (CT Constraint #: 401
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	5577.	3315.	3221.	0.000

Constraint Name: NSR Unit Level Oak Creek 5-8 - NOX Rate Annual (CU Constraint #: 402
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	5062.	4084.	2759.	0.000

Constraint Name: NSR Unit Level Oak Creek 5-8 - NOX Rate Annual (CV Constraint #: 403
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	7758.	6620.	7516.	8026.

Constraint Name: NSR Unit Level Oak Creek 5-8 - NOX Rate Annual (CW Constraint #: 404
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	1.061	1.061	1.003	0.8484
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.061	1.061	1.003	0.8484
TBtu Consumed	0.000	21.23	21.23	20.05	16.97
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
TWh Generated	0.000	2.195	2.195	2.074	1.754
TWh Generated Qualifying	0.000	-2195.	-2195.	-2073.	-1754.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1410E+05	5195.	2316.	8188.

Constraint Name: NSR Unit Level Oak Creek 5-8 - SO2 Rate Annual (CT Constraint #: 405)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1006E+05	0.1423E+05	0.1164E+05	4031.

Constraint Name: NSR Unit Level Oak Creek 5-8 - SO2 Rate Annual (CU Constraint #: 406
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.1006E+05	8267.	8841.	3615.

Constraint Name: NSR Unit Level Oak Creek 5-8 - SO2 Rate Annual (CV Constraint #: 407)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	7335.	2287.	160.3	0.000

Constraint Name: NSR Unit Level Oak Creek 5-8 - SO2 Rate Annual (CW Constraint #: 408)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	1.061	1.061	0.9848	0.7537
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.061	1.061	0.9848	0.7537
TBtu Consumed	0.000	21.23	21.23	20.05	16.97
Rate - [lb/MMBtu]	0.000	0.1000	0.1000	0.9822E-01	0.8884E-01
TWh Generated	0.000	2.195	2.195	2.074	1.754
TWh Generated Qualifying	0.000	-2195.	-2195.	-2073.	-1754.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	3764.	2572.	0.000	0.000

Constraint Name: NSR Unit Level Vermilion 1,2 - SO2 Rate Annual (CL Constraint #: 409)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Vermilion 1,2 - SO2 Rate Annual (DW Constraint #: 410)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level W H Sammis 1-5 - SO2 Rate Annual (D Constraint #: 411
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.100	1.100	1.100	1.100	1.100
-Emissions at Affected Plants [MTons]	7.101	4.737	4.442	3.374	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.101	4.737	4.442	3.374	0.000
TBtu Consumed	12.91	11.93	11.93	11.03	0.000
Rate - [lb/MMBtu]	1.100	0.7939	0.7444	0.6117	0.000
TWh Generated	1.273	1.176	1.176	1.087	0.000
TWh Generated Qualifying	-1273.	-1176.	-1176.	-1087.	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	387.9	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level W H Sammis 1-5 - SO2 Rate Annual (D Constraint #: 412
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.100	1.100	1.100	1.100	1.100
-Emissions at Affected Plants [MTons]	7.175	4.785	4.785	5.968	5.179
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.175	4.785	4.785	5.968	5.179
TBtu Consumed	13.05	12.06	12.06	10.85	9.416
Rate - [lb/MMBtu]	1.100	0.7936	0.7936	1.100	1.100
TWh Generated	1.273	1.176	1.176	1.059	0.9185
TWh Generated Qualifying	-1273.	-1176.	-1176.	-1058.	-918.5
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	387.9	0.000	0.000	0.000	171.2

Constraint Name: NSR Unit Level W H Sammis 1-5 - SO2 Rate Annual (D Constraint #: 413
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.100	1.100	1.100	1.100	1.100
-Emissions at Affected Plants [MTons]	7.012	3.968	4.342	4.669	5.354
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.012	3.968	4.342	4.669	5.354
TBtu Consumed	12.75	11.78	12.75	11.78	9.735
Rate - [lb/MMBtu]	1.100	0.6734	0.6811	0.7924	1.100
TWh Generated	1.273	1.176	1.273	1.176	0.9718
TWh Generated Qualifying	-1273.	-1176.	-1273.	-1176.	-971.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	387.9	0.000	0.000	0.000	171.2

Constraint Name: NSR Unit Level W H Sammis 1-5 - SO2 Rate Annual (D Constraint #: 414
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.100	1.100	1.100	1.100	1.100
-Emissions at Affected Plants [MTons]	6.954	4.350	4.628	5.160	5.310
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.954	4.350	4.628	5.160	5.310
TBtu Consumed	12.64	11.69	12.64	11.69	9.655
Rate - [lb/MMBtu]	1.100	0.7444	0.7320	0.8830	1.100
TWh Generated	1.273	1.176	1.273	1.176	0.9718
TWh Generated Qualifying	-1273.	-1176.	-1273.	-1176.	-971.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	387.9	0.000	0.000	0.000	171.2

Constraint Name: NSR Unit Level W H Sammis 1-5 - SO2 Rate Annual (D Constraint #: 415
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.100	1.100	1.100	1.100	1.100
-Emissions at Affected Plants [MTons]	11.38	6.695	6.339	5.364	8.692
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	11.38	6.695	6.339	5.364	8.692
TBtu Consumed	20.69	19.13	19.13	17.68	15.80
Rate - [lb/MMBtu]	1.100	0.7000	0.6628	0.6070	1.100
TWh Generated	2.088	1.930	1.930	1.784	1.595
TWh Generated Qualifying	-2088.	-1930.	-1930.	-1784.	-1595.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	141.6	0.000	0.000	0.000	72.17

Constraint Name: NSR Unit Level W H Sammis 5 - NOX Rate Annual Constraint #: 416
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2900	0.2900	0.2900	0.2900	0.2900
-Emissions at Affected Plants [MTons]	3.000	2.774	2.774	2.563	2.291
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.000	2.774	2.774	2.563	2.291
TBtu Consumed	20.69	19.13	19.13	17.68	15.80
Rate - [lb/MMBtu]	0.2900	0.2900	0.2900	0.2900	0.2900
TWh Generated	2.088	1.930	1.930	1.784	1.595
TWh Generated Qualifying	-2088.	-1930.	-1930.	-1784.	-1595.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level W H Sammis 6 - SO2 Rate Annual Constraint #: 417
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1300	0.1300	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	2.671	2.671	2.671	2.671	2.671
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.671	2.671	2.671	2.671	2.671
TBtu Consumed	41.09	41.09	41.09	41.09	41.09
Rate - [lb/MMBtu]	0.1300	0.1300	0.1300	0.1300	0.1300
TWh Generated	4.340	4.340	4.340	4.340	4.340
TWh Generated Qualifying	-4340.	-4340.	-4340.	-4340.	-4340.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	4864.	1386.	658.7	474.7	2747.

Constraint Name: NSR Unit Level W H Sammis 6,7 - NOX Rate Annual (D Constraint #: 418
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	1.233	1.233	1.233	1.233
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.233	1.233	1.233	1.233
TBtu Consumed	0.000	41.09	41.09	41.09	41.09
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	4.340	4.340	4.340	4.340
TWh Generated Qualifying	0.000	-4340.	-4340.	-4340.	-4340.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level W H Sammis 6,7 - NOX Rate Annual (D Constraint #: 419
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	0.000	1.243	1.243	1.243	1.243
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	1.243	1.243	1.243	1.243
TBtu Consumed	0.000	41.45	41.45	41.45	41.45
Rate - [lb/MMBtu]	0.000	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	0.000	4.340	4.340	4.340	4.340
TWh Generated Qualifying	0.000	-4340.	-4340.	-4340.	-4340.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level W H Sammis 7 - SO2 Rate Annual Constraint #: 420
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1300	0.1300	0.1300	0.1300
-Emissions at Affected Plants [MTons]	0.000	2.694	2.694	2.694	2.694
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	2.694	2.694	2.694	2.694
TBtu Consumed	0.000	41.45	41.45	41.45	41.45
Rate - [lb/MMBtu]	0.000	0.1300	0.1300	0.1300	0.1300
TWh Generated	0.000	4.340	4.340	4.340	4.340
TWh Generated Qualifying	0.000	-4340.	-4340.	-4340.	-4340.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	1386.	658.7	474.7	2747.

Constraint Name: NSR Unit Level Wood River 4,5 - SO2 Rate Annual (C Constraint #: 421
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR Unit Level Wood River 4,5 - SO2 Rate Annual (C Constraint #: 422)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	1.200	1.200	1.200	1.200	1.200
-Emissions at Affected Plants [MTons]	7.920	8.032	6.466	5.975	5.342
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	7.920	8.032	6.466	5.975	5.342
TBtu Consumed	27.31	27.70	25.61	23.66	21.16
Rate - [lb/MMBtu]	0.5800	0.5800	0.5050	0.5050	0.5050
TWh Generated	2.628	2.666	2.465	2.277	2.036
TWh Generated Qualifying	-2628.	-2666.	-2465.	-2277.	-2036.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR WEPCO Settlement - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 423

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	23.40	17.40	17.40	17.40	17.40
-Emissions at Affected Plants [MTons]	16.57	10.01	9.348	7.134	1.077
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	16.57	10.01	9.348	7.134	1.077
TBTu Consumed	216.3	141.4	144.0	131.5	58.54
Rate - [lb/MMBtu]	0.1532	0.1416	0.1298	0.1085	0.3679E-01
TWh Generated	20.38	13.04	14.22	13.10	8.157
TWh Generated Qualifying	-0.2038E+05	-0.1304E+05	-0.1422E+05	-0.1310E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR WEPCO Settlement - NOX Rate Annual Constraint #: 424
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1900	0.1700	0.1700	0.1700	0.1700
-Emissions at Affected Plants [MTons]	16.57	10.01	9.348	7.134	1.077
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	16.57	10.01	9.348	7.134	1.077
TBtu Consumed	216.3	141.4	144.0	131.5	58.54
Rate - [lb/MMBtu]	0.1532	0.1416	0.1298	0.1085	0.3679E-01
TWh Generated	20.38	13.04	14.22	13.10	8.157
TWh Generated Qualifying	-0.2038E+05	-0.1304E+05	-0.1422E+05	-0.1310E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR WEPCO Settlement - SO2 Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 425

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	55.40	33.30	33.30	33.30	33.30
-Emissions at Affected Plants [MTons]	48.67	15.09	16.36	8.823	0.7537
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	48.67	15.09	16.36	8.823	0.7537
TBTu Consumed	216.3	141.4	144.0	131.5	58.54
Rate - [lb/MMBtu]	0.4500	0.2136	0.2273	0.1342	0.2575E-01
TWh Generated	20.38	13.04	14.22	13.10	8.157
TWh Generated Qualifying	-0.2038E+05	-0.1304E+05	-0.1422E+05	-0.1310E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NSR WEPCO Settlement - SO2 Rate Annual Constraint #: 426
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.4500	0.3200	0.3200	0.3200	0.3200
-Emissions at Affected Plants [MTons]	48.67	15.09	16.36	8.823	0.7537
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	48.67	15.09	16.36	8.823	0.7537
TBtu Consumed	216.3	141.4	144.0	131.5	58.54
Rate - [lb/MMBtu]	0.4500	0.2136	0.2273	0.1342	0.2575E-01
TWh Generated	20.38	13.04	14.22	13.10	8.157
TWh Generated Qualifying	-0.2038E+05	-0.1304E+05	-0.1422E+05	-0.1310E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	12.41	0.000	0.000	0.000	0.000

Constraint Name: Pacific Northwest Constraint - CO2 Penalty Annual Constraint #: 427
Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	0.000	0.000	0.000	0.000	0.000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] CO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	1.061

Constraint Name: State Niagara Mohawk Power - NOX Cap Annual Constraint #: 428
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	4.861	3.241	3.241	3.241	3.241
-Emissions at Affected Plants [MTons]	4.861	3.241	3.241	2.537	0.4544
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	4.861	3.241	3.241	2.537	0.4544
TBtu Consumed	62.66	45.88	45.88	38.68	14.41
Rate - [lb/MMBtu]	0.1552	0.1413	0.1413	0.1312	0.6309E-01
TWh Generated	5.799	4.520	4.520	3.849	1.456
TWh Generated Qualifying	-5799.	-4520.	-4520.	-3849.	-1456.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1071E+05	3566.	483.4	0.000	0.000

Constraint Name: State Niagara Mohawk Power - SO2 Cap Annual Constraint #: 429
 Constraint Type: Rate Cap [MTons]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	19.44	14.17	14.17	14.17	14.17
-Emissions at Affected Plants [MTons]	19.44	14.17	14.17	10.67	14.17
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	19.44	14.17	14.17	10.67	14.17
TBtu Consumed	62.66	45.88	45.88	38.68	14.41
Rate - [lb/MMBtu]	0.6206	0.6176	0.6176	0.5515	1.967
TWh Generated	5.799	4.520	4.520	3.849	1.456
TWh Generated Qualifying	-5799.	-4520.	-4520.	-3849.	-1456.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	138.5	70.39	0.000	0.000	28.00

Constraint Name: State Unit Level Comanche 1,2 - NOX Rate Annual (C Constraint #: 430
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	1.846	1.846	1.846	1.846	1.613
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.846	1.846	1.846	1.846	1.613
TBtu Consumed	28.19	28.19	28.19	28.19	24.62
Rate - [lb/MMBtu]	0.1310	0.1310	0.1310	0.1310	0.1310
TWh Generated	2.696	2.696	2.696	2.696	2.355
TWh Generated Qualifying	-2696.	-2696.	-2696.	-2696.	-2355.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Comanche 1,2 - NOX Rate Annual (C Constraint #: 431
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	2.140	2.140	2.140	2.140	1.870
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.140	2.140	2.140	2.140	1.870
TBtu Consumed	28.54	28.54	28.54	28.54	24.93
Rate - [lb/MMBtu]	0.1500	0.1500	0.1500	0.1500	0.1500
TWh Generated	2.726	2.726	2.726	2.726	2.381
TWh Generated Qualifying	-2726.	-2726.	-2726.	-2726.	-2381.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	6274.	2540.	4209.	1960.	795.1

Constraint Name: State Unit Level Comanche 1,2 - SO2 Rate Annual (C Constraint #: 432
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	1.325	1.325	1.325	1.325	0.9983
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.325	1.325	1.325	1.325	0.9983
TBtu Consumed	28.19	28.19	28.19	28.19	24.62
Rate - [lb/MMBtu]	0.9400E-01	0.9400E-01	0.9400E-01	0.9400E-01	0.8110E-01
TWh Generated	2.696	2.696	2.696	2.696	2.355
TWh Generated Qualifying	-2696.	-2696.	-2696.	-2696.	-2355.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Comanche 1,2 - SO2 Rate Annual (C Constraint #: 433
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	1.341	1.341	1.341	1.341	1.011
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.341	1.341	1.341	1.341	1.011
TBtu Consumed	28.54	28.54	28.54	28.54	24.93
Rate - [lb/MMBtu]	0.9400E-01	0.9400E-01	0.9400E-01	0.9400E-01	0.8110E-01
TWh Generated	2.726	2.726	2.726	2.726	2.381
TWh Generated Qualifying	-2726.	-2726.	-2726.	-2726.	-2381.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Comanche 3 - NOX Rate Annual Constraint #: 434
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.8000E-01	0.8000E-01	0.8000E-01	0.8000E-01	0.8000E-01
-Emissions at Affected Plants [MTons]	1.450	1.450	1.450	1.450	1.450
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.450	1.450	1.450	1.450	1.450
TBtu Consumed	48.33	48.33	48.33	48.33	48.33
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01
TWh Generated	5.516	5.516	5.516	5.516	5.516
TWh Generated Qualifying	-5516.	-5516.	-5516.	-5516.	-5516.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Comanche 3 - SO2 Rate Annual Constraint #: 435
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.1000	0.1000	0.1000	0.1000	0.1000
-Emissions at Affected Plants [MTons]	2.175	2.175	2.175	2.175	1.875
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	2.175	2.175	2.175	2.175	1.875
TBtu Consumed	48.33	48.33	48.33	48.33	48.33
Rate - [lb/MMBtu]	0.9000E-01	0.9000E-01	0.9000E-01	0.9000E-01	0.7758E-01
TWh Generated	5.516	5.516	5.516	5.516	5.516
TWh Generated Qualifying	-5516.	-5516.	-5516.	-5516.	-5516.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - NOX Rate Annual (C Constraint #: 436
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3000	0.3000	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	3912.	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - NOX Rate Annual (C Constraint #: 437
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3000	0.3000	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	3.606	2.910	1.137	1.137	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	3.606	2.910	1.137	1.137	0.000
TBtu Consumed	24.04	19.40	7.582	7.582	0.000
Rate - [lb/MMBtu]	0.3000	0.3000	0.3000	0.3000	0.000
TWh Generated	2.372	1.915	0.7483	0.7483	0.000
TWh Generated Qualifying	-2372.	-1915.	-748.3	-748.3	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	4605.	0.000	0.000	145.6	0.000

Constraint Name: State Unit Level San Juan 1-4 - NOX Rate Annual (C Constraint #: 438

Constraint Type: Rate Limit [lb/MMBtu]

Run Year, Seasons Included: 2010 WINTER SUMMER

Run Year, Seasons Included: 2015 WINTER SUMMER

Run Year, Seasons Included: 2020 WINTER SUMMER

Run Year, Seasons Included: 2025 WINTER SUMMER

Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3000	0.3000	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	0.3153	0.2284	0.3103E-02	0.3103E-02	0.3103E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3153	0.2284	0.3103E-02	0.3103E-02	0.3103E-02
TBtu Consumed	2.102	1.674	0.5642	0.5642	0.5642
Rate - [lb/MMBtu]	0.3000	0.2729	0.1100E-01	0.1100E-01	0.1100E-01
TWh Generated	0.2308	0.1907	0.8687E-01	0.8687E-01	0.8687E-01
TWh Generated Qualifying	-230.8	-190.7	-86.87	-86.87	-86.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	1948.	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - NOX Rate Annual (C Constraint #: 439)
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.3000	0.3000	0.3000	0.3000	0.3000
-Emissions at Affected Plants [MTons]	5.882	4.245	0.4856	0.4102E-02	0.4102E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	5.882	4.245	0.4856	0.4102E-02	0.4102E-02
TBtu Consumed	39.21	28.50	3.237	0.7458	0.7458
Rate - [lb/MMBtu]	0.3000	0.2979	0.3000	0.1100E-01	0.1100E-01
TWh Generated	3.793	2.769	0.3531	0.1148	0.1148
TWh Generated Qualifying	-3793.	-2769.	-353.1	-114.8	-114.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	3996.	0.000	298.1	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - SO2 Rate Annual (C Constraint #: 440
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.1249E+05	3.366	0.000	519.9	0.000

Constraint Name: State Unit Level San Juan 1-4 - SO2 Rate Annual (C Constraint #: 441
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	1.130	0.9118	0.3075	0.3075	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.130	0.9118	0.3075	0.3075	0.000
TBtu Consumed	24.04	19.40	7.582	7.582	0.000
Rate - [lb/MMBtu]	0.9400E-01	0.9400E-01	0.8110E-01	0.8110E-01	0.000
TWh Generated	2.372	1.915	0.7483	0.7483	0.000
TWh Generated Qualifying	-2372.	-1915.	-748.3	-748.3	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - SO2 Rate Annual (C Constraint #: 442
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	0.7229E-01	0.5217E-01	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7229E-01	0.5217E-01	0.000	0.000	0.000
TBtu Consumed	2.102	1.674	0.5642	0.5642	0.5642
Rate - [lb/MMBtu]	0.6877E-01	0.6232E-01	0.000	0.000	0.000
TWh Generated	0.2308	0.1907	0.8687E-01	0.8687E-01	0.8687E-01
TWh Generated Qualifying	-230.8	-190.7	-86.87	-86.87	-86.87
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level San Juan 1-4 - SO2 Rate Annual (C Constraint #: 443
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.2500	0.2500	0.2500	0.2500
-Emissions at Affected Plants [MTons]	1.808	1.305	0.1010	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.808	1.305	0.1010	0.000	0.000
TBtu Consumed	39.21	28.50	3.237	0.7458	0.7458
Rate - [lb/MMBtu]	0.9221E-01	0.9154E-01	0.6242E-01	0.000	0.000
TWh Generated	3.793	2.769	0.3531	0.1148	0.1148
TWh Generated Qualifying	-3793.	-2769.	-353.1	-114.8	-114.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Westover 8 - NOX Rate Annual Constraint #: 444
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: State Unit Level Westover 8 - SO2 Rate Annual Constraint #: 445
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.000	0.3400	0.3400	0.3400	0.3400
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	9541.	0.1197E+05	0.1238E+05	0.1096E+05

Constraint Name: Texas DFW - NOX Cap Annual
Constraint Type: Rate Cap [MTons]

Constraint #: 446

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	2.160	2.160	2.160	2.160	2.160
-Emissions at Affected Plants [MTons]	0.6734E-01	0.2497E-02	0.2497E-02	0.2497E-02	0.2497E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6734E-01	0.2497E-02	0.2497E-02	0.2497E-02	0.2497E-02
TBtu Consumed	6.969	0.1387	0.1387	0.1387	0.1387
Rate - [lb/MMBtu]	0.1933E-01	0.3600E-01	0.3600E-01	0.3600E-01	0.3600E-01
TWh Generated	0.6822	0.1171E-01	0.1171E-01	0.1171E-01	0.1171E-01
TWh Generated Qualifying	-682.2	-11.71	-11.71	-11.71	-11.71
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas East - NOX Cap Annual

Constraint #: 447

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	58.37	58.37	58.37	58.37	58.37
-Emissions at Affected Plants [MTons]	16.15	14.24	6.333	2.094	2.250
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	16.15	14.24	6.333	2.094	2.250
TBtu Consumed	517.1	552.9	442.1	361.0	409.0
Rate - [lb/MMBtu]	0.6246E-01	0.5150E-01	0.2865E-01	0.1160E-01	0.1100E-01
TWh Generated	66.24	74.39	64.22	55.25	62.73
TWh Generated Qualifying	-0.6623E+05	-0.7439E+05	-0.6422E+05	-0.5525E+05	-0.6273E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas East - SO2 Cap Annual
Constraint Type: Rate Cap [MTons]

Constraint #: 448

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	111.2	111.2	111.2	111.2	111.2
-Emissions at Affected Plants [MTons]	53.16	46.44	14.59	0.4077	0.000
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	53.16	46.44	14.59	0.4077	0.000
TBTu Consumed	517.1	552.9	442.1	361.0	409.0
Rate - [lb/MMBtu]	0.2056	0.1680	0.6601E-01	0.2259E-02	0.000
TWh Generated	66.24	74.39	64.22	55.25	62.73
TWh Generated Qualifying	-0.6623E+05	-0.7439E+05	-0.6422E+05	-0.5525E+05	-0.6273E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas East & Central - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 449

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	123.5	123.5	123.5	123.5	123.5
-Emissions at Affected Plants [MTons]	103.2	87.51	60.89	44.63	29.65
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	103.2	87.51	60.89	44.63	29.65
TBtu Consumed	1880.	1769.	1726.	1731.	1762.
Rate - [lb/MMBtu]	0.1098	0.9893E-01	0.7054E-01	0.5156E-01	0.3366E-01
TWh Generated	205.7	201.5	218.2	234.1	250.0
TWh Generated Qualifying	-0.2057E+06	-0.2015E+06	-0.2182E+06	-0.2341E+06	-0.2500E+06
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas El Paso - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	1.060	1.060	1.060	1.060	1.060
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas Houston - NOX Cap Annual
Constraint Type: Rate Cap [MTons]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	8.460	8.460	8.460	8.460	8.460
-Emissions at Affected Plants [MTons]	6.873	6.451	5.810	5.580	4.791
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	6.873	6.451	5.810	5.580	4.791
TBtu Consumed	444.8	444.1	427.2	411.2	374.7
Rate - [lb/MMBtu]	0.3090E-01	0.2905E-01	0.2720E-01	0.2714E-01	0.2557E-01
TWh Generated	54.63	55.76	54.01	52.12	48.57
TWh Generated Qualifying	-0.5462E+05	-0.5576E+05	-0.5401E+05	-0.5212E+05	-0.4856E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Texas West - NOX Cap Annual

Constraint #: 452

Constraint Type: Rate Cap [MTons]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [MTon]	18.03	18.03	18.03	18.03	18.03
-Emissions at Affected Plants [MTons]	0.2519E-01	0.2519E-01	0.2519E-01	0.2519E-01	0.2519E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.2519E-01	0.2519E-01	0.2519E-01	0.2519E-01	0.2519E-01
TBTu Consumed	0.2519	0.2519	0.2519	0.2519	0.2519
Rate - [lb/MMBTu]	0.2000	0.2000	0.2000	0.2000	0.2000
TWh Generated	0.2271E-01	0.2271E-01	0.2271E-01	0.2271E-01	0.2271E-01
TWh Generated Qualifying	-22.71	-22.71	-22.71	-22.71	-22.71
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKK) Constraint #: 453
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKP) Constraint #: 454
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKQ) Constraint #: 455
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKR) Constraint #: 456
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKS) Constraint #: 457
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 SUMMER
Run Year, Seasons Included: 2015 SUMMER
Run Year, Seasons Included: 2020 SUMMER
Run Year, Seasons Included: 2025 SUMMER
Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BKT) Constraint #: 458
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLA) Constraint #: 459
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLG) Constraint #: 460
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1421E-02	0.1421E-02	0.1421E-02	0.1421E-02	0.1421E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1421E-02	0.1421E-02	0.1421E-02	0.1421E-02	0.1421E-02
TBtu Consumed	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01
Rate - [lb/MMBtu]	0.6400E-01	0.6400E-01	0.6400E-01	0.6400E-01	0.6400E-01
TWh Generated	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02
TWh Generated Qualifying	-3.290	-3.290	-3.290	-3.290	-3.290
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLH) Constraint #: 461
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1843E-02	0.1843E-02	0.1843E-02	0.1843E-02	0.1843E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1843E-02	0.1843E-02	0.1843E-02	0.1843E-02	0.1843E-02
TBtu Consumed	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01
Rate - [lb/MMBtu]	0.8300E-01	0.8300E-01	0.8300E-01	0.8300E-01	0.8300E-01
TWh Generated	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02
TWh Generated Qualifying	-3.290	-3.290	-3.290	-3.290	-3.290
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLI) Constraint #: 462
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1799E-02	0.1799E-02	0.1799E-02	0.1799E-02	0.1799E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1799E-02	0.1799E-02	0.1799E-02	0.1799E-02	0.1799E-02
TBtu Consumed	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01
Rate - [lb/MMBtu]	0.8100E-01	0.8100E-01	0.8100E-01	0.8100E-01	0.8100E-01
TWh Generated	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02
TWh Generated Qualifying	-3.290	-3.290	-3.290	-3.290	-3.290
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLJ) Constraint #: 463
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1888E-02	0.1888E-02	0.1888E-02	0.1888E-02	0.1888E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1888E-02	0.1888E-02	0.1888E-02	0.1888E-02	0.1888E-02
TBtu Consumed	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01	0.4442E-01
Rate - [lb/MMBtu]	0.8500E-01	0.8500E-01	0.8500E-01	0.8500E-01	0.8500E-01
TWh Generated	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02	0.3290E-02
TWh Generated Qualifying	-3.290	-3.290	-3.290	-3.290	-3.290
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLK) Constraint #: 464
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.7041E-03	0.7041E-03	0.7041E-03	0.7041E-03	0.7041E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.7041E-03	0.7041E-03	0.7041E-03	0.7041E-03	0.7041E-03
TBtu Consumed	0.4023E-01	0.4023E-01	0.4023E-01	0.4023E-01	0.4023E-01
Rate - [lb/MMBtu]	0.3500E-01	0.3500E-01	0.3500E-01	0.3500E-01	0.3500E-01
TWh Generated	0.3060E-02	0.3060E-02	0.3060E-02	0.3060E-02	0.3060E-02
TWh Generated Qualifying	-3.060	-3.060	-3.060	-3.060	-3.060
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLN) Constraint #: 465
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLR) Constraint #: 466
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	47.49	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BLS) Constraint #: 467
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2207.	2142.	2356.	2685.	3080.

Constraint Name: Wisconsin State - NOX Rate Summer (BLT) Constraint #: 468
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	2207.	2142.	2356.	2685.	3080.

Constraint Name: Wisconsin State - NOX Rate Summer (BUF) Constraint #: 469
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.3189E-01	0.3424E-01	0.3424E-01	0.2877E-01	0.1139E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3189E-01	0.3424E-01	0.3424E-01	0.2877E-01	0.1139E-01
TBtu Consumed	2.658	2.853	2.853	2.398	0.9494
Rate - [lb/MMBtu]	0.2400E-01	0.2400E-01	0.2400E-01	0.2400E-01	0.2400E-01
TWh Generated	0.2457	0.2638	0.2638	0.2217	0.8777E-01
TWh Generated Qualifying	-245.7	-263.8	-263.8	-221.7	-87.77
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (BUG) Constraint #: 470
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1569E-01	0.1569E-01	0.1569E-01	0.1569E-01	0.1361E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1569E-01	0.1569E-01	0.1569E-01	0.1569E-01	0.1361E-01
TBtu Consumed	2.853	2.853	2.853	2.853	2.474
Rate - [lb/MMBtu]	0.1100E-01	0.1100E-01	0.1100E-01	0.1100E-01	0.1100E-01
TWh Generated	0.2638	0.2638	0.2638	0.2638	0.2288
TWh Generated Qualifying	-263.8	-263.8	-263.8	-263.8	-228.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CF2) Constraint #: 471
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	9209.	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CF3) Constraint #: 472
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	9209.	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CF4) Constraint #: 473
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	9209.	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CF5) Constraint #: 474
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	9209.	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CWX) Constraint #: 475
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2559E+05	4431.	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CWY) Constraint #: 476
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.3094E+05	0.1165E+05	5276.	7249.	3269.

Constraint Name: Wisconsin State - NOX Rate Summer (CWZ) Constraint #: 477
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.4548E+05	0.1165E+05	5276.	7249.	998.9

Constraint Name: Wisconsin State - NOX Rate Summer (CXA) Constraint #: 478
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1027	0.2165E-04	0.2165E-04	0.2165E-04	0.2165E-04
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1027	0.2165E-04	0.2165E-04	0.2165E-04	0.2165E-04
TBtu Consumed	0.7333	0.3937E-02	0.3937E-02	0.3937E-02	0.3937E-02
Rate - [lb/MMBtu]	0.2800	0.1100E-01	0.1100E-01	0.1100E-01	0.1100E-01
TWh Generated	0.5183E-01	0.4596E-03	0.4596E-03	0.4596E-03	0.4596E-03
TWh Generated Qualifying	-51.83	-0.4596	-0.4596	-0.4596	-0.4596
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.8971E+05	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CXB) Constraint #: 479
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1059	0.9247E-01	0.1059	0.9247E-01	0.1586E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1059	0.9247E-01	0.1059	0.9247E-01	0.1586E-01
TBtu Consumed	0.7562	0.6605	0.7562	0.6605	0.1133
Rate - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
TWh Generated	0.7008E-01	0.6121E-01	0.7008E-01	0.6121E-01	0.1050E-01
TWh Generated Qualifying	-70.08	-61.21	-70.08	-61.21	-10.50
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.8658E+05	0.1546E+05	0.1426E+05	0.1689E+05	8499.

Constraint Name: Wisconsin State - NOX Rate Summer (CXC) Constraint #: 480
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2559E+05	0.1546E+05	0.1425E+05	0.1689E+05	0.1062E+05

Constraint Name: Wisconsin State - NOX Rate Summer (CT2) Constraint #: 481
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.2578E+05	0.1546E+05	0.1426E+05	0.1689E+05	0.1565E+05

Constraint Name: Wisconsin State - NOX Rate Summer (CT6) Constraint #: 482
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.6295	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6295	0.000	0.000	0.000	0.000
TBtu Consumed	7.319	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1720	0.000	0.000	0.000	0.000
TWh Generated	0.7425	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-742.5	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CU6) Constraint #: 483
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.6399	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6399	0.000	0.000	0.000	0.000
TBtu Consumed	7.441	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1720	0.000	0.000	0.000	0.000
TWh Generated	0.7511	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-751.1	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CV6) Constraint #: 484
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.5370	0.000	0.000	0.000	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5370	0.000	0.000	0.000	0.000
TBtu Consumed	8.326	0.000	0.000	0.000	0.000
Rate - [lb/MMBtu]	0.1290	0.000	0.000	0.000	0.000
TWh Generated	0.8478	0.000	0.000	0.000	0.000
TWh Generated Qualifying	-847.8	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CW6) Constraint #: 485
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.5268	0.4373	0.4373	0.4255	0.3635
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5268	0.4373	0.4373	0.4255	0.3635
TBtu Consumed	8.429	8.853	8.853	8.429	7.362
Rate - [lb/MMBtu]	0.1250	0.9880E-01	0.9880E-01	0.1010	0.9874E-01
TWh Generated	0.8776	0.9154	0.9154	0.8716	0.7613
TWh Generated Qualifying	-877.6	-915.4	-915.4	-871.6	-761.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (CX6) Constraint #: 486
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	1.324	1.324	1.324	1.157	1.094
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.324	1.324	1.324	1.157	1.094
TBtu Consumed	9.459	9.459	9.459	8.262	7.814
Rate - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
TWh Generated	0.9531	0.9531	0.9531	0.8325	0.7874
TWh Generated Qualifying	-953.1	-953.1	-953.1	-832.5	-787.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	16.99	6138.	2289.	2767.	2140.

Constraint Name: Wisconsin State - NOX Rate Summer (CXN) Constraint #: 487
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	1.306	1.306	1.306	1.079	1.079
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	1.306	1.306	1.306	1.079	1.079
TBtu Consumed	11.98	11.98	11.98	9.898	9.898
Rate - [lb/MMBtu]	0.2180	0.2180	0.2180	0.2180	0.2180
TWh Generated	1.183	1.183	1.183	0.9773	0.9773
TWh Generated Qualifying	-1183.	-1183.	-1183.	-977.3	-977.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DAQ) Constraint #: 488
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1065	0.9306E-01	0.9306E-01	0.9306E-01	0.2247E-04
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1065	0.9306E-01	0.9306E-01	0.9306E-01	0.2247E-04
TBtu Consumed	0.7610	0.6647	0.6647	0.6647	0.4085E-02
Rate - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.1100E-01
TWh Generated	0.7072E-01	0.6177E-01	0.6177E-01	0.6177E-01	0.4769E-03
TWh Generated Qualifying	-70.72	-61.77	-61.77	-61.77	-0.4769
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.8715E+05	0.1546E+05	0.1426E+05	0.1689E+05	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVS) Constraint #: 489
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02
TBtu Consumed	0.1075	0.1075	0.1075	0.1075	0.1075
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02
TWh Generated Qualifying	-6.070	-6.070	-6.070	-6.070	-6.070
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVT) Constraint #: 490
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02	0.1613E-02
TBtu Consumed	0.1075	0.1075	0.1075	0.1075	0.1075
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02
TWh Generated Qualifying	-6.070	-6.070	-6.070	-6.070	-6.070
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVU) Constraint #: 491
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TBtu Consumed	0.1097	0.1097	0.1097	0.1097	0.1097
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02
TWh Generated Qualifying	-6.070	-6.070	-6.070	-6.070	-6.070
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVV) Constraint #: 492
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02	0.1645E-02
TBtu Consumed	0.1097	0.1097	0.1097	0.1097	0.1097
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02	0.6070E-02
TWh Generated Qualifying	-6.070	-6.070	-6.070	-6.070	-6.070
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVW) Constraint #: 493
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
TBtu Consumed	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02
TWh Generated Qualifying	-2.023	-2.023	-2.023	-2.023	-2.023
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVX) Constraint #: 494
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
TBtu Consumed	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02
TWh Generated Qualifying	-2.023	-2.023	-2.023	-2.023	-2.023
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (DVY) Constraint #: 495
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03	0.3786E-03
TBtu Consumed	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01	0.2524E-01
Rate - [lb/MMBtu]	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01	0.3000E-01
TWh Generated	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02	0.2023E-02
TWh Generated Qualifying	-2.023	-2.023	-2.023	-2.023	-2.023
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (ENW) Constraint #: 496
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.6447	0.5501	0.5501	0.5501	0.000
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.6447	0.5501	0.5501	0.5501	0.000
TBtu Consumed	21.49	18.34	18.34	18.34	0.000
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.6000E-01	0.6000E-01	0.000
TWh Generated	1.991	1.699	1.699	1.699	0.000
TWh Generated Qualifying	-1991.	-1699.	-1699.	-1699.	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin State - NOX Rate Summer (ENX) Constraint #: 497
 Constraint Type: Rate Limit [lb/MMBtu]
 Run Year, Seasons Included: 2010 SUMMER
 Run Year, Seasons Included: 2015 SUMMER
 Run Year, Seasons Included: 2020 SUMMER
 Run Year, Seasons Included: 2025 SUMMER
 Run Year, Seasons Included: 2032 SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2800	0.2800	0.2800	0.2800	0.2800
-Emissions at Affected Plants [MTons]	0.5673	0.5542	0.4650	0.4650	0.9969E-01
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	0.000	0.000	0.000
Total [MTons]	0.5673	0.5542	0.4650	0.4650	0.9969E-01
TBtu Consumed	18.91	18.47	20.76	20.76	18.13
Rate - [lb/MMBtu]	0.6000E-01	0.6000E-01	0.4478E-01	0.4478E-01	0.1100E-01
TWh Generated	1.740	1.699	2.310	2.310	2.791
TWh Generated Qualifying	-1740.	-1699.	-2310.	-2310.	-2791.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin WEPCO - NOX Rate Annual
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 498

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.2500	0.1500	0.1500	0.1500	0.1500
-Emissions at Affected Plants [MTons]	8.615	3.696	3.480	3.421	1.077
-Less Allowances Purchased [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] NOX	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	4.482	9.546	5.035	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	-4.482	0.000	0.000
Total [MTons]	8.615	8.178	8.544	8.456	1.077
TBtu Consumed	173.3	109.0	113.9	112.7	58.54
Rate - [lb/MMBtu]	0.9944E-01	0.6779E-01	0.6109E-01	0.6069E-01	0.3679E-01
TWh Generated	16.76	10.30	11.67	11.55	8.157
TWh Generated Qualifying	-0.1676E+05	-0.1030E+05	-0.1167E+05	-0.1155E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: Wisconsin WEPCO - SO2 Rate Annual
Constraint Type: Rate Limit [lb/MMBtu]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 499

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [lb/MMBtu]	0.7000	0.4500	0.4500	0.4500	0.4500
-Emissions at Affected Plants [MTons]	25.40	3.696	3.398	2.995	0.7537
-Less Allowances Purchased [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Sold [MTons] SO2	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Banked [MTons]	0.000	20.84	39.74	19.04	0.000
-Less Allowances Withdrawn (1:1) [MTons]	0.000	0.000	0.000	0.000	0.000
-Less Allowances Withdrawn (n:1) [MTons]	0.000	0.000	-20.84	0.000	0.000
Total [MTons]	25.40	24.53	22.30	22.04	0.7537
TBtu Consumed	173.3	109.0	113.9	112.7	58.54
Rate - [lb/MMBtu]	0.2932	0.6779E-01	0.5966E-01	0.5312E-01	0.2575E-01
TWh Generated	16.76	10.30	11.67	11.55	8.157
TWh Generated Qualifying	-0.1676E+05	-0.1030E+05	-0.1167E+05	-0.1155E+05	-8157.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/Ton]	0.000	0.000	0.000	0.000	0.000

Constraint Name: AZNM 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 500

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2940E+05	0.3321E+05	0.3753E+05	0.4230E+05	0.4997E+05
-Generation at Eligible Plants [GWh]	397.7	397.7	601.7	1544.	2283.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	397.7	397.7	601.7	1544.	2283.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.3977	0.3977	0.6017	1.544	2.283
TWh Generated Qualifying	-397.7	-397.7	-601.7	-1544.	-2283.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CA-N 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 501

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2661E+05	0.2901E+05	0.3193E+05	0.3506E+05	0.3993E+05
-Generation at Eligible Plants [GWh]	0.1321E+05	0.1321E+05	0.1584E+05	0.1920E+05	0.2522E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.1321E+05	0.1321E+05	0.1584E+05	0.1920E+05	0.2522E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	13.21	13.21	15.84	19.20	25.22
TWh Generated Qualifying	-0.1321E+05	-0.1321E+05	-0.1584E+05	-0.1920E+05	-0.2522E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: CA-S 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 502

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3692E+05	0.4024E+05	0.4430E+05	0.4865E+05	0.5540E+05
-Generation at Eligible Plants [GWh]	2217.	2217.	2217.	2217.	2217.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	2217.	2217.	2217.	2217.	2217.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	2.217	2.217	2.217	2.217	2.217
TWh Generated Qualifying	-2217.	-2217.	-2217.	-2217.	-2217.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: COMD 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 503

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2303E+05	0.2437E+05	0.2555E+05	0.2673E+05	0.2845E+05
-Generation at Eligible Plants [GWh]	73.63	73.63	73.63	73.63	73.63
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	73.63	73.63	73.63	73.63	73.63
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.7363E-01	0.7363E-01	0.7363E-01	0.7363E-01	0.7363E-01
TWh Generated Qualifying	-73.63	-73.63	-73.63	-73.63	-73.63
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: DSNY 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 504

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	6662.	6891.	7238.	7584.	8089.
-Generation at Eligible Plants [GWh]	107.5	107.5	595.1	975.4	975.4
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	107.5	107.5	595.1	975.4	975.4
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1075	0.1075	0.5951	0.9754	0.9754
TWh Generated Qualifying	-107.5	-107.5	-595.1	-975.3	-975.3
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ECAK 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 505

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1162E+05	0.1241E+05	0.1326E+05	0.1413E+05	0.1543E+05
-Generation at Eligible Plants [GWh]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ECAM 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 506

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.4486E+05	0.4791E+05	0.5118E+05	0.5454E+05	0.5956E+05
-Generation at Eligible Plants [GWh]	135.8	135.8	135.8	135.8	135.8
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	135.8	135.8	135.8	135.8	135.8
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1358	0.1358	0.1358	0.1358	0.1358
TWh Generated Qualifying	-135.8	-135.8	-135.8	-135.8	-135.8
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ECAP 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 507

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.4060E+05	0.4335E+05	0.4632E+05	0.4935E+05	0.5389E+05
-Generation at Eligible Plants [GWh]	153.1	153.1	153.1	153.1	153.1
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	153.1	153.1	153.1	153.1	153.1
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.1531	0.1531	0.1531	0.1531	0.1531
TWh Generated Qualifying	-153.1	-153.1	-153.1	-153.1	-153.1
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ENTG 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 508

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3082E+05	0.3331E+05	0.3540E+05	0.3752E+05	0.4068E+05
-Generation at Eligible Plants [GWh]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: ERCT 20% Max Wind Generation
 Constraint Type: Required Generation [GWh]
 Constraint #: 509
 Run Year, Seasons Included: 2010 WINTER SUMMER
 Run Year, Seasons Included: 2015 WINTER SUMMER
 Run Year, Seasons Included: 2020 WINTER SUMMER
 Run Year, Seasons Included: 2025 WINTER SUMMER
 Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.6476E+05	0.7058E+05	0.7643E+05	0.8256E+05	0.9188E+05
-Generation at Eligible Plants [GWh]	0.1407E+05	0.1670E+05	0.2308E+05	0.2742E+05	0.2760E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.1407E+05	0.1670E+05	0.2308E+05	0.2742E+05	0.2760E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	14.07	16.70	23.08	27.42	27.60
TWh Generated Qualifying	-0.1407E+05	-0.1670E+05	-0.2308E+05	-0.2742E+05	-0.2760E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MACE 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3100E+05	0.3292E+05	0.3476E+05	0.3661E+05	0.3933E+05
-Generation at Eligible Plants [GWh]	53.09	114.7	380.9	403.4	647.1
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	53.09	114.7	380.9	403.4	647.1
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.5309E-01	0.1147	0.3809	0.4034	0.6471
TWh Generated Qualifying	-53.09	-114.7	-380.9	-403.4	-647.1
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MACS 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 511

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1565E+05	0.1663E+05	0.1755E+05	0.1849E+05	0.1986E+05
-Generation at Eligible Plants [GWh]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MACW 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 512

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1428E+05	0.1517E+05	0.1602E+05	0.1687E+05	0.1812E+05
-Generation at Eligible Plants [GWh]	398.6	398.6	398.6	398.6	398.6
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	398.6	398.6	398.6	398.6	398.6
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.3986	0.3986	0.3986	0.3986	0.3986
TWh Generated Qualifying	-398.6	-398.6	-398.6	-398.6	-398.6
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MANO 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 513

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1985E+05	0.2100E+05	0.2203E+05	0.2304E+05	0.2452E+05
-Generation at Eligible Plants [GWh]	236.4	236.4	236.4	236.4	236.4
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	236.4	236.4	236.4	236.4	236.4
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2364	0.2364	0.2364	0.2364	0.2364
TWh Generated Qualifying	-236.4	-236.4	-236.4	-236.4	-236.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MECS 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 514

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2576E+05	0.2751E+05	0.2962E+05	0.3168E+05	0.3456E+05
-Generation at Eligible Plants [GWh]	2.406	181.0	1717.	3253.	3632.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	2.406	181.0	1717.	3253.	3632.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.2406E-02	0.1810	1.717	3.253	3.632
TWh Generated Qualifying	-2.406	-181.0	-1717.	-3253.	-3632.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: MRO 20% Max Wind Generation

Constraint #: 515

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3580E+05	0.3878E+05	0.4222E+05	0.4586E+05	0.5144E+05
-Generation at Eligible Plants [GWh]	5151.	5151.	5353.	9820.	0.1022E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	5151.	5151.	5353.	9820.	0.1022E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	5.151	5.151	5.353	9.820	10.22
TWh Generated Qualifying	-5151.	-5151.	-5352.	-9820.	-0.1022E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NENG 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 516

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2785E+05	0.2919E+05	0.3022E+05	0.3121E+05	0.3261E+05
-Generation at Eligible Plants [GWh]	2333.	3310.	4088.	7095.	7095.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	2333.	3310.	4088.	7095.	7095.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	2.333	3.310	4.088	7.095	7.095
TWh Generated Qualifying	-2333.	-3310.	-4088.	-7095.	-7095.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: NWPE 20% Max Wind Generation

Constraint #: 517

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1695E+05	0.1836E+05	0.1983E+05	0.2136E+05	0.2369E+05
-Generation at Eligible Plants [GWh]	1072.	1072.	0.1932E+05	0.2136E+05	0.2369E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	1072.	1072.	0.1932E+05	0.2136E+05	0.2369E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.072	1.072	19.32	21.36	23.69
TWh Generated Qualifying	-1072.	-1072.	-0.1932E+05	-0.2136E+05	-0.2369E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	2.042	8.103

Constraint Name: PNW 20% Max Wind Generation

Constraint #: 518

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3375E+05	0.3622E+05	0.3994E+05	0.4292E+05	0.4745E+05
-Generation at Eligible Plants [GWh]	2242.	2242.	2242.	0.3409E+05	0.4745E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	2242.	2242.	2242.	0.3409E+05	0.4745E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	2.242	2.242	2.242	34.09	47.45
TWh Generated Qualifying	-2242.	-2242.	-2242.	-0.3409E+05	-0.4745E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	6.955

Constraint Name: RMPA 20% Max Wind Generation

Constraint #: 519

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1262E+05	0.1386E+05	0.1489E+05	0.1596E+05	0.1757E+05
-Generation at Eligible Plants [GWh]	787.1	787.1	787.1	787.1	787.1
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	787.1	787.1	787.1	787.1	787.1
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.7871	0.7871	0.7871	0.7871	0.7871
TWh Generated Qualifying	-787.1	-787.1	-787.1	-787.1	-787.1
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SNV 20% Max Wind Generation

Constraint #: 520

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	5078.	5736.	6482.	7307.	8632.
-Generation at Eligible Plants [GWh]	1262.	1674.	1674.	1674.	1674.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	1262.	1674.	1674.	1674.	1674.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	1.262	1.674	1.674	1.674	1.674
TWh Generated Qualifying	-1262.	-1674.	-1674.	-1674.	-1674.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SOU 20% Max Wind Generation

Constraint #: 521

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.5662E+05	0.6258E+05	0.7058E+05	0.7941E+05	0.9357E+05
-Generation at Eligible Plants [GWh]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: SPPN 20% Max Wind Generation

Constraint #: 522

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1442E+05	0.1538E+05	0.1638E+05	0.1741E+05	0.1894E+05
-Generation at Eligible Plants [GWh]	925.1	925.1	931.5	0.1033E+05	0.1894E+05
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	925.1	925.1	931.5	0.1033E+05	0.1894E+05
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.9251	0.9251	0.9315	10.33	18.94
TWh Generated Qualifying	-925.1	-925.1	-931.5	-0.1033E+05	-0.1894E+05
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.2935

Constraint Name: SPPS 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 523

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2718E+05	0.2899E+05	0.3089E+05	0.3282E+05	0.3570E+05
-Generation at Eligible Plants [GWh]	2730.	2730.	2730.	2730.	4110.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	2730.	2730.	2730.	2730.	4110.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	2.730	2.730	2.730	2.730	4.110
TWh Generated Qualifying	-2730.	-2730.	-2730.	-2730.	-4110.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: TVA 20% Max Wind Generation

Constraint #: 524

Constraint Type: Required Generation [GWh]

Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.3768E+05	0.3921E+05	0.4162E+05	0.4407E+05	0.4770E+05
-Generation at Eligible Plants [GWh]	740.4	740.4	740.4	740.4	740.4
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	740.4	740.4	740.4	740.4	740.4
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.7404	0.7404	0.7404	0.7404	0.7404
TWh Generated Qualifying	-740.4	-740.4	-740.4	-740.4	-740.4
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: UPNY 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 525

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1229E+05	0.1271E+05	0.1335E+05	0.1399E+05	0.1492E+05
-Generation at Eligible Plants [GWh]	861.2	861.2	861.2	861.2	861.2
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	861.2	861.2	861.2	861.2	861.2
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.8612	0.8612	0.8612	0.8612	0.8612
TWh Generated Qualifying	-861.2	-861.2	-861.2	-861.2	-861.2
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: VACA 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 526

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.4447E+05	0.4811E+05	0.5149E+05	0.5496E+05	0.6018E+05
-Generation at Eligible Plants [GWh]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	0.000	0.000	0.000	0.000
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.000	0.000	0.000	0.000
TWh Generated Qualifying	0.000	0.000	0.000	0.000	0.000
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: VAPW 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 527

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.2104E+05	0.2276E+05	0.2436E+05	0.2600E+05	0.2847E+05
-Generation at Eligible Plants [GWh]	0.000	496.5	1467.	2513.	2935.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	0.000	496.5	1467.	2513.	2935.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.000	0.4965	1.467	2.513	2.935
TWh Generated Qualifying	0.000	-496.5	-1467.	-2513.	-2935.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000

Constraint Name: WUMS 20% Max Wind Generation
Constraint Type: Required Generation [GWh]
Run Year, Seasons Included: 2010 WINTER SUMMER
Run Year, Seasons Included: 2015 WINTER SUMMER
Run Year, Seasons Included: 2020 WINTER SUMMER
Run Year, Seasons Included: 2025 WINTER SUMMER
Run Year, Seasons Included: 2032 WINTER SUMMER

Constraint #: 528

Time Base: Seasonal/Annual	2009-2012	2013-2017	2018-2022	2023-2027	2028-2035
Standard - [GWh]	0.1523E+05	0.1612E+05	0.1690E+05	0.1768E+05	0.1882E+05
-Generation at Eligible Plants [GWh]	814.3	814.3	1281.	5803.	7044.
-Plus Allowances Purchased [GWh] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Sold [MTons] GWh	0.000	0.000	0.000	0.000	0.000
-Less Allowances Banked [MTons]	0.000	0.000	0.000	0.000	0.000
-Plus Allowances Withdrawn [MTons]	0.000	0.000	0.000	0.000	0.000
Total [GWh]	814.3	814.3	1281.	5803.	7044.
TBtu Consumed	0.000	0.000	0.000	0.000	0.000
Heat Rate - [MMBtu/MWh]	0.000	0.000	0.000	0.000	0.000
TWh Generated	0.8143	0.8143	1.281	5.803	7.044
TWh Generated Qualifying	-814.2	-814.2	-1281.	-5803.	-7044.
Rate - [lb/MWh]	0.000	0.000	0.000	0.000	0.000
Constraint Shadow Price [US\$/MWh]	0.000	0.000	0.000	0.000	0.000