

Refrigerant Management at Giant Eagle





Cliff Timko, P.E. Energy Manager



Agenda


- About Giant Eagle
- Refrigerant Management Team
- Refrigeration Equipment
- Service Providers
- Refrigerant Management System
- Using the Information
- GreenChill Partnership
- Recognition





About Giant Eagle

- 163 Corporate Supermarkets/59 Independents
- 151 Fuel Station/Convenience Stores
- Market Area W. PA, E. OH, N. WV, W. MD
- Stores SF sizes from 26K to 126K with a 69K average
- New stores are 90+ K SF





Refrigerant Management Team

- Giant Eagle Engineering & Maintenance Groups
- Refrigeration Service Providers & Technicians
- Refrigerant Monitoring and Reporting Service



Refrigeration Systems

- Central Compressor Rooms
- Parallel Racks
- 4000 lb. Average Store Refrigerant Charge
- Heat Reclaim
- Gas Defrost
- Acquisition Stores



Service Providers

- (7) Refrigeration Service Providers in 2008
- 70% Stores with One Service Provider
- Full Service Contract Includes Refrigerant
- Preventative Maintenance Schedule
- Defined Response Time

Preventative Maintenance Program

- Check Monthly for Refrigerant Leaks
 - Display Cases
 - Walk-Ins
 - Roof Condensers
 - Compressor Room
 - Pits, Risers & Remote Manifolds
- Record and Track Receiver Levels
- Identify and Correct Potential Leaks
 - Vibration
 - Condenser Fan Blades
 - Metal-to-Metal Rub Points
- Keep Compressor Room & Racks Clean



Refrigerant Management System

Leak Detection

Automatic Email Alerts


Refrigerant Tracking

PM Program

Web-Based Reporting

Training

Leakage & Usage




Ideal Leak Detection System

- Reliable and Low Maintenance
- Consistent Sensitivity
- Refrigerant Specific
- Tracks Both Intensity and Duration of Leak
- Provides Multiple Levels of Alarm
- Provides Actionable Alarms (no false alarms)
- Samples Multiple Points in the Store
- Notifies When System is Off-Line
- Remote Monitoring Capability



Giant Eagle Typical Layout



Automated Email Alerts – Leak Detection

From: Refrigerant Leak Report Sent: Sunday, May 24, 2009 6:35 AM

To: Chris Sender, Jim Galehan Cc: Jim Snyder, PIC VA

Subject: Giant Eagle 5878 ~ Howe Ave - Refrigerant Leak Detection Report

Giant Eagle - Refrigeration Leak Detection Report This report shows new leaks reported in last 24 hours for 5878 ~ Howe Ave

Channe	Name	Occurred	Event Type	PPM
3	Rack C	2009-05-23 22:06:17	Alarm	392
3	Rack C	2009-05-23 21:36:17	Alarm	339
3	Rack C	2009-05-23 21:06:17	Alarm	351
3	Rack C	2009-05-23 20:36:17	Alarm	453
3	Rack C	2009-05-23 20:06:17	Alarm	461
3	Rack C	2009-05-23 19:36:17	Alarm	364
3	Rack C	2009-05-23 19:06:17	Alarm	140
3	Rack C	2009-05-23 18:36:17	Alarm	56
4	Rack D	2009-05-23 22:08:38	Alarm	53
4	Rack D	2009-05-23 21:38:39	Alarm	50

Total events: 38

Click to See Report

Automated Email Alerts – Refrigerant Usage

Giant Eagle Headline News



Site: 1238 ~ Vermillion

RACK D (charged with 800 lbs of R402A)
Equipment status is: Compliant

On 8/13/2009, LON WHITE added 54 lbs of refrigerant to RACK D at 1238 ~ Vermillion Usage event reference number = HLN5487 .. Works order = 4153201

The 12 month rolling average refrigerant usage is now 7%

Note: This equipment remains compliant, but action should always be taken to reduce usage

Usage activity in the past 12 months:

8/13/2009 : 54 lbs added by LON WHITE 8/13/2009 : Verified as leak free by LON WHITE

Total usage for past 12 months = 54.0 lbs


Click here to visit the Headline News Web Site

This e-mail and any files transmitted with it are private and confidential and intended for the individual or entity to which it is addressed. If you are not the named recipient you may not copy or deliver this message to anyone.

Automated Email Alerts


-Time, Date, Location and Event History

- Targeted Information



Refrigerant Tracking

 Access at Store Level or Via the Web to Refrigerant Tracking Program



Monthly and Annual Usage

Refrigerant Usage - 12 Months

Refrigerant type : All types Region/Maintainer : All stores Store : All stores						
Month -	This month's usage		Projected annual usage		12 month rolling average	
	lbs used	% of charge	lbs used	% of charge	lbs used	% of charge
Jan	3,061	0.5%	46,072	7.2%	45,949	7.2%
Feb	2,840	0.4%	45,216	7.1%	46,468	7.3%
Mar	2,934	0.5%	44,548	7.0%	46,252	7.2%
Apr	4,672	0.7%	45,268	7.1%	47,890	7.5%
May	5,389	0.8%	46,409	7.2%	48,935	7.6%
Jun	3,589	0.6%	46,224	7.3%	48,511	7.7%
Jul	4,432	0.7%	46,590	7.4%	47,384	7.5%
Aug						
Sep						
Oct						
Nov						
Dec						

KPI for Refrigerant Usage



Store Leakage Ranking

Store Refrigerant Leakage Comparisons

All sto	res	✓ All s	tore sizes [166	5]	~
Leak Events			Refrigerant Usage		
<u>Leak Index</u>	<u>Alert</u>	<u>Alarm</u>	<u>Critical</u>	<u>lbs</u>	<u>% of</u> <u>charge</u>
0.0	61	1	0	23.3	0.5
9.5	1531	0	0	274.0	6.1
4.8	1025	2	0	0.0	0.0
4.7	1016	0	0	0.0	0.0
4.2	898	0	0	0.0	0.0
3.7	797	0	0	108.0	3.7
3.0	642	0	0	1.0	0.0
2.4	508	1	0	80.0	2.1
2.3	485	0	0	202.0	8.2
1.9	399	1	0	0.0	0.0
1.8	380	0	0	0.0	0.0
	0.0 9.5 4.8 4.7 4.2 3.7 3.0 2.4 2.3 1.9	Leak Index Alert 0.0 61 9.5 1531 4.8 1025 4.7 1016 4.2 898 3.7 797 3.0 642 2.4 508 2.3 485 1.9 399	Leak Index Alert Alarm 0.0 61 1 9.5 1531 0 4.8 1025 2 4.7 1016 0 4.2 898 0 3.7 797 0 3.0 642 0 2.4 508 1 2.3 485 0 1.9 399 1	Leak Index Alert Alarm Critical 0.0 61 1 0 9.5 1531 0 0 4.8 1025 2 0 4.7 1016 0 0 4.2 898 0 0 3.7 797 0 0 3.0 642 0 0 2.4 508 1 0 2.3 485 0 0 1.9 399 1 0	Leak Index Alert Alarm Critical Ibs 0.0 61 1 0 23.3 9.5 1531 0 0 274.0 4.8 1025 2 0 0.0 4.7 1016 0 0 0.0 4.2 898 0 0 0.0 3.7 797 0 0 108.0 3.0 642 0 0 1.0 2.4 508 1 0 80.0 2.3 485 0 0 202.0 1.9 399 1 0 0.0

KPI for Refrigerant Leakage



This Year/Last Year Comparison

Refrigerant Usage - This Year v Last Year

Last twelve months All store sizes [166]	▼ A	ll stores	▼			
> >> Next Last	This year			Last year		
Location clear	Leak Index	Usage (Ibs)	% of charge	Leak Index	Usage (lbs)	% of charge
Group averages	0.3	244.7	6.2	0.3	283.6	7.2
0002 ~ Kennedy Township [69,010]	0.5	9.0	0.3	0.1	410.8	12.5
0004 ~ Bethel Park [69,514]	0.2	169.0	2.7	0.0	305.0	4.9
0008 ~ New Kensington [102,005]	0.0	121.0	2.0	0.1	117.0	1.9
0009 ~ Hempfield [82,682]	1.0	153.0	3.5	0.2	3.0	0.1
0010 ~ Irwin [106,241]	0.3	565.6	12.4	1.7	552.0	12.1
0014 ~ Village Square [125,355]	0.1	197.4	2.3	0.0	600.3	7.1
0017 ~ Shakespeare Street [56,765]	0.0	180.0	3.7	0.3	30.0	0.6
0025 ~ West View [65,378]	0.0	4.0	0.1	0.0	1.0	0.0
0031 ~ Caste Village [48,677]	0.0	14.0	0.4	0.7	56.0	1.7
0032 ~ Murrysville [57,381]	0.4	49.0	2.0	0.0	0.0	0.0

Stores 1 to 10 of 165

Store Leakage by Monitoring Point

Store Refrigerant Leakage Report


5878 ~ Howe Ave [62,614 sq ft]

From 07/19/2009 to 08/16/2009

System	Leak Index	Alert	Alarm	Critical
Rack A	0.1	1	0	0
Rack B	7.9	106	0	0
Rack C	1.7	23	0	0
Rack D	7.2	97	0	0
Dairy Sales Area	14.5	195	0	0
Frozen Sales Area	20.2	272	0	0
Fresh Meat Sales	14.4	193	0	0
Service Deli Sales	12.3	165	0	0
Groc.Frzs/Meat Frz	13.2	177	0	0
Prod.Clr/Prep.Rm	8.7	117	0	0
Meat Clr/Prep.Rm	4.8	65	0	0
Produce Sales Area	8.9	119	0	0

Graphic View of Monitoring Point

System Leakage Report



Using the Information

Usage \$	Sorted	by	Location
----------	--------	----	----------

Racks	40%
Display Cases	21%
Condensers	12%
Field Piping	10%
Walk-in Coolers/Freezers	8%
Condensing Units	4%
A/C Equipment	4%
Remote Headers	2%

Usage Sorted by Cause

Pipe Failure	25%
Valves	29%
Mechanical Joints	17%
Control Capillary Lines	15%
Welded Joints	14%

Identify Problem Areas

- High usage stores
 - Aging equipment
 - Display Cases
 - Condensers/Evaporator Coils
 - Manifold Assemblies
 - Valves
 - Poor design/installation
 - Improper brazing techniques
 - Incomplete pressure testing/evacuation
 - Improper or non-existent pipe supports
 - Lack of expansion relief
 - Metal-to-metal contact
 - Vibration




Identify Problem Areas (cont.)

- High usage service providers
 - High KPI's
 - Poorly-trained or unmotivated technicians
 - Incomplete leak checks during PM's
 - Slow response time for alarms
 - Not using store leak detector as a tool
 - First leak found syndrome
 - Poor service practices
 - Dirty compressor racks
 - Not replacing valve caps during service
 - Overuse of temporary fixes



KPIs for Service Providers

You Must Have Targets - All Contractors Are Not Equal



Corporate Refrigerant Usage Target

Develop Solutions

- Replace or rebuild aging/leak-prone equipment
- Identify and correct poor installation practices
- Identify and correct vibration issues
- Using KPI process, identify underperforming service providers and work with them to bring them up to standard



GreenChill Awards

2007

Co-recipient along with Harris Teeter of the GreenChill member award for the lowest leak rate with a 10%









2008

- Sole recipient of the GreenChill member award for the lowest leak rate with a 7.8%
- 20% year-to-year improvement

Benefits of GreenChill Partnership

- Demonstrates commitment to improving the environment by reducing emissions that harm the ozone layer and contribute to global warming
- Benchmark Leak Rates Against National and Member Averages
- Installation and Retrofit Guidelines to Improve Corporate Specs
- Refrigerant Charge Standards for New Stores
- Recognition for Leak Rate and Charge Reduction



Recognize Achievements

- Team awards
- Plaques for each service provider
- Personal thank you to service techs from senior management along with gift cards or logo imprinted tools







Why We Succeeded

- Invested in refrigerant monitoring technology
- Trained service providers and in-house staff to use technology
- Established goals for continuous improvement
- Measured performance against goals
- Communicated performance
- Recognized team success
- Joined EPA GreenChill

