

US EPA Region 9

EPCRA §302-312 / CERCLA §103 / Clean Air Act §112(r)(1) Inspection Report

Stationary Source	Allenco Energy Inc.
Date of Inspection	November 6, 2013
USEPA Contact	Jeremy Johnstone, USEPA Region 9
Description of Activities	Opening meeting with facility representatives Inspection consisting of the following activities: -Document review -Field verification -Personnel interviews Closing meeting with facility representatives
Inspection Participants	Jeremy Johnstone, USEPA Region 9 Inspector 415-972-3499 johnstone.jeremy@epa.gov Travis Cain, USEPA Region 9 Inspector 415-972-3161 cain.travis@epa.gov Janice Witul, USEPA Region 9 Inspector 415-972-3089 witul.janice@epa.gov David Basinger, USEPA Region 9 Inspector 415-972-3506 basinger.david@epa.gov Tim Parker, VP Operations, 562-989-6100 tparker@allencoca.com Logan Allen, VP Sales, 562-989-6100 lallen@allencoca.com

STATIONARY SOURCE INFORMATION

<i>USEPA Facility ID #</i>	NA
<i>Most Recent Submission</i>	NA
<i>Facility Location</i>	814 w. 23 rd St. Los Angeles, CA 90007
<i>Lat / Long</i>	34.032°S, -118.278°W
<i>Number of Employees</i>	4
<i>Description of Surrounding Area</i>	Urban, Mount St. Mary's College adjacent to east, south and west, residential across the street to the north

REGISTRATION INFORMATION

<i>Process ID #</i>	NA
<i>Program Level</i>	NA
<i>Process Chemicals</i>	Crude oil, methane
<i>NAICS Code</i>	211111, Crude Petroleum & Natural Gas Extraction

PURPOSE OF INSPECTION

An evaluation of compliance with Sections 302-312 of the Emergency Planning and Community Right-to-Know Act (EPCRA), Section 103 of the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA), and Section 112(r)(1) of the Clean Air Act (CAA) was conducted as part of a multi-media inspection of Allenco Energy Inc. (Allenco) crude oil pumping/separation/transfer facility in Los Angeles, CA. In addition to the above-mentioned authorities the inspection also included compliance evaluations under the Clean Air Act's Stationary Source Program and the Spill Prevention, Control, and Countermeasure (SPCC) program of the Oil Pollution Act (OPA). The inspection was prompted by concerns about the facility that had been expressed by the local community.

This report discusses the inspection under the above-mentioned EPCRA, CERCLA and CAA §112(r) authorities. Separate reports will be prepared for inspection activities under the other authorities.

Opening meeting

Inspector Johnstone presented his credentials and EPA inspection documents consisting of a Notice of Inspection, Right to Claim Confidentiality and Receipt for Documents and explained their contents. The facility representative and EPA inspector signed all copies prior to the end of the inspection and copies of signed documents were left with the facility.

FACILITY / PROCESS DESCRIPTION

Allenco operates a crude oil secondary recovery pumping, separation and transfer facility in south Los Angeles which produces crude oil, natural gas and produced water from five active wells. Allenco operates the facility under a lease agreement with the Catholic Archdiocese, which owns the land. The facility reportedly dates to the late 1960s, although Allenco only assumed operational control of the facility in 2009 from the predecessor operator St. James Oil. At the time of facility transfer, all 21 production wells were idle, but in 2010 Allenco restarted five of the wells and currently produces approximately 80 barrels of crude oil and 8000 barrels of produced water daily. The produced water is reinjected into the formation via a single injection pump in order to enhance further oil recovery. Crude oil is metered into the Crimson Oil Pipeline for sale. The facility also produces natural gas from the formation, this gas is consumed in onsite microturbines and the resulting electricity is fed into the local power grid for sale.

Operating equipment at the facility includes, wellhead pumps, produced fluids transfer pumps, free water knockout, test separators, crude storage tanks, produced water tanks, gas separator unit, vapor recovery unit, water injection pump, microturbines. The facility also has "Fire Eye" flame detectors and methane detectors at a few locations in the facility, as well as a water deluge system in the well gallery and three fire monitors (water cannons) along the south wall of the production pit.

OBSERVATIONS/FINDINGS

EPCRA §311-312:

1. The facility provided a copy of the California Hazardous Material Business Plan (HMBP) Hazardous Materials Inventory (EPCRS §312 Tier II equivalent) that had been submitted to the City of Los Angeles Fire Dept. (the CUPA) on September 11, 2013. The CUPA inspector had notified the facility in October 24, 2013 that the submittal was incomplete. There was no evidence of any previous submittals, and a subsequent call to the CUPA verified that none had been made.

EPCRA §304 / CERCLA §103:

1. Neither methane nor crude oil have a reportable quantity (RQ) established under either EPCRA or CERCLA. In addition, facility representatives reported that the facility has not had any significant releases of any hazardous chemical during its tenure as operator of the facility.

CAA §112(r)(1) General Duty Clause:

The obligations of the General Duty Clause apply to the crude oil and natural gas produced at the facility both may be considered Extremely Hazardous Substances within the meaning of the GDC. Therefore, evaluation of GDC compliance at the facility under this investigation was evaluated with respect to the facility's operation of components that handle, and would have the potential to be involved in an accidental release of, either of these materials.

1. On the day of the inspection no significant petroleum-based odors were apparent. Most noticeable was a slight odor of orange peel oil, which facility representatives indicated was used to mask other odors. (See Photo 20)
2. The name plate on the facility's Free Water Knock Out (FWKO) pressure vessel indicates that it was constructed in 1967. Nameplates for the other pressure vessels had been painted over and were illegible. (See Photos 8, 10)
3. External corrosion was visible on the lower pressure vessel of the west test separator. (See Photo 11)
4. The facility produced a report dated December 2012 documenting the results of tank shell thickness testing that the facility had had performed under AB1960. Other than this report the facility had no documentation available to document conformance with Recognized and Generally Acceptable Good Engineering Standards (RAGAGEPs).
5. Other than the report indicated in Item 4 immediately above, the facility was not able to provide documentation of conformance with Inspection, Testing and Preventive Maintenance (ITPM) RAGAGEPs, particularly API 653, API 510, API 570, and API RP 576.

RECOMMENDATIONS / POTENTIAL VIOLATIONS:

Potential Violation: EPCRA §312

The facility did not submit any HMBP Inventory/Tier II reports for Reporting Years 2009-2011 to CUPA.

Potential Violation: CAA §112(r)(1)

The facility was not able to document that it is operating a safe facility in that there is no evidence of its conformance with any of the following applicable RAGAGEPs:

API 653 - Tank Inspection, Repair, Alteration, and Reconstruction (with respect to the facility's atmospheric tanks)

API 510 - Pressure Vessel Inspection Code: In-Service Inspection, Rating, Repair, and Alteration (with respect to the facility's free water knockout and separator vessels)


API 570 – Piping Inspection Code: In-service Inspection, Rating, Repair, and Alteration of Piping Systems (with respect to the facility's produced fluids, crude and natural gas piping)


API RP 576 - Inspection of Pressure Relieving Devices (for PRDs on FWKO and separators)

Manufacturers' specifications for the maintenance and calibration of the flame detectors and methane detectors installed onsite.

List of Attachments –

1. EPCRA §§302-312 / CERCLA §103 Inspection Checklist
2. Signed Notice of Inspection Form
3. Signed Notice of Right to Claim Confidentiality Form
4. Signed Receipt of Documents Form
5. Inspection Participation Sign-in Sheet
6. Photo Log
7. Facility Documents

 12.3.13
Jeremy Johnstone (date)

 12-5-13
Reviewer

**ATTACHMENT 1 –
EPCRA §§302-312 / CERCLA §103 Inspection Checklist**



**EPCRA §§302-312/CERCLA §103
Inspection Checklist
EPA Region 9**

Inspection Date/Time: 6 November 2013 0930

Facility Name: Allenco Energy Inc.

Facility Address: 814 W. 23rd St
Los Angeles, CA 90007

Facility Rep. Name/Title/Phone #:
Tim Parker, VP Operations
562 989 6100

Inspector's Name/Phone #: Jeremy Johnstone, 415-972-3499

1. LEPC/CUPA and Fire Department contact(s) (include contact name and phone numbers)

LAFD CUPA
nearest station - Figueroa @ 23rd St

2. Brief description of receptors (residents, schools, other facilities, etc.)

Distance to receptors
 < 1/4 mile
 < 1 mile
 < 4 miles
 > 4 miles

3. Number of employees 4

4. Hours of operation: 24/7 pumper always here

5. Brief description of operation (hazardous substances used or stored on-site)

oil prodxn
 Allenco has operated site since Sept 16, 2009
 lease had been idle \geq 2 yrs before that
 1st operational 1967, Arco
 St James 1987-09

6. a) Has facility had EHSs on site at any time in the last three calendar years in an amount equal to or greater than the TPQ? Yes No

b) Has facility had a CERCLA HS or an OSHA HS on site at any time during the last three calendar years in an amount equal to or greater than 10,000 lbs. (Or in California, more than the CA listed TPQ)? Yes No

7. EPCRA §303: Has facility provided name and contact information for the Facility Emergency Response Coordinator? (If yes, request copy)
 Yes No

8. EPCRA §304/CERCLA §103: Has facility had any accidental releases of reportable quantities of EHSs or CERCLA HSs? If yes, fill in the information on the table in Attachment 1 and request documentation (monitoring equipment data, maintenance logs, spill reports, etc.).
 Yes No

Release Summary		
Release Date, Time and Amount (When was facility aware of the release.)	Chemical Name(s)/CAS #(s)	To Whom Reported (include report number(s), dates and times and request copies of spill reports and letters)

9. EPCRA §311: Has facility provided either a list or MSDSs for EHSs on site in quantities equal to or greater than the TPQs?
 Yes No (If yes, request copy)

10. EPCRA §312: Has facility provided a Tier II annual hazardous substance inventory to the SERC, LEPC and Fire Department (or in California, a Hazardous Material Disclosure with their Business Plan to the CUPA)?
 Yes No (If yes, request copy)

List years and dates of submittal:

Tier II Inventory Information		
Reporting Year	Agency to Whom Submitted	Date Submitted (verified by agency - y/n)

**ATTACHMENT 2 –
Signed Notice of Inspection Form**



NOTICE OF INSPECTION

U.S. ENVIRONMENTAL PROTECTION AGENCY

Region IX

Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) §103;
Emergency Planning and Community Right-to-Know Act (EPCRA) §§302-312; and
Clean Air Act §112r Risk Management Program (CAA RMP)

DATE/TIME: 6 November 2013 0930	FACILITY NAME: Allenco Energy Inc.
INSPECTOR (NAME, ADDRESS, PHONE): Jeremy Johnstone 415-972-3499 USEPA Region 9 (SFD-9-3) 75 Hawthorne St., San Francisco CA 94105	FACILITY ADDRESS: 814 W. 23 rd St. Los Angeles, CA 90007

REASON FOR INSPECTION: U. S. EPA is conducting this inspection for the purpose of determining compliance with the requirements of Section 103(e) of the Comprehensive Environmental Response, Compensation, and Liability Act (CERCLA), Sections 302 through 312 of the Emergency Planning and Community Right-to-Know Act (EPCRA), and Section 112(r) of the Clean Air Act (CAA).

The scope of this inspection may include, but is not limited to reviewing and obtaining copies of documents and records; interviews and taking of statements; reviewing of chemical manufacturing, importing, processing, and/or use facilities, including waste handling and treatment operations; taking samples and photographs; and any other inspection activities necessary to determine compliance with the Acts.

INSPECTOR SIGNATURE 		RECIPIENT SIGNATURE 	
NAME Jeremy Johnstone		NAME Tim Tacker	
TITLE Environmental Engineer	DATE SIGNED 11-6-13	TITLE Vice President	DATE SIGNED 11-6-13

ATTACHMENT 3 –

Signed Notice of Right to Claim Confidentiality Form



RECEIPT OF NOTICE OF RIGHT TO CLAIM CONFIDENTIALITY

U.S. ENVIRONMENTAL PROTECTION AGENCY
Region IX

Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) §103;
Emergency Planning and Community Right-to-Know Act (EPCRA) §§302-312; and
Clean Air Act §112r Risk Management Program (CAA RMP)

Form with fields: DATE/TIME: 6 November 2013 0930; FACILITY NAME: Allenco Energy Inc.; INSPECTOR (NAME, ADDRESS, PHONE): Jeremy Johnstone, USEPA Region 9 (SFD-9-3), 75 Hawthorne St., San Francisco CA 94105; FACILITY ADDRESS: 814 W. 23rd St., Los Angeles, CA 90007

Notice of Right to Claim Confidentiality: You may assert a business confidentiality claim covering all or part of the information requested during the course of this inspection, as provided in 40 C.F.R. §2.203(b). To make a confidentiality claim, submit the requested information and indicate that you are making a claim of confidentiality. Any document over which you make a claim of confidentiality should be marked by either attaching a cover sheet stamped or typed with a legend to indicate the intent to claim confidentiality. The stamp or typed legend or other suitable form of notice should employ language such as "trade secret" or "proprietary" or "company confidential" and indicate a date if any when the information should no longer be treated as confidential.

All confidentiality claims are subject to agency verification and must be made in accordance with 40 C.F.R. §2.208 which provides in part that you satisfactorily show that you have taken reasonable measures to protect the confidentiality of the information and that you intend to continue to do so; and that the information is not and has not been, reasonably obtainable by legitimate means without your consent.

NOTE: Signature of this Receipt of Notice of Right to Claim Confidentiality verifies only that such notice has been received and does not waive that right.

Form with signature fields: INSPECTOR SIGNATURE (Jeremy Johnstone), RECIPIENT SIGNATURE (Tim Tarkenton), NAME, TITLE, DATE SIGNED (11-6-13)

**ATTACHMENT 4 –
Signed Receipt of Documents Form**



RECEIPT OF DOCUMENTS
U.S. ENVIRONMENTAL PROTECTION AGENCY
Region IX

Comprehensive Environmental Response, Compensation and Liability Act (CERCLA) §103;
 Emergency Planning and Community Right-to-Know Act (EPCRA) §§302-312; and
 Clean Air Act §112r Risk Management Program (CAA RMP)

DATE/TIME: 6 November 2013 0930	FACILITY NAME: Allenco Energy Inc.
INSPECTOR (NAME, ADDRESS, PHONE): Jeremy Johnstone 415-972-3499 USEPA Region 9 (SFD-9-3) 75 Hawthorne St., San Francisco CA 94105	FACILITY ADDRESS: 814 W. 23 rd St. Los Angeles, CA 90007

During inspection, copies of the following documents were received from the above referenced facilities:

<u>Document Date</u>	<u>Author</u>	<u>Title</u>
12/13/02	St. James Oil Corp DPSI	Site Map for Business Plan ① * AB1960 certified Inspxn Tanks 4-6 * P&IDs for * Testing and Inspxn Records 2009-present * - Fire Eye/combustible gas detector * - methane detector * - oil flow lines (API 570) * - FWKO tank (API 570) * - Fire monitors
2013 updated		* 2013 HMBP Chemical Inventory * St James oil HMBP chemical inventory * Testing & PM records 2009-present for all Pressure Relief devices * HMBP Chem inventories 2009-2012

INSPECTOR SIGNATURE 		RECIPIENT SIGNATURE 	
NAME Jeremy Johnstone		NAME Tim Parker	
TITLE Environmental Engineer	DATE SIGNED 11.2.13	TITLE Vice President	DATE SIGNED 11-6-13

① * - to be provided by 11/15/13, pdf copies preferred

**ATTACHMENT 5 –
Inspection Participation Sheet**

**ATTACHMENT 6 –
Digital Camera Photo Log – Archival Images**

U.S. Environmental Protection Agency
Region 9 Emergency Prevention & Preparedness Program

INSPECTION PHOTO LOG

Facility Name & Location:
ALLENCO ENERGY LOS ANGELES, CA

Photographer:
T. CAIN

Camera:
CANON SX230

**Dates Photographs
Were Taken:**
11/6/2013

Photo No.
1

Photo Description:

View east into production area. Scrubber in foreground, FWKO (round horizontal vessel) in center back, brine tank to near left, crude tank to back left.



Photo No.
2

Photo Description:

Scale inhibitor added to produced water injectate





Photographer:
CAIN

Photo No.
5

Photo Description:
Fire-Eye flame detector
mounted in east end of
well gallery





Photo No.
6

Photo Description:
Dave Basinger using the
FLIR camera at a
producing wellhead







Photographer:
CAIN

Photo No.
11

Photo Description:
Paint flaking and surface pitting of bottom vessel on west separator



Photo No.
12

Photo Description:
View northeast of production area. Note fire monitors along south railing

(Note – Photo taken by J. Witul)



Photographer:
CAIN

Photo No.
13

Photo Description:
Top vessel of west separator. Note painted nameplate and pressure relief device.



Photo No.
14

Photo Description:
Fire-Eye flame detector mounted at east end of production area



Photographer:
CAIN

Photo No.
15

Photo Description:
Tank of emulsion breaker, one of 4 treatment chemicals located in the production area



Photo No.
16

Photo Description:
Methane gas detector located outside of facility office



Photographer:
CAIN

Photo No.
17

Photo Description:
Produced water injection pump, located in pump house





Photo No.
18

Photo Description:
2 natural gas compressors located in the pump house



Photographer:
CAIN

Photo No.
19

Photo Description:



Photo No.
20

Photo Description:

ORANGE-SCENTED SOLVENT TOTE IN TANK FARM CONTAINMENT AREA

(Note – Photo taken by J. Witul)



**ATTACHMENT 7 –
Facility Documents**

Facility: AllenCo Energy (CERSID: 10456009)

Home » Facility Search » Facility Summary: 10456009

Summary

Submittals

Reporting Requirements

Compliance

Notifications

Manage Facility

Change LPA

Location Map

Facility Summary for CERS ID: 10456009

Facility Name: AllenCo Energy
Business Name: AllenCo Energy (Signal Hill, CA)
CUPA: Los Angeles City Fire Department

Facility Information AllenCo Energy 814 W 23rd St Los Angeles, CA 90007 (310) 505-8536	Owner Information AllenCo Energy, Inc. 2109 Gundry Ave Signal Hill, CA 90756 (562) 989-8100
---	--

Primary Emergency Contact Tim Parker Vice President (562) 989-8100 (310) 505-8536 (24-hour)	Secondary Emergency Contact Mick Bayer Operations Manager (562) 989-8100 (310) 505-9767 (24-hour)
--	--

Environmental Contact Tim Parker (562) 989-8100 tparker@allencoenergy.com Mailing Address 2109 Gundry Ave Signal Hill, CA 90756 United States	Other Identifiers <table border="0"> <tr> <td>Local Facility ID</td> <td>EPA ID</td> </tr> <tr> <td>FA0028157</td> <td>CAL000365174</td> </tr> <tr> <td>Facility Regulator Key</td> <td>County</td> </tr> <tr> <td>No Facility Regulator Key in CERS</td> <td>Los Angeles</td> </tr> </table>	Local Facility ID	EPA ID	FA0028157	CAL000365174	Facility Regulator Key	County	No Facility Regulator Key in CERS	Los Angeles
Local Facility ID	EPA ID								
FA0028157	CAL000365174								
Facility Regulator Key	County								
No Facility Regulator Key in CERS	Los Angeles								

Submittal and Compliance Data	
Last Submittal Date	Submitted Element Count
9/11/2013 2:32 PM	4
Inspections	Enforcements
0	0

Reporting Requirements			
Submittal Element	Regulator	Reporting Requirement	Next Due Date
Facility Information	Los Angeles City Fire Department	Applicable	
Hazardous Materials Inventory	Los Angeles City Fire Department	Applicable	11/25/2013
Emergency Response and Training Plans	Los Angeles City Fire Department	Applicable	10/28/2013
Underground Storage Tanks	Los Angeles City Fire Department	Not Applicable	
Aboveground Petroleum Storage Act	Los Angeles City Fire Department	Applicable	
California Accidental Release Program	Los Angeles City Fire Department	Not Applicable	
Tiered Permitting	Los Angeles County Fire Department	Not Applicable	
Recyclable Materials Report	Los Angeles County Fire Department	Not Applicable	
Remote Waste Consolidation Site Annual Notification	Los Angeles County Fire Department	Not Applicable	
Hazardous Waste Tank Closure Certification	Los Angeles County Fire Department	Not Applicable	

Facility Submittal: AllenCo Energy (10456009)

Home » Submittal Search » Submittal: 9/11/2013 (10456009)

Submittal: Sep. 11, 2013 2:32 PM

Facility Information

Accepted Oct. 24, 2013 Set Submittal Status

Note: You cannot change the status of this Submittal Element because you have insufficient privileges for Los Angeles City Fire Department.
Submitted for CERS ID 10456009 on 9/11/2013 2:32PM by Michael Poppenheimer of AllenCo Energy (Signal Hill, CA)
Submittal was Accepted on 10/24/2013 by Marcus Look for Los Angeles City Fire Department

- [Business Activities](#)
- [Business Owner/Operator Identification](#)

Hazardous Materials Inventory

Not Accepted Oct. 24, 2013 Set Submittal Status

Note: You cannot change the status of this Submittal Element because you have insufficient privileges for Los Angeles City Fire Department.
Submitted for CERS ID 10456009 on 9/11/2013 2:32PM by Michael Poppenheimer of AllenCo Energy (Signal Hill, CA)
Submittal was Not Accepted on 10/24/2013 by Marcus Look for Los Angeles City Fire Department
Comments by regulator: You must include all chemicals that are over CUPA disclosure amount. You have solvent over 1000 gal and several other unidentified chemicals on site, please include all chemicals in your inventory disclosure. Your map must include all required information see sample map at this link <https://www.lafd.cupinfo.org/see/images/SampleFacilityMap.gif>

- [Hazardous Material Inventory](#)
- [Site Map \(Official Use Only\): Upload Document\(s\)](#)

Emergency Response and Training Plans

Not Accepted Oct. 24, 2013 Set Submittal Status

Note: You cannot change the status of this Submittal Element because you have insufficient privileges for Los Angeles City Fire Department.
Submitted for CERS ID 10456009 on 9/11/2013 2:32PM by Michael Poppenheimer of AllenCo Energy (Signal Hill, CA)
Submittal was Not Accepted on 10/24/2013 by Marcus Look for Los Angeles City Fire Department
Comments by regulator: Consolidated Emergency Response/Contingency plan is missing local Unified Program Agency phone #. Training requirements are incomplete per Title 19, Section 2731. Missing mitigation, prevention and abatement of hazards to persons, property or the environment.

- [Emergency Response/Contingency Plan: Upload Document\(s\)](#)
- [Employee Training Plan: Upload Document\(s\)](#)

Aboveground Petroleum Storage Act

Submitted Sep. 11, 2013 Set Submittal Status

Note: You cannot change the status of this Submittal Element because you have insufficient privileges for Los Angeles City Fire Department.
Submitted for CERS ID 10456009 on 9/11/2013 2:32PM by Michael Poppenheimer of AllenCo Energy (Signal Hill, CA)
[Aboveground Petroleum Storage Act Documentation: Provided Elsewhere in CERS](#)

[Download EDT Regulator Facility Submittal XML Package](#)

[Submittal Search](#)

California Environmental Reporting System Regulator

JANICE WATKINS Account Sign Out Tools Reports Help

Submittals Facilities Businesses Regulators Compliance Responders Reports

Hazardous Material Inventory: AllenCo Energy

Home » Submittal Search » Submittal: 9/11/2013 (10456009) » Materials Inventory: Hazardous Material Inventory (Not Accepted) » Material Detail

You must complete a separate inventory page for each individual hazardous material and hazardous waste that you handle at your facility in an aggregate quantity subject to Hazardous Material Business Plan (HMBP) reporting requirements. The completed inventory must reflect all hazardous materials at your facility, reported separately for each building or outside storage area, with separate entries for unique occurrences of physical state, storage temperature, storage pressure. Where the aggregate quantities of some hazardous materials are below the HMBP threshold reporting quantity, report the general hazard class of the materials (e.g., "Misc. Flammable Liquids"), rather than the Common Name, and the aggregate quantity of all hazardous materials having this hazard class which individually are below the threshold reporting quantity.

Submittal Element History

Submitted for CERS ID 10456009 on 9/11/2013 2:32PM by Michael Poppenheimer of AllenCo Energy (Signal Hill, CA)
 Submittal was Not Accepted on 10/24/2013 by Marcus Look for Los Angeles City Fire Department
 Comments by regulator: You must include all chemicals that are over CUPA disclosure amount. You have solvent over 1000 gal and several other unidentified chemicals on site, please include all chemicals in your inventory disclosure. Your map must include all required information see sample map at this link <https://www.lafdcupainfo.org/ees/images/SampleFacilityMap.gif>



[Return to Submittal Inventory](#)

Chemical Identification and Physical Properties

Chemical Name Crude Oil	CERS Chemical Library ID -
Common Name CAS Number Crude Oil 8002-05-9	US EPA SRS ID 425009
Physical State Liquid	Hazardous Material Type % Pure
	Trade Secret No

Chemical Hazard Classification

EHS No	Fire Code Hazard Classes (by priority) -	Federal Hazard Categories Yes Fire 2	DOT Hazard Class 10 -
Radioactive No	-	No Reactive *	State Waste Code -
Corrosives -	-	No Pressure Release	Lookup Code
-	-	No Acute Health	
-	-	No Chronic Health	

Inventory Location and Quantity

Chemical Location Tank Farm	Average Daily Amount 3570	Maximum Daily Amount * 3570	Units (Inventory) gallons
Chemical Location Confidential EPCRA No	Largest Container 10500	Annual Waste Amount *	
Map# (Optional) Grid# (Optional) -	Days on Site		

Inventory Storage Information

Yes Aboveground Tank	No Can	No Box	No Tank Truck, Tank Wagon
No Underground Tank	No Carboy	No Cylinder	No Tank Car, Rail Car
No Tank inside Building	No Silo	No Glass Bottle	No Other
No Steel Drum	No Fiber Drum	No Plastic Bottle	
No Plastic/Non-Metallic Drum	No Bag	No Tote Bin	
Storage Pressure Ambient	Storage Temperature Ambient		

Mixture Components

Hazardous Component Name	CAS Number	% by Weight	EHS	Additional Mixture Components *C
-	-	-	-	
-	-	-	-	
-	-	-	-	
-	-	-	-	

Additional Chemical/Material Description

Additional Chemical Description information %
-

Created By: Michael Poppenheimer on 9/28/2013 3:04 PM
 Last Updated By: Michael Poppenheimer on 9/28/2013 3:51 PM

[Return to Submittal Inventory](#)



Diagnose Conditions of Use | Privacy Policy | Contact Us

Hazardous Material Inventory: AllenCo Energy

Home » Submittal Search » Submittal 9/11/2013 (10456009) » Materials Inventory: Hazardous Material Inventory (Not Accepted)

Submittal Element History
 Submitted for CERS ID [10456009](#) on 9/11/2013 2:32PM by [Michael Poppenheimer](#) of [AllenCo Energy \(Signal Hill, CA\)](#)
 Submittal was **Not Accepted** on 10/24/2013 by [Marcus Look](#) for [Los Angeles City Fire Department](#)
 Comments by regulator: You must include all chemicals that are over CUPA disclosure amount. You have solvent over 1000 gal and several other unidentified chemicals on site, please include all chemicals in your inventory disclosure. Your map must include all required information see sample map at this link <https://www.lafdcpainfo.org/eee/images/SampleFacilityMap.gif>

[Return to Submittal](#)

Hazardous Materials Inventory (1)

Not Accepted Oct. 24, 2013

	Common Name	CAS	Location	Max Daily Amount
View	Crude Oil	8002-65-9	Tank Farm	3,570 gallons

HMS Matrix Report [Export To Excel](#)

1 15 Page 1 of 1 Displaying items 1 - 1 of 1

California Environmental Reporting System: Regulator

JANICE WITLU's Account Sign Out Tools Reports Help

Submittals Facilities Businesses Regulators Compliance Responders Reports

Site Map (Official Use Only): AllenCo Energy

Home » [Submittal Search](#) » [Submittal: 9/11/2013: 10456009](#) » Materials Inventory Site Map (Official Use Only) (Not Accepted)

Supplemental Documentation

Site Map (Official Use Only)

You are only required to provide supplemental documentation as specified by your local regulator(s)

Submittal Element History

Submitted for CERS ID ~~10456009~~ on 9/11/2013 2:32PM by [Michael Poppenheimer](#) of [AllenCo Energy \(Signal Hill, CA\)](#)
 Submittal was *Not Accepted* on 10/24/2013 by [Marcus Look](#) for [Los Angeles City Fire Department](#)
 Comments by regulator: You must include all chemicals that are over CUPA disclosure amount. You have solvent over 1000 gal and several other unidentified chemicals on site, please include all chemicals in your inventory disclosure. Your map must include all required information see sample map at this link <https://www.lafdcpainfo.org/eee/images/SampleFacilityMap.gif>

[Return to Submittal](#)

Unified Program Local Reporting Requirements for Los Angeles City Fire Department

Regulated facilities in this jurisdiction are required to report hazardous materials where quantities exceed the California Fire Code permit amounts as amended by LA City Fire. Refer to LAFD Std # 68 (http://lafd.org/prevention/pdf/forms/68_hm_cat_dis_amnts.pdf) for a complete list of permit amounts. LAFD Fire Code Sec. 57.08.03

Document Options

- Upload Document(s)
- Public Internet URL
- Provided Elsewhere in CERS
- Provided to Regulator
- Stored at Facility
- Exempt

Document Upload(s)

[CERS Document Upload Policy](#)

Document Title	Date Authored
Annotated Site Map (Official Use Only) (Adobe PDF, 302 KB)	9/11/2013

Created By: Michael Poppenheimer on 9/11/2013 2:28 PM
Last Updated By: Michael Poppenheimer on 9/11/2013 2:28 PM


[Back](#)


[Version 2.22.0147 | Enhancement | CERS Central](#)

[Discontinuing | Conditions of Use | Privacy Policy | Contact | Help](#)

California Environmental Reporting System: Business | © 2013 California Environmental Protection Agency
CERS Technical Support: [Request Technical Assistance](#)









2308 Sheet 1

Google



To see all the details that are visible on the screen, use the "Print" link next to the map.





Customer: AllenCo
AB 1960 Certified Inspection
12/14/2012

Brine Water Tank #1
AllenCo Energy Lease
814 West 23rd Street, Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the tank located at 814 West 23rd, Los Angeles, CA 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The Ultrasonic thickness readings and visual inspection methods were used to assess the shell plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular 1 course above ground storage tank that is currently in service. This tank is 8' H x 24' L x 8'W and equipped with a fixed roof. The following lists all findings and recommendations.

A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0) The re-inspection date is based on AB 1960 Section 1773.4.a.


No visual external corrosion was noted on shell staves.

RECOMENDATIONS:

It is recommended if this tank is "Out Of Service" to be properly take this tank out of service as stated in AB1960 1773.5.(a).(4)

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____



Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number/ID:	None
Tank Owner:	AllenCo
Construction Design:	API 12F (Shop welded - 90-750bbl)
Product:	Out of Service
Specific Gravity:	NA
Manufacturer:	unknown
Manufacture Date:	unknown
Data Plate Present:	None
NFPA Placard:	Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		24
Width (ft.):		8
Capacity (BBLs):		273.55

Design

Foundation:	Native Soil w/ Ringwall
Secondary Containment:	Concrete Containment
Leak Detection Barrier:	Yes
Cathodic Protection:	N/A
Ground Cable:	None
Bottom:	Butt Welded
Shell:	Butt Welded
Roof:	Butt Welded
Primary Seal:	None
Secondary Seal:	None

Access

Internal Access:	Manway
Roof Access:	Vertical Ladder w/o Platform

Coatings

Floor Internal:	Unknown
Shell Internal:	Unknown
Shell External:	Epoxy Coated
Roof: External:	Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

**Brian Wilson
API 653 Inspector**

**Ron Allen
Level II ASNT Technician**

**Jesse Kindrat
Technician Assistant**

**Shane Manning
Technician Assistant**

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FH_c = Calculated Fill Height = $SE_{tact}/2.6DG+1$ ($SE_{tact}/4.6DG+.3$) plus the total product height below the course of study, in feet.

Y_t = Time span between thickness readings or age of the tank if nominal thickness is used for **t_{prev}**, in years.

Ca = **T_{act}** - **T_{min}** = Remaining Corrosion Allowance (inches)

Cr = $(T_{prev} - T_{act}) / Y_t$ = Corrosion Rate (inches per year)

RL = **Ca** / **Cr** = Remaining Life (years)


Date Inspected	12/14/2012	
Y _t = Tank age (years)	20	(Estimated)
E = Efficiency	0.7	
D = Tank Diameter	-	
Y = Min. Yield Strength	30000	** 30000 lb./in ² if unknown
T = Min. Tensile Strength	55000	** 55000 lb./in ² if unknown
G = Product Gravity	1	

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.250	0.139	0.060	0.079	0.006	14.2

*** Next Inspection Due Date:

December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA




Course #1


TML #1	0.257
TML #2	0.253
TML #3	0.247
TML #4	0.139

Min	0.139
Average	0.224
Max	0.257

6.0 PICTURES



Vessel Overview



Tank Corner



Tank Wall



Tank Wall

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
Longitude -118.27804





AllenCo
AB 1960 Certified Inspection
12/13/2012

Crude Oil Tank #4
AllenCo Energy Lease
814 West 23rd. Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

4.2 Shell Corrosion Rate

4.3 Next Inspection Date

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the lease located at 814 W. 23rd. St. Los Angeles, CA 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The Ultrasonic thickness readings and visual inspection methods were used to assess the shell plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular, 1 course above ground storage tank that is currently in service. This tank is 8'H x 35'L x 10'W and equipped with a welded metal roof. The following lists all findings and recommendations.

A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0). The re-inspection date is based on AB 1960 Section 1773.4.a.

No visual external corrosion was noted on shell staves.

RECOMENDATIONS:

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____
Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number:	None
Tank Owner:	AllenCo
Construction Design:	API 12F (Shop welded - 90-750bbl)
Product:	Oil
Specific Gravity:	0.79
Manufacturer:	Unknown
Manufacture Date:	Unknown
Data Plate Present:	None
NFPA Placard:	Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		35
Width (ft.):		10
Capacity (BBLs):		498.67

Design

Foundation:	Native Soil w/ Ringwall
Secondary Containment:	Concrete Containment
Leak Detection Barrier:	Yes
Cathodic Protection:	None
Ground Cable:	None
Bottom:	Butt Welded
Shell:	Butt Welded
Roof:	Butt Welded
Primary Seal:	None
Secondary Seal:	None

Access

Internal Access:	Manway
Roof Access:	Vertical Ladder w/o Platform

Coatings

Floor Internal:	Unknown
Shell Internal:	Unknown
Shell External:	Epoxy Coated
Roof: External:	Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

**Brian Wilson
API 653 Inspector**

**Ron Allen
Level II ASNT Technician**

**Jesse Kindrat
Technician Assistant**

**Shane Manning
Technician Assistant**

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FHc = Calculated Fill Height = $SE_{tact}/2.6DG+1$ ($SE_{tact}/4.6DG+3$) plus the total product height below the course of study, in feet.

Yt = Time span between thickness readings or age of the tank if nominal thickness is used for **t_{prev}**, in years.

Ca = **T_{act}** - **T_{min}** = Remaining Corrosion Allowance (inches)

Cr = **T_{prev}** - **T_{act}** / **Yt** = Corrosion Rate (inches per year)

RL = **Ca** / **Cr** = Remaining Life (years)

Date Inspected

12/14/2012

Yt = Tank age (years)

20

(Estimated)

E = Efficiency

1

D = Tank Diameter

-

Y = Min. Yield Strength

30000

** 30000 lbf/in² if unknown

T = Min. Tensile Strength

55000

** 55000 lbf/in² if unknown

G = Product Gravity


0.79

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.250	0.236	0.060	0.176	0.001	251.4

*** Next Inspection Due Date:

December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA



Course #1	
TML #1	0.236
TML #4	0.241
TML #7	0.237
TML #10	0.240

Min	0.236
Average	0.239
Max	0.241

6.0 PICTURES



Tank Side View



Tank Corner




Tank



Tank



Roof View



NFPA Placard

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
 Longitude -118.278038





AllenCo
AB 1960 Certified Inspection
12/14/2012

Crude Oil Tank #5
AllenCo Energy Lease
814 West 23rd. Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

4.2 Shell Corrosion Rate

4.3 Next Inspection Date

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the AllenCo Energy Lease located at 814 W. 23rd. St. Los Angeles, 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The Ultrasonic thickness readings and visual inspection methods were used to assess the shell plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular, 1 course above ground storage tank that is currently in service. This tank is 8'H x 10'L x 10'W with a fixed welded roof. The following lists all findings and recommendations.

A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0). The re-inspection date is based on AB 1960 Section 1773.4.a.

No visual external corrosion was noted.

RECOMENDATIONS:

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____
Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number:	None
Tank Owner:	AllenCo
Construction Design:	API 12F (Shop welded - 90-750hbl)
Product:	Crude Oil
Specific Gravity:	0.79
Manufacturer:	Unknown
Manufacture Date:	Unknown
Data Plate Present:	No
NFPA Placard:	Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		10
Width (ft.):		10
Capacity (BBLS):	0	142.48

Design

Foundation:	Native Soil w/ Ringwall
Secondary Containment:	Concrete Containment
Leak Detection Barrier:	Yes
Cathodic Protection:	None
Ground Cable:	None
Bottom:	Butt Welded
Shell:	Butt Welded
Roof:	Butt Welded
Primary Seal:	None
Secondary Seal:	None

Access

Internal Access:	Manway
Roof Access:	Vertical Ladder w/o Platform

Coatings

Floor Internal:	Unknown
Shell Internal:	Unknown
Shell External:	Epoxy Coated
Roof: External:	Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

**Brian Wilson
API 653 Inspector**

**Ron Allen
Level II ASNT Technician**

**Jesse Kindrat
Technician Assistant**

**Shane Manning
Technician Assistant**

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FHc = Calculated Fill Height = $SE_{tact}/2.6DG+1$ ($SE_{tact}/4.6DG+.3$) plus the total product height below the course of study, in feet.

Yt = Time span between thickness readings or age of the tank if nominal thickness is used for t_{prev} , in years.

Ca = $T_{act} - T_{min}$ = Remaining Corrosion Allowance (inches)

Cr = $(T_{prev} - T_{act}) / Yt$ = Corrosion Rate (inches per year)

RL = Ca / Cr = Remaining Life (years)


Date Inspected	12/14/2012	
Yt = Tank age (years)	20	(Estimated)
E = Efficiency	1	
D = Tank Diameter	-	
Y = Min. Yield Strength	30000	** 30000 lb/in ² if unknown
T = Min. Tensile Strength	55000	** 55000 lb/in ² if unknown
G = Product Gravity	0.79	

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.250	0.228	0.060	0.168	0.001	152.7

*** Next Inspection Due Date:

December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA




Course #1	
TML #1	0.243
TML #2	0.235
TML #3	0.330
TML #4	0.228

Min	0.228
Average	0.259
Max	0.330


6.0 PICTURES



Tank Side



Close-up of Tank



Corner of Tank



Tank Corner



Tank Corner



Tank Corner

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
 Longitude -118.278038





AllenCo
AB 1960 Certified Inspection
12/14/2012

Crude Oil Tank #6
AllenCo Energy Lease
814 West 23rd. Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

4.2 Shell Corrosion Rate

4.3 Next Inspection Date

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the located at 814 W. 23rd. St. Los Angeles, CA 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The Ultrasonic thickness readings and visual inspection methods were used to assess the shell plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular, 1 course above ground storage tank that is currently in service. This tank is 8'H x 20'L x 10'W and equipped with a welded fixed roof. The following lists all findings and recommendations.

A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0). The re-inspection date is based on AB 1960 Section 1773.4.a.

No visual external corrosion was noted.

RECOMENDATIONS:

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____
Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number:	None
Tank Owner:	AllenCo
Construction Design:	API 12F (Shop welded - 90-750bbl)
Product:	Crude Oil
Specific Gravity:	0.79
Manufacturer:	Unknown
Manufacture Date:	Unknown
Data Plate Present:	None
NFPA Placard:	Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		20
Width (ft.):		10
Capacity (BBLs):		284.95

Design

Foundation:	Native Soil w/ Ringwall
Secondary Containment:	Concrete Containment
Leak Detection Barrier:	Yes
Cathodic Protection:	None
Ground Cable:	None
Bottom:	Butt Welded
Shell:	Butt Welded
Roof:	Butt Welded
Primary Seal:	None
Secondary Seal:	None

Access

Internal Access:	Manway
Roof Access:	Vertical Ladder w/o Platform

Coatings

Floor Internal:	Unknown
Shell Internal:	Unknown
Shell External:	Epoxy Coated
Roof: External:	Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

Brian Wilson
API 653 Inspector

Ron Allen
Level II ASNT Technician

Jesse Kindrat
Technician Assistant

Shane Manning
Technician Assistant

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FHc = Calculated Fill Height = $SE_{tact}/2.6DG+1$ ($SE_{tact}/4.6DG+3$) plus the total product height below the course of study, in feet.

Yt = Time span between thickness readings or age of the tank if nominal thickness is used for **t_{prev}**, in years.

Ca = **T_{act}** - **T_{min}** = Remaining Corrosion Allowance (inches)

Cr = **T_{prev}** - **T_{act}** / **Yt** = Corrosion Rate (inches per year)

RL = **Ca** / **Cr** = Remaining Life (years)

Date Inspected

12/14/2012

Yt = Tank age (years)

20

(Estimated)

E = Efficiency

1

D = Tank Diameter

-

Y = Min. Yield Strength

30000

** 30000 lbf/in² if unknown

T = Min. Tensile Strength

55000

** 55000 lbf/in² if unknown

G = Product Gravity


0.79

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.281	0.252	0.060	0.192	0.001	132.4

*** Next Inspection Due Date:


December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA



Course #1	
TML #1	0.262
TML #2	0.275
TML #3	0.268
TML #4	0.252
Min	0.252
Average	0.264
Max	0.275

6.0 PICTURES



Side of Tank



NFPA Placard



Tank Side



Tank Side



Tank Side



Tank Side

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
 Longitude -118.278038





AllenCo
AB 1960 Certified Inspection
12/14/2012

Injection Water Tank #2
AllenCo Energy Lease
814 West 23rd. Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

4.2 Shell Corrosion Rate

4.3 Next Inspection Date

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the lease located at 814 W. 23rd St. Los Angeles, CA 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The Ultrasonic thickness readings and visual inspection methods were used to assess the shell plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular, 1 course above ground storage tank that is currently in service. This tank is 8'H x 30'L x 10'W equipped with a fixed welded roof. The following lists all findings and recommendations.


A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0). The re-inspection date is based on AB 1960 Section 1773.4.a.

No visual external corrosion was noted on shell staves.

RECOMENDATIONS:

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____



Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number:	None
Tank Owner:	AllenCo
Construction Design:	API 12F (Shop welded - 90-750bbf)
Product:	Injection Water
Specific Gravity:	1.0
Manufacturer:	Unknown
Manufacture Date:	Unknown
Data Plate Present:	None
NFPA Placard:	Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		30
Width (ft.):		10
Capacity (BBLs):	0	427.43

Design

Foundation:	Native Soil w/o Ringwall
Secondary Containment:	Concrete Containment
Leak Detection Barrier:	Yes
Cathodic Protection:	None
Ground Cable:	None
Bottom:	Butt Welded
Shell:	Butt Welded
Roof:	Butt Welded
Primary Seal:	None
Secondary Seal:	None

Access

Internal Access:	Manway
Roof Access:	Vertical Ladder w/o Platform

Coatings

Floor Internal:	Unknown
Shell Internal:	Unknown
Shell External:	Epoxy Coated
Roof: External:	Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

**Brian Wilson
API 653 Inspector**

**Ron Allen
Level II ASNT Technician**

**Jesse Kindrat
Technician Assistant**

**Shane Manning
Technician Assistant**

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FHc = Calculated Fill Height = $SE_{tact}/2.6DG+1$ ($SE_{tact}/4.6DG+3$) plus the total product height below the course of study, in feet.

Yt = Time span between thickness readings or age of the tank if nominal thickness is used for **t_{prev}**, in years.

Ca = **T_{act}** - **T_{min}** = Remaining Corrosion Allowance (inches)

Cr = **T_{prev}** - **T_{act}** / **Yt** = Corrosion Rate (inches per year)

RL = **Ca** / **Cr** = Remaining Life (years)


Date Inspected	12/14/2012	
Yt = Tank age (years)	20	(Estimated)
E = Efficiency	1	
D = Tank Diameter	-	
Y = Min. Yield Strength	30000	** 30000 lb/in ² if unknown
T = Min. Tensile Strength	55000	** 55000 lb/in ² if unknown
G = Product Gravity	1	

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.281	0.257	0.060	0.197	0.001	164.2

*** Next Inspection Due Date:

December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA



Course #1	
TML #1	0.272
TML #4	0.263
TML #7	0.257
TML #10	0.260
Min	0.257
Average	0.263
Max	0.272

6.0 PICTURES



Side of Tank



Tank



Tank corner



Epoxy coating



Wall picture



Tank Top Picture

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
 Longitude -118.278038





Customer: AllenCo
AB 1960 Certified Inspection
12/13/2012

Injection Water Tank #3
AllenCo Energy Lease
814 West 23rd. Los Angeles, CA 90007
MI121212

INDEX

1.0 Executive Summary

2.0 Tank Summary

3.0 Inspection Personnel

4.0 Engineering Calculations

4.1 Shell Renewal Calculations

4.2 Shell Corrosion Rate

4.3 Next Inspection Date

5.0 Shell Diagram

6.0 Pictures

7.0 GPS Location Map

1.0 EXECUTIVE SUMMARY

AllenCo has contracted Diversified Project Services International, Inc. to perform an In Service inspection on the Lease located at 814 W. 23rd. St. Los Angeles, CA 90007. This inspection was completed with the current criteria set forth in AB 1960 Title 14, Division 2, Chapter 4, Section 1773.4.

The primary goal of this inspection is to provide your company with an assessment of the equipment condition. The resultant report shall contain the required information to assess the general condition of the tank shell per AB 1960.

The ultrasonic thickness readings and visual inspection methods were used to assess the steel plate condition. These methods were used externally and provided data relating to the present condition of the equipment.

The tank is a rectangular, 1 course above ground storage tank that is currently in service. This tank is 8'H x 20'L x 10'W and equipped with a welded fixed roof. The following lists all findings and recommendations.

A total of 4 spot thickness readings were taken at the Thickness Monitoring Locations (TML) shown on the provided Shell Diagram (5.0). For all corrosion data based on the gathered thickness readings see Shell Renewal Calculations (4.0). The re-inspection date is based on AB 1960 Section 1773.4.a.

No visual external corrosion was noted on shell staves.

RECOMENDATIONS:

It is recommended to properly identify this tank with the operator's tank identification number as stated in AB1960 1773.3 (a).

Inspector Signature: _____

Brian Wilson API 653 Certification # 6051

2.0 TANK SUMMARY

General

Tank Number: None
Tank Owner: AllenCo
Construction Design: API 12F (Shop welded - 90-750bbbl)
Product: Injection Water
Specific Gravity: 1
Manufacturer: Unknown
Manufacture Date: Unknown
Data Plate Present: None
NFPA Placard: Yes

Dimensions

	<u>Round</u>	<u>Square</u>
Diameter (ft.):		
Height (ft.):		8
Length (ft.):		20
Width (ft.):		10
Capacity (BBLs):	0	284.95

Design

Foundation: Native Soil w/ Ringwall
Secondary Containment: Concrete Containment
Leak Detection Barrier: Yes
Cathodic Protection: None
Ground Cable: None
Bottom: Butt Welded
Shell: Butt Welded
Roof: Butt Welded
Primary Seal: None
Secondary Seal: None

Access

Internal Access: Manway
Roof Access: Vertical Ladder w/o Platform

Coatings

Floor Internal: Unknown
Shell Internal: Unknown
Shell External: Epoxy Coated
Roof: External: Epoxy Coated

3.0 INSPECTION PERSONNEL AND QUALIFICATIONS:

DPSI examination personnel are qualified and certified in accordance with DPSI's Quality Assurance Program, Procedure DPSI-WP-01. This procedure meets or exceeds the guidelines contained in the American Society for Nondestructive Testing's Recommended Practice, SNT-TC-1A.

**Brian Wilson
API 653 Inspector**

**Ron Allen
Level II ASNT Technician**

**Jesse Kindrat
Technician Assistant**

**Shane Manning
Technician Assistant**

4.0 SHELL RENEWAL CALCULATIONS

T_{prev} = previous thickness measurement of shell course under consideration, as recorded at last inspection or nominal thickness if no previous thickness measurements, in inches.

T_{act} = Minimum thickness measurement of the shell course under consideration, as recorded at the time of inspection, in inches.

T_{min} = minimum required thickness of shell course, at the maximum allowable fill height, in inches.

Ca = Remaining corrosion allowance of the shell course under consideration, in inches.

Cr = Corrosion rate of the shell course under consideration, in inches per year.

RL = Estimated remaining life of the shell course under consideration, in years.

FHc = Calculated Fill Height = $SE_{act}/2.6DG+1$ ($SE_{act}/4.6DG+.3$) plus the total product height below the course of study, in feet.

Yt = Time span between thickness readings or age of the tank if nominal thickness is used for t_{prev} , in years.

$Ca = T_{act} - T_{min}$ = Remaining Corrosion Allowance (inches)

$Cr = T_{prev} - T_{act} / Yt$ = Corrosion Rate (inches per year)

$RL = Ca / Cr$ = Remaining Life (years)

Date Inspected

12/14/2012

Yt = Tank age (years)

20

(Estimated)

E = Efficiency

1

D = Tank Diameter

-

Y = Min. Yield Strength

30000

** 30000 lb/in² if unknown

T = Min. Tensile Strength

55000

** 55000 lb/in² if unknown

G = Product Gravity


1

Course	T _{prev}	T _{act}	T _{min}	Ca	Cr	RL
Course 1	0.281	0.223	0.060	0.163	0.003	56.2

*** Next Inspection Due Date:

December 14, 2017

5.0 SHELL DIAGRAM AND THICKNESS DATA



Course #1

TML #1	0.229
TML #4	0.223
TML #7	0.235
TML #10	0.231

Min	0.223
Average	0.230
Max	0.235

6.0 PICTURES



Tank Side View



Side view



Side View



Tank Side View



Side View

7.0 GPS Location Map

Address: 814 West 23rd. Los Angeles, CA 90007

GPS: Latitude 34.072526
 Longitude -118.278038

